



State of Utah

GARY R. HERBERT  
Governor

SPENCER J. COX  
Lieutenant Governor

Department of  
Environmental Quality

L. Scott Baird  
Executive Director

DIVISION OF DRINKING WATER  
Marrie E. Ownes, P.E.  
Director

October 13, 2020

Rodger A Smith  
Highland Subdivision Utah15005  
6373 Gordan Creek  
Morgan ,UT 84050

**Subject: RTCR Level 2 Assessment Highland Subdivision Utah15005**

Dear Mr. Smith ,

I would like to thank your self, Nate Hadley,Marjilee Smith,Kent Wilkerson P.E.,and Bart Smith for taking the time to meet with me to conduct a Level 2 Assessment of Highland Subdivision Water System on Sept. 24<sup>th</sup> , 2020. The level 2 Assessment was required because of Multiple TC+,EC+ Samples from Spring Source WS002 Gordan Creek Spring 2 and WS003 Gordan Creek Spring 7 .

**Observations:**

**My Assessment covered all the componates of Highland water system Sources, Tanks, Distribution System ( Air vacs, PRV stations, Fire Hydrant program ) , Chlorinators, etc.**

**The main focus however was on the Spring Source WS 002 and WS003 . WS002 consists of 1 collection Box ( Manhole) #2, WS003 consists of 7 collection Boxes ( manholes) numbered 3 thru 9. The WS003 Boxes are all identical with 3 inflow pipes and an outflow pipe, approximately 15 ft. in depth from access hatch to bottom. WS002 box is a different design as it is larger in diameter and not as deep as the others. The outflow lines Tee off outside of box and this line acts as an overflow/Drain combo as there is a manuel shutoff valve downstream of the tee.**

**These lines then all connect as they come off the mountain in several locations with valving at all the intersections and turn outs /overflows at these intersections. Continuing as one line further down gradient to a Chlorination facility at 2 Tanks ST003 & ST004.**

**All of the boxes had vents, downturned, screened #14 , shoe box lid on access , gaskets , 18” above ground.**

**Springs were all fenced ( stock tight ) 50 ft upgradient from box , no deep rooted vegetation with in the fenced area.**

**Spring collection areas were all on slopes some steeper than others , this would divert run off away spring and boxes.**

**Spring Box WS002 #2 and WS003 # 9 had several insects in them.  
Overflow lines were all screened with # 4 and intact with 12 inches plus of clearance free fall.  
One of the overflow/Blowoff lines at one of the intersection points down the mountain was found to have a small hole in the #4 screen.**

**Deficiencies identified during the L2 Assessment: UPDATE as of 10/14/2020- These Deficiencies have been resolved and will be removed. BP**

| Deficiency | Facility | Significant Deficiency Y/N | IPS Points | Description                                     | Rule Reference                     | Due Date for Fix |
|------------|----------|----------------------------|------------|---|------------------------------------|------------------|
| SS04       | WS002    | Y                          | 25         | Spring Box Overflow Lacks #4 screen.            | R309-515-7(7)(d)<br>R309-545-13(3) |                  |
| D007       | DS001    | Y                          | 25         | Air Relief Valve or Chamber subject to Flooding | R309-550-6(6)(b)<br>(7)(b)         |                  |
|            |          |                            |            |   |                                    |                  |
|            |          |                            |            |   |                                    |                  |
|            |          |                            |            |   |                                    |                  |

**Recommendations:**

**Operator Nate Hadley had indicated there was possibly a leak in one of the main lines coming from the springs , this would be something to determine if in fact there was one and repair the line.**

**System needs to be able to collect a good sanitary Bacteriological sample from each collection box when required to , system should devise a way to accomplish this. The overflow line is not an ideal location to collect Bac T samples.**

**Evaluate the 2 spring boxes which had insects in them and try to determine how to prevent them from entering.**

**If spring areas can be accessed when snow melts, observing the run off to make sure it is not compromising the collection area of each spring .**

**Continue to keep vegetation out of the collection area.**

**Conclusions:**

**WS003 Box 4 & 5 had TC+ EC+ samples , some of the other boxes had only TC+, box 5 had some root intrusion according to the operator , they had been removed upon my assessment. It is possible the TC EC followed a pathway with the roots at least on box 5 , however no root intrusion occurred on box 4 . The other possibility is the TC EC came from the overflow pipe where the samples were collected even though the operator indicated he had flushed them for a while. Box 4 & 5 are within a few hundred feet of one another however 5 is up on a ridge and 4 is down a ravine not in the same drainage area as box 5.**

**All the boxes at WS003 were in good condition and showed no influence of debris or water at the joints of the manhole section , WS002 was in good condition as well.**

**The deficiencies found on system would not have affected the TC EC event , Air Vac issue is down in Distribution System and hole in overflow screen is on an intersection of the spring transmission line several blocks from spring boxes and down gradient/elevation by several hundred feet.**

**Finally our assessment did not determine a definitive cause for the EC+ samples at WS003 Box 4 & 5.**

Feel free to contact me at 385-270-7272 [bpattee@utah.gov](mailto:bpattee@utah.gov), with questions or if we can be of further assistance.

Sincerely,



Brian Pattee  
Environmental Scientist  
Utah Division of Drinking Water

Enclosures: Survey Responses, Deficiency Report  
cc:

Brian Pattee, Division of Drinking Water, [bpattee@utah.gov](mailto:bpattee@utah.gov)  
Sitara Federico, Division of Drinking Water, [sfederico@utah.gov](mailto:sfederico@utah.gov)

# Utah Department Of Environmental Quality

## Division Of Drinking Water Level 2 Assessment

### Level 2 Assessment

| Site Visit Date | Surveyor Name |
|-----------------|---------------|
| 09/24/2020      | Brian Pattee  |

| HIGHLAND SUBDIVISION (MORGAN) | PWS ID: UTAH15005 | Rating: Approved | 02/16/1988 | Active |
|-------------------------------|-------------------|------------------|------------|--------|
|-------------------------------|-------------------|------------------|------------|--------|

### General System Information

|   |  |                                    |
|---|--|------------------------------------|
| 1 | Admin Contact (AC) [ eMail address is REQUIRED ]   | *First Name: RODGER A              |
|   | <i>MIN   15pts   SM   G004   R309-100-4(5)   Rule requires a person or organization be designated as the owner of the system and name, address and phone number of such be supplied to the Division.</i> | *Last Name: SMITH                  |
|   |  | *Organization:                     |
|   |  | *Address: Redacted                 |
|   |  | *City: MORGAN                      |
|   |  | *State: UT                         |
|   |  | *Zip: 84050                        |
|   |  | *Email: rodgersmithone@hotmail.com |
|   |  | *Phone: 801-876-2510               |

### Site Visit Info

|   |  |  |
|---|--|--|
| 2 | Date of Survey (First Day of Field Work)   | 09/24/2020   |
| 3 | Date of Survey (Last Day of Field Work) ** this should match the Date of Survey in the header ** | 09/24/2020   |
| 4 | Date final report sent to system (questionnaire, deficiency report and cover letter)             | 10/14/2020   |
| 5 | Water system representative present during the survey:   | Rodger Smith, Marjalee Smith, Kent Wilkerson P.E. , Nate Hadley, Bart Smith. |
| 6 | What condition triggered the level 2 assessment?   | LV03   |

### Management and Operations

|   |   |                                     |
|---|---|-------------------------------------|
| 7 | For a community water system without naturally flowing water sources (springs or artesian wells), system has at least one source of standby power.  | NA (Notes: Springs are main source) |
|   | <i>SIG   25pts   SO   S033   R309-515-6(2)(a)   Rule requires a community water system without naturally flowing water sources, such as springs or flowing wells, to have one or more of the system's sources equipped for operation during power outages. To ensure continuous service when the primary power has been interrupted, a redundant power supply is required. A redundant power supply may include a transfer switch for auxiliary power such as a generator or a power supply service with coverage from two independent substations. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |                                     |

|     |  |   |
|-----|--|---|
| 8   | Are there any individual home booster pumps installed in the distribution system (not for fire suppression)?   | C   |
|     | <i>SIG   50pts   DS   M020   R309-105-12(1)   Rule states that a water supplier shall not allow a connection to his system which may jeopardize its quality and integrity. Cross connections are not allowed unless controlled by an approved and properly operating backflow prevention assembly. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 9   | Does the system haul water? ... if yes, answer the following question(s)   | N   |
| 10  | For a community system serving 100 or more connections, at least 2 water sources are available.  | C   |
|     | <i>SIG   50pts   SO   TGR7   R309-515-4(3)   Rule requires Community Water Systems serving more than 100 connections to have a minimum of two sources except where served by a water treatment plant. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 11  | Does system have a consecutive connection to another water system not listed in the SOURCE section of Waterlink Report? If yes, answer the following question(s)   | N   |
| 12  | Sell water? ... if yes, answer the following question(s)   | N   |
| 13  | Is the sample tap clean and free from obstruction?   | N (Notes: Sample in question was collected from Spring Box/Line Overflow , Screened however would not be considered an Ideal sanitary spot . ( No way to disinfect the entire surface of inside these pipes. )) |
| 14  | Describe the type of sample tap (outside hose bib, frost free hydrant, kitchen tap, etc.)  | Spring Box/Line Overflow  |
| 15  | Was the sample collected on a supply line that is used regularly? (Samples should not be taken from a line with little or no use)  | NA (Notes: Sample Taken from Spring Overflow)   |
| 16  | Have any conditions changed since the last sample collection?  | Y (Notes: Root intrusion into 2 of the spring Boxes.)   |
| 16A | Have there been any plumbing changes or construction where the sample was collected?   | N   |
| 16B | Have there been any plumbing breaks or failure in the premise plumbing?  | N   |
| 17  | Are there any cross-connections after the service connection or in premise plumbing?   | N   |
| 18  | Were there any low pressure events or changes in the water pressure after the service connection or in premise plumbing?   | N   |
| 19  | Are there any treatment devices after the service connection or in the premise piping?   | N   |
| 20  | Could the sample be mixed with hot water or water passing through a water softener?  | N   |
| 21  | Was the sample representative of the water system?   | N   |
| 22  | Did the sampler explain their procedures for collecting samples?   | Y   |
| 23  | Was the sample tap adequately flushed prior to taking sample?  | Y   |
| 24  | Was the sample tap properly disinfected?   | NA (Notes: No way to disinfect these overflow lines)  |
| 25  | If the sample tap has an aerator, was the aerator removed before taking the sample?  | NA (Notes: Overflow line)   |
| 26  | Was the sample taken from a tap with a swivel connection?  | N   |
| 27  | Were sealed, fresh sample bottles used?  | Y   |

|    |  |   |
|----|--|---|
| 28 | Are sample bottles properly stored?  | Y   |
| 29 | Were there any adverse environmental conditions when the TC+ sample was collected? | Y (Notes: Outdoors from open pipe in mountains) |
| 30 | Were samples kept on ice during transportation to the laboratory?                  | Y   |
| 31 | Were samples transported to the laboratory within the 30 hour holding time?        | Y   |
| 32 | Was a Boil Water Order issued for the E.coli sample results?                       | N   |
| 33 | Was the Boil Water Order lifted?   | NA (Notes: No Boil order)                       |
| 34 | Does the system have any unresolved significant deficiencies?                      | N (Notes: Have been resolved)                   |

### Cross Connection and Operator Certification

|     |  |                       |
|-----|--|-----------------------|
| 35  | Sampler's Last Name  | Hadley                |
| 36  | Sampler's First Name   | Nate                  |
| 37  | Sampler's telephone number                                       | 801-458-0175          |
| 38  | Sampler's eMail address  | highlandsn8@gmail.com |
| 39  | Emergency phone number:  | 801-458-0175          |
| 40  | How long has the sampler been taking TCR samples?                | 8 years               |
| 41  | Is the sampler certified in either distribution or treatment?    | Y                     |
| 41A | What type(s) and grade(s) of certification? (for example, D2 T4) | D2                    |

### General Maintenance and Environment

|     |   |  |
|-----|---|--|
| 42  | Has there been a loss of power to any portion(s) of the system?   | N  |
| 43  | Has there been any loss of pressure events?   | N  |
| 44  | Have there been any customer complaints (cloudy water, smell, taste, interruptions of service)?   | Y (Notes: Air in water , discolored water)                   |
| 44A | Describe customer complaint(s):   | Air in water , discolored water                              |
| 45  | Have there been any visual indications of unsanitary conditions?  | N  |
| 46  | Has there been any operation, maintenance, or repair activities that could have introduced total coliform or E.coli into the system?  | N  |
| 47  | Has there been any vandalism and/or unauthorized access to facilities?  | N  |
| 48  | Has there been any recent fire fighting events, flushing operations, sheared hydrants, etc.?  | N  |
| 49  | Has there been any recent construction activities such as a new water line, tank, pump station, well installation, etc. or other facility that has been tied into the existing distribution system? | N  |
| 50  | Have there been any analytical results or any additional samples collected, including source samples which were positive (not for compliance)?  | Y (Notes: Several Spring boxes were TC+ from overflow pipes) |
| 51  | Has there been any community illness suspected of being waterborne?   | N  |
| 52  | Did the water system receive any TCR monitoring violations in the past 12 months?   | N  |

|    |   |            |
|----|---|------------|
| 53 | What was the most recent date on which a satisfactory total coliform sample(s) were taken?  | 10/10/2020 |
| 54 | Is there any evidence of intentional contamination of the system?   | N          |
| 55 | Was there an increase in water turbidity at any point in the system?  | N          |
| 56 | Have there been any recent modifications to the water system that could lead to contamination of the system?                        | N          |
| 57 | Have any new sources been added to the system?  | Y          |
| 58 | Have any inactive sources recently been introduced into the system (e.g. existing source, auxiliary systems)?                       | N          |
| 59 | Has there been any recent treatment or operational changes?   | N          |
| 60 | Is there any evidence of potential sources of contamination?  | N          |
| 61 | Was there any unusually high (or low) water demand that might have altered typical flow patterns in the water system?               | N          |
| 62 | Have there been any sewer spills, source water spills or other disturbances?  | N          |
| 63 | Have there been any algal blooms?   | N          |
| 64 | Has source water turnover occurred?   | N          |
| 65 | Has there been any unusual weather events that could have contributed to the TC+/EC+ samples?                                       | N          |
| 66 | Has there been any recent heavy rainfall?   | N          |
| 67 | Has there been any rapid snow melt or flooding?   | N          |
| 68 | Have there been any changes in available source water? (e.g. significant drop in water table, well output reservoir capacity, etc.) | N          |
| 69 | Have there been any extremes in heat or cold?   | N          |

## Distribution

|     |  |   |
|-----|--|---|
| 70  | No unprotected connection between the distribution system and a source of contamination. (If there is an unprotected connection, describe the location in detail.)<br><br><i>SIG   50pts   DS   M020   R309-105-12(1)   Rule states that a water supplier shall not allow a connection to his system which may jeopardize its quality and integrity. Cross connections are not allowed unless controlled by an approved and properly operating backflow prevention assembly. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 71  | Are air release/vacuum valves in the distribution system? ... if yes, answer the following question(s)   | Y |
| 71A | Open end of vent line covered with #14 mesh screen and down-turned.<br><br><i>SIG   25pts   DS   D004   R309-550-6(6)(b)   Rule states the open end of the air relief vent pipe from automatic valves shall be provided with a #14 mesh, non-corrodible screen and a downward elbow, and where possible, be extended to at least one foot above grade. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |

|     |   |  |
|-----|---|--|
| 71B | <p>For a valve in a chamber, open end of vent pipe is at least 12 inches above grade or one foot above distribution line in a chamber that does not flood.</p> <p><i>SIG   25pts   DS   D006   R309-550-6(6)(b)   Rule states the open end of the air relief vent pipe from automatic valves shall be provided with a #14 mesh, non-corrodible screen and a downward elbow, and where possible, be extended to at least one foot above grade. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | C (Notes: valve in chamber could easily be flooded and needs to be vented above grade .) |
| 71C | <p>Chamber has drain to daylight, gravel-filled adsorption pit if not subject to flooding, or sump pump.</p> <p><i>SIG   25pts   DS   D007   R309-550-6(6)(b) and (7)(b)   Rule states chambers shall be provided with a drain to daylight, if possible. Where this is not possible, underground gravel-filled absorption pits may be used if the site is not subject to flooding and conditions will assure adequate drainage. Sump pumps may also be considered if a drain to daylight or absorption pit is not feasible. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p> | D (Notes: valve in chamber could easily be flooded and needs to be vented above grade .) |
| 71D | <p>Chamber is not flooded at the time of the inspection.</p> <p><i>MIN   0pts   DS   D008   R309-550-6(7)(b)   Rule states the chamber for an air relief valve shall not be subject to flooding and shall have a drain to daylight wherever possible or a gravel fill absorption pit. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | C  |
| 72  | <p>Water system has a program to maintain, operate, or control the use of fire hydrants.</p> <p><i>REC   0pts   DS   D012   N/A   Fire hydrants provide a direct access to the water in the distribution system. In order to protect the quality and integrity of the water, fire hydrant access should be controlled.</i></p>  | C  |
| 73  | <p>Blow offs or air release valves are not directly connected to a sanitary sewer line.</p> <p><i>SIG   50pts   DS   D013   R309-550-6(5)(a), R309-550-6(6)(c) and (7)(a)   Rule states blow-offs or air relief valves shall not be connected directly to a sewer. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C  |
| 74  | <p>Blow offs or air release valves do not discharge below flood level in ditches or streams.</p> <p><i>SIG   50pts   DS   M020   R309-105-12(1)   Rule states that a water supplier shall not allow a connection to his system which may jeopardize its quality and integrity. Cross connections are not allowed unless controlled by an approved and properly operating backflow prevention assembly. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C  |
| 75  | <p>Does the system have fire hydrants or blow offs?</p>   | Y  |
| 75A | <p>Are there any fire hydrants located in areas with a high water table?</p>  | N  |
| 76  | <p>All water mains installed after 1995 that provide fire flow are at least 8 inches in diameter.</p> <p><i>MIN   15pts   DS   D019   R309-550-5(4) &amp; (5)   Rule states that the minimum line size serving a fire hydrant lateral shall be 8-inch diameter unless a hydraulic analysis indicates that required flow and pressures can be maintained by 6-inch lines.</i></p>  | C  |

|     |   |   |
|-----|---|---|
| 77  | Distribution system capable of providing minimum pressure of 20 psi at all service connections.   | C |
|     | <i>SIG   50pts   DS   D003   R309-105-9, R309-550-5(1)   Rule states the distribution system shall maintain minimum pressures as required by R309-105-9 at all points of connection under all flow conditions. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 78  | Was the water system constructed or new portions added after January 1, 2007? ... if yes, answer the following question(s)  | Y |
| 78A | Distribution system capable of maintaining the following pressures at all service connections: (a) 20 psi during fire flow and fire demand during peak day demand; (b) 30 psi during peak instantaneous demand; and (c) 40 psi during peak day demand.  | C |
|     | <i>SIG   50pts   DS   D010   R309-105-9, R309-550-5(1)   Rule states that unless otherwise specifically approved by the Director, public water systems constructed after January 1, 2007, shall be designed and shall meet the following minimum water pressures at points of connection: (a) 20 psi during conditions of fire flow and fire demand experienced during peak day demand; (b) 30 psi during peak instantaneous demand; and (c) 40 psi during peak day demand. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 79  | Is there any evidence that the system experienced low or negative pressure?   | N |
| 80  | Is there adequate pressure throughout the entire distribution system at all times?  | Y |
| 81  | Are blow offs or air relief valves directly connected to a sewer or do not have a proper air gap or do they exit below flood level in ditches or streams?   | N |
| 82  | Does the system have pressure reducing / sustaining valve stations?   | Y |
| 82A | Do the valves function properly?  | Y |
| 82B | Is the valve vault free of standing water, debris, etc.?  | Y |
| 83  | Has appropriate backflow prevention (devices/assemblies) been installed on all high risk (hazard) sites?  | Y |
| 83A | Have these devices/assemblies been inspected, maintained and/or tested at least annually?   | Y |

## General Disinfection

|    |   |   |
|----|---|---|
| 84 | Water system follows AWWA disinfection procedures for new, repaired, or seasonal water mains and tanks.   | C |
|    | <i>SIG   25pts   MR   D018   R309-550-8(10)   All new and repaired water mains and appurtenances shall be disinfected in accordance with AWWA Standard C651. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 85 | How often do you periodically disinfect any or all parts of your water system (i.e. batch disinfection) other than for repairs or maintenance?  | C |
|    | <i>SIG   50pts   TR   TD25   R309-520-6   Rule requires continuous disinfection of groundwater sources that do not consistently meet bacteriological quality standards, all surface water sources, and groundwater sources under the direct influence of surface water. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 86 | Did the system batch disinfect for this TC+, EC+ event?   | N |

|    |   |   |
|----|---|---|
| 87 | Did the system conduct any flushing associated with this event?   | N |
| 88 | Has the system completed any recent water main, service connection repairs, maintenance on a well or pump, fire hydrant, pressure regulator, etc. that may have introduced contamination into the distribution system?, | N |
| 89 | Were investigative TCR samples taken after repairs were made?   | N |
| 90 | Were any isolation valves recently opened, closed or damaged?   | N |

## WS002 - GORDON CREEK SPRING 2 - Active

|     |   |  |
|-----|---|--|
| 91  | Undocumented sources shall not be physically connected to the drinking water system. (IF SOURCE IS NOT IN SYSTEM INVENTORY MARK "DEFICIENT")<br><br><i>SIG   200pts   SO   S001   R309-515-6(5), R309-515-7(4), R309-500-9(2) and (3)   R309-105-6(1) requires plans and specifications for all public drinking water projects to be approved in writing by the Director prior to the commencement of construction. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C  |
| 92  | Area of equal or higher elevation within 50 feet of spring collection devices is fenced.<br><br><i>MIN   15pts   SO   SS02   R309-515-7(7)(e)   Rule requires a stock-tight fence around the spring collection area.</i>  | C  |
| 93  | Surface water runoff diverted away from spring by diversion channel or berm.<br><br><i>MIN   15pts   SO   SS03   R309-515-7(7)(g)   Rule requires a diversion channel or berm, constructed immediately inside the fenced area, capable of diverting all anticipated surface water runoff away from the spring collection area.</i>  | C  |
| 94  | Spring box has a means of providing overflow?<br><br><i>MIN   15pts   SO   SS23   R309-515-7(7)(d), R309-545-13(1)   All junction boxes and collection boxes, must comply with R309-545 with respect to access openings, venting, and tank overflow. Lids for these spring boxes shall be gasketed and the box adequately vented.</i>   | Y  |
| 94A | Overflow screened with #4 mesh screen<br><br><i>SIG   25pts   SO   SS04   R309-515-7(7)(d), R309-545-13(3)   Overflow pipes on junction and collection boxes shall comply with R309-545 and be screened with No. 4 mesh non-corrodible screens. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | D (Notes: Overflow turn out at Intersection of combining springs had a small hole in the Screen) |
| 94B | Overflow has a minimum of 12 inch clearance above flood rim of receiving basin<br><br><i>SIG   25pts   SO   SS14   R309-515-7(7)(d), R309-545-13   Overflow pipes on junction and collection boxes shall comply with R309-545 and discharge a minimum of 12 inches above the ground surface or rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C  |
| 95  | Drain has minimum of 12 inch clearance above flood rim of receiving basin<br><br><i>SIG   25pts   SO   SS14   R309-515-7(7)(d), R309-545-13   Overflow pipes on junction and collection boxes shall comply with R309-545 and discharge a minimum of 12 inches above the ground surface or rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C  |

|      |   |   |
|------|---|---|
| 96   | Is the spring collection area subject to ponding of surface water?<br><br><i>  0pts   SO   SSL1   TBD   TBD</i>   | N |
| 97   | If a liner is present, spring liner integrity is maintained.<br><br><i>SIG   50pts   SO   SS19   R309-515-7(7)(b)(iv)   If a liner is present, it shall be installed to assure its integrity. No sharp-edged stones or stones two inches or larger shall be located within two inches of the liner. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 98   | No deep-rooted vegetation is within the fenced collection area.<br><br><i>SIG   25pts   SO   SS07   R309-515-7(7)(f)   All deep-rooted vegetation within the fenced collection area shall be removed by a means not negatively affecting water quality. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 99   | No roots seen in collection lines.<br><br><i>SIG   25pts   SO   SS08   R309-105-10(4)(a), R309-515-8(1)(a)   Spring collection areas shall be periodically (preferably annually) cleared of deep-rooted vegetation to prevent root growth from clogging collection lines. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 100  | Is a spring collection box present? ... if yes, answer the following question(s)<br><br><i>MIN   5pts   SO   SS11   R309-515-7(7)(d), R309-545-15   Rule requires junction boxes and collection boxes to comply with R309-545 with respect to venting. Therefore, a junction or collection box requires a vent to be fitted with #14 mesh or finer non-corrodible screen, be fitted with a protective heavy-gauge screen or covering if 6 inches in diameter or greater, be down-turned and shielded to prevent the entrance of contaminants, be located and sized to avoid blockage during winter, and have the end of the vent discharge a minimum of 24 inches above the earth on buried structures.</i> | Y |
| 100A | Spring box has shoe box type lid with 2 inch overlap around frame<br><br><i>SIG   25pts   SO   SS09   R309-515-7(7)(d), R309-545-14 (2)   Access openings shall comply with R309-545 and be provided with a close-fitting, solid shoebox-type cover that extends down around the frame at least 2 inches. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 100B | Spring box lid is gasketed<br><br><i>SIG   25pts   SO   SS10   R309-515-7(7)(d), R309-545-14 (2)   Access openings shall comply with R309-545 and be provided with a cover furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |

|      |  |   |
|------|--|---|
| 100C | Does lid show evidence of a vacuum on the spring box?<br><i>MIN   5pts   SO   SS11   R309-515-7(7)(d), R309-545-15   Rule requires junction boxes and collection boxes to comply with R309-545 with respect to venting. Therefore, a junction or collection box requires a vent to be fitted with #14 mesh or finer non-corrodible screen, be fitted with a protective heavy-gauge screen or covering if 6 inches in diameter or greater, be down-turned and shielded to prevent the entrance of contaminants, be located and sized to avoid blockage during winter, and have the end of the vent discharge a minimum of 24 inches above the earth on buried structures.</i> | C |
| 100D | Spring box opening is at least 4 inches above the surface of the box or 18 inches above an earthen cover if the box is buried.<br><i>MIN   15pts   SO   SS12   R309-515-7(7)(d), R309-545-14 (1),   Access openings shall comply with R309-545 and be framed at least 4 inches above the surface of the spring box roof at the opening or 18 inches above the ground surface on a buried spring box.</i>   | C |
| 100E | Spring box lid is locked<br><i>SIG   25pts   SO   SS13   R309-515-7(7)(d), R309-545-14 (3)   Access openings shall comply with R309-545 and the lids to the openings shall be locked. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 100F | All openings/penetrations in the spring collection box are sealed.<br><i>SIG   50pts   SO   SS20   R309-515-7(7)(d), R309-545-9(1) and (2)   All junction and collection boxes shall comply with R309-545 and shall have suitable watertight roofs and sidewalls that exclude birds, animals, insects, and excessive dust. All openings shall be kept to a minimum and be watertight. Pipes that may contain water of lesser quality than drinking water shall not penetrate the spring box. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 100G | Are there signs of small animals, slugs, bugs, etc. in the spring box?   | Y |
| 101  | Is a spring box vent present? ... if yes, answer the following question(s)<br><i>MIN   0pts   SO   SSL2   R309-515-7(7)(d)   A spring vent has been required for many years by R309-515-7(7)(d). For existing sources where vacuum conditions do not exist we have not required the system to retro fit the spring box. However, whenever the spring is re-developed a vent will be required</i>   | Y |
| 101A | Vent is down-turned.<br><i>SIG   25pts   SO   SS16   R309-515-7(7)(d), R309-545-15(1)   All vents on junction and collection boxes shall comply with R309-545 and be downturned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |

|      |   |   |
|------|---|---|
| 101B | Vent has #14 or finer non-corrodible mesh screen and a protective screen/covering if 6-inch diameter or greater.  | C |
|      | <i>SIG   25pts   SO   SS17   R309-515-7(7)(d), R309-545-15(4) and (5)   All vents on junction and collection boxes shall comply with R309-545 and be fitted with No. 14 or finer non-corrodible mesh screen. Vents 6-inch diameter or larger shall be fitted with additional heavy gage screen or substantial covering to protect the No. 14 mesh screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 101C | End of vent has sufficient clearance to prevent ice/snow blockage or is at least 24 inches above the earthen cover  | C |
|      | <i>SIG   25pts   SO   SS18   R309-515-7(7)(d), R309-545-15(2) and (3)   All vents on junction and collection boxes shall comply with R309-545 and shall be located and sized to avoid blockage during winter. The end of a vent on a buried spring box shall discharge a minimum of 24 inches above the ground. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |   |
| 102  | Spring has permanent flow-measuring device.   | C |
|      | <i>MIN   5pts   SO   SS01   R309-515-7(7)(h)   Rule requires a spring to have a permanent flow measuring device.</i>  |   |

### WS003 - GORDON CREEK SPRING 7 - Active

|      |   |   |
|------|---|---|
| 103  | Undocumented sources shall not be physically connected to the drinking water system. (IF SOURCE IS NOT IN SYSTEM INVENTORY MARK "DEFICIENT")  | C |
|      | <i>SIG   200pts   SO   S001   R309-515-6(5), R309-515-7(4), R309-500-9(2) and (3)   R309-105-6(1) requires plans and specifications for all public drinking water projects to be approved in writing by the Director prior to the commencement of construction. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 104  | Area of equal or higher elevation within 50 feet of spring collection devices is fenced.  | C |
|      | <i>MIN   15pts   SO   SS02   R309-515-7(7)(e)   Rule requires a stock-tight fence around the spring collection area.</i>  |   |
| 105  | Surface water runoff diverted away from spring by diversion channel or berm.  | C |
|      | <i>MIN   15pts   SO   SS03   R309-515-7(7)(g)   Rule requires a diversion channel or berm, constructed immediately inside the fenced area, capable of diverting all anticipated surface water runoff away from the spring collection area.</i>  |   |
| 106  | Spring box has a means of providing overflow?   | Y |
|      | <i>MIN   15pts   SO   SS23   R309-515-7(7)(d), R309-545-13(1)   All junction boxes and collection boxes, must comply with R309-545 with respect to access openings, venting, and tank overflow. Lids for these spring boxes shall be gasketed and the box adequately vented.</i>  |   |
| 106A | Overflow screened with #4 mesh screen   | C |
|      | <i>SIG   25pts   SO   SS04   R309-515-7(7)(d), R309-545-13(3)   Overflow pipes on junction and collection boxes shall comply with R309-545 and be screened with No. 4 mesh non-corrodible screens. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |

|      |  |                              |
|------|--|------------------------------|
| 106B | <p>Overflow has a minimum of 12 inch clearance above flood rim of receiving basin</p> <p><i>SIG   25pts   SO   SS14   R309-515-7(7)(d), R309-545-13   Overflow pipes on junction and collection boxes shall comply with R309-545 and discharge a minimum of 12 inches above the ground surface or rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C                            |
| 107  | <p>Drain has minimum of 12 inch clearance above flood rim of receiving basin</p> <p><i>SIG   25pts   SO   SS14   R309-515-7(7)(d), R309-545-13   Overflow pipes on junction and collection boxes shall comply with R309-545 and discharge a minimum of 12 inches above the ground surface or rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | C                            |
| 108  | <p>Is the spring collection area subject to ponding of surface water?</p> <p><i>  0pts   SO   SSL1   TBD   TBD</i></p>   | N                            |
| 109  | <p>If a liner is present, spring liner integrity is maintained.</p> <p><i>SIG   50pts   SO   SS19   R309-515-7(7)(b)(iv)   If a liner is present, it shall be installed to assure its integrity. No sharp-edged stones or stones two inches or larger shall be located within two inches of the liner. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | NA (Notes: Unknown on liner) |
| 110  | <p>No deep-rooted vegetation is within the fenced collection area.</p> <p><i>SIG   25pts   SO   SS07   R309-515-7(7)(f)   All deep-rooted vegetation within the fenced collection area shall be removed by a means not negatively affecting water quality. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | C                            |
| 111  | <p>No roots seen in collection lines.</p> <p><i>SIG   25pts   SO   SS08   R309-105-10(4)(a), R309-515-8(1)(a)   Spring collection areas shall be periodically (preferably annually) cleared of deep-rooted vegetation to prevent root growth from clogging collection lines. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>   | C                            |
| 112  | <p>Is a spring collection box present? ... if yes, answer the following question(s)</p> <p><i>MIN   5pts   SO   SS11   R309-515-7(7)(d), R309-545-15   Rule requires junction boxes and collection boxes to comply with R309-545 with respect to venting. Therefore, a junction or collection box requires a vent to be fitted with #14 mesh or finer non-corrodible screen, be fitted with a protective heavy-gauge screen or covering if 6 inches in diameter or greater, be down-turned and shielded to prevent the entrance of contaminants, be located and sized to avoid blockage during winter, and have the end of the vent discharge a minimum of 24 inches above the earth on buried structures.</i></p> | Y                            |

|      |  |   |
|------|--|---|
| 112A | Spring box has shoe box type lid with 2 inch overlap around frame<br><i>SIG   25pts   SO   SS09   R309-515-7(7)(d), R309-545-14 (2)   Access openings shall comply with R309-545 and be provided with a close-fitting, solid shoebox-type cover that extends down around the frame at least 2 inches. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 112B | Spring box lid is gasketed<br><i>SIG   25pts   SO   SS10   R309-515-7(7)(d), R309-545-14 (2)   Access openings shall comply with R309-545 and be provided with a cover furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 112C | Does lid show evidence of a vacuum on the spring box?<br><i>MIN   5pts   SO   SS11   R309-515-7(7)(d), R309-545-15   Rule requires junction boxes and collection boxes to comply with R309-545 with respect to venting. Therefore, a junction or collection box requires a vent to be fitted with #14 mesh or finer non-corrodible screen, be fitted with a protective heavy-gauge screen or covering if 6 inches in diameter or greater, be down-turned and shielded to prevent the entrance of contaminants, be located and sized to avoid blockage during winter, and have the end of the vent discharge a minimum of 24 inches above the earth on buried structures.</i> | C |
| 112D | Spring box opening is at least 4 inches above the surface of the box or 18 inches above an earthen cover if the box is buried.<br><i>MIN   15pts   SO   SS12   R309-515-7(7)(d), R309-545-14 (1),   Access openings shall comply with R309-545 and be framed at least 4 inches above the surface of the spring box roof at the opening or 18 inches above the ground surface on a buried spring box.</i>   | C |
| 112E | Spring box lid is locked<br><i>SIG   25pts   SO   SS13   R309-515-7(7)(d), R309-545-14 (3)   Access openings shall comply with R309-545 and the lids to the openings shall be locked. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 112F | All openings/penetrations in the spring collection box are sealed.<br><i>SIG   50pts   SO   SS20   R309-515-7(7)(d), R309-545-9(1) and (2)   All junction and collection boxes shall comply with R309-545 and shall have suitable watertight roofs and sidewalls that exclude birds, animals, insects, and excessive dust. All openings shall be kept to a minimum and be watertight. Pipes that may contain water of lesser quality than drinking water shall not penetrate the spring box. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 112G | Are there signs of small animals, slugs, bugs, etc. in the spring box?   | Y |
| 113  | Is a spring box vent present? ... if yes, answer the following question(s)<br><i>MIN   0pts   SO   SSL2   R309-515-7(7)(d)   A spring vent has been required for many years by R309-515-7(7)(d). For existing sources where vacuum conditions do not exist we have not required the system to retro fit the spring box. However, whenever the spring is re-developed a vent will be required</i>   | Y |

|      |   |   |
|------|---|---|
| 113A | Vent is down-turned.<br><i>SIG   25pts   SO   SS16   R309-515-7(7)(d), R309-545-15(1)   All vents on junction and collection boxes shall comply with R309-545 and be downturned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 113B | Vent has #14 or finer non-corrodible mesh screen and a protective screen/covering if 6-inch diameter or greater.<br><i>SIG   25pts   SO   SS17   R309-515-7(7)(d), R309-545-15(4) and (5)   All vents on junction and collection boxes shall comply with R309-545 and be fitted with No. 14 or finer non-corrodible mesh screen. Vents 6-inch diameter or larger shall be fitted with additional heavy gage screen or substantial covering to protect the No. 14 mesh screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 113C | End of vent has sufficient clearance to prevent ice/snow blockage or is at least 24 inches above the earthen cover<br><i>SIG   25pts   SO   SS18   R309-515-7(7)(d), R309-545-15(2) and (3)   All vents on junction and collection boxes shall comply with R309-545 and shall be located and sized to avoid blockage during winter. The end of a vent on a buried spring box shall discharge a minimum of 24 inches above the ground. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 114  | Spring has permanent flow-measuring device.<br><i>MIN   5pts   SO   SS01   R309-515-7(7)(h)   Rule requires a spring to have a permanent flow measuring device.</i>   | C |

**WS001 - PATE-POLL WELL (OUT) -**

|     |  |   |
|-----|--|---|
| 115 | Operating Period (Start Date)  | 01/01   |
| 116 | Operating Period (Ending Date)   | 12/31   |
| 117 | Undocumented sources shall not be physically connected to the drinking water system. (IF SOURCE IS NOT IN SYSTEM INVENTORY MARK "DEFICIENT")<br><i>SIG   200pts   SO   S001   R309-515-6(5), R309-515-7(4), R309-500-9(2) and (3)   R309-105-6(1) requires plans and specifications for all public drinking water projects to be approved in writing by the Director prior to the commencement of construction. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | NA (Notes: Source no longer connected to this system) |
| 118 | Well casing is at least 18 inches above finished ground surface and 12 inches above well house floor.<br><i>SIG   25pts   SO   S003   R309-515-6(6)(b)(vi), R309-515-6(12)(c)(ii), R309-515-6(13)(a)   Rule requires the permanent well casing to project at least 18 inches above the final ground surface and 12 inches above the pump house floor; at sites subject to flooding, the top of the casing must terminate at least 3 feet above the 100-year flood level or highest known flood elevation, whichever is higher. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | NA (Notes: Source no longer connected to this system) |

|      |  |   |
|------|--|---|
| 119  | Is there a proper seal at wellhead surface to prevent contamination?<br><br><i>SIG   50pts   SO   S013   R309-515-6(6)(i)   R309-515-6(6)(i) require a sanitary seal be installed and maintained at the wellhead and discharge piping. 50 demerit points. This significant deficiency should be corrected within 120 days of notification or have a corrective action plan approved by</i>               | NA (Notes: Source no longer connected to this system) |
| 120  | Is the well casing vented? ... if yes, answer the following question(s)  | Y (Notes: Source no longer connected to this system)  |
| 120A | Vent screened with #14 mesh screen<br><br><i>SIG   25pts   SO   S006   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(a) require vents be fitted with a #14 mesh or finer non-corrodible screen.</i>   | C   |
| 120B | Vent down-turned<br><br><i>SIG   25pts   SO   S007   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(b) requires vents be downturned or shielded to prevent the entrance of surface water or rainwater. 2 demerit points shall be assessed.</i>   | C   |
| 120C | Vent has adequate clearance to prevent contamination from entering the well<br><br><i>SIG   25pts   SO   S008   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(b) requires vents be terminated with a discharge with an appropriate air gap. 2 demerit points shall be assigned.</i>         | C   |
| 121  | Does the well have a pump to waste line? ... if yes, answer the following question(s)  | Y (Notes: Source no longer connected to this system)  |
| 121A | Pump to waste line discharges with a minimum of 12-inch clearance to flood rim<br><br><i>SIG   25pts   SO   S009   R309-515-6(12)(d)(ix)   Rule requires a pump-to-waste line connected to a sewer/storm drain to have a minimum 12-inch clearance to the flood rim. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C   |
| 121B | Pump to waste line equipped with #4 non-corrodible mesh screen<br><br><i>SIG   25pts   SO   S010   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be covered with a No. 4 mesh corrosion-resistant screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                                | C   |
| 121C | Pump to waste line downturned<br><br><i>SIG   25pts   SO   S011   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be downturned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |
| 121D | Pump to waste line discharges to receptacle with proper local authorization<br><br><i>SIG   25pts   SO   S011   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be downturned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |

|     |   |  |
|-----|---|--|
| 122 | Provisions available to periodically measure water levels<br><br><i>MIN   5pts   SO   S015   R309-515-6(12)(e) , R309-515-6(12)(c)(vi)   Rule requires provisions be made to permit periodic measurement of water levels in the completed well.</i>   | C (Notes: Source no longer connected to this system) |
| 123 | Wellhead secured to protect quality water<br><br><i>SIG   25pts   SO   S002   R309-105-10(5)   All water system facilities shall be secure. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C (Notes: Source no longer connected to this system) |
| 124 | Well head or well house and equipment protected from flooding<br><br><i>SIG   25pts   SO   S020   R309-515-6(6)(b)(vi), R309-515-6(12)(d)(iii), R309-515-6(13)(a) to (d)   Top of well casing shall terminate at least 18" above ground level or 12" above well house floor and for sites that flood at least 3' above 100-year flood level or highest known flood elevation. Well casing terminating in underground vault shall have a drain to daylight and surface runoff directed away from vault access. Well house floor shall be at least 6" above ground elevation, be sloped for drainage, and have a drain to daylight unless highly impractical. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C (Notes: Source no longer connected to this system) |
| 125 | There are no unprotected cross-connections in well discharge piping.<br><br><i>SIG   50pts   SO   S021   R309-105-12(1), R309-515-6(12)(d)(iii)   Rule requires the well discharge piping to be protected against the entrance of contamination. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C (Notes: Source no longer connected to this system) |
| 126 | No toxic chemicals, hazardous or flammable materials, or lubricants inside the well house or near well head?<br><br><i>MIN   15pts   TR   TGR9   R309-105-8, R309-100 through 605   Trigger for regulatory followup to address concerns.</i>  | C (Notes: Source no longer connected to this system) |
| 127 | Well discharge line has a smooth-nosed sampling tap, which samples the well water before any chemical injection. (first item from the wellhead).<br><br><i>MIN   5pts   SO   S023   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>  | C (Notes: Source no longer connected to this system) |
| 128 | Well discharge line has a check valve.<br><br><i>MIN   5pts   SO   S024   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>  | C (Notes: Source no longer connected to this system) |
| 129 | Well discharge line has a pressure gauge.<br><br><i>MIN   5pts   SO   S025   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   | C (Notes: Source no longer connected to this system) |
| 130 | Well discharge line has a means to measure flow.<br><br><i>MIN   5pts   SO   S026   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>  | C (Notes: Source no longer connected to this system) |

|      |  |   |
|------|--|---|
| 131  | Well discharge line has a shut-off valve (last item from the well head).<br><br><i>MIN   5pts   SO   S027   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   | C (Notes: Source no longer connected to this system)        |
| 132  | Is there an air/vac valve on the well discharge line? If yes, answer the following question(s)   | Y (Notes: Source no longer connected to this system)        |
| 132A | Air vacuum relief valve on well discharge piping downturned<br><br><i>SIG   25pts   SO   S028   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be down-turned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |
| 132B | Air vacuum relief valve on well discharge piping screened with #14 mesh screen<br><br><i>SIG   25pts   SO   S029   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be covered with a #14 mesh corrosion-resistant screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |
| 132C | Air vacuum relief valve on well discharge piping has at least 6 inches of clearance above floor<br><br><i>SIG   25pts   SO   S030   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be at least 6 inches above the well house floor. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C   |
| 133  | Wells that pump directly into a distribution system have means to release trapped air from pump discharge piping (for example, pumps directly to a tank, has an air release valve or pump to waste line)<br><br><i>MIN   5pts   SO   SL01   R309-515-6(12)(d)(v)   Rule requires a well that pumps directly into the distribution system be equipped with an air release/vacuum relief valve located upstream of the check valve, unless the wellhead valve and piping provide for pumping to waste all trapped air before water is introduced into the distribution system.</i> | C (Notes: Source no longer connected to this system)        |
| 134  | Well lubricants ANSI/NSF 60 certified<br><br><i>SIG   25pts   SO   S031   R309-105-10(7), R309-515-6(6)(a)   Rules require all oil-lubricated pumps for drinking water wells to utilize food-grade mineral oil suitable for human consumption as determined by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i><br><br><a href="https://www.youtube.com/watch?v=UABQMeeUz1g">Click here for addition training</a>   | C (Notes: Source no longer connected to this system)        |
| 135  | How is the well used?  | Culinary (Notes: Source no longer connected to this system) |
| 136  | How deep is the well (in feet)?  | unknown (Notes: Source no longer connected to this system)  |
| 137  | What is the output of the well (gpm) and has it changed recently?  | Source no longer connected to this system                   |
| 138  | Is there evidence of standing water, floodwater or runoff, depressions, unsanitary conditions, rodents or animals, birds near the wellhead?  | N (Notes: Source no longer connected to this system)        |

**WS004 - ABANDONED OLD HIGHLAND WELL -**

|     |   |  |
|-----|---|--|
| 139 | Operating Period (Start Date)   | 01/01 (Notes: Source no longer connected to this system) |
| 140 | Operating Period (Ending Date)  | 12/31 (Notes: Source no longer connected to this system) |
| 141 | <p>Undocumented sources shall not be physically connected to the drinking water system. (IF SOURCE IS NOT IN SYSTEM INVENTORY MARK "DEFICIENT")</p> <p><i>SIG   200pts   SO   S001   R309-515-6(5), R309-515-7(4), R309-500-9(2) and (3)   R309-105-6(1) requires plans and specifications for all public drinking water projects to be approved in writing by the Director prior to the commencement of construction. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C (Notes: Source no longer connected to this system)     |
| 142 | <p>Well casing is at least 18 inches above finished ground surface and 12 inches above well house floor.</p> <p><i>SIG   25pts   SO   S003   R309-515-6(6)(b)(vi), R309-515-6(12)(c)(ii), R309-515-6(13)(a)   Rule requires the permanent well casing to project at least 18 inches above the final ground surface and 12 inches above the pump house floor; at sites subject to flooding, the top of the casing must terminate at least 3 feet above the 100-year flood level or highest known flood elevation, whichever is higher. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p> | C (Notes: Source no longer connected to this system)     |
| 143 | <p>Is there a proper seal at wellhead surface to prevent contamination?</p> <p><i>SIG   50pts   SO   S013   R309-515-6(6)(i)   R309-515-6(6)(i) require a sanitary seal be installed and maintained at the wellhead and discharge piping. 50 demerit points. This significant deficiency should be corrected within 120 days of notification or have a corrective action plan approved by</i></p>   | C (Notes: Source no longer connected to this system)     |
| 144 | Is the well casing vented? ... if yes, answer the following question(s)   | N (Notes: Source no longer connected to this system)     |
| 145 | Does the well have a pump to waste line? ... if yes, answer the following question(s)   | N (Notes: Source no longer connected to this system)     |
| 146 | <p>Provisions available to periodically measure water levels</p> <p><i>MIN   5pts   SO   S015   R309-515-6(12)(e), R309-515-6(12)(c)(vi)   Rule requires provisions be made to permit periodic measurement of water levels in the completed well.</i></p>   | C (Notes: Source no longer connected to this system)     |
| 147 | <p>Wellhead secured to protect quality water</p> <p><i>SIG   25pts   SO   S002   R309-105-10(5)   All water system facilities shall be secure. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C (Notes: Source no longer connected to this system)     |

|     |  |  |
|-----|--|--|
| 148 | <p>Well head or well house and equipment protected from flooding</p> <p><i>SIG   25pts   SO   S020   R309-515-6(6)(b)(vi), R309-515-6(12)(d)(iii), R309-515-6(13)(a) to (d)   Top of well casing shall terminate at least 18" above ground level or 12" above well house floor and for sites that flood at least 3' above 100-year flood level or highest known flood elevation. Well casing terminating in underground vault shall have a drain to daylight and surface runoff directed away from vault access. Well house floor shall be at least 6" above ground elevation, be sloped for drainage, and have a drain to daylight unless highly impractical. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p> | C (Notes: Source no longer connected to this system) |
| 149 | <p>There are no unprotected cross-connections in well discharge piping.</p> <p><i>SIG   50pts   SO   S021   R309-105-12(1), R309-515-6(12)(d)(iii)   Rule requires the well discharge piping to be protected against the entrance of contamination. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i></p>  | C (Notes: Source no longer connected to this system) |
| 150 | <p>No toxic chemicals, hazardous or flammable materials, or lubricants inside the well house or near well head?</p> <p><i>MIN   15pts   TR   TGR9   R309-105-8, R309-100 through 605   Trigger for regulatory followup to address concerns.</i></p>  | C (Notes: Source no longer connected to this system) |
| 151 | <p>Well discharge line has a smooth-nosed sampling tap, which samples the well water before any chemical injection. (first item from the wellhead).</p> <p><i>MIN   5pts   SO   S023   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i></p>  | C (Notes: Source no longer connected to this system) |
| 152 | <p>Well discharge line has a check valve.</p> <p><i>MIN   5pts   SO   S024   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i></p>  | C (Notes: Source no longer connected to this system) |
| 153 | <p>Well discharge line has a pressure gauge.</p> <p><i>MIN   5pts   SO   S025   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i></p>   | C (Notes: Source no longer connected to this system) |
| 154 | <p>Well discharge line has a means to measure flow.</p> <p><i>MIN   5pts   SO   S026   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i></p>  | C (Notes: Source no longer connected to this system) |
| 155 | <p>Well discharge line has a shut-off valve (last item from the well head).</p> <p><i>MIN   5pts   SO   S027   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i></p>  | C (Notes: Source no longer connected to this system) |
| 156 | <p>Is there an air/vac valve on the well discharge line? If yes, answer the following question(s)</p>  | Y (Notes: Source no longer connected to this system) |

|   |  |   |
|---|--|---|
| 156A                                      | Air vacuum relief valve on well discharge piping downturned<br><i>SIG   25pts   SO   S028   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be down-turned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |
| 156B                                      | Air vacuum relief valve on well discharge piping screened with #14 mesh screen<br><i>SIG   25pts   SO   S029   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be covered with a #14 mesh corrosion-resistant screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C   |
| 156C                                      | Air vacuum relief valve on well discharge piping has at least 6 inches of clearance above floor<br><i>SIG   25pts   SO   S030   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be at least 6 inches above the well house floor. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C   |
| 157                                       | Wells that pump directly into a distribution system have means to release trapped air from pump discharge piping (for example, pumps directly to a tank, has an air release valve or pump to waste line)<br><br><i>MIN   5pts   SO   SL01   R309-515-6(12)(d)(v)   Rule requires a well that pumps directly into the distribution system be equipped with an air release/vacuum relief valve located upstream of the check valve, unless the wellhead valve and piping provide for pumping to waste all trapped air before water is introduced into the distribution system.</i> | C (Notes: Source no longer connected to this system)        |
| 158                                       | Well lubricants ANSI/NSF 60 certified<br><i>SIG   25pts   SO   S031   R309-105-10(7), R309-515-6(6)(a)   Rules require all oil-lubricated pumps for drinking water wells to utilize food-grade mineral oil suitable for human consumption as determined by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i><br><a href="https://www.youtube.com/watch?v=UABQMeeUz1g">Click here for additional training</a>   | C (Notes: Source no longer connected to this system)        |
| 159                                       | How is the well used?  | culinary (Notes: Source no longer connected to this system) |
| 160                                       | How deep is the well (in feet)?  | unknown (Notes: Source no longer connected to this system)  |
| 161                                       | What is the output of the well (gpm) and has it changed recently?  | Source no longer connected to this system                   |
| 162                                       | Is there evidence of standing water, floodwater or runoff, depressions, unsanitary conditions, rodents or animals, birds near the wellhead?  | N (Notes: Source no longer connected to this system)        |
| <b>WS005 - HIGHLANDS WELL #1 - Active</b> |  |   |
| 163                                       | Operating Period (Start Date)  | 01/01   |
| 164                                       | Operating Period (Ending Date)   | 12/31   |

|      |   |   |
|------|---|---|
| 165  | Undocumented sources shall not be physically connected to the drinking water system. (IF SOURCE IS NOT IN SYSTEM INVENTORY MARK "DEFICIENT")  | C |
|      | <i>SIG   200pts   SO   S001   R309-515-6(5), R309-515-7(4), R309-500-9(2) and (3)   R309-105-6(1) requires plans and specifications for all public drinking water projects to be approved in writing by the Director prior to the commencement of construction. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |   |
| 166  | Well casing is at least 18 inches above finished ground surface and 12 inches above well house floor.   | C |
|      | <i>SIG   25pts   SO   S003   R309-515-6(6)(b)(vi), R309-515-6(12)(c)(ii), R309-515-6(13)(a)   Rule requires the permanent well casing to project at least 18 inches above the final ground surface and 12 inches above the pump house floor; at sites subject to flooding, the top of the casing must terminate at least 3 feet above the 100-year flood level or highest known flood elevation, whichever is higher. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 167  | Is there a proper seal at wellhead surface to prevent contamination?  | C |
|      | <i>SIG   50pts   SO   S013   R309-515-6(6)(i)   R309-515-6(6)(i) require a sanitary seal be installed and maintained at the wellhead and discharge piping. 50 demerit points. This significant deficiency should be corrected within 120 days of notification or have a corrective action plan approved by</i>  |   |
| 168  | Is the well casing vented? ... if yes, answer the following question(s)   | Y |
| 168A | Vent screened with #14 mesh screen  | C |
|      | <i>SIG   25pts   SO   S006   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(a) require vents be fitted with a #14 mesh or finer non-corrodible screen.</i>  |   |
| 168B | Vent down-turned  | C |
|      | <i>SIG   25pts   SO   S007   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(b) requires vents be downturned or shielded to prevent the entrainment of surface water or rainwater. 2 demerit points shall be assessed.</i>   |   |
| 168C | Vent has adequate clearance to prevent contamination from entering the well   | C |
|      | <i>SIG   25pts   SO   S008   R309-515-6(12)(d)(iii)   Guidance states provisions should be made for venting the well casing, however if vented R309-515-6(12)(d)(iii) and R309-550-6(6)(b) requires vents be terminated with a discharge with an appropriate air gap. 2 demerit points shall be assigned.</i>   |   |
| 169  | Does the well have a pump to waste line? ... if yes, answer the following question(s)   | Y |
| 169A | Pump to waste line discharges with a minimum of 12-inch clearance to flood rim  | C |
|      | <i>SIG   25pts   SO   S009   R309-515-6(12)(d)(ix)   Rule requires a pump-to-waste line connected to a sewer/storm drain to have a minimum 12-inch clearance to the flood rim. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |

|      |   |   |
|------|---|---|
| 169B | Pump to waste line equipped with #4 non-corrodible mesh screen<br><i>SIG   25pts   SO   S010   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be covered with a No. 4 mesh corrosion-resistant screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 169C | Pump to waste line downturned<br><i>SIG   25pts   SO   S011   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be downturned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 169D | Pump to waste line discharges to receptacle with proper local authorization<br><i>SIG   25pts   SO   S011   R309-515-6(12)(d)(ix)   The discharge end of the pump-to-waste line shall be downturned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 170  | Provisions available to periodically measure water levels<br><i>MIN   5pts   SO   S015   R309-515-6(12)(e ), R309-515-6(12)(c)(vi)   Rule requires provisions be made to permit periodic measurement of water levels in the completed well.</i>   | C |
| 171  | Wellhead secured to protect quality water<br><i>SIG   25pts   SO   S002   R309-105-10(5)   All water system facilities shall be secure. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 172  | Well head or well house and equipment protected from flooding<br><i>SIG   25pts   SO   S020   R309-515-6(6)(b)(vi), R309-515-6(12)(d)(iii), R309-515-6(13)(a) to (d)   Top of well casing shall terminate at least 18" above ground level or 12" above well house floor and for sites that flood at least 3' above 100-year flood level or highest known flood elevation. Well casing terminating in underground vault shall have a drain to daylight and surface runoff directed away from vault access. Well house floor shall be at least 6" above ground elevation, be sloped for drainage, and have a drain to daylight unless highly impractical. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 173  | There are no unprotected cross-connections in well discharge piping.<br><i>SIG   50pts   SO   S021   R309-105-12(1), R309-515-6(12)(d)(iii)   Rule requires the well discharge piping to be protected against the entrance of contamination. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 174  | No toxic chemicals, hazardous or flammable materials, or lubricants inside the well house or near well head?<br><i>MIN   15pts   TR   TGR9   R309-105-8, R309-100 through 605   Trigger for regulatory followup to address concerns.</i>  | C |

|      |  |   |
|------|--|---|
| 175  | Well discharge line has a smooth-nosed sampling tap, which samples the well water before any chemical injection. (first item from the wellhead).   | C |
|      | <i>MIN   5pts   SO   S023   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   |   |
| 176  | Well discharge line has a check valve.   | C |
|      | <i>MIN   5pts   SO   S024   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   |   |
| 177  | Well discharge line has a pressure gauge.  | C |
|      | <i>MIN   5pts   SO   S025   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   |   |
| 178  | Well discharge line has a means to measure flow.   | C |
|      | <i>MIN   5pts   SO   S026   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   |   |
| 179  | Well discharge line has a shut-off valve (last item from the well head).   | C |
|      | <i>MIN   5pts   SO   S027   R309-515-6(12)(d)(iv)   Rule requires the discharge piping to be equipped with (in order of placement from the wellhead) a smooth nosed sampling tap, a check valve, a pressure gauge, a means of measuring flow, and a shutoff valve.</i>   |   |
| 180  | Is there an air/vac valve on the well discharge line? If yes, answer the following question(s)   | Y |
| 180A | Air vacuum relief valve on well discharge piping downturned  | C |
|      | <i>SIG   25pts   SO   S028   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be down-turned. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 180B | Air vacuum relief valve on well discharge piping screened with #14 mesh screen   | C |
|      | <i>SIG   25pts   SO   S029   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be covered with a #14 mesh corrosion-resistant screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 180C | Air vacuum relief valve on well discharge piping has at least 6 inches of clearance above floor  | C |
|      | <i>SIG   25pts   SO   S030   R309-515-6(12)(d)(v)   Rule requires the exhaust/relief piping on an air release/vacuum relief valve on the well discharge piping to be at least 6 inches above the well house floor. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>       |   |

|     |  |          |
|-----|--|----------|
| 181 | Wells that pump directly into a distribution system have means to release trapped air from pump discharge piping (for example, pumps directly to a tank, has an air release valve or pump to waste line)   | C        |
|     | <i>MIN   5pts   SO   SL01   R309-515-6(12)(d)(v)   Rule requires a well that pumps directly into the distribution system be equipped with an air release/vacuum relief valve located upstream of the check valve, unless the wellhead valve and piping provide for pumping to waste all trapped air before water is introduced into the distribution system.</i>   |          |
| 182 | Well lubricants ANSI/NSF 60 certified  | C        |
|     | <i>SIG   25pts   SO   S031   R309-105-10(7), R309-515-6(6)(a)   Rules require all oil-lubricated pumps for drinking water wells to utilize food-grade mineral oil suitable for human consumption as determined by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i><br><i>&lt;a href="https://www.youtube.com/watch?v=UABQMeeUz1g"&gt;Click here for addition training&lt;/a&gt;</i> |          |
| 183 | How is the well used?  | culinary |
| 184 | How deep is the well (in feet)?  | unknown  |
| 185 | What is the output of the well (gpm) and has it changed recently?  | unknown  |
| 186 | Is there evidence of standing water, floodwater or runoff, depressions, unsanitary conditions, rodents or animals, birds near the wellhead?  | N        |

**ST001 - TANK #1 - Active**

|     |  |       |
|-----|--|-------|
| 187 | There are no undocumented drinking water facilities (i.e. tanks, pump stations, treatment facilities, etc.) or recent modifications that have not gone through DDW review  | C     |
|     | <i>SIG   50pts   SM   G001   R309-100-5(2), R309-500-6, R309-500-9, R309-500-9(2) and (3)   Rule requires complete plans &amp; specification for all public drinking water projects to be approved in writing by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |       |
| 188 | Storage tank capacity in gallons (from SDWIS; if different explain why in the comments)  | 80000 |
| 189 | Ladders, ladder guards, platform railings, or safely located entrance hatches are provided.  | C     |
|     | <i>MIN   15pts   FW   V004   R309-545-18   Rule requires ladders, ladder guards, platform railings, and safely located entrance hatches where applicable for water storage tanks and requires safety practices to conform to pertinent laws and regulations of the Utah Occupational Safety and Health Division.</i>   |       |
| 190 | Tank is vented.  | C     |
|     | <i>SIG   25pts   FW   VL02   R309-545-15   Rule requires drinking water storage tanks to be vented. Overflows cannot be considered or used as vents. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |       |
| 191 | Are air vents present? ... if yes, answer the following question(s)  | Y     |

|      |  |   |
|------|--|---|
| 191A | Vent is either down-turned or shielded from contaminants (at least 2 inches below the bottom of the opening)<br><br><i>SIG   25pts   FW   V005   R309-545-15(1)   Rule requires inverted vents on water storage tanks to be down-turned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 191B | End of vent terminates at least 24 inches above earthen cover (buried tank) and is located and sized to avoid blockage during winter.<br><br><i>MIN   15pts   FW   V006   R309-545-15(2)   For buried structures, the rule requires the end of the vent discharge to be a minimum of 24 inches above the earthen covering.</i>   | C |
| 191C | Vent covered with #14 or finer non-corrodible mesh screen.<br><br><i>SIG   25pts   FW   V007   R309-545-15(4)   Rule requires a water storage tank vent to be fitted with #14 mesh or finer non-corrodible screen and vents 6-inches or greater in diameter to be fitted with additional heavy gauge screen or substantial covering to protect the #14 mesh screen from vandalism or damage. This significant deficiency must be corrected within 120 days of notification or have a compliance action plan approved by DDW.</i> | C |
| 191D | Vent 6-inch diameter and larger protected with additional heavy-gauge screen or substantial covering.<br><br><i>MIN   5pts   FW   V035   R309-545-15(5)   Rule requires vents that are 6-inch diameter or greater to be fitted with additional heavy gauge screen or substantial covering, which will protect the No. 14 mesh screen against vandalism or damage.</i>  | C |
| 192  | Are access openings present? ... if yes, answer the following question(s)<br><br><i>MIN   15pts   FW   VL03   R309-545-14 and 14(1)   Rule requires drinking water storage tanks to be designed with reasonably convenient access to the interior for cleaning and maintenance.</i>  | Y |
| 192A | Access opening framed at least 4 inches above roof surface or 18 inches above earthen cover.<br><br><i>MIN   15pts   FW   V008   R309-545-14(1)   Rule requires tank access opening to be framed at least 4 inches above the surface of the roof, or on a buried tank, to be at least 18 inches above any earthen cover over the tank.</i>   | C |
| 192B | Access opening shoe box type with at least 2 inches of overlap<br><br><i>SIG   25pts   FW   V010   R309-545-14(2)   Rule requires the frame of an access opening to be provided with a close fitting solid shoebox type cover which extends down around the frame at least two inches and is furnished with a gasket(s) between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 192C | Access opening lid properly gasketed<br><br><i>SIG   25pts   FW   V009   R309-545-14(2)   Rule requires the access opening to a tank to be furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |

|      |  |   |
|------|--|---|
| 193  | Access opening locked  | C |
|      | <i>SIG   25pts   FW   V029   R309-545-14(3)   Rule requires the lid to any access opening to have a locking device. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 194  | Roof or wall penetrations sealed   | C |
|      | <i>SIG   100pts   FW   V017   R309-545-6(1) and 545-9   Rule requires openings in a storage tank roof or top, designed to accommodate control apparatus or pump columns, to be welded, gasketed, or curbed and sleeved and to have additional proper shielding to prevent vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 195  | Area surrounding ground-level or buried storage tank is graded to prevent surface water from standing within 50 feet.  | C |
|      | <i>SIG   25pts   TR   V001   R309-545-7(4)   Rule requires the area surrounding a ground-level or buried water storage tank be graded in a manner to prevent surface water from standing within 50 feet of the tank. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |   |
| 196  | Storage tank roof is sloped to prevent ponding   | C |
|      | <i>MIN   15pts   FW   V003   R309-545-9(4)   Rule requires drainage of storage tank roofs to eliminate water ponding.</i>  |   |
| 197  | Are there cracks in the walls or roof of the storage tank? (if yes, select only one of the following options)  | N |
| 198  | Is a tank overflow present? ... if yes, answer the following question(s)   | Y |
|      | <i>SIG   25pts   FW   VL01   R309-545-13   Rule requires all storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 198A | Overflow line discharges at least 12 inches above ground or the flood rim of receiving basin?  | C |
|      | <i>SIG   25pts   FW   V011   R309-545-13   Rule requires all water storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin.</i>  |   |
| 198B | Overflow line covered with #4 mesh non-corrodible screen   | C |
|      | <i>SIG   25pts   FW   V012   R309-545-13(3)   Rule requires overflow pipes to be screened with #4 mesh non-corrodible screens installed at a location least susceptible to damage by vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 198C | Overflow line connected or discharges to a sanitary sewer drain?   | C |
|      | <i>SIG   50pts   FW   V013   R309-545-13(5)   Rule prohibits overflow pipes from connecting to, or discharging into, a sanitary sewer system. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 199  | Are the drain line and overflow combined?  | N |

|      |  |                          |
|------|--|--------------------------|
| 199A | Drain line shall terminate at least 12 inches above ground or flood rim of receiving basin<br><br><i>SIG   25pts   FW   V016   R309-545-10(1)(d)   If the local authority allows discharge to a storm drain, the rule requires the drain discharge to have a physical clearance of at least 12 inches between the discharge end of the pipe and the overflow rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C                        |
| 200  | Is the storage structure interior coating or liner peeling or cracked?<br><br><i>REC   0pts   FW   V019   N/A   The integrity of the interior coating or liner is essential for proper quality control of the drinking water and may be intergral to the structural integrity of the tank. The system management should closely monitor the status of the liner and make plans</i>   | C                        |
| 201  | If the tank interior has been re-coated, did the materials used comply with ANSI/ NSF Standard 61?   | NA (Notes: Not recoated) |
| 202  | When was the tank last inspected/cleaned?  | 07/01/2020               |
| 203  | Do you perform routine security checks of this tank?   | Y                        |
| 203A | How often do you perform routine security checks of this tank?   | monthly                  |
| 204  | Could the physical condition of the tank be a source of contamination?   | N                        |
| 205  | Is proper O&M being performed for this storage tank?   | Y                        |
| 206  | Does the tank have an excess of floating material on the surface of the water and/or sediment on the bottom of the tank?   | N                        |
| 207  | Is there evidence of outside water intrusion into the tank?  | N                        |
| 208  | Are the inside walls of the tank free from staining or bacterial growth?   | Y                        |

**ST002 - 160K TANK - Active**

|     |   |        |
|-----|---|--------|
| 209 | There are no undocumented drinking water facilities (i.e. tanks, pump stations, treatment facilities, etc.) or recent modifications that have not gone through DDW review<br><br><i>SIG   50pts   SM   G001   R309-100-5(2), R309-500-6, R309-500-9, R309-500-9(2) and (3)   Rule requires complete plans &amp; specification for all public drinking water projects to be approved in writing by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C      |
| 210 | Storage tank capacity in gallons (from SDWIS; if different explain why in the comments)   | 160000 |
| 211 | Ladders, ladder guards, platform railings, or safely located entrance hatches are provided.<br><br><i>MIN   15pts   FW   V004   R309-545-18   Rule requires ladders, ladder guards, platform railings, and safely located entrance hatches where applicable for water storage tanks and requires safety practices to conform to pertinent laws and regulations of the Utah Occupational Safety and Health Division.</i>   | C      |

|      |  |   |
|------|--|---|
| 212  | Tank is vented.<br><br><i>SIG   25pts   FW   VL02   R309-545-15   Rule requires drinking water storage tanks to be vented. Overflows cannot be considered or used as vents. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 213  | Are air vents present? ... if yes, answer the following question(s)  | Y |
| 213A | Vent is either down-turned or shielded from contaminants (at least 2 inches below the bottom of the opening)<br><br><i>SIG   25pts   FW   V005   R309-545-15(1)   Rule requires inverted vents on water storage tanks to be down-turned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 213B | End of vent terminates at least 24 inches above earthen cover (buried tank) and is located and sized to avoid blockage during winter.<br><br><i>MIN   15pts   FW   V006   R309-545-15(2)   For buried structures, the rule requires the end of the vent discharge to be a minimum of 24 inches above the earthen covering.</i>   | C |
| 213C | Vent covered with #14 or finer non-corrodible mesh screen.<br><br><i>SIG   25pts   FW   V007   R309-545-15(4)   Rule requires a water storage tank vent to be fitted with #14 mesh or finer non-corrodible screen and vents 6-inches or greater in diameter to be fitted with additional heavy gauge screen or substantial covering to protect the #14 mesh screen from vandalism or damage. This significant deficiency must be corrected within 120 days of notification or have a compliance action plan approved by DDW.</i> | C |
| 213D | Vent 6-inch diameter and larger protected with additional heavy-gauge screen or substantial covering.<br><br><i>MIN   5pts   FW   V035   R309-545-15(5)   Rule requires vents that are 6-inch diameter or greater to be fitted with additional heavy gauge screen or substantial covering, which will protect the No. 14 mesh screen against vandalism or damage.</i>  | C |
| 214  | Are access openings present? ... if yes, answer the following question(s)<br><br><i>MIN   15pts   FW   VL03   R309-545-14 and 14(1)   Rule requires drinking water storage tanks to be designed with reasonably convenient access to the interior for cleaning and maintenance.</i>  | Y |
| 214A | Access opening framed at least 4 inches above roof surface or 18 inches above earthen cover.<br><br><i>MIN   15pts   FW   V008   R309-545-14(1)   Rule requires tank access opening to be framed at least 4 inches above the surface of the roof, or on a buried tank, to be at least 18 inches above any earthen cover over the tank.</i>   | C |
| 214B | Access opening shoe box type with at least 2 inches of overlap<br><br><i>SIG   25pts   FW   V010   R309-545-14(2)   Rule requires the frame of an access opening to be provided with a close fitting solid shoebox type cover which extends down around the frame at least two inches and is furnished with a gasket(s) between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |

|      |   |  |
|------|---|--|
| 214C | Access opening lid properly gasketed<br><i>SIG   25pts   FW   V009   R309-545-14(2)   Rule requires the access opening to a tank to be furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C                                      |
| 215  | Access opening locked<br><i>SIG   25pts   FW   V029   R309-545-14(3)   Rule requires the lid to any access opening to have a locking device. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                                      |
| 216  | Roof or wall penetrations sealed<br><i>SIG   100pts   FW   V017   R309-545-6(1) and 545-9   Rule requires openings in a storage tank roof or top, designed to accommodate control apparatus or pump columns, to be welded, gasketed, or curbed and sleeved and to have additional proper shielding to prevent vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                      | C                                      |
| 217  | Area surrounding ground-level or buried storage tank is graded to prevent surface water from standing within 50 feet.<br><i>SIG   25pts   TR   V001   R309-545-7(4)   Rule requires the area surrounding a ground-level or buried water storage tank be graded in a manner to prevent surface water from standing within 50 feet of the tank. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C                                      |
| 218  | Storage tank roof is sloped to prevent ponding<br><i>MIN   15pts   FW   V003   R309-545-9(4)   Rule requires drainage of storage tank roofs to eliminate water ponding.</i>   | C                                      |
| 219  | Are there cracks in the walls or roof of the storage tank? (if yes, select only one of the following options)   | Y                                      |
| 219A | Mild deterioration or spalling?<br><i>MIN   15pts   FW   V021   R309-545-6(1) and 545-9(1)   Rule requires all water storage tanks to have suitable watertight roofs and sidewalls that shall also exclude birds, animals, insects, and excessive dust.</i>   | Y (Notes: small Cracks on top of tank) |
| 219B | Severe deterioration or spalling?<br><i>SIG   50pts   FW   V022   R309-545-6(1) and 545-9(1)   Rule requires all water storage tanks to have suitable watertight roofs and sidewalls that shall also exclude birds, animals, insects, and excessive dust. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | N                                      |
| 220  | Is a tank overflow present? ... if yes, answer the following question(s)<br><i>SIG   25pts   FW   VL01   R309-545-13   Rule requires all storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                                   | Y                                      |

|      |  |                          |
|------|--|--------------------------|
| 220A | Overflow line discharges at least 12 inches above ground or the flood rim of receiving basin?<br><br><i>SIG   25pts   FW   V011   R309-545-13   Rule requires all water storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin.</i>   | C                        |
| 220B | Overflow line covered with #4 mesh non-corrodible screen<br><br><i>SIG   25pts   FW   V012   R309-545-13(3)   Rule requires overflow pipes to be screened with #4 mesh non-corrodible screens installed at a location least susceptible to damage by vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 220C | Overflow line connected or discharges to a sanitary sewer drain?<br><br><i>SIG   50pts   FW   V013   R309-545-13(5)   Rule prohibits overflow pipes from connecting to, or discharging into, a sanitary sewer system. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 221  | Are the drain line and overflow combined?  | N                        |
| 221A | Drain line shall terminate at least 12 inches above ground or flood rim of receiving basin<br><br><i>SIG   25pts   FW   V016   R309-545-10(1)(d)   If the local authority allows discharge to a storm drain, the rule requires the drain discharge to have a physical clearance of at least 12 inches between the discharge end of the pipe and the overflow rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C                        |
| 222  | Is the storage structure interior coating or liner peeling or cracked?<br><br><i>REC   0pts   FW   V019   N/A   The integrity of the interior coating or liner is essential for proper quality control of the drinking water and may be intergral to the structural integrity of the tank. The system management should closely monitor the status of the liner and make plans</i>   | C                        |
| 223  | If the tank interior has been re-coated, did the materials used comply with ANSI/ NSF Standard 61?   | NA (Notes: Not recoated) |
| 224  | When was the tank last inspected/cleaned?  | 07/01/2020               |
| 225  | Do you perform routine security checks of this tank?   | Y                        |
| 225A | How often do you perform routine security checks of this tank?   | monthly                  |
| 226  | Could the physical condition of the tank be a source of contamination?   | N                        |
| 227  | Is proper O&M being performed for this storage tank?   | Y                        |
| 228  | Does the tank have an excess of floating material on the surface of the water and/or sediment on the bottom of the tank?   | N                        |
| 229  | Is there evidence of outside water intrusion into the tank?  | N                        |
| 230  | Are the inside walls of the tank free from staining or bacterial growth?   | Y                        |

**ST003 - 250 K GORDON CREEK NO. 1 - Active**

|      |  |        |
|------|--|--------|
| 231  | There are no undocumented drinking water facilities (i.e. tanks, pump stations, treatment facilities, etc.) or recent modifications that have not gone through DDW review  | C      |
|      | <i>SIG   50pts   SM   G001   R309-100-5(2), R309-500-6, R309-500-9, R309-500-9(2) and (3)   Rule requires complete plans &amp; specification for all public drinking water projects to be approved in writing by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |        |
| 232  | Storage tank capacity in gallons (from SDWIS; if different explain why in the comments)  | 250000 |
| 233  | Ladders, ladder guards, platform railings, or safely located entrance hatches are provided.  | C      |
|      | <i>MIN   15pts   FW   V004   R309-545-18   Rule requires ladders, ladder guards, platform railings, and safely located entrance hatches where applicable for water storage tanks and requires safety practices to conform to pertinent laws and regulations of the Utah Occupational Safety and Health Division.</i>   |        |
| 234  | Tank is vented.  | C      |
|      | <i>SIG   25pts   FW   VL02   R309-545-15   Rule requires drinking water storage tanks to be vented. Overflows cannot be considered or used as vents. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |        |
| 235  | Are air vents present? ... if yes, answer the following question(s)  | Y      |
| 235A | Vent is either down-turned or shielded from contaminants (at least 2 inches below the bottom of the opening)   | C      |
|      | <i>SIG   25pts   FW   V005   R309-545-15(1)   Rule requires inverted vents on water storage tanks to be down-turned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |        |
| 235B | End of vent terminates at least 24 inches above earthen cover (buried tank) and is located and sized to avoid blockage during winter.  | C      |
|      | <i>MIN   15pts   FW   V006   R309-545-15(2)   For buried structures, the rule requires the end of the vent discharge to be a minimum of 24 inches above the earthen covering.</i>  |        |
| 235C | Vent covered with #14 or finer non-corrodible mesh screen.   | C      |
|      | <i>SIG   25pts   FW   V007   R309-545-15(4)   Rule requires a water storage tank vent to be fitted with #14 mesh or finer non-corrodible screen and vents 6-inches or greater in diameter to be fitted with additional heavy gauge screen or substantial covering to protect the #14 mesh screen from vandalism or damage. This significant deficiency must be corrected within 120 days of notification or have a compliance action plan approved by DDW.</i> |        |
| 235D | Vent 6-inch diameter and larger protected with additional heavy-gauge screen or substantial covering.  | C      |
|      | <i>MIN   5pts   FW   V035   R309-545-15(5)   Rule requires vents that are 6-inch diameter or greater to be fitted with additional heavy gauge screen or substantial covering, which will protect the No. 14 mesh screen against vandalism or damage.</i>   |        |

|      |  |   |
|------|--|---|
| 236  | Are access openings present? ... if yes, answer the following question(s)<br><br><i>MIN   15pts   FW   VL03   R309-545-14 and 14(1)   Rule requires drinking water storage tanks to be designed with reasonably convenient access to the interior for cleaning and maintenance.</i>  | Y |
| 236A | Access opening framed at least 4 inches above roof surface or 18 inches above earthen cover.<br><br><i>MIN   15pts   FW   V008   R309-545-14(1)   Rule requires tank access opening to be framed at least 4 inches above the surface of the roof, or on a buried tank, to be at least 18 inches above any earthen cover over the tank.</i>   | C |
| 236B | Access opening shoe box type with at least 2 inches of overlap<br><br><i>SIG   25pts   FW   V010   R309-545-14(2)   Rule requires the frame of an access opening to be provided with a close fitting solid shoebox type cover which extends down around the frame at least two inches and is furnished with a gasket(s) between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 236C | Access opening lid properly gasketed<br><br><i>SIG   25pts   FW   V009   R309-545-14(2)   Rule requires the access opening to a tank to be furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 237  | Access opening locked<br><br><i>SIG   25pts   FW   V029   R309-545-14(3)   Rule requires the lid to any access opening to have a locking device. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 238  | Roof or wall penetrations sealed<br><br><i>SIG   100pts   FW   V017   R309-545-6(1) and 545-9   Rule requires openings in a storage tank roof or top, designed to accommodate control apparatus or pump columns, to be welded, gasketed, or curbed and sleeved and to have additional proper shielding to prevent vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                       | C |
| 239  | Area surrounding ground-level or buried storage tank is graded to prevent surface water from standing within 50 feet.<br><br><i>SIG   25pts   TR   V001   R309-545-7(4)   Rule requires the area surrounding a ground-level or buried water storage tank be graded in a manner to prevent surface water from standing within 50 feet of the tank. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 240  | Storage tank roof is sloped to prevent ponding<br><br><i>MIN   15pts   FW   V003   R309-545-9(4)   Rule requires drainage of storage tank roofs to eliminate water ponding.</i>  | C |
| 241  | Are there cracks in the walls or roof of the storage tank? (if yes, select only one of the following options)  | N |

|      |  |                          |
|------|--|--------------------------|
| 242  | Is a tank overflow present? ... if yes, answer the following question(s)<br><br><i>SIG   25pts   FW   VL01   R309-545-13   Rule requires all storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | Y                        |
| 242A | Overflow line discharges at least 12 inches above ground or the flood rim of receiving basin?<br><br><i>SIG   25pts   FW   V011   R309-545-13   Rule requires all water storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin.</i>   | C                        |
| 242B | Overflow line covered with #4 mesh non-corrodible screen<br><br><i>SIG   25pts   FW   V012   R309-545-13(3)   Rule requires overflow pipes to be screened with #4 mesh non-corrodible screens installed at a location least susceptible to damage by vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 242C | Overflow line connected or discharges to a sanitary sewer drain?<br><br><i>SIG   50pts   FW   V013   R309-545-13(5)   Rule prohibits overflow pipes from connecting to, or discharging into, a sanitary sewer system. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 243  | Are the drain line and overflow combined?  | N                        |
| 243A | Drain line shall terminate at least 12 inches above ground or flood rim of receiving basin<br><br><i>SIG   25pts   FW   V016   R309-545-10(1)(d)   If the local authority allows discharge to a storm drain, the rule requires the drain discharge to have a physical clearance of at least 12 inches between the discharge end of the pipe and the overflow rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C                        |
| 244  | Is the storage structure interior coating or liner peeling or cracked?<br><br><i>REC   0pts   FW   V019   N/A   The integrity of the interior coating or liner is essential for proper quality control of the drinking water and may be intergral to the structural integrity of the tank. The system management should closely monitor the status of the liner and make plans</i>   | C                        |
| 245  | If the tank interior has been re-coated, did the materials used comply with ANSI/ NSF Standard 61?   | NA (Notes: Not recoated) |
| 246  | When was the tank last inspected/cleaned?  | 07/01/2020               |
| 247  | Do you perform routine security checks of this tank?   | Y                        |
| 247A | How often do you perform routine security checks of this tank?   | weekly                   |
| 248  | Could the physical condition of the tank be a source of contamination?   | N                        |
| 249  | Is proper O&M being performed for this storage tank?   | Y                        |
| 250  | Does the tank have an excess of floating material on the surface of the water and/or sediment on the bottom of the tank?   | N                        |

|   |   |        |
|---|---|--------|
| 251   | Is there evidence of outside water intrusion into the tank?   | N      |
| 252   | Are the inside walls of the tank free from staining or bacterial growth?  | Y      |
| <b>ST004 - 700K GORDON CREEK NO.2 TANK - Active</b> |   |        |
| 253   | There are no undocumented drinking water facilities (i.e. tanks, pump stations, treatment facilities, etc.) or recent modifications that have not gone through DDW review<br><br><i>SIG   50pts   SM   G001   R309-100-5(2), R309-500-6, R309-500-9, R309-500-9(2) and (3)   Rule requires complete plans &amp; specification for all public drinking water projects to be approved in writing by the Director. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C      |
| 254   | Storage tank capacity in gallons (from SDWIS; if different explain why in the comments)   | 700000 |
| 255   | Ladders, ladder guards, platform railings, or safely located entrance hatches are provided.<br><br><i>MIN   15pts   FW   V004   R309-545-18   Rule requires ladders, ladder guards, platform railings, and safely located entrance hatches where applicable for water storage tanks and requires safety practices to conform to pertinent laws and regulations of the Utah Occupational Safety and Health Division.</i>   | C      |
| 256   | Tank is vented.<br><br><i>SIG   25pts   FW   VL02   R309-545-15   Rule requires drinking water storage tanks to be vented. Overflows cannot be considered or used as vents. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C      |
| 257   | Are air vents present? ... if yes, answer the following question(s)   | Y      |
| 257A  | Vent is either down-turned or shielded from contaminants (at least 2 inches below the bottom of the opening)<br><br><i>SIG   25pts   FW   V005   R309-545-15(1)   Rule requires inverted vents on water storage tanks to be down-turned a minimum of 2 inches below any opening and shielded to prevent the entrance of contaminants. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C      |
| 257B  | End of vent terminates at least 24 inches above earthen cover (buried tank) and is located and sized to avoid blockage during winter.<br><br><i>MIN   15pts   FW   V006   R309-545-15(2)   For buried structures, the rule requires the end of the vent discharge to be a minimum of 24 inches above the earthen covering.</i>  | C      |
| 257C  | Vent covered with #14 or finer non-corrodible mesh screen.<br><br><i>SIG   25pts   FW   V007   R309-545-15(4)   Rule requires a water storage tank vent to be fitted with #14 mesh or finer non-corrodible screen and vents 6-inches or greater in diameter to be fitted with additional heavy gauge screen or substantial covering to protect the #14 mesh screen from vandalism or damage. This significant deficiency must be corrected within 120 days of notification or have a compliance action plan approved by DDW.</i>                    | C      |

|      |  |   |
|------|--|---|
| 257D | Vent 6-inch diameter and larger protected with additional heavy-gauge screen or substantial covering.<br><br><i>MIN   5pts   FW   V035   R309-545-15(5)   Rule requires vents that are 6-inch diameter or greater to be fitted with additional heavy gauge screen or substantial covering, which will protect the No. 14 mesh screen against vandalism or damage.</i>  | C |
| 258  | Are access openings present? ... if yes, answer the following question(s)<br><br><i>MIN   15pts   FW   VL03   R309-545-14 and 14(1)   Rule requires drinking water storage tanks to be designed with reasonably convenient access to the interior for cleaning and maintenance.</i>  | Y |
| 258A | Access opening framed at least 4 inches above roof surface or 18 inches above earthen cover.<br><br><i>MIN   15pts   FW   V008   R309-545-14(1)   Rule requires tank access opening to be framed at least 4 inches above the surface of the roof, or on a buried tank, to be at least 18 inches above any earthen cover over the tank.</i>   | C |
| 258B | Access opening shoe box type with at least 2 inches of overlap<br><br><i>SIG   25pts   FW   V010   R309-545-14(2)   Rule requires the frame of an access opening to be provided with a close fitting solid shoebox type cover which extends down around the frame at least two inches and is furnished with a gasket(s) between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 258C | Access opening lid properly gasketed<br><br><i>SIG   25pts   FW   V009   R309-545-14(2)   Rule requires the access opening to a tank to be furnished with a gasket between the lid and frame. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 259  | Access opening locked<br><br><i>SIG   25pts   FW   V029   R309-545-14(3)   Rule requires the lid to any access opening to have a locking device. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 260  | Roof or wall penetrations sealed<br><br><i>SIG   100pts   FW   V017   R309-545-6(1) and 545-9   Rule requires openings in a storage tank roof or top, designed to accommodate control apparatus or pump columns, to be welded, gasketed, or curbed and sleeved and to have additional proper shielding to prevent vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                       | C |
| 261  | Area surrounding ground-level or buried storage tank is graded to prevent surface water from standing within 50 feet.<br><br><i>SIG   25pts   TR   V001   R309-545-7(4)   Rule requires the area surrounding a ground-level or buried water storage tank be graded in a manner to prevent surface water from standing within 50 feet of the tank. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |

|      |  |                          |
|------|--|--------------------------|
| 262  | Storage tank roof is sloped to prevent ponding<br><br><i>MIN   15pts   FW   V003   R309-545-9(4)   Rule requires drainage of storage tank roofs to eliminate water ponding.</i>  | C                        |
| 263  | Are there cracks in the walls or roof of the storage tank? (if yes, select only one of the following options)  | N                        |
| 264  | Is a tank overflow present? ... if yes, answer the following question(s)<br><br><i>SIG   25pts   FW   VL01   R309-545-13   Rule requires all storage tanks to be provided with an overflow that discharges at an an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | Y                        |
| 264A | Overflow line discharges at least 12 inches above ground or the flood rim of receiving basin?<br><br><i>SIG   25pts   FW   V011   R309-545-13   Rule requires all water storage tanks to be provided with an overflow that discharges at an elevation between 12 and 24 inches above the ground surface or the rim of the receiving basin.</i>   | C                        |
| 264B | Overflow line covered with #4 mesh non-corrodible screen<br><br><i>SIG   25pts   FW   V012   R309-545-13(3)   Rule requires overflow pipes to be screened with #4 mesh non-corrodible screens installed at a location least susceptible to damage by vandalism. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 264C | Overflow line connected or discharges to a sanitary sewer drain?<br><br><i>SIG   50pts   FW   V013   R309-545-13(5)   Rule prohibits overflow pipes from connecting to, or discharging into, a sanitary sewer system. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C                        |
| 265  | Are the drain line and overflow combined?  | N                        |
| 265A | Drain line shall terminate at least 12 inches above ground or flood rim of receiving basin<br><br><i>SIG   25pts   FW   V016   R309-545-10(1)(d)   If the local authority allows discharge to a storm drain, the rule requires the drain discharge to have a physical clearance of at least 12 inches between the discharge end of the pipe and the overflow rim of the receiving basin. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C                        |
| 266  | Is the storage structure interior coating or liner peeling or cracked?<br><br><i>REC   0pts   FW   V019   N/A   The integrity of the interior coating or liner is essential for proper quality control of the drinking water and may be intergral to the structural integrity of the tank. The system management should closely monitor the status of the liner and make plans</i>   | C                        |
| 267  | If the tank interior has been re-coated, did the materials used comply with ANSI/ NSF Standard 61?   | NA (Notes: Not recoated) |
| 268  | When was the tank last inspected/cleaned?  | 09/01/2020               |
| 269  | Do you perform routine security checks of this tank?   | Y                        |

|      |  |        |
|------|--|--------|
| 269A | How often do you perform routine security checks of this tank?   | weekly |
| 270  | Could the physical condition of the tank be a source of contamination?   | N      |
| 271  | Is proper O&M being performed for this storage tank?   | Y      |
| 272  | Does the tank have an excess of floating material on the surface of the water and/or sediment on the bottom of the tank? | N      |
| 273  | Is there evidence of outside water intrusion into the tank?  | N      |
| 274  | Are the inside walls of the tank free from staining or bacterial growth?   | Y      |

## TP002 - GORDON CREEK CHLORINATOR -- Treatment - Chlorination General - Active

**Exception Granted:** R309-520-7(2)(d)(v) | R309-520-7(2)(d)(v) requires separate switches for ventilation fans and lighting near the chlorine facility entrance. As the Gordon Creek Springs chlorinator (TP002) building does not have electrical powered lighting or ventilation, this Rule requirement is not applicable in this situation (see other exceptions to power/ventilation).

**Exception Granted:** R309-520-7(2)(d)(iii) requires the exhaust fan suction to be located near the floor | As per the above, the Gordon Creek Springs chlorinator (TP002) building does not have electrical power with ventilation provided by natural means rather than mechanical. The existing screen access openings are located at ceiling height, intended to allow fresh air in, and at the floor to allow any collected chlorine gas to exit the facility. The locations of the openings, in combination with the SOP, are proposed to meet the intent of the rule.

**Exception Granted:** R309-520-7(1)(l), chlorination buildings to be heated, lighted and ventilated | TP002 is a historical installation that does not have electrical power. It is a partially buried facility with insulation installed on the walls, which effectively insulates the facility from extremes in temperatures. The water system notes historical experience has demonstrated the system does not experience freezing of the equipment, or negative impacts from excessive heat. An exception to the requirement for heating is requested on the basis that the facility construction and insulation meets the intent of the rule.

|      |  |   |
|------|--|---|
| 275  | Is system required to provide primary disinfection? Prompt - If system knows they are required to chlorinate based on water quality issues and/or knows they are required to provide a minimum CT then follow-up by DDW is needed.   | Y |
| 275A | If yes, no new connections have been added prior to approved first connection that would change the disinfection CT calculation.<br><br><b>SIG   50pts   TR   TD26   R309-505-7(2), R309-520-4 and 6(4)   Point of application of disinfectants shall be at a location that will achieve the required disinfection CT prior to the first service connection. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</b>   | C |
| 276  | When chlorination is required, disinfection has operated uninterrupted during the past year while supplying drinking water.<br><br><b>SIG   50pts   TR   TD25   R309-520-6   Rule requires continuous disinfection of groundwater sources that do not consistently meet bacteriological quality standards, all surface water sources, and groundwater sources under the direct influence of surface water. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</b>                             | C |
| 277  | Chlorine (gas & hypochlorite solution, tablets, granules, ) and chemicals used to generate chlorine solutions and chlorine dioxide meet ANSI/NSF 60.<br><br><b>SIG   50pts   TR   TD90   R309-525-11(5), R309-520-6(2)   All chemicals added to drinking water, including chlorine, chloramines and chemicals used to generate hypochlorite solutions and chlorine dioxide, shall be certified as complying with ANSI/NSF Standard 60. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</b> | C |

|     |   |   |
|-----|---|---|
| 278 | If chemical dilution or dissolution is needed, cross-connection control is provided on water lines feeding solution tanks.  | C |
|     | <i>SIG   50pts   TR   TX07   R309-525-11(2)(c), R309-525-11(9)(b)(i) to (iv)   Cross connection control shall be provided on make-up water lines feeding solution tanks. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>                          |   |
| 279 | Water flow rate is measured to control chemical feed?   | C |
|     | <i>SIG   25pts   TR   TD79   R309-525-11(7)(d)(ii) and (iii), R309-252-11(7)(a)(i)   Chemical feed rates shall be proportional to flows and a means to measure water flow rate shall be provided. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> |   |
| 280 | Free chlorine residual test equipment on-site or available?   | C |
|     | <i>MIN   15pts   TR   TD78   R309-520-7(1)(j)   Rule requires chlorine residual test equipment available capable of measuring residuals to the nearest 0.1 mg/l in the range below 0.5 mg/l, to the nearest 0.3 mg/l between 0.5 mg/l and 1.0 mg/l and to the nearest 0.5 mg/l above 1.0 mg/l.</i>                                    |   |
| 281 | Spare parts are available to replace parts subject to wear and breakage   | C |
|     | <i>MIN   15pts   TR   TD75   R309-520-7(1)(k)(i)   Spare parts shall be provided and maintained for all chlorinators to repair parts subject to wear and breakage.</i>  |   |
| 282 | Treatment plant properly secured to protect the quality of the treated water  | C |
|     | <i>SIG   25pts   SM   A050   R309-400-11   If the water system does not comply with the directive, the Director may assess 25 to 200 points to the water system. Points shall be assessed based upon the severity of the non-compliance, the threat to public health and the underlying basis for the original directive.</i>         |   |

## TP002 - GORDON CREEK CHLORINATOR -- Gaseous Chlorination - Active

|     |  |   |
|-----|--|---|
| 283 | If disinfection is required, standby chlorination equipment of sufficient capacity is available to replace the largest unit.   | C |
|     | <i>SIG   25pts   TR   TD22   R309-520-7(1)(k)(ii)   Where chlorination is required for disinfection of the water supply, the rule requires standby equipment of sufficient capacity to be available to replace the largest unit in the event of its failure. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   |   |
| 284 | Is the chlorinator room heated and has the ability to be protected from excessive heat?  | C |
|     | <i>Exception Granted: R309-520-7(1)(l), chlorination buildings to be heated, lighted and ventilated   TP002 is a historical installation that does not have electrical power. It is a partially buried facility with insulation installed on the walls, which effectively insulates the facility from extremes in temperatures. The water system notes historical experience has demonstrated the system does not experience freezing of the equipment, or negative impacts from excessive heat. An exception to the requirement for heating is requested on the basis that the facility construction and insulation meets the intent of the rule.</i> |   |
|     | <i>MIN   15pts   TR   TD08   R309-520-7(1)(l)   Rule requires chlorinator buildings to be heated, lighted, and ventilated as necessary to assure proper operation of the equipment and safety of the operators.</i>  |   |

|     |  |   |
|-----|--|---|
| 285 | If continuous disinfection is required, automatic switch over of chlorine cylinders is provided.   | C |
|     | <i>MIN   15pts   TR   TD01   R309-520-7(2)(a), R309-520-6(1)   Rule requires automatic switch over of chlorine cylinders be provided if continuous disinfection is required.</i>   |   |
| 286 | Exhaust fan takes suction near the floor as far as practical from the door and air inlet, and discharges outside away from air inlets.   | C |
|     | <i>Exception Granted: R309-520-7(2)(d)(iii) requires the exhaust fan suction to be located near the floor   As per the above, the Gordon Creek Springs chlorinator (TP002) building does not have electrical power with ventilation provided by natural means rather than mechanical. The existing screen access openings are located at ceiling height, intended to allow fresh air in, and at the floor to allow any collected chlorine gas to exit the facility. The locations of the openings, in combination with the SOP, are proposed to meet the intent of the rule.</i> |   |
|     | <i>MIN   15pts   TR   TD09   R309-520-7(2)(d)(iii)   Rule requires a chlorine room exhaust fan to take suction inside the chlorine room near the floor, as far as practical from the door and air inlet, and discharge air outside of the building away from air inlets.</i>   |   |
| 287 | Air inlets are located near the ceiling and fitted with louvers.   | C |
|     | <i>MIN   15pts   TR   TD10   R309-520-7(2)(d)(iv)   Rule requires chlorine room air inlets to be through wall louvers near the ceiling.</i>  |   |
| 288 | Chlorine vent line discharges outside and above grade and is screened with #14 mesh screen.  | C |
|     | <i>SIG   25pts   TR   TD13   R309-520-7(2)(e)   Rule requires the chlorine vent line to discharge outside, above grade, at a point least susceptible to vandalism, and to have the end covered with a #14 mesh non-corrodible screen. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  |   |
| 289 | Separate switches for chlorine room fans and lights are located near the entrance to the room (or are located outside the chlorine room if housed in a water treatment plant).   | C |
|     | <i>Exception Granted: R309-520-7(2)(d)(v)   R309-520-7(2)(d)(v) requires separate switches for ventilation fans and lighting near the chlorine facility entrance. As the Gordon Creek Springs chlorinator (TP002) building does not have electrical powered lighting or ventilation, this Rule requirement is not applicable in this situation (see other exceptions to power/ventilation).</i>  |   |
|     | <i>MIN   15pts   TR   TD12   R309-520-7(2)(d)(v)   Rule requires separate switches for the chlorine room fans and lights to be located near the entrance to the room and to be protected from vandalism. The switches are required to be located outside the chlorine room if housed in a water treatment plant.</i>   |   |
| 290 | Chlorine cylinder is restrained in position to prevent upset.  | C |
|     | <i>SIG   25pts   TR   TD18   R309-520-7(2)(d)(iv)   For gas a chlorinator housed at a water treatment plant, the rule requires all openings between the chlorine room and the remainder of the plant to be sealed.</i>   |   |

|      |  |   |
|------|--|---|
| 291  | Chlorine cylinder is not stored in direct sunlight or exposed to excessive heat.<br><br><i>SIG   25pts   TR   TD17   R309-520-7(2)(f)(ii)   Rule prohibits chlorine cylinders from being stored in direct sunlight or exposed to excessive heat. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>   | C |
| 292  | Weight scale is provided for weighing chlorine gas cylinders/containers.<br><br><i>SIG   25pts   TR   TD02   R309-520-7(2)(i)   Rule requires scales to be provided for determining chlorine cylinder weight. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 293  | Respiratory protection equipment is available where chlorine gas is handled, stored in convenient location, and not stored where chlorine is used/stored.<br><br><i>SIG   25pts   TR   TD06   R309-520-7(2)(k)(i) and (ii)   Rule requires respiratory protection equipment meeting requirements of NIOSH be available where 1-ton cylinders are handled and a respirator recommended by NIOSH be available where 150-lb cylinders are used. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i> | C |
| 294  | Is the chlorine cylinder 150 pounds in capacity? ... if yes, answer the following question(s)  | Y |
| 294A | Leak response/repair plan available<br><br><i>MIN   15pts   TR   TGR9   R309-105-8, R309-100 through 605   Trigger for regulatory followup to address concerns.</i>  | C |
| 294B | Bottle of ammonium hydroxide (56 % ammonia solution) is available for chlorine leak detection<br><br><i>MIN   15pts   TR   TD14   R309-520-7(2)(l)(i)   Rule requires a bottle of ammonium hydroxide (56% ammonia solution) to be available for leak detection.</i>  | C |
| 294C | Immediate access to NIOSH respirator available<br><br><i>SIG   25pts   TR   TD04   R309-520-7(2)(k)(ii)   Where 150 pound chlorine cylinders are used, a respirator recommended the National Institute of Occupational Safety and Health must be available. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.</i>  | C |
| 295  | Is the chlorine cylinder 1 ton in capacity? ... if yes, answer the following question(s)   | N |

## Level 2 Assessment - Deficiency Report

PWS Number: UTAH15005

Deficiency Points: 65

Survey Date: 09/24/2020

Survey Name: HIGHLAND SUBDIVISION  
(MORGAN)

Surveyor: Brian Pattee

Sanitary Survey Category: DS

SDWIS Severity Code: Significant Deficiency

Distribution | DS001 | UTAH15005 DISTRIBUTION SYSTEM

71C. Chamber has drain to daylight, gravel-filled adsorption pit if not subject to flooding, or sump pump.

Rule: R309-550-6(6)(b) and (7)(b)

Rule states chambers shall be provided with a drain to daylight, if possible. Where this is not possible, underground gravel-filled absorption pits may be used if the site is not subject to flooding and conditions will assure adequate drainage. Sump pumps may also be considered if a drain to daylight or absorption pit is not feasible. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.

Notes:

valve in chamber could easily be flooded and needs to be vented above grade .

Deficiency Points: 25

Days until points become effective on IPS: 30

SDWIS Deficiency Description: D007

AIR RELIEF VALVE OR CHAMBER SUBJECT TO FLOODING

Sanitary Survey Category: SO

SDWIS Severity Code: Significant Deficiency

Springs | WS002 | GORDON CREEK SPRING 2

94A. Overflow screened with #4 mesh screen

Rule: R309-515-7(7)(d), R309-545-13(3)

Overflow pipes on junction and collection boxes shall comply with R309-545 and be screened with No. 4 mesh non-corrodible screens. This significant deficiency must be corrected within 120 days of notification or have a corrective action plan approved by DDW.

Notes:

Overflow turn out at Intersection of combining springs had a small hole in the Screen

Deficiency Points: 25

Days until points become effective on IPS: 30

SDWIS Deficiency Description: SS04

SPRING BOX OVERFLOW LACKS NO. 4 SCREEN

Sanitary Survey Category: FW

SDWIS Severity Code: Minor Deficiency

Storage Tanks | ST002 | 160K TANK

219A. Mild deterioration or spalling?

Rule: R309-545-6(1) and 545-9(1)

Rule requires all water storage tanks to have suitable watertight roofs and sidewalls that shall also exclude birds, animals, insects, and excessive dust.

Notes:

small Cracks on top of tank

Deficiency Points: 15

Days until points become effective on IPS: 0

SDWIS Deficiency Description: V021

STORAGE TANK ROOF OR SIDEWALLS SHOW SIGNS OF MILD OR MODERATE DETERIORATION