

Plan Submittal Waiver Versus Approved Standard Installation Drawings and Specifications

	Plan Submittal Waiver [R309-500-6(3)(a) & (3)(b)]	Approved Standard Installation Drawings and Specifications [R309-500-7 (proposed)]
1	Two waiver types	A single approval
2	Master plan-based waiver available [(3)(a)]	Unavailable
3	Various pipe diameter limits based on PWS population [(3)(b)]	One pipe diameter limit ($\leq 16''$) for all; not population based
4	PWS must obtain waiver eligibility first	PWS must submit application for approved Standard Installation Drawings and Specs
5	Waiver eligibility does not expire	Approval must be renewed every 5 years (or whenever standard installation drawings and specifications change)
6	Required for waiver eligibility : <ol style="list-style-type: none"> 1. Letter requesting eligibility 2. Standard installation drawings and specs meeting R309-550 requirements [(3)(a) & (3)(b)] 3. PE designation for system design by PWS [(3)(b)] 4. PE designation for hydraulic analysis by PWS [(3)(b)] 	Required for approval : <ol style="list-style-type: none"> 1. Application form 2. Standard installation drawings and specs (with effective date) meeting R309-550 requirements 3. PE designation for system design by PWS (notify DDW of change) 4. PE designation for hydraulic analysis by PWS (notify DDW of change) 5. Statement with application form acknowledging hydraulic analysis, flushing, disinfection, coliform sampling, and as-built/record drawings
7	Obtain waiver for each water line project prior to construction [(3)(a) & (3)(b)]	Not required
8	Submit with each water line waiver request: <ol style="list-style-type: none"> 1. Project Notification Form (PNF) 2. Certification by designated PEs for (1) hydraulic analysis and (2) flushing, disinfection, coliform sampling, as-built/record drawings 	Not required
9	May obtain year-end after-the-fact waiver for multiple water line projects [(3)(b)]	Not required
10	Must maintain a tracking sheet for year-end, after-the-fact waivers [(3)(b)]	Not required
11	Water line projects with pump stations ineligible for waivers	Same
12	Water lines >16'' ineligible for waivers	Same
13	Water line projects not meeting water/sewer separation must obtain exception to R309-550-7	Same