

Utah's Summary Information On Underground Storage Tanks (USTs)

General Information

Public Record Posted Date:	11/5/2018
Total Number Of UST Facilities::	1331
Total Number Of USTs:	3644

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected:	957
Inspection Period Dates:	October 1, 2017 To September 30, 2018
Percent Compliance at Time of Inspection (Combined Measure):	82 %

Note: Tank, facility, and on-site inspection information is based on State of Utah site inspections, and file records. On-site inspections measure compliance with State and Federal UST regulations. Percent Compliance is based on the combined performance measure (release detection and release prevention compliance) of the significant operational compliance (SOC) requirements described in EPA's September 30, 2003 Memorandum.

Summary Information For Releases

Number Of Confirmed UST Releases:	70
Release Reporting Period Dates:	October 1, 2017 To September 30, 2018

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Damage		Corrosion		Install		Other		Unknown	
#	%		#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	7	10 %	0	0 %	0	0 %	1	100 %	3	60 %	0	0 %	0	0 %	3	5 %
Piping	5	7 %	0	0 %	0	0 %	0	0 %	2	40 %	0	0 %	0	0 %	3	5 %
Dispenser	6	9 %	4	80 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	2	4 %
STP	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Delivery Problem	4	6 %	1	20 %	3	100 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Other	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %
Unknown	48	69 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	0	0 %	48	86 %
Totals	70		5		3		1		5		0		0		56	

= number, % = percent of total number

Note: Release, source and cause information is based on Federally Regulated Underground Storage Tanks and Federally Regulated Leaking Underground Storage Tanks. Source and cause data were collected using data provided to the State of Utah from Site Inspections and Closure Notices.

The public can obtain site-specific UST information on compliance and releases. In making a request to review files, please call (801) 536-4100, fax (801) 359-8853, or mail the GRAMA Coordinator at: P.O. Box 144840 (195 North 1950 West), Salt Lake City, Utah, 84114-4840. You will be notified when your files are ready to be reviewed. For additional information, please visit our web site at <https://deq.utah.gov/> or our interactive map at <https://enviro.deq.utah.gov/>

The purpose of this report is to comply with the Public Record Provision Of The Energy Policy Act Of 2005