



<b>If you perform Interstitial Monitoring on your tanks and/or piping and use a visual check rather than sump or interstitial sensors for your monthly leak detection, complete the table to document the monthly visual checks.</b>													
	<b>Months of the Current Year</b>	<b>J</b>	<b>F</b>	<b>M</b>	<b>A</b>	<b>M</b>	<b>J</b>	<b>J</b>	<b>A</b>	<b>S</b>	<b>O</b>	<b>N</b>	<b>D</b>
1	Visual check of the interstitial space of the double-walled tank indicated no release or unusual operating conditions.												
2	Visual check of piping (STP, dispenser and transition) containment sumps indicates normal function and no indication of water or leaked product.												

<b>Impressed Current 60 Day Rectifier Check</b>													
	<b>Months of the Current Year</b>	<b>J</b>	<b>F</b>	<b>M</b>	<b>A</b>	<b>M</b>	<b>J</b>	<b>J</b>	<b>A</b>	<b>S</b>	<b>O</b>	<b>N</b>	<b>D</b>
	<b>Show the date the Impressed Current system was inspected to ensure the equipment is running properly</b>												
	<b>Amperage reading from impressed current rectifier</b>												
	<b>Voltage reading from impressed current rectifier</b>												

**INSTRUCTIONS**

1. The monthly UST system inspections must be conducted by or under the direction of the Primary Class B UST Operator.
2. The Primary Class B UST Operator must alert the UST Owner or Operator of any condition discovered during the monthly visual inspection that may require follow-up actions.
3. The UST Owner or Operator must maintain a copy of the monthly inspection reports for the most recent 12 months. The records shall be maintained on-site or off-site at a readily available location.