

# Utah's Summary Information On Underground Storage Tanks (USTs)

## General Information

Public Record Posted Date:	11/14/2023
Total Number Of UST Facilities::	1311
Total Number Of USTs:	3621

## Summary Information For On-Site Inspections

Number Of UST Facilities Inspected:	855
Inspection Period Dates:	October 1, 2022 To September 30, 2023
Percent Compliance at Time of Inspection (Combined Measure):	77%

Note: Tank, facility, and on-site inspection information is based on State of Utah site inspections, and file records. On-site inspections measure compliance with State and Federal UST regulations. Percent Compliance is based on the Technical Compliance Rate (TCR), which is a composite measure of compliance with spill prevention, overfill prevention, corrosion protection, and release detection requirements. The TCR and supporting measures are described in EPA's April 2018 guidance.

## Summary Information For Releases

Number Of Confirmed UST Releases:	53
Release Reporting Period Dates:	October 1, 2022 To September 30, 2023

## Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Damage		Corrosion		Install		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	15	28%	1	25%	0	0%	0	0%	4	100%	0	0%	0	0%	10	37%
Piping	5	9%	0	0%	0	0%	3	38%	0	0%	0	0%	1	25%	1	4%
Dispenser	17	32%	1	25%	4	67%	5	63%	0	0%	0	0%	3	75%	4	15%
STP	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	3	6%	1	25%	2	33%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	3	6%	1	25%	0	0%	0	0%	0	0%	0	0%	0	0%	2	7%
Unknown	10	19%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	10	37%
<b>Totals</b>	<b>53</b>		<b>4</b>		<b>6</b>		<b>8</b>		<b>4</b>		<b>0</b>		<b>4</b>		<b>27</b>	

# = number, % = percent of total number

Note: Release, source and cause information is based on Federally Regulated Underground Storage Tanks and Federally Regulated Leaking Underground Storage Tanks. Source and cause data were collected using data provided to the State of Utah from Site Inspections and Closure Notices.

The public can obtain site-specific UST information on compliance and releases. In making a request to review files, please call (801) 536-4100, fax (801) 359-8853, or mail the GRAMA Coordinator at: P.O. Box 144840 (195 North 1950 West), Salt Lake City, Utah, 84114-4840. You will be notified when your files are ready to be reviewed. For additional information, please visit our web site at <https://deq.utah.gov/> or our interactive map at <https://enviro.deq.utah.gov/>

The purpose of this report is to comply with the Public Record Provision Of The Energy Policy Act Of 2005