



State of Utah

GARY R. HERBERT  
*Governor*

SPENCER J. COX  
*Lieutenant Governor*

Department of  
Environmental Quality

Amanda Smith  
*Executive Director*

DIVISION OF WATER QUALITY  
Walter L. Baker, P.E.  
*Director*

September 4, 2014

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE OF A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

|                    |  |
|--------------------|--|
| PERMITTEE NAME:    | Canyonlands by Night                   |
| MAILING ADDRESS:   | 1871 North Highway 191, Moab, UT 84532 |
| TELEPHONE NUMBER:  | (435) 259-2628                         |
| FACILITY LOCATION: | 1871 North Highway 191, Moab, UT 84532 |
| UPDES PERMIT NO.:  | UT0025828                              |
| PERMITTED OUTFALLS | 001, 002                               |
| RECEIVING WATER:   | Colorado River                         |

**BACKGROUND**

Canyonlands by Night is a tourism business which has an upgraded water treatment system and has installed a wastewater treatment system. The wastewater treatment process consists of settling tanks, a recirculation tank, six Advantex textile filter pods, a storage tank and a U/V disinfection system. The discharge from the water treatment system consists of excess raw water intake and backwash water from the membrane filters. The final combined discharge will be to the Colorado River and to a large underground wastewater disposal system.

**PUBLIC COMMENTS**

Public comments are invited any time prior to the deadline of the close of business on October 3, 2014. Written public comments can be submitted to: Matthew Garn, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [mgarn@utah.gov](mailto:mgarn@utah.gov). After considering public comment the Division of Water Quality may execute the permit reissuance, revise it, or abandon it. The permit is available for public review under "Public Notices" at [www.waterquality.utah.gov](http://www.waterquality.utah.gov). If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.