


## GEOSYNTEC CONSULTANTS COMPUTATION COVER SHEET


Client: IUC Project: Tailings Cell 4A Project/Proposal #: SC0349 Task #: 03

Title of Computations: Pipe Strength Calculations


Computations By:

  
 SIGNATURE \_\_\_\_\_ DATE 05/11/08  
 \_\_\_\_\_  
 Jennifer Ferguson, Staff Engineer  
 PRINTED NAME AND TITLE \_\_\_\_\_


Assumptions and Procedures  
Checked By (Peer Reviewer):

  
 SIGNATURE \_\_\_\_\_ DATE 11/23/05  
 \_\_\_\_\_  
 Gregory T. Corcoran, Associate  
 PRINTED NAME AND TITLE \_\_\_\_\_


Computations Checked By:

  
 SIGNATURE \_\_\_\_\_ DATE 11/23/05  
 \_\_\_\_\_  
 PRINTED NAME AND TITLE \_\_\_\_\_

Computations Backchecked  
By (Originator):

  
 SIGNATURE \_\_\_\_\_ DATE 05/11/08  
 \_\_\_\_\_  
 Jennifer Ferguson, Staff Engineer  
 PRINTED NAME AND TITLE \_\_\_\_\_

Approved By  
(PM or Designate):

  
 SIGNATURE \_\_\_\_\_ DATE 11/23/05  
 \_\_\_\_\_  
 Gregory T. Corcoran, Associate  
 PRINTED NAME AND TITLE \_\_\_\_\_

Approval Notes: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Revisions: (Number and Initial All Revisions)

No.	Sheet	Date	By	Checked By	Approval
<u>1</u>	<u>5</u>	<u>8/22/06</u>	<u>JF</u>	<u>GTC</u>	<u>GTC</u>

Written by: Jennifer Ferguson Date: 05 / 10 / 27 Reviewed by: ETC Date: 05 / 11 / 23  
YY MM DD YY MM DD

Client: IUC Project: Tailings Cell 4A Project/Proposal No.: SC0349 Task No.: 03

**Wall Buckling**

Wall buckling, a longitudinal wrinkling in the pipe wall, can occur when the external vertical pressure exceeds the critical buckling pressure of the pipe/bedding aggregate system. Wall buckling can be calculated using the following equation:

$$P_{cr} = \frac{2E}{(DR - 1)^3} \quad \text{(Attachment B, 7/8)}$$

where:

$P_{cr}$  Buckling pressure, psi  
 E Modulus of elasticity = 400,000 psi (Attachment E, 2/2)

DR Standard dimension ratio =  $\frac{D_o}{t} = \frac{4.500}{0.237} = 19.0$

Therefore,

$$P_{cr} = \frac{2(400000)}{(19.0 - 1)^3} = 137 \text{ psi}$$

Comparing the above estimated value to the maximum loading allowed under ring deflection criteria (136 psi) provides:

*37.5 psi*  
 $FS_{WC} = 137/37.5$   
 $= 3.6$

This value is greater than the acceptable factor of safety of 2.

**SUMMARY AND CONCLUSIONS**

Using the Modified Iowa Formula as outlined in the Uni-Bell Plastic Pipe Association Handbook on PVC Pipe, the maximum load on the buried pipe assumed to be 37.5 psi will only cause a ring deflection of 3.5 percent, which is below the acceptable ring deflection of 7.5 percent. Acceptable factor of safety values against wall crushing and wall buckling were also evaluated using methods outlined in Uni-Bell Plastic Pipe Association Handbook on PVC Pipe. Therefore, schedule 40 PVC pipe with 4-in diameter is suitable for this application.

