

DMR DATE	FLOW	PH		TSS		BOD		TDS
	DAILY MAX	DAILY MIN	DAILY MAX	30 DAY AVG	30-DAY AVG	30 DAY AVG	MAX WEEKLY AVG	DAILY MAX
	MGD	6.5 SU	9 SU	25 mg/L	35 mg/L	25 mg/L	35 mg/L	1,200 mg/L
1/31/2007	0.115	8.1	8.1	NODI=C	NODI=C	8	8	210
2/28/2007	0.064	7.9	7.9	NODI=C	NODI=C	16	16	510
3/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
4/30/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
5/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
6/30/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
7/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
8/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
9/30/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
10/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
11/30/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
12/31/2007	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
1/31/2008	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
2/29/2008	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
3/31/2008	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C	NODI=C
4/30/2008	0.149	7.59	7.59	NODI=C	NODI=C	17	17	280
5/31/2008	0.149	8.1	8.1	NODI=C	NODI=C	NODI=C	NODI=C	270
6/30/2008	0.218	7.11	7.11	NODI=C	NODI=C	9	9	300
7/31/2008	0.307	7.3	7.3	NODI=C	NODI=C	37	37	250
8/31/2008	0.184	7.13	7.13	NODI=C	NODI=C	25	25	230
9/30/2008	0.213	8.2	8.2	NODI=B	NODI=B	0	17	220
10/31/2008	0.396	8.45	8.45	NODI=B	NODI=B	NODI=9	16	230
11/30/2008	0.218	8.3	8.3	NODI=B	NODI=B	NODI=9	13	230
12/31/2008	0.218	8.3	8.3	NODI=B	NODI=B	0	10	270
1/31/2009	0.307	8.2	8.2	NODI=B	NODI=B	<5	<5	480
2/28/2009	0.184	7.5	7.5	NODI=B	NODI=B	8	8	320
3/31/2009	0.184	8.5	8.5	NODI=B	NODI=B	NODI=B	NODI=B	350
4/30/2009	0.218	8.11	8.11	<20	<20	NODI=B	NODI=B	340
5/31/2009	0.396	7.7	7.7	20	20	110	110	270
6/30/2009	0.218	7.7	7.7	<20	<20	NODI=B	NODI=B	310
7/31/2009	0.184	7.09	7.09	NODI=B	NODI=B	NODI=B	NODI=B	230
8/31/2009	0.047	6.6	6.6	NODI=B	NODI=B	NODI=B	NODI=B	380
9/30/2009	0.086	7	7	NODI=B	NODI=B	11	11	240
10/31/2009	0.086	7.5	7.5	NODI=B	NODI=B	7	7	280
11/30/2009	0.086	7.6	7.6	NODI=C	NODI=C	NODI=C	NODI=C	270
12/31/2009	0.149	7.4	7.4	NODI=B	NODI=B	12	12	370
1/31/2010	0.115	8.3	8.3	NODI=9	NODI=9	NODI=9	NODI=9	250
2/28/2010	0.149	7.9	7.9	NODI=B	NODI=B	NODI=B	NODI=B	230
3/31/2010	0.307	8.1	8.1	NODI=B	NODI=B	NODI=B	NODI=B	250
4/30/2010	0.08	7.7	7.7	NODI=9	NODI=9	NODI=9	NODI=9	260
5/31/2010	0.184	7.7	7.7	0	0	0	0	260
6/30/2010	0.115	7.6	7.6	0	0	0	9	290
7/31/2010	0.396	7.3	7.3	0	0	0	10	290
8/31/2010	0.115	7.5	7.5	0	0	0	0	240
9/30/2010	0.149	7.25	7.25	NODI=9	NODI=9	NODI=9	NODI=9	360
10/31/2010	0.115	7.5	7.5	NODI=9	NODI=9	NODI=9	NODI=9	360
11/30/2010	0.149	8.4	8.4	NODI=9	NODI=9	NODI=9	NODI=9	240
12/31/2010	0.149	7.6	7.6	0	0	0	0	310
1/31/2011	0.396	7.4	7.4	0	0	0	0	330

2/28/2011	0.149	7.3	7.3	NODI=9	NODI=9	0	8	260
3/31/2011	0.218	7.4	7.4	0	0	0	9	250
4/30/2011	0.08	6.9	6.9	0	0	0	19	260
5/31/2011	0.157	7.52	7.52	0	0	0	0	290
6/30/2011	0.0157	7.4	7.4	NODI=B	NODI=B	25	25	250
7/31/2011	0.149	7.1	7.1	NODI=B	NODI=B	NODI=B	NODI=B	260
8/31/2011	0.218	7.8	7.8	NODI=B	NODI=B	NODI=B	NODI=B	220
9/30/2011	0.184	7.18	7.18	NODI=B	NODI=B	NODI=9	17	310
10/31/2011	0.132	7.2	7.2	NODI=9	NODI=B	NODI=9	NODI=B	200
11/30/2011	0.157	7.1	7.1	NODI=B	NODI=B	26	26	290
12/31/2011	0.184	6.6	6.6	NODI=B	NODI=B	12	12	250
1/31/2012	0.15	7.2	7.2	NODI=B	NODI=B	13	13	210
2/29/2012	0.115	6.95	6.95	NODI=B	NODI=B	NODI=B	NODI=B	250
3/31/2012	0.081	6.8	6.8	NODI=B	NODI=B	NODI=B	NODI=B	250
4/30/2012	0.132	7.05	7.05	NODI=B	NODI=B	NODI=B	NODI=B	350
5/31/2012	0.115	7	7	NODI=B	NODI=B	NODI=B	NODI=B	270
6/30/2012	0.184	6.8	6.8	NODI=B	NODI=B	NODI=B	NODI=B	320
7/31/2012	0.115	7	7	NODI=B	NODI=B	6	6	320
8/31/2012	0.15	7.1	7.1	NODI=B	NODI=B	5	5	350
9/30/2012	0.184	8.3	8.3	NODI=B	NODI=B	20	20	450

red indicates effluent limit violation

NODI=B:below method detection limit

NODI=C: no discharge

NODI=9: not monitored