



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

August 15, 2014

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF REISSUANCE OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-106 AND 107, UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING THE TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303 (d) OF THE FEDERAL CLEAN WATER ACT (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Richmond City Wastewater Treatment Facility
MAILING ADDRESS: 6 West Main, P.O. Box 9, Richmond, UT 84333
TELEPHONE NUMBER: (435) 994-1572
FACILITY LOCATION: 6 West Main, P.O. Box 9, Richmond, UT 84333
UPDES PERMIT NO.: UT0020907
OUTFALLS: 001, 002
RECEIVING WATERS: Cub River

BACKGROUND

This Permit renewal was originally public noticed in The Herald Journal and on the Utah Division of Water Quality's website from March 14, 2014 through April 14, 2014. During that time, comments were received from Richmond City. Richmond City made comments regarding the total residual chlorine limits from Outfall 001. After careful consideration of those comments, the Division of Water Quality modeled the decay rate of total residual chlorine from the facility and a new TRC limit for Outfall 001 was determined to be 0.875 mg/L. As a result of this change in permit limits, the permit is being re-public noticed.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on September 15, 2014. Written public comments can be submitted to: Lonnie Shull, UPDES IES Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lshull@utah.gov. After considering public comment the Division of Water Quality may execute the permit reissuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at www.waterquality.utah.gov. If internet access is not available, a copy may be obtained by calling Lonnie Shull at 801-536-4394.

195 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 536-4300 • Fax (801) 536-4301 • T.D.D. (801) 536-4414

www.deq.utah.gov

Printed on 100% recycled paper