

**Utah Division of Water Quality
Statement of Basis
ADDENDUM
Wasteload Analysis and Antidegradation Level I Review - PRELIMINARY**

Date: October 1, 2012

Prepared by: Nicholas von Stackelberg, P.E.
Water Quality Management Section

Facility: Salem City Wastewater Treatment Facility
Salem, UT
UPDES No. UT0020249

Receiving water: Beer Creek (2B, 3C, 4)

This addendum summarizes the wasteload analysis that was performed to determine water quality based effluent limits (WQBEL) for this discharge. Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses (UAC R317-2-8). Projected concentrations are compared to numeric water quality standards to determine acceptability. The numeric criteria in this wasteload analysis may be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

Discharge

Outfall 001: Irrigation Ditch → Beer Creek → Benjamin Slough of Utah Lake
Outfall 002: Constructed Wetlands → Irrigation Ditch → Beer Creek → Benjamin Slough

The maximum daily design discharge is 2.0 MGD and the maximum monthly design discharge is 1.25 MGD for the facility.

Receiving Water

The receiving water for Outfall 001 is an irrigation ditch, which is tributary to Beer Creek, which drains to Benjamin Slough of Utah Lake.

The receiving water for Outfall 002 is a constructed wetland, which outlets to the same irrigation ditch as Outfall 001.

Per UAC R317-2-13.5.c, the designated beneficial uses for Beer Creek (Utah County) from 4850 West (in NE1/4NE1/4 sec. 36, T.8 S., R.1 E.) to headwaters are 2B, 3C, and 4.

- *Class 2B - Protected for infrequent primary contact recreation. Also protected for secondary contact recreation where there is a low likelihood of ingestion of water or a low degree of bodily contact with the water. Examples include, but are not limited to, wading, hunting, and fishing.*

Utah Division of Water Quality
Wasteload Analysis
Salem City Wastewater Treatment Plant, Salem, UT
UPDES No. UT0020249

- *Class 3C - Protected for nongame fish and other aquatic life, including the necessary aquatic organisms in their food chain*
- *Class 4 - Protected for agricultural uses including irrigation of crops and stock watering.*

Typically, the critical flow for the wasteload analysis is considered the lowest stream flow for seven consecutive days with a ten year return frequency (7Q10). Due to a lack of flow records for the irrigation ditch and Beer Creek, the 20th percentile of flow measurements was calculated to estimate annual critical flow in the receiving water (Table 1).

Table 1: Annual critical low flow

Waterbody	Flow (cfs)
Irrigation Ditch above Lagoons	0.5
Beer Creek above confluence with Irrigation Ditch	2.0

TMDL

Beer Creek is not listed as impaired for any parameters according to the 2010 303(d) list. Utah Lake is listed as impaired for Total Phosphorus and Total Dissolved Solids.

Mixing Zone

The discharge is considered instantaneously fully mixed since the discharge is more than twice the background receiving water flow. Therefore, no mixing zone is allowed.

Parameters of Concern

The potential parameters of concern identified for the discharge/receiving water were total suspended solids (TSS), dissolved oxygen (DO), BOD₅, total phosphorus (TP), total nitrogen (TN), total ammonia (TAM), E. coli, pH, and total residual chlorine (TRC) as determined in consultation with the UPDES Permit Writer.

Water Quality Modeling

A QUAL2Kw model of the receiving water was built based on physiographic information from Google Earth and site data collected by DWQ staff. The model extends from the facility discharge past the confluence with Beer Creek to Arrowhead Trail Road.

Insufficient observed data was available for model calibration. The rate parameters used in the model were the same as those used for the Spanish Fork WWTP QUAL2Kw model, which was calibrated under contract by Utah State University. Beer Creek was considered to have similar stream characteristics as Dry Creek.

Receiving water quality data was obtained from monitoring sites 4995460 Beer Creek (L-FK) above Salem WWTP and 5919820 Beer Creek at Arrowhead Road. The average seasonal value was calculated for each constituent with available data in the receiving water.

The QUAL2Kw model was used for determining the WQBELs. Effluent concentrations were

Utah Division of Water Quality
Wasteload Analysis
Salem City Wastewater Treatment Plant, Salem, UT
UPDES No. UT0020249

adjusted so that water quality standards were not exceeded in the receiving water.

Where WQBELs exceeded secondary standards or categorical limits, the concentration in the model was set at the secondary standard or categorical limit.

The wasteload model is available for review by request.

WET Limits

The percent of effluent in the receiving water in a fully mixed condition, and acute and chronic dilution in a not fully mixed condition are calculated in the WLA in order to generate WET limits.

The LC₅₀ (lethal concentration, 50%) percent effluent for acute toxicity and the IC₂₅ (inhibition concentration, 25%) percent effluent for chronic toxicity, as determined by the WET test, needs to be below the WET limits, as determined by the WLA. The WET limit for LC₅₀ is typically 100% effluent and does not need to be determined by the WLA.

Table 2: WET Limits for IC₂₅

Season	Percent Effluent
Annual	79%

Effluent Limits

The effect of the effluent on the DO in the receiving water was evaluated using the QUAL2Kw model. A DO sag downstream resulting from the plant discharge was predicted by the model in the irrigation ditch. However, the DO recovered at the confluence with Beer Creek and limits beyond secondary standards are not required for DO and BOD₅ (Table 3).

Due to relatively high temperature and pH in the receiving water after mixing, the ammonia limits for acute and chronic toxicity are stringent.

QUAL2Kw rates, input and output for DO, eutrophication related constituents, and TRC are summarized in Appendix A.

A simple mixing analysis was conducted for conservative constituents such as dissolved metals. The simple mixing analysis WQBELs are summarized in Appendix B.

Models and supporting documentation are available for review upon request.

Utah Division of Water Quality
Wasteload Analysis
Salem City Wastewater Treatment Plant, Salem, UT
UPDES No. UT0020249

Table 3: Water Quality Based Effluent Limits Summary

Effluent Constituent	Acute			Chronic		
	Standard	Limit	Averaging Period	Standard	Limit	Averaging Period
Flow (MGD)		2.0	1 day		1.25	30 days
Ammonia (mg/L) ¹	Varies	5.0	1 hour	Varies	1.5	30 days
Min. Dissolved Oxygen (mg/L)	3.0	5.0	Instantaneous	5.0	5.0	30 days
BOD ₅ (mg/L) ²	None	65	7 days	None	45	30 days
TRC (mg/L)	0.019	0.110	1 hour	0.011	0.075	4 days
<p>1: Ammonia limit due to toxicity requirements. 2: CBOD₅ test could be used in lieu of BOD₅ test.</p>						

Antidegradation Level I Review

The objective of the Level I ADR is to ensure the protection of existing uses, defined as the beneficial uses attained in the receiving water on or after November 28, 1975. No evidence is known that the existing uses deviate from the designated beneficial uses for the receiving water. Therefore, the beneficial uses will be protected if the discharge remains below the WQBELs presented in this wasteload.

A Level II Antidegradation Review (ADR) is not required for this discharge since the pollutant concentration and load is not increasing under this permit renewal.

WLA Document: *salem_potw_wla_2012_preliminary.docx*
QUAL2Kw Wasteload Model: *salem_potw_wla_2012.xlsm*

Utah Division of Water Quality

Date: 10/1/2012

WASTELOAD ANALYSIS [WLA]

Appendix A: QUAL2Kw Analysis for Eutrophication

Discharging Facility: Salem WWTP
 UPDES No: UT-0020249
 Permit Flow [MGD]: 1.25 Maximum Monthly Flow
 2.00 Maximum Daily Flow

Receiving Water: Beer Creek
 Stream Classification: 2B, 3C, 4
 Stream Flows [cfs]: 0.50 Summer (July-Sept) Critical Low Flow
 0.50 Fall (Oct-Dec)
 0.50 Winter (Jan-Mar)
 0.50 Spring (Apr-June)

Fully Mixed: YES
 Acute River Width: 100%
 Chronic River Width: 100%

Modeling Information

A QUAL2Kw model was used to determine these effluent limits.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Headwater/Upstream Information	Summer	Fall	Winter	Spring
Flow (cfs)	0.5	0.5	0.5	0.5
Temperature (deg C)	22.4	8.6	2.9	14.9
Specific Conductance (µmhos)	1180	1180	1180	1180
Inorganic Suspended Solids (mg/L)	10.7	12.9	12.2	21.8
Dissolved Oxygen (mg/L)	8.1	8.6	10.9	11.8
CBOD ₅ (mg/L)	1.8	2.1	2.3	2.7
Organic Nitrogen (mg/L)	1.500	1.500	1.500	1.500
NH ₄ -Nitrogen (mg/L)	0.081	0.072	0.103	0.169
NO ₃ -Nitrogen (mg/L)	1.000	1.000	1.000	1.000
Organic Phosphorus (mg/L)	0.168	0.107	0.154	0.199
Inorganic Ortho-Phosphorus (mg/L)	0.042	0.027	0.039	0.050
Phytoplankton (µg/L)	0.0	0.0	0.0	0.0
Detritus [POM] (mg/L)	1.2	1.4	1.4	2.4
Alkalinity (mg/L)	235	235	235	235
pH	8.0	8.1	8.2	8.5
TRC (mg/L)	0.0	0.0	0.0	0.0

Discharge Information	Summer	Fall	Winter	Spring
Flow (cfs)	1.3	1.3	1.3	1.3
Temperature (deg C)	23.9	10.9	4.4	16.3
Inorganic Suspended Solids (mg/L)	12.0	13.3	21.8	23.6
NO ₃ -Nitrogen (mg/L)	0.833	3.033	0.444	2.148
Organic Phosphorus (mg/L)	0.000	0.000	0.000	0.000
Alkalinity (mg/L)	235	235	235	235
pH	8.2	8.2	8.2	8.4

Utah Division of Water Quality

Tributary Information	Summer	Fall	Winter	Spring
Flow (cfs)	2.0	2.0	2.0	2.0
Temperature (deg C)	24.6	10.7	4.3	15.4
Specific Conductance (µmhos)	1050.0	1050.0	1050.0	1050.0
Inorganic Suspended Solids (mg/L)	44.3	34.6	13.0	38.0
Dissolved Oxygen (mg/L)	8.2	9.4	10.5	8.7
CBOD ₅ (mg/L)	6.9	2.3	3.6	9.0
Organic Nitrogen (mg/L)	1.0	1.0	1.0	1.0
NH ₄ -Nitrogen (mg/L)	0.2	0.1	0.5	0.4
NO ₃ -Nitrogen (mg/L)	1.0	1.0	1.0	1.0
Organic Phosphorus (mg/L)	0.6	0.4	0.3	0.3
Inorganic Ortho-Phosphorus (mg/L)	0.1	0.1	0.1	0.1
Phytoplankton (µg/L)	0.0	0.0	0.0	0.0
Detritus [POM] (mg/L)	4.9	3.8	1.4	4.2
Alkalinity (mg/L)	235.0	235.0	235.0	235.0
pH	8.3	8.1	8.2	8.3
TRC (mg/L)	0.0	0.0	0.0	0.0

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort reflect the environmental conditions expected at low stream flows.

Effluent Limitations based upon Water Quality Standards for DO and Ammonia Toxicity

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent limitation as follows:

	Chronic Standard	Summer	Fall	Winter	Spring
Flow (MGD)	N/A	1.25	1.25	1.25	1.25
Organic Nitrogen (mg/L)	N/A	5.0	5.0	5.0	5.0
NH ₄ -Nitrogen (mg/L)	Varies	1.5	1.5	1.5	1.5
Inorganic Phosphorus (mg/L)	N/A	5.0	5.0	5.0	5.0
CBOD ₅ (mg/L)	N/A	45.0	45.0	45.0	45.0
Dissolved Oxygen [30-day Ave] (mg/L)	5.0	5.0	5.0	5.0	5.0
TRC (mg/L)	0.011	0.075	0.075	0.075	0.075

	Acute Standard	Summer	Fall	Winter	Spring
Flow (cfs)	N/A	2.0	2.0	2.0	2.0
Organic Nitrogen (mg/L)	N/A	10.0	10.0	10.0	10.0
NH ₄ -Nitrogen (mg/L)	Varies	5.0	5.0	5.0	5.0
Inorganic Phosphorus (mg/L)	N/A	10.0	10.0	10.0	10.0
CBOD ₅ (mg/L)	N/A	65.0	65.0	65.0	65.0
Dissolved Oxygen [Minimum] (mg/L)	3.0	5.0	5.0	5.0	5.0
TRC (mg/L)	0.019	0.110	0.110	0.110	0.110

Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

Utah Division of Water Quality

Coefficients and Other Model Information

<i>Parameter</i>	<i>Value</i>	<i>Units</i>
<i>Stoichiometry:</i>		
Carbon	40	gC
Nitrogen	7.2	gN
Phosphorus	1	gP
Dry weight	100	gD
Chlorophyll	1	gA
<i>Inorganic suspended solids:</i>		
Settling velocity	0.001	m/d
<i>Oxygen:</i>		
Reaeration model	Internal	
Temp correction	1.024	
Reaeration wind effect	None	
O2 for carbon oxidation	2.69	gO2/gC
O2 for NH4 nitrification	4.57	gO2/gN
Oxygen inhib model CBOD oxidation	Exponential	
Oxygen inhib parameter CBOD oxidation	0.60	L/mgO2
Oxygen inhib model nitrification	Exponential	
Oxygen inhib parameter nitrification	0.60	L/mgO2
Oxygen enhance model denitrification	Exponential	
Oxygen enhance parameter denitrification	0.60	L/mgO2
Oxygen inhib model phyto resp	Exponential	
Oxygen inhib parameter phyto resp	0.60	L/mgO2
Oxygen enhance model bot alg resp	Exponential	
Oxygen enhance parameter bot alg resp	0.60	L/mgO2
<i>Slow CBOD:</i>		
Hydrolysis rate	0	/d
Temp correction	1.047	
Oxidation rate	0.242802	/d
Temp correction	1.047	
<i>Fast CBOD:</i>		
Oxidation rate	10	/d
Temp correction	1.047	
<i>Organic N:</i>		
Hydrolysis	0.2625675	/d
Temp correction	1.07	
Settling velocity	0.087906	m/d
<i>Ammonium:</i>		
Nitrification	2.817054	/d
Temp correction	1.07	
<i>Nitrate:</i>		
Denitrification	1.756367	/d
Temp correction	1.07	
Sed denitrification transfer coeff	0.24334	m/d
Temp correction	1.07	
<i>Organic P:</i>		
Hydrolysis	0.227735	/d
Temp correction	1.07	
Settling velocity	0.103774	m/d
<i>Inorganic P:</i>		
Settling velocity	0.06798	m/d
Sed P oxygen attenuation half sat constant	0.99342	mgO2/L

Utah Division of Water Quality

Phytoplankton:

Max Growth rate	2.57133	/d
Temp correction	1.07	
Respiration rate	0.1432355	/d
Temp correction	1.07	
Death rate	0.45734	/d
Temp correction	1	
Nitrogen half sat constant	15	ugN/L
Phosphorus half sat constant	2	ugP/L
Inorganic carbon half sat constant	1.30E-05	moles/L
Phytoplankton use HCO3- as substrate	Yes	
Light model	Smith	
Light constant	57.6	langleys/d
Ammonia preference	15	ugN/L
Settling velocity	0.0645665	m/d

Bottom Plants:

Growth model	Zero-order	
Max Growth rate	8.663865	gD/m2/d or /d
Temp correction	1.07	
First-order model carrying capacity	100	gD/m2
Basal respiration rate	0.1046738	/d
Photo-respiration rate parameter	0.39	unitless
Temp correction	1.07	
Excretion rate	0.05015	/d
Temp correction	1.07	
Death rate	0.1437	/d
Temp correction	1.07	
External nitrogen half sat constant	127.576	ugN/L
External phosphorus half sat constant	89.161	ugP/L
Inorganic carbon half sat constant	1.10E-04	moles/L
Bottom algae use HCO3- as substrate	Yes	
Light model	Half saturation	
Light constant	71.6656	langleys/d
Ammonia preference	15.2922	ugN/L
Subsistence quota for nitrogen	0.9375732	mgN/gD
Subsistence quota for phosphorus	0.058037	mgP/gD
Maximum uptake rate for nitrogen	640.4095	mgN/gD/d
Maximum uptake rate for phosphorus	190.7675	mgP/gD/d
Internal nitrogen half sat ratio	1.8677685	
Internal phosphorus half sat ratio	4.4374015	
Nitrogen uptake water column fraction	1	
Phosphorus uptake water column fraction	1	

Detritus (POM):

Dissolution rate	3.773984	/d
Temp correction	1.07	
Settling velocity	0.097025	m/d

pH:

Partial pressure of carbon dioxide	370	ppm
------------------------------------	-----	-----

TRC:

Decay rate	20	/d
------------	----	----

Atmospheric Inputs:

	Summer	Fall	Winter	Spring
Min. Air Temperature, F	57.7	29.5	24.0	45.0
Max. Air Temperature, F	90.5	51.0	44.9	74.2
Dew Point, Temp., F	58.6	35.0	30.3	48.5
Wind, ft./sec. @ 21 ft.	9.8	7.5	7.6	9.2
Cloud Cover, %	10%	10%	10%	10%

Other Inputs:

Bottom Algae Coverage	100%
Bottom SOD Coverage	100%
Prescribed SOD, gO ₂ /m ² /day	0

Utah Division of Water Quality

Date: 10/1/2012

WASTELOAD ANALYSIS [WLA]

Appendix B: Simple Mixing Analysis for Conservative Constituents

Discharging Facility: Salem WWTP
 UPDES No: UT-0020249
 Permit Flow [MGD]: 1.25 Maximum Monthly Flow
 2.00 Maximum Daily Flow

Receiving Water: Beer Creek
 Stream Classification: 2B, 3C, 4
 Stream Flows [cfs]: 0.50 Summer (July-Sept) Critical Low Flow
 0.50 Fall (Oct-Dec)
 0.50 Winter (Jan-Mar)
 0.50 Spring (Apr-June)

Fully Mixed: YES
 Acute River Width: 100%
 Chronic River Width: 100%

Modeling Information

A simple mixing analysis was used to determine these effluent limits.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Headwater/Upstream Information

	Irrigation	
	Ditch cfs	Beer Creek cfs
Summer	0.5	2.00
Fall	0.5	2.00
Winter	0.5	2.00
Spring	0.5	2.00

Discharge Information

	Flow MGD
Maximum Daily	2.0
Maximum Monthly	1.25

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort reflect the environmental conditions expected at low stream flows.

Utah Division of Water Quality

Effluent Limitations for Protection of Recreation (Class 2B Waters)

Physical		Maximum Concentration
Parameter		
	pH Minimum	6.5
	pH Maximum	9.0
Bacteriological		
	E. coli (30 Day Geometric Mean)	206 (#/100 mL)
	E. coli (Maximum)	668 (#/100 mL)

Effluent Limitations for Protection of Aquatic Wildlife (Class 3C Waters)

Physical		Maximum Concentration	
Parameter			
	Temperature (deg C)	27	
	Temperature Change (deg C)	4	
Inorganics			
	Parameter	Chronic Standard (4 Day Average) Standard	Acute Standard (1 Hour Average) Standard
	Phenol (mg/L)		0.010
	Hydrogen Sulfide (Undissociated) [mg/L]		0.002

Dissolved Metals	Parameter	Chronic Standard (4 Day Average) ¹			Acute Standard (1 Hour Average) ¹		
		Standard	Background ²	Limit	Standard	Background ²	Limit
	Aluminum (µg/L)	87.0	58.3	124.1	750.0	58.3	1308.9
	Arsenic (µg/L)	150.0	100.5	214.0	340.0	100.5	533.5
	Cadmium (µg/L)	0.4	0.3	0.6	3.9	0.3	6.9
	Chromium VI (µg/L)	11.0	7.4	15.7	16.0	7.4	23.0
	Chromium III (µg/L)	130.8	87.6	186.5	1005.2	87.6	1746.6
	Copper (µg/L)	16.2	10.8	23.1	25.8	10.8	37.9
	Cyanide (µg/L)	22.0	14.7	31.4	5.2	14.7	-2.5
	Iron (µg/L)				1000.0	670.0	1266.6
	Lead (µg/L)	5.3	3.6	7.6	136.1	3.6	243.3
	Mercury (µg/L)	0.012	0.008	0.017	2.4	0.0	4.3
	Nickel (µg/L)	93.5	62.6	133.4	841.7	62.6	1471.1
	Selenium (µg/L)	4.6	3.1	6.6	18.4	3.1	30.8
	Silver (µg/L)				10.6	7.1	13.4
	Tributyltin (µg/L)	0.072	0.048	0.103	0.46	0.05	0.79
	Zinc (µg/L)	212.5	142.4	303.2	210.8	142.4	266.1

1: Based upon a Hardness of 200 mg/l as CaCO₃

2: Background concentration assumed 67% of chronic standard

Utah Division of Water Quality

Organics [Pesticides]	Chronic Standard (4 Day Average)			Acute Standard (1 Hour Average)			
	Parameter	Standard	Background ¹	Limit	Standard	Background ¹	Limit
Aldrin (µg/L)					1.5	1.0	1.9
Chlordane (µg/L)	0.0043	0.0029	0.0061	1.2	0.0	2.2	
DDT, DDE (µg/L)	0.001	0.001	0.001	0.55	0.00	0.99	
Diazinon (µg/L)	0.17	0.11	0.24	0.17	0.11	0.22	
Dieldrin (µg/L)	0.0056	0.0038	0.0080	0.24	0.00	0.43	
Endosulfan, a & b (µg/L)	0.056	0.038	0.080	0.11	0.04	0.17	
Endrin (µg/L)	0.036	0.024	0.051	0.086	0.024	0.136	
Heptachlor & H. epoxide (µg/L)	0.0038	0.0025	0.0054	0.26	0.00	0.47	
Lindane (µg/L)	0.08	0.05	0.11	1.0	0.1	1.8	
Methoxychlor (µg/L)				0.03	0.02	0.04	
Mirex (µg/L)				0.001	0.001	0.001	
Nonylphenol (µg/L)	6.6	4.4	9.4	28.0	4.4	47.1	
Parathion (µg/L)	0.0130	0.0087	0.0185	0.066	0.009	0.112	
PCB's (µg/L)	0.014	0.009	0.020				
Pentachlorophenol (µg/L)	15.0	10.1	21.4	19.0	10.1	26.2	
Toxephene (µg/L)	0.0002	0.0001	0.0003	0.73	0.00	1.32	

1: Background concentration assumed 67% of chronic standard

Radiological

Parameter	Maximum Concentration		
	Standard	Background ¹	Limit
Gross Alpha (pCi/L)	15	10.1	21.4

1: Background concentration assumed 67% of chronic standard; TDS is based on observed ambient data

Effluent Limitation for Protection of Agriculture (Class 4 Waters)

Parameter	Maximum Concentration		
	Standard	Background ¹	Limit
Total Dissolved Solids (mg/L)	1200	700	1846
Boron (µg/L)	75	50.3	107.0
Arsenic (µg/L)	100	67.0	142.7
Cadmium (µg/L)	10	6.7	14.3
Chromium (µg/L)	100	67.0	142.7
Copper (µg/L)	200	134.0	285.3
Lead (µg/L)	100	67.0	142.7
Selenium (µg/L)	50	33.5	71.3
Gross Alpha (pCi/L)	15	10.1	21.4

1: Background concentration assumed 67% of chronic standard; TDS is based on observed ambient data

