



State of Utah

GARY R. HERBERT  
Governor

SPENCER J. COX  
Lieutenant Governor

Department of  
Environmental Quality

Alan Matheson  
Executive Director

DIVISION OF WATER QUALITY  
Walter L. Baker, P.E.  
Director

October 6, 2016

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to issue a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: South Davis Sewer District-North Plant  
MAILING ADDRESS: P.O. Box 140111, Salt Lake City, UT 84114  
TELEPHONE NUMBER: 801-295-3469  
FACILITY LOCATION: 1800 W 1200 North, West Bountiful, UT 84087  
UPDES PERMIT NO.: UT0021636  
PERMITTED OUTFALLS: 001  
RECEIVING WATER: State Canal

BACKGROUND

The South Davis County Sewer District North Wastewater Treatment Plant (SDSDN) serves the cities of Centerville, Woods Cross, West Bountiful and portions of Bountiful with a daily average design flow of 12 million gallons per day (MGD) and a design population equivalent of 75,000. The facility functions in single-stage trickling filter mode. Unit operations and processes at SDSDN include influent pumping, screening, grit removal, primary clarification, biological processing using trickling filters, secondary clarification, chlorination, and dechlorination prior to release into the State Canal. Sludge generated during unit processes is stabilized in two-stage mesophilic anaerobic digesters and dried in drying beds.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on November 7, 2016. Written public comments can be submitted to: Matthew Garn, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [mgarn@utah.gov](mailto:mgarn@utah.gov). After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.