

**WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis
SUMMARY**

Date: 9/14/2012 Time: 4:37 PM

Discharging Facility: EA Miller

UPDES No: UT00000281
Current Flow: 2.00 MGD
Design Flow: 2.00 MGD

Non-Irrigation Season (October - March) ← 

Receiving Water: Ditch to So. Fork of Spring Creek
Stream Classification: 2B, 3A, 3B, 4 Controlling: 3A
Stream Flows [cfs]:
0.10 Summer (July-Sept) Critical Low Flow
- Fall (Oct-Dec) Critical Low Flow
0.12 Winter (Jan-Mar) Critical Low Flow
- Spring (Apr-June) Critical Low Flow

Stream TDS Values [mg/l as CaCO3]
- Summer (July-Sept)
- Fall (Oct-Dec)
- Winter (Jan-Mar)
- Spring (Apr-June)

Parameter:	Effluent Limits:	WQ Standard:
Winter Flow, MGD:	2.00 MGD	
BOD, mg/l:	25.00 Winter	5.0 Indicator
Dissolved Oxygen, mg/l:	4.00 Winter	6.5 30 Day Average
NH4	4.00 Winter	Standard is a function of pH and Temperature.
TDS, mg/l:	3,600.00 Winter	1950.00 mg/l

Modeling Parameters:
Acute River Width: 50.0%
Chronic River Width: 100.0%

Antidegradation Review: An Antidegradation Level I Review was completed.
Antidegradation Level II Review is NOT Required

Permit Writer: _____
WLA by: Geir U. Uay 9-14-12
WQM Sec. Approval: _____
TMDL Sec. Approval: _____

**WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis**

Date: 9/14/2012
Time: 4:37 PM

Facilities: EA Miller
Discharging to: Ditch to So. Fork of Spring Creek

UPDES No: UT00000281

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Ditch to So. Fork of Spring Creek 2B, 3A, 3B, 4
Antidegradation Review: Antidegradation Level II Review is NOT Required

III. Numeric Stream Standards for Protection of Aquatic Wildlife

Total Ammonia (TNH3)	Varies as a function of Temperature and pH Rebound. See Water Quality Standards
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average)
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average) N/A mg/l (7Day Average) 3.00 mg/l (1 Day Average)
Maximum Total Dissolved Solids	1200.0 mg/l

Acute and Chronic Heavy Metals (Dissolved)

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Aluminum	87.00 ug/l**	0.056 lbs/day	750.00 ug/l	0.485 lbs/day
Arsenic	190.00 ug/l	0.123 lbs/day	340.00 ug/l	0.220 lbs/day
Cadmium	0.75 ug/l	0.000 lbs/day	8.65 ug/l	0.006 lbs/day
Chromium III	266.17 ug/l	0.172 lbs/day	5568.73 ug/l	3.602 lbs/day
ChromiumVI	11.00 ug/l	0.007 lbs/day	16.00 ug/l	0.010 lbs/day
Copper	30.26 ug/l	0.020 lbs/day	51.23 ug/l	0.033 lbs/day
Iron			1000.00 ug/l	0.647 lbs/day
Lead	18.36 ug/l	0.012 lbs/day	471.16 ug/l	0.305 lbs/day
Mercury	0.012 ug/l	0.000 lbs/day	2.40 ug/l	0.002 lbs/day
Nickel	167.21 ug/l	0.108 lbs/day	1503.94 ug/l	0.973 lbs/day

Selenium	4.60 ug/l	0.003 lbs/day	20.00 ug/l	0.013 lbs/day
Silver	N/A ug/l	N/A lbs/day	40.41 ug/l	0.026 lbs/day
Zinc	384.76 ug/l	0.249 lbs/day	384.76 ug/l	0.249 lbs/day

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃
Metals Standards based upon a hardness of 396.266334785314 mg/l as CaCO₃ where applicable.

Organics [Pesticides]

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Aldrin	ug/l		1.5000 ug/l	9.702E-04 lbs/day
Chlordane	0.0043 ug/l	2.781E-06 lbs/day	1.2000 ug/l	7.762E-04 lbs/day
DDT, DDE	0.0010 ug/l	6.468E-07 lbs/day	0.5500 ug/l	3.557E-04 lbs/day
Dieldrin	0.0019 ug/l	1.229E-06 lbs/day	1.2500 ug/l	8.085E-04 lbs/day
Endosulfan	0.0560 ug/l	3.622E-05 lbs/day	0.1100 ug/l	7.115E-05 lbs/day
Endrin	0.0023 ug/l	1.488E-06 lbs/day	0.0900 ug/l	5.821E-05 lbs/day
Guthion			0.0100	
Heptachlor	0.0038 ug/l	2.458E-06 lbs/day	0.2600 ug/l	1.682E-04 lbs/day
Lindane	0.0800 ug/l	5.174E-05 lbs/day	1.0000 ug/l	6.468E-04 lbs/day
Methoxychlor			0.0300	
Mirex			0.0100	
Parathion			0.0400	
PCB's	0.0140 ug/l	9.055E-06 lbs/day	2.0000 ug/l	1.294E-03 lbs/day
Pentachlorophenol	13.0000 ug/l	8.408E-03 lbs/day	20.0000 ug/l	1.294E-02 lbs/day
Toxephene	0.0002 ug/l	1.294E-07 lbs/day	0.7300 ug/l	4.722E-04 lbs/day

IV. Numeric Stream Standards for Protection of Agriculture

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic	N/A		100.0 ug/l	6.47E-02 lbs/day
Boron	N/A		750.0 ug/l	4.85E-01 lbs/day
Cadmium	N/A		10.0 ug/l	6.47E-03 lbs/day
Chromium	N/A		100.0 ug/l	6.47E-02 lbs/day
Copper	N/A		200.0 ug/l	1.29E-01 lbs/day
Lead	N/A		100.0 ug/l	6.47E-02 lbs/day
Selenium	N/A		50.0 ug/l	3.23E-02 lbs/day
TDS	N/A		1200.0 mg/l	3.88E-01 tons/day

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

Metals	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic	N/A		50.0 ug/l	3.23E-02 lbs/day
Barium	N/A		1000.0 ug/l	6.47E-01 lbs/day
Cadmium	N/A		10.0 ug/l	6.47E-03 lbs/day
Chromium	N/A		50.0 ug/l	3.23E-02 lbs/day
Lead	N/A		50.0 ug/l	3.23E-02 lbs/day
Mercury	N/A		2.0 ug/l	1.29E-03 lbs/day
Selenium	N/A		10.0 ug/l	6.47E-03 lbs/day
Silver	N/A		50.0 ug/l	3.23E-02 lbs/day
Fluoride (3)	N/A		1.4 ug/l	9.06E-04 lbs/day
to	N/A		2.4 ug/l	1.55E-03 lbs/day
Nitrates as N	N/A		10.0 ug/l	6.47E-03 lbs/day

Chlorophenoxy Herbicides	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
2,4-D	N/A		100.0 ug/l	6.47E-02 lbs/day
2,4,5-TP	N/A		10.0 ug/l	6.47E-03 lbs/day

Endrin	N/A	0.2 ug/l	1.29E-04 lbs/day
Hexachlorocyclohexane (Lindane)	N/A	4.0 ug/l	2.59E-03 lbs/day
Methoxychlor	N/A	100.0 ug/l	6.47E-02 lbs/day
Toxaphene	N/A	5.0 ug/l	3.23E-03 lbs/day

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

	Maximum Conc., ug/l - Acute Standards			
	Class 1C [2 Liters/Day for 70 Kg Person over 70 Yr.]		Class 3A, 3B [6.5 g for 70 Kg Person over 70 Yr.]	
Antimony	6E+00 ug/l	6E+00 lbs/day	6E+02 ug/l	6.65E+02 lbs/day
Arsenic				
Beryllium				
Cadmium				
Chromium III				
Chromium VI				
Copper	1E+03 ug/l	1E+03 lbs/day	0E+00 ug/l	0.00E+00 lbs/day
Lead				
Mercury				
Nickel	1E+02 ug/l	1E+02 lbs/day	5E+03 ug/l	4.78E+03 lbs/day
Selenium			4E+03 ug/l	4.36E+03 lbs/day
Silver				
Thallium	2E-01 ug/l	2E-01 lbs/day	5E-01 ug/l	4.84E-01 lbs/day
Zinc	7E+03 ug/l	8E+03 lbs/day	3E+04 ug/l	2.70E+04 lbs/day
Cyanide	1E+02 ug/l	1E+02 lbs/day	1E+02 ug/l	1.45E+02 lbs/day
Asbestos				
2,3,7,8-TCDD	5E-09			
Dioxin				
Acrolein	2E+02 ug/l	2E+02 lbs/day	3E+02 ug/l	2.98E+02 lbs/day
Acrylonitrile	5E-02 ug/l	5E-02 lbs/day	3E-01 ug/l	2.59E-01 lbs/day
Alachlor	2E+00 ug/l	2E+00 lbs/day		
Atrazine	3E+00 ug/l	3E+00 lbs/day		
Benzene	2E+00 ug/l	2E+00 lbs/day	5E+01 ug/l	5.29E+01 lbs/day
Bromoforn	4E+00 ug/l	4E+00 lbs/day	1E+02 ug/l	1.45E+02 lbs/day
Carbofuran	4E+01 ug/l	4E+01 lbs/day		
Carbon Tetrachloride	2E-01 ug/l	2E-01 lbs/day	2E+00 ug/l	1.66E+00 lbs/day
Chlorobenzene	1E+02 ug/l	1E+02 lbs/day	2E+03 ug/l	1.66E+03 lbs/day
Chlorodibromomethane	4E-01 ug/l	4E-01 lbs/day	1E+01 ug/l	1.35E+01 lbs/day
Chloroethane				
2-Chloroethylvinyl Ether				
Chloroform	6E+00 ug/l	6E+00 lbs/day	5E+02 ug/l	4.88E+02 lbs/day
Dalapon	2E+02 ug/l	2E+02 lbs/day		
Di(2ethylhexyl)adipate	4E+02 ug/l	4E+02 lbs/day		
Dibromochloropropane	2E-01 ug/l	2E-01 lbs/day		
Dichlorobromomethane	6E-01 ug/l	6E-01 lbs/day	2E+01 ug/l	1.76E+01 lbs/day
1,1-Dichloroethane				
1,2-Dichloroethane	4E-01 ug/l	4E-01 lbs/day	4E+01 ug/l	3.84E+01 lbs/day
1,1-Dichloroethylene	7E+00 ug/l	7E+00 lbs/day	7E+03 ug/l	7.38E+03 lbs/day
Dichloroethylene (cis-1,2	7E+01 ug/l	7E+01 lbs/day	0E+00 ug/l	
Dinose	7E+00 ug/l	7E+00 lbs/day	0E+00 ug/l	
Diquat	2E+01 ug/l	2E+01 lbs/day	0E+00 ug/l	
1,2-Dichloropropane	5E-01 ug/l	5E-01 lbs/day	2E+01 ug/l	1.56E+01 lbs/day
1,3-Dichloropropene	3E-01 ug/l	3E-01 lbs/day	2E+01 ug/l	2.18E+01 lbs/day
Endothall	1E+02 ug/l	1E+02 lbs/day		
Ethylbenzene	5E+02 ug/l	5E+02 lbs/day	2E+03 ug/l	2.17E+03 lbs/day
Ethylene Dibromide	5E-02 ug/l	5E-02 lbs/day		
Glyphosate	7E+02 ug/l	7E+02 lbs/day		
Haloacetic acids	6E+01 ug/l	6E+01 lbs/day		
Methyl Bromide	5E+01 ug/l	5E+01 lbs/day	2E+03 ug/l	1.56E+03 lbs/day

Methyl Chloride				
Methylene Chloride	5E+00 ug/l	5E+00 lbs/day	6E+02 ug/l	6.13E+02 lbs/day
Ocamyl (vidate)	2E+02 ug/l	2E+02 lbs/day		
Picloram	5E+02 ug/l	5E+02 lbs/day		
Simazine	4E+00 ug/l	4E+00 lbs/day		
Styrene	1E+02 ug/l	1E+02 lbs/day		
1,1,2,2-Tetrachloroethane	2E-01 ug/l	2E-01 lbs/day	4E+00 ug/l	4.15E+00 lbs/day
Tetrachloroethylene	7E-01 ug/l	7E-01 lbs/day	3E+00 ug/l	3.41E+00 lbs/day
Toluene	1E+03 ug/l	1E+03 lbs/day	2E+04 ug/l	1.56E+04 lbs/day
1,2 -Trans-Dichloroethyle	1E+02 ug/l	1E+02 lbs/day	1E+04 ug/l	1.04E+04 lbs/day
1,1,1-Trichloroethane	2E+02 ug/l	2E+02 lbs/day		
1,1,2-Trichloroethane	6E-01 ug/l	6E-01 lbs/day	2E+01 ug/l	1.66E+01 lbs/day
Trichloroethylene	3E+00 ug/l	3E+00 lbs/day	3E+01 ug/l	3.11E+01 lbs/day
Vinyl Chloride	3E-02 ug/l	3E-02 lbs/day	2E+00 ug/l	2.49E+00 lbs/day
Xylenes	1E+04 ug/l	1E+04 lbs/day		
2-Chlorophenol	8E+01 ug/l	8E+01 lbs/day	2E+02 ug/l	1.54E+02 lbs/day
2,4-Dichlorophenol	8E+01 ug/l	8E+01 lbs/day	3E+02 ug/l	3.00E+02 lbs/day
2,4-Dimethylphenol	4E+02 ug/l	4E+02 lbs/day	9E+02 ug/l	8.76E+02 lbs/day
2-Methyl-4,6-Dinitrophenol	1E+01 ug/l	1E+01 lbs/day	3E+02 ug/l	2.91E+02 lbs/day
2,4-Dinitrophenol	7E+01 ug/l	7E+01 lbs/day	5E+03 ug/l	5.50E+03 lbs/day
2-Nitrophenol				
4-Nitrophenol				
3-Methyl-4-Chlorophenol				
Penetachlorophenol	3E-01 ug/l	3E-01 lbs/day	3E+00 ug/l	3.11E+00 lbs/day
Phenol	2E+04 ug/l	2E+04 lbs/day	2E+06 ug/l	1.77E+06 lbs/day
2,4,6-Trichlorophenol	1E+00 ug/l	1E+00 lbs/day	2E+00 ug/l	2.47E+00 lbs/day
Acenaphthene	7E+02 ug/l	7E+02 lbs/day	1E+03 ug/l	1.02E+03 lbs/day
Acenaphthylene				
Anthracene	8E+03 ug/l	8E+03 lbs/day	4E+04 ug/l	4.14E+04 lbs/day
Benzidine	9E-05 ug/l	9E-05 lbs/day	2E-04 ug/l	2.06E-04 lbs/day
BenzoaAnthracene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
BenzoaPyrene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
BenzobFluoranthene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
BenzoghiPerylene	0E+00 ug/l	0E+00 lbs/day	0E+00 ug/l	0.00E+00 lbs/day
BenzokFluoranthene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
Bis2-ChloroethoxyMethane	0E+00 ug/l	0E+00 lbs/day	0E+00 ug/l	0.00E+00 lbs/day
Bis2-ChloroethylEther	3E-02 ug/l	3E-02 lbs/day	5E-01 ug/l	5.50E-01 lbs/day
Bis2-Chloroisopropy1Ether	1E+03 ug/l	1E+03 lbs/day	7E+04 ug/l	6.75E+04 lbs/day
Bis2-EthylhexylPhthalate	1E+00 ug/l	1E+00 lbs/day	2E+00 ug/l	2.26E+00 lbs/day
4-Bromophenyl Phenyl Ether	0E+00			
Butylbenzyl Phthalate	2E+03 ug/l	2E+03 lbs/day	2E+03 ug/l	1.94E+03 lbs/day
2-Chloronaphthalene	1E+03 ug/l	1E+03 lbs/day	2E+03 ug/l	1.64E+03 lbs/day
4-Chlorophenyl Phenyl Ether				
Chrysene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
Dibenzoa, (h)Anthracene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
1,2-Dichlorobenzene	4E+02 ug/l	4E+02 lbs/day	1E+03 ug/l	1.34E+03 lbs/day
1,3-Dichlorobenzene	3E+02 ug/l	3E+02 lbs/day	1E+03 ug/l	9.91E+02 lbs/day
1,4-Dichlorobenzene	6E+01 ug/l	6E+01 lbs/day	2E+02 ug/l	1.96E+02 lbs/day
3,3-Dichlorobenzidine	2E-02 ug/l	2E-02 lbs/day	3E-02 ug/l	2.87E-02 lbs/day
Diethyl Phthalate	2E+03 ug/l	2E+03 lbs/day	4E+04 ug/l	4.57E+04 lbs/day
Dimethyl Phthalate	3E+05 ug/l	3E+05 lbs/day	1E+06 ug/l	1.14E+06 lbs/day
Di-n-Butyl Phthalate	2E+03 ug/l	2E+03 lbs/day	5E+03 ug/l	4.64E+03 lbs/day
2,4-Dinitrotoluene	1E-01 ug/l	1E-01 lbs/day	3E+00 ug/l	3.53E+00 lbs/day
2,6-Dinitrotoluene				
Di-n-Octyl Phthalate				
1,2-Diphenylhydrazine	4E-02 ug/l	4E-02 lbs/day	2E-01 ug/l	2.07E-01 lbs/day
Fluoranthene	1E+02 ug/l	1E+02 lbs/day		
Fluorene	1E+03 ug/l	1E+03 lbs/day	5E+03 ug/l	5.48E+03 lbs/day
Hexachlorobenzene	3E-04 ug/l	3E-04 lbs/day	3E-04 ug/l	2.96E-04 lbs/day
Hexachlorobutedine	4E-01 ug/l	4E-01 lbs/day	2E+01 ug/l	1.87E+01 lbs/day

Hexachloroethane	1E+00 ug/l	1E+00 lbs/day	3E+00 ug/l	3.40E+00 lbs/day
Hexachlorocyclopentadiene	4E+01 ug/l	4E+01 lbs/day	1E+03 ug/l	1.14E+03 lbs/day
Ideno 1,2,3-cdPyrene	4E-03 ug/l	4E-03 lbs/day	2E-02 ug/l	1.86E-02 lbs/day
Isophorone	4E+01 ug/l	4E+01 lbs/day	1E+03 ug/l	9.97E+02 lbs/day
Naphthalene			ug/l	
Nitrobenzene	2E+01 ug/l	2E+01 lbs/day	7E+02 ug/l	7.16E+02 lbs/day
N-Nitrosodimethylamine	7E-04 ug/l	7E-04 lbs/day	3E+00 ug/l	3.12E+00 lbs/day
N-Nitrosodi-n-Propylamine	5E-03 ug/l	5E-03 lbs/day	5E-01 ug/l	5.30E-01 lbs/day
N-Nitrosodiphenylamine	3E+00 ug/l	3E+00 lbs/day	6E+00 ug/l	6.17E+00 lbs/day
Phenanthrene				
Pyrene	8E+02 ug/l	8E+02 lbs/day	4E+03 ug/l	4.14E+03 lbs/day
1,2,4-Trichlorobenzene	4E+01 ug/l	4E+01 lbs/day	7E+01 ug/l	7.20E+01 lbs/day
Aldrin	5E-05 ug/l	5E-05 lbs/day	5E-05 ug/l	5.10E-05 lbs/day
alpha-BHC	3E-03 ug/l	3E-03 lbs/day	5E-03 ug/l	5.04E-03 lbs/day
beta-BHC	9E-03 ug/l	9E-03 lbs/day	2E-02 ug/l	1.75E-02 lbs/day
gamma-BHC (Lindane)	2E-01 ug/l	2E-01 lbs/day	2E+00 ug/l	1.87E+00 lbs/day
delta-BHC	0E+00 ug/l	0E+00 lbs/day	0E+00 ug/l	0.00E+00 lbs/day
Chlordane	8E-04 ug/l	8E-04 lbs/day	8E-04 ug/l	8.26E-04 lbs/day
4,4-DDT	2E-04 ug/l	2E-04 lbs/day	2E-04 ug/l	2.24E-04 lbs/day
4,4-DDE	2E-04 ug/l	2E-04 lbs/day	2E-04 ug/l	2.24E-04 lbs/day
4,4-DDD	3E-04 ug/l	3E-04 lbs/day	3E-04 ug/l	3.16E-04 lbs/day
Dieldrin	5E-05 ug/l	5E-05 lbs/day	5E-05 ug/l	5.51E-05 lbs/day
alpha-Endosulfan	6E+01 ug/l	6E+01 lbs/day	9E+01 ug/l	9.12E+01 lbs/day
beta-Endosulfan	6E+01 ug/l	6E+01 lbs/day	9E+01 ug/l	9.12E+01 lbs/day
Endosulfan Sulfate	6E+01 ug/l	6E+01 lbs/day	9E+01 ug/l	9.12E+01 lbs/day
Endrin	6E-02 ug/l	6E-02 lbs/day	6E-02 ug/l	6.12E-02 lbs/day
Endrin Aldehyde	3E-02 ug/l	3E-02 lbs/day	3E-01 ug/l	3.11E-01 lbs/day
Heptachlor	8E-05 ug/l	8E-05 lbs/day	8E-05 ug/l	8.05E-05 lbs/day
Heptachlor Epoxide	4E-05 ug/l	4E-05 lbs/day	4E-05 ug/l	3.98E-05 lbs/day
Polychlorinated Biphenyls	6E-05 ug/l	7E-05 lbs/day	6E-05 ug/l	6.52E-05 lbs/day
PCB's				
Toxaphene	3E-04 ug/l	3E-04 lbs/day	3E-04 ug/l	0.00E+00 lbs/day

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon QUAL2kw EPA and the University of Washington.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. QUAL2kw default values or as adjusted by user, as noted.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

Flow, Q, (cfs or MGD)	D.O. mg/l
Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH ₃ -N, mg/l
BOD ₅ , mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Headwater/Upstream Information

	Stream		Temp.	pH	T-NH ₄	BOD ₅	DO	TRC	TDS
	Low Flow	Critical							
	cfs	Deg. C		mg/l as N	mg/l	mg/l	mg/l	mg/l	mg/l
Summer	0.100	15.0	8.3	0.05	0.10	9.10	0.00	1875.0	
Fall	0.000	0.0	0.0	0.00	0.00	0.00	0.00	0.0	
Winter	0.120	15.0	8.2	0.31	0.10	10.70	0.00	2335.0	
Spring	0.000	0.0	0.0	0.00	0.00	0.00	0.00	0.0	
Dissolved	Al	As	Cd	CrIII	CrVI	Copper	Fe	Pb	

Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l
All Seasons	15.00	2.50	0.38	133.08	5.50	5.59	0.00	9.18
Dissolved Metals	Hg	Ni	Se	Ag	Zn	Boron		
All Seasons	0.0060	3.75	1.30	1.00	41.00	375.0		* 1/2 MDL

Projected Discharge Information [See page 5 for additional information]

Season	Flow, MGD	Temp.	TDS mg/l	TDS tons/day
Summer	2.00	25.00	3,000.00	25.01
Fall	-	-	-	-
Winter	2.00	25.00	3,600.00	30.02
Spring	-	-	-	-

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

Season	Daily Average
Summer	2.00 MGD 3.094 cfs
Fall	- MGD 0.000 cfs
Winter	2.00 MGD 3.094 cfs
Spring	- MGD 0.000 cfs

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 2 MGD. If the discharger is allowed to have a flow greater than 2 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	EOP Effluent	[Acute]
System is Totally Mixed	IC25 >	96.3% Effluent	[Chronic]

Effluent Limitation for Biological Oxygen Demand (BOD₅) based upon Water Quality Standards or Regulations

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent BOD₅ limitation as follows:

Season	Concentration	
Summer	25.00 mg/l as CBOD ₅	416.92 lbs/day
Fall	- mg/l as CBOD ₅	- lbs/day
Winter	25.00 mg/l as CBOD ₅	416.92 lbs/day
Spring	- mg/l as CBOD ₅	- lbs/day

Effluent Limitation for Dissolved Oxygen (DO) based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent D.O. limitation as follows:

Season	Concentration	Load
Summer	4.00 mg/l	66.71 lbs/day
Fall	- mg/l	- lbs/day
Winter	4.00 mg/l	66.71 lbs/day
Spring	- mg/l	- lbs/day

Effluent Limitation for Total Ammonia based upon Water Quality Standards

In-stream criteria of downstream segments for Total Ammonia will be met with an effluent limitation (expressed as Total Ammonia as N) as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	3.00 mg/l as N	50.03 lbs/day
	1 Hour Avg. - Acute	11.78 mg/l as N	196.52 lbs/day
Fall	4 Day Avg. - Chronic	- mg/l as N	- lbs/day
	1 Hour Avg. - Acute	- mg/l as N	- lbs/day
Winter	4 Day Avg. - Chronic	4.00 mg/l as N	66.71 lbs/day
	1 Hour Avg. - Acute	15.71 mg/l as N	262.03 lbs/day
Spring	4 Day Avg. - Chronic	- mg/l as N	- lbs/day
	1 Hour Avg. - Acute	- mg/l as N	- lbs/day

Effluent Limitation for Total Residual Chlorine based upon Water Quality Standards

In-stream criteria of downstream segments for Total Residual Chlorine will be met with an effluent limitation as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	0.25 mg/l	4.17 lbs/day
	1 Hour Avg. - Acute	0.43 mg/l	7.20 lbs/day
Fall	4 Day Avg. - Chronic	- mg/l	- lbs/day
	1 Hour Avg. - Acute	- mg/l	- lbs/day
Winter	4 Day Avg. - Chronic	0.15 mg/l	2.50 lbs/day
	1 Hour Avg. - Acute	0.26 mg/l	4.32 lbs/day
Spring	4 Day Avg. - Chronic	- mg/l	- lbs/day
	1 Hour Avg. - Acute	- mg/l	- lbs/day

Effluent Limitations for Total Dissolved Solids based upon Water Quality Standards

Season	Concentration	Load
--------	---------------	------

Summer	Maximum, Acute	3,000.0 mg/l	50,030 tons/day
Fall	Maximum, Acute	- mg/l	- tons/day
Winter	Maximum, Acute	3,600.0 mg/l	60,036 tons/day
Spring	Maximum, Acute	- mg/l	- tons/day

Colorado Salinity Form Limits Determined by Permitting Section

Effluent Limitations for Heat/Temperature based upon Water Quality Standards

Summer	Maximum	25.00 Deg. C.	77.0 Deg. F
Fall	Maximum	- Deg. C.	- Deg. F
Winter	Maximum	25.00 Deg. C.	77.0 Deg. F
Spring	Maximum	- Deg. C.	- Deg. F

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	EOP Effluent	[Acute]
	IC25 >	96.3% Effluent	[Chronic]

Effluent Limitations for Organics [Pesticides] Based upon Water Quality Standards [Class 3]

In-stream criteria of downstream segments for Organics [Pesticides] will be met with an effluent limit as follows:

	4 Day Average		1 Hour Average		
	Concentration	Load	Concentration	Load	
Aldrin			1.5E+00	ug/l	9.80E-01 lbs/day
Chlordane	4.38E-03 ug/l	2.84E-03 lbs/day	1.2E+00	ug/l	7.91E-01 lbs/day
DDT, DDE	1.02E-03 ug/l	6.59E-04 lbs/day	5.6E-01	ug/l	3.63E-01 lbs/day
Dieldrin	1.94E-03 ug/l	1.25E-03 lbs/day	1.3E+00	ug/l	8.24E-01 lbs/day
Endosulfan	5.71E-02 ug/l	3.69E-02 lbs/day	1.1E-01	ug/l	7.22E-02 lbs/day
Endrin	2.34E-03 ug/l	1.52E-03 lbs/day	9.2E-02	ug/l	5.93E-02 lbs/day
Guthion	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	6.53E-03 lbs/day
Heptachlor	3.87E-03 ug/l	2.51E-03 lbs/day	2.7E-01	ug/l	1.71E-01 lbs/day
Lindane	8.16E-02 ug/l	5.27E-02 lbs/day	1.0E+00	ug/l	6.59E-01 lbs/day
Methoxychlor	0.00E+00 ug/l	0.00E+00 lbs/day	3.0E-02	ug/l	1.96E-02 lbs/day
Mirex	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	6.53E-03 lbs/day
Parathion	0.00E+00 ug/l	0.00E+00 lbs/day	4.0E-02	ug/l	2.61E-02 lbs/day
PCB's	1.43E-02 ug/l	9.23E-03 lbs/day	2.0E+00	ug/l	1.32E+00 lbs/day
Pentachlorophenol	1.33E+01 ug/l	8.57E+00 lbs/day	2.0E+01	ug/l	1.31E+01 lbs/day
Toxephene	2.04E-04 ug/l	1.32E-04 lbs/day	7.4E-01	ug/l	4.81E-01 lbs/day

Effluent Limitations for E. coli Based upon Water Quality Standards [Class 2]

E. coli 126.0 organisms per 100 ml

Effluent Targets for Pollution Indicators Based upon Water Quality Standards

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

	1 Hour Average	
	Concentration	Loading
Gross Beta (pCi/l)	51.0 pCi/L	0.00
BOD (mg/l)	5.1 mg/l	85.0 lbs/day
Nitrate as N (mg/l)	4.1 mg/l	68.0 lbs/day
Total Phosphorus as P	0.1 mg/l	0.1 lbs/day

Note: Pollution indicator targets are for information purposes only.

Effluent Limitations for Protection of Human Health [Toxics Rule]

Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

Toxic Organics	Effluent Limitation (30 Day Avg.) Class 1C	Maximum Concentration	
		Concentration	Load
		Effluent Limit (30 Day Avg.) Class 3	
Antimony	5.709E+00	6.647E+02	
Arsenic			
Beryllium			
Cadmium			
Chromium III			
Chromium VI			
Copper	1.350E+03		
Lead			
Mercury			
Nickel	1.037E+02	4.78E+03	
Selenium		4.36E+03	
Silver		0.00E+00	
Thallium	2.447E-01	4.84E-01	
Zinc	7.685E+03	2.70E+04	
Cyanide	1.453E+02	1.45E+02	
Asbestos	7.000E+06		
2,3,7,8-TCDD Dioxin		5.20E-09	
Acrolein	1.937E+02	2.98E+02	
Acrylonitrile	5.199E-02	2.59E-01	
Alachlor	2.039E+00	0.00E+00	
Atrazine	3.058E+00	0.00E+00	
Benzene	2.243E+00	5.29E+01	
Bromoform	4.383E+00	1.45E+02	
Carbofuran	4.078E+01		
Carbon Tetrachloride	2.345E-01	1.66E+00	
Chlorobenzene	1.019E+02	1.66E+03	
Chlorodibromomethane	4.078E-01	1.35E+01	
Chloroethane			
2-Chloroethylvinyl Ether			
Chloroform	5.811E+00	4.88E+02	
Dalapon	2.039E+02		
Di(2ethylhexyl)adipate	4.078E+02		
Dibromochloropropane	2.039E-01		
Dichlorobromomethane	5.607E-01	1.76E+01	
1,1-Dichloroethane		0.00E+00	
1,2-Dichloroethane	3.874E-01	3.84E+01	
1,1-Dichloroethylene	7.136E+00	7.38E+03	
Dichloroethylene (cis-1,2	7.136E+01	0.00E+00	

Dinose	7.136E+00	0.00E+00
Diquat	2.039E+01	0.00E+00
1,2-Dichloropropane	5.097E-01	1.56E+01
1,3-Dichloropropene	3.466E-01	2.18E+01
Endothall	1.019E+02	0.00E+00
Ethylbenzene	5.403E+02	2.17E+03
Ethylene Dibromide	5.097E-02	0.00E+00
Glyphosate	7.136E+02	0.00E+00
Haloacetic acids	6.116E+01	0.00E+00
Methyl Bromide	4.791E+01	1.56E+03
Methyl Chloride	0.000E+00	
Methylene Chloride	4.689E+00	6.13E+02
Ocamyl (vidate)	2.039E+02	
Picloram	5.097E+02	
Simazine	4.078E+00	
Styrene	1.019E+02	
1,1,2,2-Tetrachloroethane	1.733E-01	4.15E+00
Tetrachloroethylene	7.034E-01	3.41E+00
Toluene	1.019E+03	1.56E+04
1,2 -Trans-Dichloroethyle	1.019E+02	1.04E+04
1,1,1-Trichloroethane	2.039E+02	0.00E+00
1,1,2-Trichloroethane	6.014E-01	1.66E+01
Trichloroethylene	2.548E+00	3.11E+01
Vinyl Chloride	2.548E-02	2.49E+00
Xylenes	1.019E+04	
2-Chlorophenol	8.257E+01	1.54E+02
2,4-Dichlorophenol	7.849E+01	3.00E+02
2,4-Dimethylphenol	3.874E+02	8.76E+02
2-Methyl-4,6-Dinitrophenol	1.325E+01	2.91E+02
2,4-Dinitrophenol	7.034E+01	5.50E+03
2-Nitrophenol		
4-Nitrophenol		
3-Methyl-4-Chlorophenol		
Penetachlorophenol	2.752E-01	3.11E+00
Phenol	2.141E+04	1.77E+06
2,4,6-Trichlorophenol	1.427E+00	2.47E+00
Acenaphthene	6.830E+02	1.02E+03
Acenaphthylene	0.000E+00	0.00E+00
Anthracene	8.461E+03	4.14E+04
Benzidine	8.767E-05	2.06E-04
BenzoaAnthracene	3.874E-03	1.86E-02
BenzoaPyrene	3.874E-03	1.86E-02
BenzobFluoranthene	3.874E-03	1.86E-02
BenzoghiPerylene		0.00E+00
BenzokFluoranthene	3.874E-03	1.86E-02
Bis2-ChloroethoxyMethane		0.00E+00
Bis2-ChloroethylEther	3.058E-02	5.50E-01
Bis2-Chloroisopropy1Ether	1.427E+03	6.75E+04
Bis2-EthylhexylPhthalate	1.223E+00	2.26E+00
4-Bromophenyl Phenyl Ether		0.00E+00
Butylbenzyl Phthalate	1.529E+03	1.94E+03
2-Chloronaphthalene	1.019E+03	1.64E+03
4-Chlorophenyl Phenyl Ether		
Chrysene	3.874E-03	1.86E-02
Dibenzoa, (h)Anthracene	3.874E-03	1.86E-02
1,2-Dichlorobenzene	4.281E+02	1.34E+03
1,3-Dichlorobenzene	3.262E+02	9.91E+02
1,4-Dichlorobenzene	6.422E+01	1.96E+02
3,3-Dichlorobenzidine	2.141E-02	2.87E-02
Diethyl Phthalate	1.733E+03	4.57E+04

Dimethyl Phthalate	2.752E+05	1.14E+06
Di-n-Butyl Phthalate	2.039E+03	4.64E+03
2,4-Dinitrotoluene	1.121E-01	3.53E+00
2,6-Dinitrotoluene		0.00E+00
Di-n-Octyl Phthalate		0.00E+00
1,2-Diphenylhydrazine	3.670E-02	2.07E-01
Fluoranthene	1.325E+02	
Fluorene	1.121E+03	5.48E+03
Hexachlorobenzene	2.854E-04	2.96E-04
Hexachlorobutadiene	4.485E-01	1.87E+01
Hexachloroethane	1.427E+00	3.40E+00
Hexachlorocyclopentadiene	4.078E+01	1.14E+03
Ideno 1,2,3-cdPyrene	3.874E-03	1.86E-02
Isophorone	3.568E+01	9.97E+02
Naphthalene		
Nitrobenzene	1.733E+01	7.16E+02
N-Nitrosodimethylamine	7.034E-04	3.12E+00
N-Nitrosodi-n-Propylamine	5.097E-03	5.30E-01
N-Nitrosodiphenylamine	3.364E+00	6.17E+00
Phenanthrene		
Pyrene	8.461E+02	4.14E+03
1,2,4-Trichlorobenzene	3.568E+01	7.20E+01
Aldrin	4.995E-05	5.10E-05
alpha-BHC	2.650E-03	5.04E-03
beta-BHC	9.276E-03	1.75E-02
gamma-BHC (Lindane)	2.039E-01	1.87E+00
delta-BHC		0.00E+00
Chlordane	8.155E-04	8.26E-04
4,4-DDT	2.243E-04	2.24E-04
4,4-DDE	2.243E-04	2.24E-04
4,4-DDD	3.160E-04	3.16E-04
Dieldrin	5.301E-05	5.51E-05
alpha-Endosulfan	6.320E+01	9.12E+01
beta-Endosulfan	6.320E+01	9.12E+01
Endosulfan Sulfate	6.320E+01	9.12E+01
Endrin	6.014E-02	6.12E-02
Endrin Aldehyde	2.956E-02	3.11E-01
Heptachlor	8.053E-05	8.05E-05
Heptachlor Epoxide	3.976E-05	3.98E-05
PCBs	6.524E-05	6.52E-05
Toxaphene	2.854E-04	

**Metals Effluent Limitations for Protection of All Beneficial Uses
Based upon Water Quality Standards and Toxics Rule**

	Class 3 Chronic Aquatic Wildlife ug/l	Class 3: Acute Aquatic Wildlife ug/l	Class 1C: Drinking Water Supply	Class 1C: Acute Toxics Drinking Water Source ug/l	Class 3: Acute Toxics Drinking & Consumption Criteria ug/l	Class 4: Acute Agricultural ug/l	Acute Most Stringent ug/l
Aluminum	N/A	764.3					764.3
Antimony				5.7			5.7
Arsenic	197.3	346.5	51.8			103.8	51.8
Asbestos				7.00E+06			7000000.0
Barium			1019.4				1019.4
Beryllium							0.0
Cadmium	0.8	8.8	10.4			10.4	0.8
Chromium (III)	271.3	5674.1	46.8				46.8
Chromium (VI)	11.21	16.2				98.7	11.2
Copper	31.2	52.1		1350.2		207.5	31.2
Cyanide	5.3	22.4		145.3			5.3
Iron		1019.4					1019.4
Lead	18.7	480.1	51.6			103.5	18.7
Mercury	0.012	2.45	2.08				0.0
Nickel	173.5	1533.0		103.7			103.7
Selenium	4.7	20.4	10.3		4362.6	51.9	4.7
Silver		41.2	51.9				41.2
Thallium							0.0
Zinc	398.1	391.4			27006.8		391.4
Boron						764.5	764.5

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

	WLA Acute ug/l	WLA Chronic ug/l	
Aluminum	764.3	N/A	
Antimony	5.71		
Arsenic	51.8	197.3	Acute Controls
Asbestos	7.00E+06		
Barium	1019.4		
Beryllium			
Cadmium	0.8	0.8	
Chromium (III)	46.8	271	Acute Controls
Chromium (VI)	11.2	11.2	
Copper	31.2	31.2	
Cyanide	5.3	5.3	
Iron	1019.4		
Lead	18.7	18.7	
Mercury	0.012	0.012	
Nickel	103.7	174	Acute Controls
Selenium	4.7	4.7	
Silver	41.2	N/A	
Thallium	0.0		
Zinc	391.4	398.1	Acute Controls
Boron	764.54		

Other Effluent Limitations are based upon R317-1.

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an **Antidegradation Level II Review is NOT Required.**

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

XIV. Special Considerations

EA Miller discharges to a tributary of Spring Creek which is listed on the Utah 303(d) listed for total phosphorous (TP), ammonia and dissolved oxygen (DO). A TMDL was completed for Spring Creek on September 9th, 2002. The TMDL set the load allocation for EA Miller at 170 kg/yr TP based on the anticipated capacity of the plant (2 mgd) and an average total phosphorus concentration of 0.10 mg/l (30 day average).

File Name: EA Miller & Hyrum WWTP.xls

Level I Antidegradation Review for: EA Miller

A level I Antidegradation Review has been completed. Level II antidegradation review not required. The proposed action is a simple permit renewal, with no increase in concentration or loading over the previously issued permit.

APPENDIX - Coefficients and Other Model Information

Parameter	Value	Units
Stoichiometry:		
Carbon	40	gC
Nitrogen	7.2	gN
Phosphorus	1	gP
Dry weight	100	gD
Chlorophyll	1	gA
Inorganic suspended solids:		
Settling velocity	0.06128	m/d
Oxygen:		
Reaeration model	Internal	
Temp correction	1.024	
Reaeration wind effect	None	
O2 for carbon oxidation	2.69	gO2/gC
O2 for NH4 nitrification	4.57	gO2/gN
Oxygen inhib model CBOD oxidation	Exponential	
Oxygen inhib parameter CBOD oxidation	0.60	L/mgO2
Oxygen inhib model nitrification	Exponential	
Oxygen inhib parameter nitrification	0.60	L/mgO2
Oxygen enhance model denitrification	Exponential	
Oxygen enhance parameter denitrification	0.60	L/mgO2
Oxygen inhib model phyto resp	Exponential	
Oxygen inhib parameter phyto resp	0.60	L/mgO2
Oxygen enhance model bot alg resp	Exponential	
Oxygen enhance parameter bot alg resp	0.60	L/mgO2
Slow CBOD:		
Hydrolysis rate	1.93545	/d
Temp correction	1.047	
Oxidation rate	1.18385	/d
Temp correction	1.047	
Fast CBOD:		
Oxidation rate	0.5447	/d
Temp correction	1.047	
Organic N:		
Hydrolysis	0.8365	/d
Temp correction	1.07	
Settling velocity	0.24964	m/d
Ammonium:		
Nitrification	2.1554	/d
Temp correction	1.07	
Nitrate:		
Denitrification	1.02986	/d
Temp correction	1.07	
Sed denitrification transfer coeff	0.05126	m/d
Temp correction	1.07	
Organic P:		
Hydrolysis	3.4361	/d
Temp correction	1.07	
Settling velocity	0.62926	m/d
Inorganic P:		
Settling velocity	0.01384	m/d
Sed P oxygen attenuation half sat constant	1.69154	mgO2/L

Phytoplankton:

Max Growth rate	2.5	/d
Temp correction	1.07	
Respiration rate	0.1	/d
Temp correction	1.07	
Death rate	0	/d
Temp correction	1	
Nitrogen half sat constant	15	ugN/L
Phosphorus half sat constant	2	ugP/L
Inorganic carbon half sat constant	1.30E-05	moles/L
Phytoplankton use HCO3- as substrate	Yes	
Light model	Half saturation	
Light constant	57.6	langleys/d
Ammonia preference	25	ugN/L
Settling velocity	0.15	m/d

Bottom Plants:

Growth model	Zero-order	
Max Growth rate	49.3845	gD/m2/d or /d
Temp correction	1.07	
First-order model carrying capacity	100	gD/m2
Basal respiration rate	0.48434	/d
Photo-respiration rate parameter	0	unitless
Temp correction	1.07	
Excretion rate	0.46367	/d
Temp correction	1.07	
Death rate	0.40579	/d
Temp correction	1.07	
External nitrogen half sat constant	163.368	ugN/L
External phosphorus half sat constant	47.556	ugP/L
Inorganic carbon half sat constant	1.05E-05	moles/L
Bottom algae use HCO3- as substrate	Yes	
Light model	Half saturation	
Light constant	2.09098	langleys/d
Ammonia preference	1.48807	ugN/L
Subsistence quota for nitrogen	29.957365	mgN/gD
Subsistence quota for phosphorus	0.3928168	mgP/gD
Maximum uptake rate for nitrogen	446.5885	mgN/gD/d
Maximum uptake rate for phosphorus	114.4235	mgP/gD/d
Internal nitrogen half sat ratio	2.856177	
Internal phosphorus half sat ratio	1.752547	
Nitrogen uptake water column fraction	1	
Phosphorus uptake water column fraction	1	

Detritus (POM):

Dissolution rate	2.7754	/d
Temp correction	1.07	
Settling velocity	3.89475	m/d

Pathogens:

Decay rate	0.8	/d
Temp correction	1.07	
Settling velocity	1	m/d
alpha constant for light mortality	1	/d per ly/hr

pH:

Partial pressure of carbon dioxide	347	ppm
------------------------------------	-----	-----

Hyporheic metabolism

Model for biofilm oxidation of fast CBOD	Zero-order	
Max biofilm growth rate	5	gO2/m^2/d or /d
Temp correction	1.047	
Fast CBOD half-saturation	0.5	mgO2/L
Oxygen inhib model	Exponential	
Oxygen inhib parameter	0.60	L/mgO2

Respiration rate	0.2	/d
Temp correction	1.07	
Death rate	0.05	/d
Temp correction	1.07	
External nitrogen half sat constant	15	ugN/L
External phosphorus half sat constant	2	ugP/L
Ammonia preference	25	ugN/L
First-order model carrying capacity	100.0	gD/m2
<i>Generic constituent</i>		
Decay rate	30.0	/d
Temp correction	1.1	
Settling velocity	1.0	m/d

Atmospheric Inputs:

	Winter	Summer	Fall	Winter	Spring
Air Temperature, F	30.0	65.0	45.0	30.0	45.0
Dew Point, Temp., F	32.0	44.0	35.0	32.0	35.0
Wind, ft./sec. @ 21 ft.	2.0	2.0	2.0	2.0	2.0
Cloud Cover, %	10.0%	10.0%	10.0%	10.0%	10.0%
Shade, %	5.0%	5.0%	5.0%	5.0%	5.0%

Other Inputs:

Manning Coefficient	0.04	Default
Side Slope	10.0%	
Bottom Algae Coverage	50.0%	
Bottom SOD Coverage	50.0%	
Prescribed SOD	0.0	gO2/m2/d
Hyporheic Zone Thickness	10.0	cm
Hyporheic Exchange Flow	5.0%	
Hyporheic Sediment Porosity	10.0%	