

Utah Division of Water Quality
Salt Lake City, Utah

WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis
SUMMARY

Discharging Facility: Wellsville
UPDES No: UT-0020371
Current Flow: 0.28 MGD
Design Flow: 0.68 MGD

Receiving Water: Little Bear River
Stream Classification: 2B, 3A, 3D, 4
Stream Flows [cfs]:
2.0 Summer (July-Sept) 20th Percentile
4.8 Fall (Oct-Dec) 20th Percentile
20.0 Winter (Jan-Mar) 20th Percentile
30.8 Spring (Apr-June) 20th Percentile
89.4 Average
Stream TDS Values:
410.0 Summer (July-Sept) 80th Percentile
410.0 Fall (Oct-Dec) 80th Percentile
410.0 Winter (Jan-Mar) 80th Percentile
410.0 Spring (Apr-June) 80th Percentile

Effluent Limits:		WQ Standard:	
Flow, MGD:	0.68 MGD	Design Flow	
BOD, mg/l:	25.0 Summer	5.0 Indicator	
Dissolved Oxygen, mg/l	5.0 Summer	6.5 30 Day Average	
TNH3, Chronic, mg/l:	6.7 Summer	Varies Function of pH and Temperature	
TDS, mg/l:	2695.4 Summer	1200.0	

Modeling Parameters:
Acute River Width: 50.0%
Chronic River Width: 100.0%

**Level I antidegradation review completed. Level II review NOT required. Basic renewal
No increase in permitted load or concentration**

Date: 11/16/2012

Permit Writer:

WLA by:

WQM Sec. Approval:

TMDL Sec. Approval:

[Signature]

11-16-12

Utah Division of Water Quality
Salt Lake City, Utah

**WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis**

16-Nov-12
4:00 PM

Facilities: Wellsville
Discharging to: Little Bear River

UPDES No: UT-0020371

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Little Bear River: 2B, 3A, 3D, 4
Antidegradation Review: Level II Antidegradation Review not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

Total Ammonia (TNH3)	Varies as a function of Temperature and pH Rebound. See Water Quality Standards
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average)
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average) 5.00 mg/l (7Day Average) 4.00 mg/l (1 Day Average)
Maximum Total Dissolved Solids	1200.0 mg/l

Acute and Chronic Heavy Metals (Dissolved)

**Utah Division of Water Quality
Salt Lake City, Utah**

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aluminum	87.00 ug/l**	0.495 lbs/day	750.00	ug/l	4.271 lbs/day
Arsenic	190.00 ug/l	1.082 lbs/day	340.00	ug/l	1.936 lbs/day
Cadmium	0.61 ug/l	0.003 lbs/day	6.52	ug/l	0.037 lbs/day
Chromium III	211.92 ug/l	1.207 lbs/day	4433.71	ug/l	25.250 lbs/day
ChromiumVI	11.00 ug/l	0.063 lbs/day	16.00	ug/l	0.091 lbs/day
Copper	23.85 ug/l	0.136 lbs/day	39.41	ug/l	0.224 lbs/day
Iron			1000.00	ug/l	5.695 lbs/day
Lead	12.88 ug/l	0.073 lbs/day	330.60	ug/l	1.883 lbs/day
Mercury	0.0120 ug/l	0.000 lbs/day	2.40	ug/l	0.014 lbs/day
Nickel	132.13 ug/l	0.752 lbs/day	1188.44	ug/l	6.768 lbs/day
Selenium	4.60 ug/l	0.026 lbs/day	20.00	ug/l	0.114 lbs/day
Silver	N/A ug/l	N/A lbs/day	25.04	ug/l	0.143 lbs/day
Zinc	303.93 ug/l	1.731 lbs/day	303.93	ug/l	1.731 lbs/day

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO

Metals Standards Based upon a Hardness of 300 mg/l as CaCO₃

Organics [Pesticides]

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aldrin			1.500	ug/l	0.009 lbs/day
Chlordane	0.004 ug/l	0.071 lbs/day	1.200	ug/l	0.007 lbs/day
DDT, DDE	0.001 ug/l	0.016 lbs/day	0.550	ug/l	0.003 lbs/day
Dieldrin	0.002 ug/l	0.031 lbs/day	1.250	ug/l	0.007 lbs/day
Endosulfan	0.056 ug/l	0.923 lbs/day	0.110	ug/l	0.001 lbs/day
Endrin	0.002 ug/l	0.038 lbs/day	0.090	ug/l	0.001 lbs/day
Guthion			0.010	ug/l	0.000 lbs/day
Heptachlor	0.004 ug/l	0.063 lbs/day	0.260	ug/l	0.001 lbs/day
Lindane	0.080 ug/l	1.318 lbs/day	1.000	ug/l	0.006 lbs/day
Methoxychlor			0.030	ug/l	0.000 lbs/day
Mirex			0.010	ug/l	0.000 lbs/day
Parathion			0.040	ug/l	0.000 lbs/day
PCB's	0.014 ug/l	0.231 lbs/day	2.000	ug/l	0.011 lbs/day
Pentachlorophenol	13.00 ug/l	214.176 lbs/day	20.000	ug/l	0.114 lbs/day
Toxephene	0.0002 ug/l	0.003 lbs/day	0.7300	ug/l	0.004 lbs/day

IV. Numeric Stream Standards for Protection of Agriculture

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			100.0 ug/l	lbs/day
Boron			750.0 ug/l	lbs/day
Cadmium			10.0 ug/l	0.03 lbs/day
Chromium			100.0 ug/l	lbs/day
Copper			200.0 ug/l	lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Lead	100.0 ug/l	lbs/day
Selenium	50.0 ug/l	lbs/day
TDS, Summer	1200.0 mg/l	3.42 tons/day

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

Metals	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			ug/l	lbs/day
Barium			ug/l	lbs/day
Cadmium			ug/l	lbs/day
Chromium			ug/l	lbs/day
Lead			ug/l	lbs/day
Mercury			ug/l	lbs/day
Selenium			ug/l	lbs/day
Silver			ug/l	lbs/day
Fluoride (3)			ug/l	lbs/day
to			ug/l	lbs/day
Nitrates as N			ug/l	lbs/day
Chlorophenoxy Herbicides				
2,4-D			ug/l	lbs/day
2,4,5-TP			ug/l	lbs/day
Endrin			ug/l	lbs/day
ocyclohexane (Lindane)			ug/l	lbs/day
Methoxychlor			ug/l	lbs/day
Toxaphene			ug/l	lbs/day

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

Toxic Organics	Maximum Conc., ug/l - Acute Standards			
	Class 1C		Class 3A, 3B	
	[2 Liters/Day for 70 Kg Person over 70 Yr.]		[6.5 g for 70 Kg Person over 70 Yr.]	
Acenaphthene	ug/l	lbs/day	2700.0 ug/l	44.48 lbs/day
Acrolein	ug/l	lbs/day	780.0 ug/l	12.85 lbs/day
Acrylonitrile	ug/l	lbs/day	0.7 ug/l	0.01 lbs/day
Benzene	ug/l	lbs/day	71.0 ug/l	1.17 lbs/day
Benzidine	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Carbon tetrachloride	ug/l	lbs/day	4.4 ug/l	0.07 lbs/day
Chlorobenzene	ug/l	lbs/day	21000.0 ug/l	345.98 lbs/day
1,2,4-Trichlorobenzene				
Hexachlorobenzene	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Dichloroethane	ug/l	lbs/day	99.0 ug/l	1.63 lbs/day
1,1,1-Trichloroethane				
Hexachloroethane	ug/l	lbs/day	8.9 ug/l	0.15 lbs/day
1,1-Dichloroethane				
1,1,2-Trichloroethane	ug/l	lbs/day	42.0 ug/l	0.69 lbs/day
1,1,2,2-Tetrachloroethane	ug/l	lbs/day	11.0 ug/l	0.18 lbs/day
Chloroethane			0.0 ug/l	0.00 lbs/day
Bis(2-chloroethyl) ether	ug/l	lbs/day	1.4 ug/l	0.02 lbs/day
2-Chloroethyl vinyl ether	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

2-Chloronaphthalene	ug/l	lbs/day	4300.0 ug/l	70.84 lbs/day
2,4,6-Trichlorophenol	ug/l	lbs/day	6.5 ug/l	0.11 lbs/day
p-Chloro-m-cresol			0.0 ug/l	0.00 lbs/day
Chloroform (HM)	ug/l	lbs/day	470.0 ug/l	7.74 lbs/day
2-Chlorophenol	ug/l	lbs/day	400.0 ug/l	6.59 lbs/day
1,2-Dichlorobenzene	ug/l	lbs/day	17000.0 ug/l	280.08 lbs/day
1,3-Dichlorobenzene	ug/l	lbs/day	2600.0 ug/l	42.84 lbs/day
1,4-Dichlorobenzene	ug/l	lbs/day	2600.0 ug/l	42.84 lbs/day
3,3'-Dichlorobenzidine	ug/l	lbs/day	0.1 ug/l	0.00 lbs/day
1,1-Dichloroethylene	ug/l	lbs/day	3.2 ug/l	0.05 lbs/day
1,2-trans-Dichloroethyle	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dichlorophenol	ug/l	lbs/day	790.0 ug/l	13.02 lbs/day
1,2-Dichloropropane	ug/l	lbs/day	39.0 ug/l	0.64 lbs/day
1,3-Dichloropropylene	ug/l	lbs/day	1700.0 ug/l	28.01 lbs/day
2,4-Dimethylphenol	ug/l	lbs/day	2300.0 ug/l	37.89 lbs/day
2,4-Dinitrotoluene	ug/l	lbs/day	9.1 ug/l	0.15 lbs/day
2,6-Dinitrotoluene	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Diphenylhydrazine	ug/l	lbs/day	0.5 ug/l	0.01 lbs/day
Ethylbenzene	ug/l	lbs/day	29000.0 ug/l	477.78 lbs/day
Fluoranthene	ug/l	lbs/day	370.0 ug/l	6.10 lbs/day
4-Chlorophenyl phenyl ether				
4-Bromophenyl phenyl ether				
Bis(2-chloroisopropyl) e	ug/l	lbs/day	170000.0 ug/l	2800.76 lbs/day
Bis(2-chloroethoxy) met	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Methylene chloride (HM)	ug/l	lbs/day	1600.0 ug/l	26.36 lbs/day
Methyl chloride (HM)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Methyl bromide (HM)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Bromoform (HM)	ug/l	lbs/day	360.0 ug/l	5.93 lbs/day
Dichlorobromomethane	ug/l	lbs/day	22.0 ug/l	0.36 lbs/day
Chlorodibromomethane	ug/l	lbs/day	34.0 ug/l	0.56 lbs/day
Hexachlorobutadiene(c)	ug/l	lbs/day	50.0 ug/l	0.82 lbs/day
Hexachlorocyclopentadi	ug/l	lbs/day	17000.0 ug/l	280.08 lbs/day
Isophorone	ug/l	lbs/day	600.0 ug/l	9.89 lbs/day
Naphthalene				
Nitrobenzene	ug/l	lbs/day	1900.0 ug/l	31.30 lbs/day
2-Nitrophenol	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
4-Nitrophenol	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dinitrophenol	ug/l	lbs/day	14000.0 ug/l	230.65 lbs/day
4,6-Dinitro-o-cresol	ug/l	lbs/day	765.0 ug/l	12.60 lbs/day
N-Nitrosodimethylamine	ug/l	lbs/day	8.1 ug/l	0.13 lbs/day
N-Nitrosodiphenylamine	ug/l	lbs/day	16.0 ug/l	0.26 lbs/day
N-Nitrosodi-n-propylami	ug/l	lbs/day	1.4 ug/l	0.02 lbs/day
Pentachlorophenol	ug/l	lbs/day	8.2 ug/l	0.14 lbs/day
Phenol	ug/l	lbs/day	4.6E+06 ug/l	7.58E+04 lbs/day
Bis(2-ethylhexyl)phthala	ug/l	lbs/day	5.9 ug/l	0.10 lbs/day
Butyl benzyl phthalate	ug/l	lbs/day	5200.0 ug/l	85.67 lbs/day
Di-n-butyl phthalate	ug/l	lbs/day	12000.0 ug/l	197.70 lbs/day
Di-n-octyl phthlate				
Diethyl phthalate	ug/l	lbs/day	120000.0 ug/l	1977.01 lbs/day
Dimethyl phthlate	ug/l	lbs/day	2.9E+06 ug/l	4.78E+04 lbs/day
Benzo(a)anthracene (P)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Benzo(a)pyrene (PAH)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Benzo(b)fluoranthene (F)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Benzo(k)fluoranthene (F)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Chrysene (PAH)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Acenaphthylene (PAH)				
Anthracene (PAH)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Dibenzo(a,h)anthracene	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Indeno(1,2,3-cd)pyrene	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Pyrene (PAH)	ug/l	lbs/day	11000.0 ug/l	181.23 lbs/day
Tetrachloroethylene	ug/l	lbs/day	8.9 ug/l	0.15 lbs/day
Toluene	ug/l	lbs/day	200000.0 ug/l	3295.02 lbs/day
Trichloroethylene	ug/l	lbs/day	81.0 ug/l	1.33 lbs/day
Vinyl chloride	ug/l	lbs/day	525.0 ug/l	8.65 lbs/day
				lbs/day
				lbs/day
Pesticides				
Aldrin	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Dieldrin	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Chlordane	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDT	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDE	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDD	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
alpha-Endosulfan	ug/l	lbs/day	2.0 ug/l	0.03 lbs/day
beta-Endosulfan	ug/l	lbs/day	2.0 ug/l	0.03 lbs/day
Endosulfan sulfate	ug/l	lbs/day	2.0 ug/l	0.03 lbs/day
Endrin	ug/l	lbs/day	0.8 ug/l	0.01 lbs/day
Endrin aldehyde	ug/l	lbs/day	0.8 ug/l	0.01 lbs/day
Heptachlor	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Heptachlor epoxide				
PCB's				
PCB 1242 (Arochlor 1242)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1254 (Arochlor 1254)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1221 (Arochlor 1221)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1232 (Arochlor 1232)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1248 (Arochlor 1248)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1260 (Arochlor 1260)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1016 (Arochlor 1016)	ug/l	lbs/day	0.0 ug/l	0.00 lbs/day
Pesticide				
Toxaphene	ug/l		0.0 ug/l	0.00 lbs/day
Dioxin				
Dioxin (2,3,7,8-TCDD)	ug/l	lbs/day		
Metals				
Antimony	ug/l	lbs/day		
Arsenic	ug/l	lbs/day	4300.00 ug/l	70.84 lbs/day
Asbestos	ug/l	lbs/day		
Beryllium				
Cadmium				

**Utah Division of Water Quality
Salt Lake City, Utah**

Chromium (III)				
Chromium (VI)				
Copper				
Cyanide	ug/l	lbs/day	2.2E+05 ug/l	3624.52 lbs/day
Lead	ug/l	lbs/day		
Mercury			0.15 ug/l	0.00 lbs/day
Nickel			4600.00 ug/l	75.79 lbs/day
Selenium	ug/l	lbs/day		
Silver	ug/l	lbs/day		
Thallium			6.30 ug/l	0.10 lbs/day
Zinc				

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

- (1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).
- (2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.
- (3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8
- (4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

- (1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.
- (2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

**Utah Division of Water Quality
Salt Lake City, Utah**

Flow, Q, (cfs or MGD)	D.O. mg/l
Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH3-N, mg/l
BOD5, mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

	Stream							
	Critical							
	Low Flow	Temp.	pH	T-NH3	BOD5	DO	TRC	TDS
	cfs	Deg. C		mg/l as N	mg/l	mg/l	mg/l	mg/l
Summer (Irrig. Season)	2.0	20.0	8.2	0.10	0.50	6.93	0.00	410.0
Fall	4.8	12.0	8.1	0.10	0.50	---	0.00	410.0
Winter	20.0	4.0	8.0	0.10	0.50	---	0.00	410.0
Spring	30.8	12.0	8.1	0.10	0.50	---	0.00	410.0
Dissolved	Al	As	Cd	CrIII	CrVI	Copper	Fe	Pb
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l
All Seasons	1.59*	0.53*	0.053*	0.53*	2.65*	0.53*	0.83*	0.53*
Dissolved	Hg	Ni	Se	Ag	Zn	Boron		
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l		
All Seasons	0.0000	0.53*	1.06*	0.1*	0.053*	10.0		* 1/2 MDL

Projected Discharge Information

Season	Flow, MGD	Temp.	TDS mg/l	TDS tons/day
Summer	0.68300	17.0	528.00	1.50350
Fall	0.68300	15.0		
Winter	0.68300	12.0		
Spring	0.68300	15.0		

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

**Utah Division of Water Quality
Salt Lake City, Utah**

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

Season	Daily Average	
Summer	0.683 MGD	1.057 cfs
Fall	0.683 MGD	1.057 cfs
Winter	0.683 MGD	1.057 cfs
Spring	0.683 MGD	1.057 cfs

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 0.683 MGD. If the discharger is allowed to have a flow greater than 0.683 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	EOP Effluent	[Acute]
	IC25 >	34.6% Effluent	[Chronic]

Effluent Limitation for Biological Oxygen Demand (BOD) based upon Water Quality Standards or Regulations

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent BOD limitation as follows:

Season	Concentration	
Summer	25.0 mg/l as BOD5	142.4 lbs/day
Fall	25.0 mg/l as BOD5	142.4 lbs/day
Winter	25.0 mg/l as BOD5	142.4 lbs/day
Spring	25.0 mg/l as BOD5	142.4 lbs/day

Effluent Limitation for Dissolved Oxygen (DO) based upon Water Quality Standards

**Utah Division of Water Quality
Salt Lake City, Utah**

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent D.O. limitation as follows:

Season	Concentration
Summer	5.00
Fall	5.00
Winter	5.00
Spring	5.00

Effluent Limitation for Total Ammonia based upon Water Quality Standards

In-stream criteria of downstream segments for Total Ammonia will be met with an effluent limitation (expressed as Total Ammonia as N) as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	6.7 mg/l as N	38.1 lbs/day
	1 Hour Avg. - Acute	19.9 mg/l as N	113.4 lbs/day
Fall	4 Day Avg. - Chronic	62.0 mg/l as N	353.4 lbs/day
	1 Hour Avg. - Acute	96.4 mg/l as N	549.3 lbs/day
Winter	4 Day Avg. - Chronic	47.7 mg/l as N	271.8 lbs/day
	1 Hour Avg. - Acute	77.6 mg/l as N	442.0 lbs/day
Spring	4 Day Avg. - Chronic	14.1 mg/l as N	0.0 lbs/day
	1 Hour Avg. - Acute	24.4 mg/l as N	0.0 lbs/day

Acute limit calculated with an Acute Zone of Initial Dilution (ZID) to be equal to 100.0%.

Effluent Limitation for Total Residual Chlorine based upon Water Quality Standards

In-stream criteria of downstream segments for Total Residual Chlorine will be met with an effluent limitation as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	0.032 mg/l	0.18 lbs/day
	1 Hour Avg. - Acute	0.055 mg/l	0.31 lbs/day
Fall	4 Day Avg. - Chronic	0.061 mg/l	0.35 lbs/day
	1 Hour Avg. - Acute	0.105 mg/l	0.60 lbs/day
Winter	4 Day Avg. - Chronic	0.219 mg/l	1.25 lbs/day
	1 Hour Avg. - Acute	0.379 mg/l	2.16 lbs/day
Spring	4 Day Avg. - Chronic	0.332 mg/l	0.00 lbs/day
	1 Hour Avg. - Acute	0.574 mg/l	0.00 lbs/day

Effluent Limitations for Total Dissolved Solids based upon Water Quality Standards

**Utah Division of Water Quality
Salt Lake City, Utah**

Season		Concentration		Load	
Summer	Maximum, Acute	2695.4	mg/l	7.68	tons/day
Fall	Maximum, Acute	2695.4	mg/l	7.68	tons/day
Winter	Maximum, Acute	2695.4	mg/l	7.68	tons/day
Spring	4 Day Avg. - Chronic	2695.4	mg/l	7.68	tons/day
Colorado Salinity Form Limits			Determined by Permitting Section		

**Effluent Limitations for Total Recoverable Metals based upon
Water Quality Standards**

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 300 mg/l):

	4 Day Average		1 Hour Average		Load
	Concentration	Load	Concentration	Load	
Aluminum	N/A	N/A	1,457.6	ug/l	8.3 lbs/day
Arsenic	548.14 ug/l	2.0 lbs/day	661.0	ug/l	3.8 lbs/day
Cadmium	1.62 ug/l	0.0 lbs/day	12.6	ug/l	0.1 lbs/day
Chromium III	611.54 ug/l	2.3 lbs/day	8,629.2	ug/l	49.1 lbs/day
Chromium VI	24.30 ug/l	0.1 lbs/day	27.4	ug/l	0.2 lbs/day
Copper	67.50 ug/l	0.2 lbs/day	76.0	ug/l	0.4 lbs/day
Iron	N/A	N/A	1,945.2	ug/l	11.1 lbs/day
Lead	35.76 ug/l	0.1 lbs/day	642.7	ug/l	3.7 lbs/day
Mercury	0.03 ug/l	0.0 lbs/day	4.7	ug/l	0.0 lbs/day
Nickel	380.73 ug/l	1.4 lbs/day	2,312.5	ug/l	13.2 lbs/day
Selenium	10.30 ug/l	0.0 lbs/day	37.4	ug/l	0.2 lbs/day
Silver	N/A ug/l	N/A lbs/day	48.7	ug/l	0.3 lbs/day
Zinc	879.09 ug/l	3.2 lbs/day	591.5	ug/l	3.4 lbs/day
Cyanide	15.04 ug/l	0.1 lbs/day	42.8	ug/l	0.2 lbs/day

**Effluent Limitations for Heat/Temperature based upon
Water Quality Standards**

Summer	25.8 Deg. C.	78.4 Deg. F
Fall	23.1 Deg. C.	73.6 Deg. F
Winter	43.9 Deg. C.	110.9 Deg. F
Spring	72.4 Deg. C.	162.3 Deg. F

**Effluent Limitations for Organics [Pesticides]
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Organics [Pesticides] will be met with an effluent limit as follows:

**Utah Division of Water Quality
Salt Lake City, Utah**

	4 Day Average		1 Hour Average	
	Concentration	Load	Concentration	Load
Aldrin			1.5E+00	ug/l 1.32E-02 lbs/day
Chlordane	4.30E-03 ug/l	2.45E-02 lbs/day	1.2E+00	ug/l 1.06E-02 lbs/day
DDT, DDE	1.00E-03 ug/l	5.70E-03 lbs/day	5.5E-01	ug/l 4.85E-03 lbs/day
Dieldrin	1.90E-03 ug/l	1.08E-02 lbs/day	1.3E+00	ug/l 1.10E-02 lbs/day
Endosulfan	5.60E-02 ug/l	3.19E-01 lbs/day	1.1E-01	ug/l 9.69E-04 lbs/day
Endrin	2.30E-03 ug/l	1.31E-02 lbs/day	9.0E-02	ug/l 7.93E-04 lbs/day
Guthion	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l 8.81E-05 lbs/day
Heptachlor	3.80E-03 ug/l	2.16E-02 lbs/day	2.6E-01	ug/l 2.29E-03 lbs/day
Lindane	8.00E-02 ug/l	4.56E-01 lbs/day	1.0E+00	ug/l 8.81E-03 lbs/day
Methoxychlor	0.00E+00 ug/l	0.00E+00 lbs/day	3.0E-02	ug/l 2.64E-04 lbs/day
Mirex	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l 8.81E-05 lbs/day
Parathion	0.00E+00 ug/l	0.00E+00 lbs/day	4.0E-02	ug/l 3.52E-04 lbs/day
PCB's	1.40E-02 ug/l	7.97E-02 lbs/day	2.0E+00	ug/l 1.76E-02 lbs/day
Pentachlorophenol	1.30E+01 ug/l	7.40E+01 lbs/day	2.0E+01	ug/l 1.76E-01 lbs/day
Toxephene	2.00E-04 ug/l	1.14E-03 lbs/day	7.3E-01	ug/l 6.43E-03 lbs/day

**Effluent Targets for Pollution Indicators
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Pollution Indicators would be met by achieving the following effluent targets

	1 Hour Average	
	Concentration	Loading
Gross Beta (pCi/l)	50.0 pCi/L	
BOD (mg/l)	5.0 mg/l	28.5 lbs/day
Nitrates as N	4.0 mg/l	22.8 lbs/day
Total Phosphorus as P	0.05 mg/l	0.3 lbs/day
Total Suspended Solids	90.0 mg/l	512.6 lbs/day

Note: Pollution indicator targets are for information purposes only.

**Effluent Limitations for Protection of Human Health [Toxics Rule]
Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)**

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

Toxic Organics	Maximum Concentration	
	Concentration	Load
Acenaphthene	7.81E+03 ug/l	4.45E+01 lbs/day
Acrolein	2.26E+03 ug/l	1.29E+01 lbs/day
Acrylonitrile	1.91E+00 ug/l	1.09E-02 lbs/day
Benzene	2.05E+02 ug/l	1.17E+00 lbs/day
Benzidine	ug/l	lbs/day

Utah Division of Water Quality
Salt Lake City, Utah

Carbon tetrachloride	1.27E+01 ug/l	7.25E-02 lbs/day
Chlorobenzene	6.08E+04 ug/l	3.46E+02 lbs/day
1,2,4-Trichlorobenzene		
Hexachlorobenzene	2.23E-03 ug/l	1.27E-05 lbs/day
1,2-Dichloroethane	2.86E+02 ug/l	1.63E+00 lbs/day
1,1,1-Trichloroethane		
Hexachloroethane	2.57E+01 ug/l	1.47E-01 lbs/day
1,1-Dichloroethane		
1,1,2-Trichloroethane	1.22E+02 ug/l	6.92E-01 lbs/day
1,1,2,2-Tetrachloroethane	3.18E+01 ug/l	1.81E-01 lbs/day
Chloroethane		
Bis(2-chloroethyl) ether	4.05E+00 ug/l	2.31E-02 lbs/day
2-Chloroethyl vinyl ether		
2-Chloronaphthalene	1.24E+04 ug/l	7.08E+01 lbs/day
2,4,6-Trichlorophenol	1.88E+01 ug/l	1.07E-01 lbs/day
p-Chloro-m-cresol		
Chloroform (HM)	1.36E+03 ug/l	7.74E+00 lbs/day
2-Chlorophenol	1.16E+03 ug/l	6.59E+00 lbs/day
1,2-Dichlorobenzene	4.92E+04 ug/l	2.80E+02 lbs/day
1,3-Dichlorobenzene	7.52E+03 ug/l	4.28E+01 lbs/day
1,4-Dichlorobenzene	7.52E+03 ug/l	4.28E+01 lbs/day
3,3'-Dichlorobenzidine	2.23E-01 ug/l	1.27E-03 lbs/day
1,1-Dichloroethylene	9.26E+00 ug/l	5.27E-02 lbs/day
1,2-trans-Dichloroethylene1		
2,4-Dichlorophenol	2.29E+03 ug/l	1.30E+01 lbs/day
1,2-Dichloropropane	1.13E+02 ug/l	6.43E-01 lbs/day
1,3-Dichloropropylene	4.92E+03 ug/l	2.80E+01 lbs/day
2,4-Dimethylphenol	6.65E+03 ug/l	3.79E+01 lbs/day
2,4-Dinitrotoluene	2.63E+01 ug/l	1.50E-01 lbs/day
2,6-Dinitrotoluene		
1,2-Diphenylhydrazine	1.56E+00 ug/l	8.90E-03 lbs/day
Ethylbenzene	8.39E+04 ug/l	4.78E+02 lbs/day
Fluoranthene	1.07E+03 ug/l	6.10E+00 lbs/day
4-Chlorophenyl phenyl ether		
4-Bromophenyl phenyl ether		
Bis(2-chloroisopropyl) ether	4.92E+05 ug/l	2.80E+03 lbs/day
Bis(2-chloroethoxy) methane		
Methylene chloride (HM)	4.63E+03 ug/l	2.64E+01 lbs/day
Methyl chloride (HM)		
Methyl bromide (HM)		
Bromoform (HM)	1.04E+03 ug/l	5.93E+00 lbs/day
Dichlorobromomethane(HM)	6.36E+01 ug/l	3.62E-01 lbs/day
Chlorodibromomethane (HM)	9.84E+01 ug/l	5.60E-01 lbs/day
Hexachlorocyclopentadiene	4.92E+04 ug/l	2.80E+02 lbs/day
Isophorone	1.74E+03 ug/l	9.89E+00 lbs/day
Naphthalene		
Nitrobenzene	5.50E+03 ug/l	3.13E+01 lbs/day
2-Nitrophenol		
4-Nitrophenol		
2,4-Dinitrophenol	4.05E+04 ug/l	2.31E+02 lbs/day
4,6-Dinitro-o-cresol	2.21E+03 ug/l	1.26E+01 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

N-Nitrosodimethylamine	2.34E+01 ug/l	1.33E-01 lbs/day
N-Nitrosodiphenylamine	4.63E+01 ug/l	2.64E-01 lbs/day
N-Nitrosodi-n-propylamine	4.05E+00 ug/l	2.31E-02 lbs/day
Pentachlorophenol	2.37E+01 ug/l	1.35E-01 lbs/day
Phenol	1.33E+07 ug/l	7.58E+04 lbs/day
Bis(2-ethylhexyl)phthalate	1.71E+01 ug/l	9.72E-02 lbs/day
Butyl benzyl phthalate	1.50E+04 ug/l	8.57E+01 lbs/day
Di-n-butyl phthalate	3.47E+04 ug/l	1.98E+02 lbs/day
Di-n-octyl phthlate		
Diethyl phthalate	3.47E+05 ug/l	1.98E+03 lbs/day
Dimethyl phthlate	8.39E+06 ug/l	4.78E+04 lbs/day
Benzo(a)anthracene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Benzo(a)pyrene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Benzo(b)fluoranthene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Benzo(k)fluoranthene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Chrysene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Acenaphthylene (PAH)		
Anthracene (PAH)		
Dibenzo(a,h)anthracene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Indeno(1,2,3-cd)pyrene (PAH)	8.97E-02 ug/l	5.11E-04 lbs/day
Pyrene (PAH)	3.18E+04 ug/l	1.81E+02 lbs/day
Tetrachloroethylene	2.57E+01 ug/l	1.47E-01 lbs/day
Toluene	5.79E+05 ug/l	3.30E+03 lbs/day
Trichloroethylene	2.34E+02 ug/l	1.33E+00 lbs/day
Vinyl chloride	1.52E+03 ug/l	8.65E+00 lbs/day
Pesticides		
Aldrin	4.05E-04 ug/l	2.31E-06 lbs/day
Dieldrin	4.05E-04 ug/l	2.31E-06 lbs/day
Chlordane	1.71E-03 ug/l	9.72E-06 lbs/day
4,4'-DDT	1.71E-03 ug/l	9.72E-06 lbs/day
4,4'-DDE	1.71E-03 ug/l	9.72E-06 lbs/day
4,4'-DDD	2.43E-03 ug/l	1.38E-05 lbs/day
alpha-Endosulfan	5.79E+00 ug/l	3.30E-02 lbs/day
beta-Endosulfan	5.79E+00 ug/l	3.30E-02 lbs/day
Endosulfan sulfate	5.79E+00 ug/l	3.30E-02 lbs/day
Endrin	2.34E+00 ug/l	1.33E-02 lbs/day
Endrin aldehyde	2.34E+00 ug/l	1.33E-02 lbs/day
Heptachlor	6.08E-04 ug/l	3.46E-06 lbs/day
Heptachlor epoxide		
PCB's		
PCB 1242 (Arochlor 1242)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1254 (Arochlor 1254)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1221 (Arochlor 1221)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1232 (Arochlor 1232)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1248 (Arochlor 1248)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1260 (Arochlor 1260)	1.30E-04 ug/l	7.41E-07 lbs/day
PCB-1016 (Arochlor 1016)	1.30E-04 ug/l	7.41E-07 lbs/day

Pesticide

**Utah Division of Water Quality
Salt Lake City, Utah**

Toxaphene	2.17E-03 ug/l	1.24E-05 lbs/day
Metals		
Antimony	ug/l	lbs/day
Arsenic	ug/l	lbs/day
Asbestos	ug/l	lbs/day
Beryllium		
Cadmium		
Chromium (III)		
Chromium (VI)		
Copper	ug/l	lbs/day
Cyanide	ug/l	lbs/day
Lead		
Mercury	ug/l	lbs/day
Nickel	ug/l	lbs/day
Selenium		
Silver		
Thallium	ug/l	lbs/day
Zinc		
Dioxin		
Dioxin (2,3,7,8-TCDD)	4.05E-08 ug/l	2.31E-10 lbs/day

**Metals Effluent Limitations for Protection of All Beneficial Uses
Based upon Water Quality Standards and Toxics Rule**

	Class 4 Acute Agricultural ug/l	Class 3 Acute Aquatic Wildlife ug/l	Acute Toxics Drinking Water Source ug/l	Acute Toxics Wildlife ug/l	1C Acute Health Criteria ug/l	Acute Most Stringent ug/l	Class 3 Chronic Aquatic Wildlife ug/l
Aluminum		1457.6				1457.6	N/A
Antimony				12439.3		12439.3	
Arsenic	289.3	661.0			0.0	289.3	548.1
Barium						0.0	
Beryllium						0.0	
Cadmium	28.8	12.6			0.0	12.6	1.6
Chromium (III)		8629.2			0.0	8629.2	611.5
Chromium (VI)	287.8	27.4			0.0	27.38	24.30
Copper	577.1	76.0				76.0	67.5
Cyanide		42.8	636429.7			42.8	15.0
Iron		1945.2				1945.2	
Lead	287.8	642.7			0.0	287.8	35.8
Mercury		4.67		0.43	0.0	0.43	0.035
Nickel		2312.5		13307.2		2312.5	380.7
Selenium	141.6	37.4			0.0	37.4	10.3
Silver		48.7			0.0	48.7	

**Utah Division of Water Quality
Salt Lake City, Utah**

Thallium		18.2	18.2	
Zinc	591.5		591.5	879.1
Boron	2169.6		2169.6	

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

	WLA Acute ug/l	WLA Chronic ug/l	
Aluminum	1457.6	N/A	
Antimony	12439.31		
Arsenic	289.3	548.1	Acute Controls
Asbestos	0.00E+00		
Barium			
Beryllium			
Cadmium	12.6	1.6	
Chromium (III)	8629.2	612	
Chromium (VI)	27.4	24.3	
Copper	76.0	67.5	
Cyanide	42.8	15.0	
Iron	1945.2		
Lead	287.8	35.8	
Mercury	0.434	0.035	
Nickel	2312.5	381	
Selenium	37.4	10.3	
Silver	48.7	N/A	
Thallium	18.2		
Zinc	591.5	879.1	Acute Controls
Boron	2169.65		

Other Effluent Limitations are based upon R317-1.

E. coli 126.0 organisms per 100 ml

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the

**Utah Division of Water Quality
Salt Lake City, Utah**

receiving water. Based upon that review, it has been determined that an Level II Antidegradation Review is NOT required. Permit is a simple renewal. No increase in load or concentration.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important down-stream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised.

XIV. Special Considerations - TMDL

A Total Maximum Daily Load (TMDL) for total phosphorous was completed for the Little Bear River on May 23, 2000. As part of that TMDL, the Wellsville Wastewater Facility was given a discharge load allocation of 0.27 kg/day. As a result of TP reductions from other sources in the the watershed, specifically the elimination of the load attributed to feedlots (1.06 kg/d), Wellsville's allocation was increased to 1.2 kg/day (annual average). In order to minimize TP discharges to the Little Bear River during the critical summer months, we recommend that the 1.2 kg/day load allocation be distributed on a seasonal basis to yield the following effluent limits:

Summer (4 months)	June-September	0.60 kg/day total phosphorous as a seasonal average or 72 total kg for the 4 month season.
Non-summer (8 months)	October-May	1.50 kg/day total phosphorous as a seasonal average or 360 total kg for the 8 month season.

Prepared by:
David Wham
Utah Division of Water Quality
801-538-6052
File Name: Wellsville_WLA_11-16-12

APPENDIX - Coefficients and Other Model Information

**Utah Division of Water Quality
Salt Lake City, Utah**

CBOD Coeff. (Kd)20 1/day 2.000	CBOD Coeff. FORCED (Kd)/day 0.000	CBOD Coeff. (Ka)T 1/day 2.000	REAER. Coeff. (Ka)20 (Ka)/day 59.157	REAER. Coeff. FORCED 1/day 0.000	REAER. Coeff. (Ka)T 1/day 59.157	NBOD Coeff. (Kn)20 1/day 0.400	NBOD Coeff. (Kn)T 1/day 0.400
Open Coeff. (K4)20 1/day 0.000	Open Coeff. (K4)T 1/day 0.000	NH3 LOSS (K5)20 1/day 4.000	NH3 (K5)T 1/day 4.000	NO2+NO3 LOSS (K6)20 1/day 0.000	NO2+NO3 (K6)T 1/day 0.000	TRC Decay K(Cl)20 1/day 32.000	TRC K(Cl)(T) 1/day 32.000
BENTHIC DEMAND (SOD)20 gm/m2/day 1.000	BENTHIC DEMAND (SOD)T gm/m2/day 1.000						
K1 CBOD {theta} 1.0	K2 Reaer. {theta} 1.0	K3 NH3 {theta} 1.1	K4 Open {theta} 1.0	K5 NH3 Loss {theta} 1.0	K6 NO2+3 {theta} 1.0	K(Cl) TRC {theta} 1.1	S Benthic {theta} 1.1