

LARGE UNDERGROUND WASTEWATER OPERATING PERMIT Division of Water Quality

NAME OF SYSTEM: ATI TITANIUM LLC Welsey Clifton ATI Rowley Operations 12633 N. Rowley Rd. CONTACT PERSON/MAILING ADDRESS/PHONE NO: North Skull Valley UT 84029 8014339955 SYSTEM LOCATION: West end of Great Salt Lake on North Rowley Road, Tooele, Tooele County **ISSUE DATE:** 12/02/2014 **EXPIRATION DATE:** 12/02/2019 **ISSUED BY:** Walter L. Baker, P.E., Director, Division of Water Quality Until such time as this permit expires or is modified or revoked, the permitee is authorized to operate a large underground wastewater disposal system in conformance with all the requirements, limitations, and conditions set forth in *Utah Administrative* Code R317-5, with the attached schedules as follows: **SCHEDULE A Waste Disposal Limitations:** The permittee is authorized to operate and maintain a large underground wastewater disposal system that has been 1. constructed in accordance with plans and specifications approved by the Division of Water Quality and with the following conditions: a. System type Conventional Gravity; Conventional with Pump-to-Gravity: ✓ Pressure Distribution; ☐ Alternative (describe) b. Maximum Daily Design Flow of 4.519 gpd (East System) and 3.465 gpd (West System) c. Components of wastewater disposal system (check) ☐ RecirculatingTank Septic Tanks; 2-4,000 gal ☐ GreaseTrap ☐ Distribution Box **✓** PumpTankWithFloats **✓** Pressure Distribution Control Panel ☐ Drip Irrigation **✓** Trenches ☐ Enhanced Trt Unit DeepTrench ✓ Ratcheting Valve Box Mound ☐ Bed

e. Effluent parameters will meet R317-4 for domestic wastewater or additional treatment may be required.

✓ Gravelless Chambers Gravelles Chambers

Other (describe) Ratcheting valves (1 for each system) control panel

Gravel;

d. Drainfield media

- 2.. Discharge of untreated or partially treated sewage or septic tank effluent directly or indirectly onto the ground surface or the surface waters of the state constitutes a public health hazard and is prohibited. This permit does not relieve the permittee from responsibility for compliance with any other applicable federal, state, or local law(s), rule(s) or standard(s).
- 3.. No cooling water, air conditioner water, ground water, oil, hazardous materials, roof drainage, storm water runoff, or other aq ueous or non-aqueous substance which is, in the judgment of the Division, detrimental to the performance of the
- 4.. No activities shall be conducted that could cause an adverse impact on existing or potential beneficial use of groundwater.

SCHEDULE B Required Servicing and Inspections

1.	☐ Annually	Semi-Annually (every 6 months)	Other (specify)				
2.	All servicing and inspections must be conducted by a certified maintenance person per R317-11. Level 2 is required for conventional systems and level 3 for all other LUWDS.						
	Name of person performing maintenance on thsi system:/						
	☐ Level 2	Level 3 Note: if this person is repl within 30 day of change.	aced with another maintenance person, the owner must notify the Division				

Page 2

ATI TITANIUM LLC OPERATING PERMIT

3. If Sample results exceed Operating Parameters (other than Flow of wastewater) in table titled "Minimum Monitoring and Reporting Requirements", report to the Division within 5 days and follow rules in R317-5-1.4 (F).

Inspection Components

TYPE OF SYSTEM	•	Inspect and clean when necessary * Pump/Floats * Control Panel * Pump Filter	Flush/clean pressure laterals; inspect for ponding or surfacing in dispersal area; reset squirt height for equal pressure	Manufacturers Recommendations: * Recirc Tank * Pre-Treatment Unit * Misc
Conventional Gravity or Pump-to-Gravity				
Presure System (Drip)	✓	•	•	
Mound, At-Grade				
Packed Bed				

^{*} Or more per manufacturer requirements

Minimum Frequency of Periodic Inspections

TYPE OF SYSTEM	Every 12 months	Every 6 months
Conventional Gravity or Pump-to-Gravity 5,000 - 15,000 gal/day 15,000 + gal/day		
At-Grade Alternative System (first 5 years only) Mound (drip, pressure)		✓
Packed Bed		
Treatment System (to lower waste strength levels)		

Monitoring and Reporting Requirements

Item or Parameter	Minimum Frequency	Type of Sample	Operating Parameters
Flow of wastewater (gpd)	Monthly	Measurement based on meter readings	Approved design flow (gpd)
COD, TSS			
Total Inorganic Nitrogen (TIN)			

Reporting

Monitoring, maintenance practices, solids handling and results shall be reported on Division approved forms and must be submitted by **August 1**, **following the "reporting year" period of July 1 to June 30**.

Mail or email Reports to (permitting agency): Division of Water Quality, c/o LUWDS, PO Box 144870,

Salt Lake City, UT 84114-4870

Office: 801-536-4329 Fax: 801-536-4301 email: LUWDS@utah.gov

SCHEDULE C

Special and General Conditions

- 1. All septage/sludge shall be managed by a licensed sewage scavenger (pumper) as defined in R317-550.
- 2. Any observations of excessive kitchen wastes, surfacing sewage, etc., must be report to the Division within 5 working days
- 3. The permittee must maintain all treatment and control facilities in good working order and in conformance with permit requirements.