

LARGE UNDERGROUND WASTEWATER OPERATING PERMIT Division of Water Quality

| NAME (| OF SYSTEM: PIUTE HIGH SCHOOL | | | | |
|----------------|---|--|--|--|--|
| CONTA | CT PERSON/MAILING ADDRESS/PHONE NO: Terry Higgins Piute County School District 500 N. Main P.O. Box 69 Junction UT 84740 4555772912 | | | | |
| SYSTEM | A LOCATION: 500 North Main, Junction, Piute County | | | | |
| ISSUE D | DATE: 08/17/2015 //// / EXPIRATION DATE: 08/17/2020 | | | | |
| ISSUED | MILLET D. | | | | |
| - | | | | | |
| wastewate | a time as this permit expires or is modified or revoked, the permitee is authorized to operate a large underground er disposal system in conformance with all the requirements, limitations, and conditions set forth in <i>Utah Administrative</i> 17-5, with the attached schedules as follows: | | | | |
| | SCHEDULE A | | | | |
| Waste Di 1. | isposal Limitations: The permittee is authorized to operate and maintain a large underground wastewater disposal system that has been constructed in accordance with plans and specifications approved by the Division of Water Quality and with the following conditions: | | | | |
| | a. System type ✓ Conventional Gravity; | | | | |
| | information on system not provided | | | | |
| 2 | c. Components of wastewater disposal system (check) RecirculatingTank GreaseTrap Distribution Box PumpTankWithFloats Pressure Distribution Control Panel Drip Irrigation Trenches Enhanced Trt Unit DeepTrench Ratcheting Valve Box Bed Other (describe) Information of drainfield, grease trap, etc., not available. Permit holder needs to provide information with next annual inspection repot due Aug 1, 2011 d. Drainfield media Gravel; Gravelless Chambers e. Effluent parameters will meet R317-4 for domestic wastewater or additional treatment may be required. Discharge of untreated or partially treated sewage or septic tank effluent directly or indirectly onto the ground surface or the surface waters of the state constitutes a public health hazard and is prohibited. This permit does not relieve the permittee from responsibility for compliance with any other applicable federal, state, or local law(s), rule(s) or standard(s). No cooling water, air conditioner water, ground water, oil, hazardous materials, roof drainage, storm water runoff, or | | | | |
| | other aq ueous or non-aqueous substance which is, in the judgment of the Division, detrimental to the performance of the | | | | |
| 4 | groundwater. | | | | |
| | SCHEDULE B <u>Required Servicing and Inspections</u> | | | | |
| 1. | ✓ Annually □ Semi-Annually (every 6 months) □ Other (specify) | | | | |
| 2. | All servicing and inspections must be conducted by a certified maintenance person per R317-11. Level 2 is required for conventional systems and level 3 for all other LUWDS. | | | | |

Name of person performing maintenance on thsi system:/

✓ Level 2

Level 3 Note: if this person is replaced with another maintenance person, the owner must notify the Division within 30 day of change.

Page 2 PIUTE HIGH SCHOOL OPERATING PERMIT

If Sample results exceed Operating Parameters (other than Flow of wastewater) in table titled "Minimum 3. Monitoring and Reporting Requirements", report to the Division within 5 days and follow rules in R317-5-1.4 (F).

Inspection Components

| TYPE OF SYSTEM | Measure sludge/ scum levels, pump when necessary: * Septic Tank * Pump Tank * Grease Trap | Inspect and clean when necessary * Pump/Floats * Control Panel * Pump Filter | Flush/clean pressure laterals; inspect for ponding or surfacing in dispersal area; reset squirt height for equal pressure | Manufacturers Recommendations: * Recirc Tank * Pre-Treatment Unit * Misc |
|--|--|--|---|--|
| Conventional Gravity or Pump-to-Gravity | ✓ | | | |
| Presure System (Drip) | | | | |
| Mound, At-Grade | | | | |
| Packed Bed | | | | |

* Or more per manufacturer requirements

Minimum Frequency of Periodic Inspections

| TYPE OF SYSTEM | Every 12 months | Every 6 months |
|---|--------------------|-------------------|
| Conventional Gravity or Pump-to-Gravity 5,000 - 15,000 gal/day 15,000 + gal/day | | |
| At-Grade Alternative System (first 5 years only) | | |
| Mound (drip, pressure) | | |
| Packed Bed | | |
| Treatment System (to lower waste strength levels) | | |

Monitoring and Reporting Requirements

| Item or Parameter | Minimum Frequency | Type of Sample | Operating Parameters |
|--------------------------------|----------------------|--|----------------------------|
| Flow of wastewater (gpd) | 2 | Measurement based on meter readings | Approved design flow (gpd) |
| COD, TSS | | | |
| Total Inorganic Nitrogen (TIN) | | | |
| | | | |

Reporting

Monitoring, maintenance practices, solids handling and results shall be reported on Division approved forms and must be submitted by August 1, following the "reporting year" period of July 1 to June 30.

Mail or email Reports to (permitting agency): Division of Water Quality, c/o LUWDS, PO Box 144870, Salt Lake City, UT 84114-4870 Office: 801-536-4329 Fax: 801-536-4301

email: LUWDS@utah.gov

SCHEDULE C

Special and General Conditions

- 1. All septage/sludge shall be managed by a licensed sewage scavenger (pumper) as defined in R317-550.
- 2. Any observations of excessive kitchen wastes, surfacing sewage, etc., must be report to the Division within 5 working days
- 3. The permittee must maintain all treatment and control facilities in good working order and in conformance with permit requirements.