



James Harris <jamesharris@utah.gov>

Little Cottonwood Creek pH in the 2016 Integrated Report

1 message

Eric Sorensen [REDACTED]@mwdsls.org>
To: "jamesharris@utah.gov" <jamesharris@utah.gov>

Tue, Aug 2, 2016 at 12:41 PM

James,

In reviewing the 2016 Integrated Report I noticed that Little Cottonwood Creek was listed for pH. I was interested in this because we treat Little Cottonwood Creek water here at the Little Cottonwood Water Treatment Plant. As I reviewed the data, two dates stood out to me. On 5/7/2012 high pH values (9.34-11.03) were reported for all sites measured and on 7/9/2012 low pH values (5.86 – 6.81) for all sites. This led me to review our data for Little Cottonwood Creek and neither our online instrument nor our daily grab results showed high pH values on 5/7/12 or low pH values on 7/9/12. Our grab sample results were 7.83 and 7.92 on 5/7/12 and 7/9/12 respectively. Online pH values were between 7.28 and 7.31 on 5/7/12 and between 7.33 and 7.53 on 7/9/2012.

I'm not sure if this information is of value to you in the integrated report process but I wanted to pass it along. Please let me know if you have any questions or if there is any additional information that I can provide that would be of interest.

Thanks,

Eric Sorensen

Environmental Services Specialist II

Metropolitan Water District of Salt Lake & Sandy

[REDACTED]

[REDACTED]