

Jennifer



CEDAR CITY

10 NORTH MAIN • CEDAR CITY, UTAH 84720
435-586-2950 • FAX: 435-586-4362
www.cedarcity.org

Mayor

Joe Burgess

Council Members

Ronald R. Adams
Nina R. Barnes
Georgia Beth Thompson
John R. Westwood
Steve Wood

City Manager

Ronald F. Chandler



Jennifer Robinson
Utah State Pretreatment Coordinator
Division of Water Quality
P.O. Box 144870
Salt Lake City, UT. 84114-4870

Dear Mrs. Robinson

Subject: Cedar City Ordinance 30a:

Per your request, enclosed you will find the following documentation:

- Cedar City Attorney Statement
- Ordinance 30a council minutes; submission, and approval
- City authorization of Ordinance 30a being amended.
- Public notification in the Spectrum.
- Summary of Ordinance Changes
- Exhibit A- Amended Ordinance 30a.

If there is anything else you are in need of please do not hesitate to contact me.

Sincerely,

Peter Sury
Pretreatment Coordinator
CCRWTF

Document Date 10/11/2011



DWQ-2011-008534

DW



CEDAR CITY


10 NORTH MAIN • CEDAR CITY, UTAH 84720
435-586-2950 • FAX: 435-586-4362
www.cedarcity.org

Mayor
Joe Burgess

Council Members
Ronald R. Adams
Nina R. Barnes
Georgia Beth Thompson
John R. Westwood
Steve Wood

City Manager
Ronald F. Chandler

Jennifer



November 1, 2011

Jennifer Robinson
Pretreatment Coordinator
Environmental Engineer
Utah Division of Water Quality
P.O. Box 144870
Salt Lake City, Utah 84114-4870

Dear Ms. Robinson:


Subject: Attorney Statement for Cedar City's Ordinance/Rules and Regulations

This office is legal counsel for Cedar City and its publicly owned treatment works (POTW). Cedar City has amended its Ordinance to modify the pretreatment provisions to be consistent with R317-8-8 and 40 CFR 403.

I have reviewed the changes to the ordinance and it is my opinion that the Ordinance, allows the Cedar City to continue to have adequate legal authority to administer the pretreatment program as described in R317-8-8 and 40 CFR 403.8(f). The changes are consistent with R317-8-8 and 40 CFR 403. The proposed changes are consistent and in compliance with Cedar City's approved Pretreatment Program, R317-8-8 and 40 CFR 403. The changes have been approved by the Cedar City Council. Once the State has approved the Ordinance it's the Cedar City's intent to implement the Ordinance.

If you have any questions regarding the matter please contact Pete Sury, Pretreatment Coordinator at (435)867-9462.

Sincerely,


Paul Bittmenn
Cedar City Attorney

cc: Pete Sury

Document Date 11/1/2011



DWQ-2011-008669

DW

COUNCIL WORK MINUTES
JUNE 17, 2009

The City Council held a work meeting on Wednesday, June 17, 2009, at 5:30 p.m., in the Council Chambers at the City Office at 10 North Main Street, Cedar City, UT.

PRESENT: Mayor Gerald R. Sherratt; Council Members: Nina Barnes; Dale Brinkerhoff; Jolene Goff; Georgia Beth Thompson; Steve Wood; City Manager Ron Chandler; City Attorney Paul Bittmenn; City Engineer Kit Wareham; Public Works Director Rick Holman; City Recorder Renon Savage.

OTHERS: Robert D. Allinson, Jace Bunting, Brian Maxfield, Reed Erickson, Tom Jett, Natasha Hirschi, Pete Sury, Darrell Olmsted, Chad Boshell, Paul Irons, Joel Hansen, Roger Black, Bailu Gongsun, Irwin Moosman, Samantha Arnold, June Sewing.

CALL TO ORDER: The opening prayer was given by Council Member Steve Wood and the Pledge of Allegiance was led by Council Member Nina Barnes.

AGENDA ORDER APPROVAL: There were no changes.

ADMINISTRATION AGENDA - MAYOR AND COUNCIL BUSINESS; STAFF

COMMENTS: ■ Mayor introduced a new intern from SUU Bailu Gongsun. She is working in the Mayor's office and becoming acquainted with how we do things in America. ■ Steve Wood – there are a lot of people that have chicken runs, and others that would like to have them. We may want to look into the issue and see about allowing chickens. There are people that do it anyway.

CONSIDER APPROVAL OF AN AGREEMENT WITH IRON COUNTY FOR THE FUNDING AND USE OF THE AQUATIC CENTER – REED ERICKSON/ PAUL BITTMENN:

Reed Erickson – the Commission felt they wanted to clarify a few things in the agreement to increase the stream of revenue for this purpose. There is also a term issue of 15 years versus 20 years which bonding requires. Consent.

CONSIDER AN AGREEMENT WITH WORKFORCE SERVICES TO ALLOW YOUTH PAID INTERNSHIPS, UNPAID INTERNSHIPS, AND ON THE JOB TRAINING PROGRAMS – NATASHA HIRSCHI:

Natasha - this is a program we have used in the past and is part of the stimulus package to get youth back in the workforce. They have to have qualifying status, most of which is income and welfare. Dale – surprised to see the age as low as 14. Natasha – they have 16 youth from 14 to 21 years of age. Dale - do we have an obligation to continue? Natasha – No, and we are not allowed to use them in positions we have opened. This has to be a created job for the youth. Georgia – do we have concerns with supervision with our staff? Natasha – the areas that will use them are ok. We also have the option to decline an individual. Consent.

GENERAL PLAN UPDATE – PLANNING COMMISSION MEMBER: Roger Black – at Planning Commission meeting we concluded the contribution to the revised General Plan. This has been underway for a long time. There were a large number of opportunities for public input. Planning Commission had two public hearings, without much participation. Staff has also received phone calls regarding the Plan. This is a good Plan and we turn it over to the City Council.

Paul – there is two parts that need to be added, a statutory requirement for inventory of agriculture use and a moderate income housing component. Both of these things can be attached to the written Plan as we have it and incorporated in the Plan. Mayor – who will provide that information? Staff and the Planning Commission will provide that information. Paul – you will get written text and maps. Brian Maxfield will provide that to you. Brian – we will show you the differences from the May 26th document and what you have. Steve – it is on the web page. Brian – it is there, but is in pieces. Ron – we will bring to you the revised General Plan. Brian has been putting together ordinance changes; we will have a list of those for you. We will also work up a tentative schedule for holding hearings. We just wanted the Planning Commission to pass this off to you. Steve – they are interested in a time line of ordinance changes between the old and new Plan. Brian – we will have information available the first meeting in July. Ron – we will get you the information before July 1st, but July 1st is when it will first be on the agenda.

**CONSIDER AMENDMENTS TO ORDINANCE 30A, WASTEWATER/
PRETREATMENT – DARRELL OLMSTED/PETER SURY:** Pete – above and beyond federal and state requirements, changes have been made to streamline. Those amendments have been enclosed in the summary which is attached as Exhibit “A”. It is my belief that the amendments will assist industrial users in the pretreatment program. The ordinance is on the website. All amendments were required by EPA to the State and from State to local government. We only implemented required amendments. There were other amendments that are outlined in the summary. It was also to more efficiently allow me to interact with public institutions, food industry and industrial users. There were also some editorial changes.

Georgia – I have a few formatting corrections I will forward to you and Paul. Action.

**CONSIDER APPROVAL OF CHANGE ORDER #1 FOR THE MANHOLE
RENEWAL PROJECT 2009 – CHAD BOSHELL:** Chad - this is for \$6,000. We were doing 14 manholes, four ended up being five foot diameter instead of four feet. We are still under budget on the project. Georgia – this is good. Long term should they all be the same size? Chad – there was an upsize in pipe. This is at 2300 West to Midvalley Road. Consent.

**REVIEW BIDS FOR THE 1045 NORTH STREET IMPROVEMENT PROJECT –
KIT WAREHAM:** We have in the capital improvement budget money to improve 1045 North from Main to 400 West. We had money in there for water improvements to go along with this project. We received bids last week, low bid is Curtis DeMille

Construction for \$89,107. We are putting in approximately 800 feet of curb, 1600 feet of sidewalk and moving some fire hydrants and water meters. The water line is a 6" line.

Mayor – we have done a few projects that have cleaned up the area, one by Sunbow and one on south Main by Wells Fargo Bank.

Dale – are we concerned about the bid amount? Kit – the second low bid was \$93,000. The bottom 4 bidders are close. Dale – the reason we do this because the lots back up to 1045 North. That was not a street side when the development was done. Consent.

CONSIDER APPROVAL OF THE CERTIFIED TAX RATE – JACE BUNTING:

Jace – I called at 4:45 and the County Auditor still did not have the rate from the State, but may have it tomorrow. Action.


CONSIDER BOARD APPOINTMENTS: (A) PARKS AND RECREATION RAP TAX ADVISORY BOARD; (B) ARTS RAP TAX ADVISORY BOARD:

Mayor Sherratt – on the Arts Board, Dianne Peveler and Harold Shirley's terms are up. I am recommending Roland Williams who has been a member of the Music Arts Board, and Shauna Mendini, she is head of theatre and dance department at SUU. To the Parks & Recreation Board I am recommending Ricky Mindini, who is the Director of Sports Medicine at SUU, and Penny Alger, she is a judicial services manager for the Fifth District Court, she also has daughters involved in High School sports. Georgia – my concern with Ricky is the intensive travel schedule. Mayor – they only meet a few times a year. Consent.

PUBLIC COMMENTS: There were no comments.

EXECUTIVE SESSION – PROPERTY NEGOTIATIONS:

ADJOURN: Council Member Georgia Beth Thompson moved to adjourn and go into an executive session at 6:00 p.m.; second by Council Member Nina Barnes; vote unanimous.


Renon Savage, City Recorder

COUNCIL MINUTES
JUNE 24, 2009

The City Council held a meeting on Wednesday, June 24, 2009, at 5:30 p.m., in the Council Chambers at the City Office at 10 North Main Street, Cedar City, UT.

PRESENT: Mayor Gerald R. Sherratt; Council Members: Nina Barnes; Jolene Goff; Georgia Beth Thompson; Steve Wood; City Manager Ron Chandler; City Attorney Paul Bittmenn; City Engineer Kit Wareham; Public Works Director Rick Holman; City Recorder Renon Savage.

ABSENT: Dale Brinkerhoff, Ron Chandler.

OTHERS: Darrell Olmsted, Pete Sury, Darin Adams, Victor Medina, Tom Jett, Cathy Wentz, June Sewing, Jace Bunting, Kelly Newville, Samantha Arnold.

CALL TO ORDER: The opening prayer was given by Council Member Georgia Beth Thompson and the Pledge of Allegiance was led by Council Member Jolene Goff.

AGENDA ORDER APPROVAL: There were no changes.

ADMINISTRATION AGENDA - MAYOR AND COUNCIL BUSINESS; STAFF

COMMENTS: ■ Steve Wood read a letter from Dave Morris and Wayne Clark regarding the July Jamboree. They want the power outlets checked and working from Center to 300 North on July 10th for the July Jamboree. They asked to have a City electrician on duty from 2 to 10 p.m. Rick – we don't have an electrician. Kit said R-57 Electric comes in to make sure everything is working. Steve - they already have 66 booths, 5 food vendors and 50 cars for the show. ■ Nina – I have been visiting and a lot are excited about the events coordinator. There are people trying to recruit events on their own now. Mayor – there will be a meeting on July 7th with the Council. Nina – I am hearing about tournaments for September.

CONSENT AGENDA: (1) APPROVAL OF MINUTES DATED JUNE 3 & 10, 2009; (2) APPROVAL OF BILLS DATED JUNE 18 - 22, 2009; (3) APPROVE AN AGREEMENT WITH IRON COUNTY FOR THE FUNDING AND USE OF THE AQUATIC CENTER – REED ERICKSON/PAUL BITTMENN; (4) APPROVE AN AGREEMENT WITH WORKFORCE SERVICES TO ALLOW YOUTH PAID INTERNSHIPS, UNPAID INTERNSHIPS, AND ON THE JOB TRAINING PROGRAMS – NATASHA HIRSCHI ; (5) APPROVE CHANGE ORDER #1 FOR THE MANHOLE RENEWAL PROJECT 2009 IN THE AMOUNT OF \$6,000 – CHAD BOSHELL; (6) APPROVE THE BID FROM CURTIS DEMILLE CONSTRUCTION IN THE AMOUNT OF \$89,107.00 FOR THE 1045 NORTH STREET IMPROVEMENT PROJECT – KIT WAREHAM; (7) APPROVE APPOINTING RICKY MENDINI AND PENNY ALGER TO THE PARKS & RECREATION RAP TAX ADVISORY BOARD; AND SHAUNA MENDINI AND ROLAND WILLIAMS TO THE ARTS RAP TAX ADVISORY BOARD – MAYOR

SHERRATT: Council Member Steve Wood moved to approve the consent agenda items 1 through 7 as written above; second by Council Member Jolene Goff; vote unanimous.

CONSIDER AN ORDINANCE AMENDING CHAPTER 30A, WASTEWATER/PRETREATMENT – DARRELL OLMSTED/PETER SURY: Council Member Georgia Beth Thompson moved to adopt the ordinance amending Chapter 30A, Wastewater/Pretreatment; second by Council Member Nina Barnes; vote

Nina Barnes	-	AYE
Jolene Goff	-	AYE
Georgia Beth Thompson	-	AYE
Steve Wood	-	AYE

CONSIDER APPROVAL OF THE CERTIFIED TAX RATE – JACE BUNTING:

Jace - the certified tax rose from .002163 to .002462. Mayor – we accept what the County gives us. Jace – the County does their portion then it goes to the State and it comes back. Nina – it has gone down over the past few years. Mayor – we have done that, but the property values have gone down this year. Jace – the Certified Tax Rate should generate the same amount of property taxes that we received last year. The rate goes up because the property values are down. They take a 5 year time frame to fully reassess the City so it takes some time to have the City equalized. For every \$100,000 of assessed value the property value would increase by \$29.90, but the assessed value should go down so a home owner should not see a change. Jolene – some will go up because their property has been reassessed previously.

Council Member Georgia Beth Thompson moved to approve the certified tax rate at .002462; second by Council Member Steve Wood; vote unanimous.

PUBLIC COMMENTS: There were no comments.

ADJOURN: Council Member Georgia Beth Thompson moved to adjourn at 5:40 p.m.; second by Council Member Nina Barnes; vote unanimous.


Renon Savage, City Recorder

CEDAR CITY ORDINANCE NO. 0624-09
AN ORDINANCE AMENDING CHAPTER 30a, WASTEWATER - PRETREATMENT

WHEREAS, Cedar City has adopted Chapter 30a in order to establish uniform requirements for users of the Publicly Owned Treatment Works (POTW) for the Cedar City Water Reclamation Facility (CCWRF) of Cedar City, Utah and enable the CCWRF to comply with all applicable State and Federal laws including the Clean Water Act (33 U.S.C. 1251 et seq.), the General Pretreatment Regulations found in the U.S. Code of Federal Regulations (CFR) 40 CFR Part 403, and the Utah Administrative Code R317-8-8; and

WHEREAS, both the state and federal law regulating the CCWRF have changed since the original adoption of Chapter 30a; and

WHEREAS, in an effort to maintain compliance with State and Federal law, the Cedar City Council finds that it is in the best interests of the health, safety, and general welfare of the Citizens of Cedar City to adopt the proposed amendments contained in exhibit A.

NOW THEREFORE, BE IT ORDAINED, by the City Council of Cedar City, Iron County, State of Utah that Chapter 30a is amended as reflected in exhibit A.

Dated this 25th day of June, 2009.


GERALD R. SHERRATT
MAYOR

[SEAL]

ATTEST:




RENON SAVAGE
RECORDER

SPECTRUM

A Marketing and Communications Company

PROOF OF PUBLICATION

STATE OF UTAH SS.
COUNTY OF WASHINGTON

Aubrey Paxton, being duly sworn,
deposes and says that she is
an accounting representative, at
the daily newspaper published at
St. George, Washington County,
State of Utah, also distributed in
Iron County, and that the notice

PUB # : L7182

is a true copy of which is here to
attached, was published in its issue
dated the 30 day of

June 2008

and was published again in the
issues of said newspaper dated:

_____ for
a total of 1 insertion(s)

JUL 06 2009

NOTICE OF ORDINANCE


Notice is hereby given
that the Cedar City
Council, at its regular
meeting of June 24,
2009, passed the fol-
lowing ordinance:

1. Ordinance 0624-09,
an Ordinance amend-
ing Chapter 30a,
Wastewater - Pretreat-
ment.

Said Ordinance shall
become effective imme-
diately upon publica-
tion.

A copy of said ordi-
nance(s) may be seen
and/or purchased at
the office of the Cedar
City Recorder, 10
North Main Street, Ce-
dar City, Utah.


Pub#L7182
published on
June 30, 2009.
The Spectrum
UPAXLP


Aubrey Paxton

Subscribed and sworn before me
this 2nd day of

July 2009.


NOTARY PUBLIC RESIDING
AT WASHINGTON COUNTY



ST. GEORGE OFFICE
275 E. St. George Blvd. - St. George, UT 84770
Office (435) 674-6200 FAX 674-6265
CEDAR CITY OFFICE
369 N. 100 W. - Cedar City, UT 84720
Office (435) 586-7646 FAX 586-7471



Cedar City Regional Wastewater Treatment Facility
Summary of Ordinance Changes

30a 1.2 Administration

General Manager of the Cedar City Wastewater Treatment Facility, (CCRWTF)
(This will back up definition of General Manager found in 30a-1.3 KK.

30a 1.3

C. Authorized Representative of the Industrial User or Authorized Representative.

1.B This passage gave a statement as to a numerical maximum of manufacturing, production, or operation facility personnel, and expenditures. In relation to defining an authorized representative whom would be appropriate to conduct business with CCRWTF, we felt the numerical standards expressed are superfluous, and do not represent how CCRWTF conducts business with existing, and/or future Industrial Users, (IU's).

Definitions:

- J. Food Establishment.
- M. Grease Oil, and Sand Interceptor.
- N. Oil/Water Separator
- O. Grease Trap.
- W. Non-Domestic Wastewater. Any wastewater that is not produced as sanitary wastewater from restroom facilities, showers, or kitchens.

30a 2.1 Prohibited Discharge Standards

Language change to include the following:

General prohibitions. No industrial user shall introduce or cause to be introduced into the POTW any pollutant or wastewater which has a reasonable potential to cause pass through or interference, or in any other way violate the POTW's regulations, local limits or Permit conditions.

30a 3.1 Pretreatment Operations:

- C. Expanded explanation of subject-able wastewater flow of which would be considered by the General Manager as necessary to be directed through Grease, sand and oil Interceptor, and/or Oil/Water Separator.

Defines residential users not subject to installation of an Interceptor as, Private living quarters, or dwelling units.

Defines responsibility of the owner, or any other person as a tenant under any rental or lease agreement set forth by the owner to be responsible for the proper maintenance, record keeping, and hiring of a certified licensed waste disposal firm.

D. and/or Oil/Water Separators

E. Grease Interceptor Vs. Grease Trap. Please reference definitions 30a 1.3 (M)(N).

F. Defines new source commercial structures that are planned occupied, or planned un-occupied to be required during construction to install independent 6-inch wastewater discharge lines stubbed out within each unit. Completing this during the early stages of construction will streamline the process of Interceptor installation.

G. Allows leverage to the owner whom would prefer to contract out the engineering, and or Grease Interceptor calculations vs. solely utilizing CCRWTF. Requires review and approval by CCRWTF of any, and all related calculations based on calculated Grease Interceptor size, and capacity. Defines pumping frequency of all new source, and existing Grease Oil, and Sand Interceptors.

H. New source strip mall, multi-tenant planned un-occupied building, were owner of said building deems not to facilitate the installation of independent wastewater lines to be designated for a future food establishment, then no future food establishments shall be permitted.

I. Defines General Manager requiring existing commercial kitchen to install a new Grease, Oil, and Sand Interceptor that fully complies with this ordinance, or to modify, replace, or repair noncompliant plumbing or existing grease trap or interceptor upon notice to the food establishment, and or commercial kitchen.

J. Allows Pretreatment Coordinator to inspect, review existing, and/or new source facilities as needed not limited to annually. Completes review process. Reference 30a 3.3 Tenant Responsibility.

30a 3.3 Tenant Responsibility

Explains responsibility delegated solely to the property owner, and or person as a tenant under any lease agreement that contracts and/or performs work for the installation or repair of building.

30a 4.3 Certification.

Non Permitted Industrial User Report will be distributed after user classification process is completed as stated in 30a 6.7.

Please reference EPA Model Pretreatment Ordinance, (MPO)
and/or 40 CFR 403

30a 1.3 Definitions

1.

a. Addition of or

b. Addition of language similar to 40 CFR 403.12 (I)(1)(ii) and as stated in (MPO) line 248-257.

L. Language change; not to exceed From; ~~over~~

P. Language change; source. Regulated under section (a), (b), and (c) of the act. From; ~~source, regulated by the UPDES program and/or the US Water Quality Act 307 B, C, and D.~~

R. Language change; collected, From; ~~collected.~~

S. Language change; POTW treatment processes or operations, or its sludge processes, use or disposal From; ~~POTW~~

S. CCRWTF's UPDES permit conditions, or From; ~~CCRWTF's UPDES permit, or~~

U. New source (3)

Language change similar to (MPO) lines 382-397.

Language change; Construction of a new source as defined under this section has commenced if the owner or operator has From; ~~defined has commenced if the owner or operator has begun, or caused to begin as part of a continuous on site construction program~~

U. New source (3) a. Language change; begun, or caused to begin as part of a continuous on site construction program

U. New source (3)

Format changes: a, I, ii, b

X. Pass Through

Language change; of the CCRWTF's UPDES permit From; ~~of the UPDES permit~~

AA. Pollutant

Language change; waste, filter backwash, incinerator From; ~~waste, incinerator~~

BB. Pretreatment

Language change; inserted language pursuant to 40 CFR 403.3 (s)

403.6 (d). Appropriate pretreatment technology includes control equipment, such as equalization tanks or facilities, for protection against surges or slug loadings that might interfere with or otherwise be incompatible with the POTW. However, where wastewater from a regulated process is mixed in an equalization facility with unregulated process, the effluent from the equalization facility must meet an adjusted pretreatment limit calculated in accordance with 403.6 (e).

DD. Pretreatment Standards, or Standards

Language change similar to (MPO) 430-431 established by the CCRWTF.

JJ. Slug Load/Discharge

Language change; DEQ per (MPO) lines 494-499, and 40 CFR 403.8 (f)(2)(viii).

30a 1.4 Abbreviations

Language change; ~~gpd~~ to GPD, and ~~mgd~~ to MGD.

30a 2.1 Prohibited Discharge Standards

Language, and or format changes per DEQ;

30a 2.1

(A), (B), 1,2,3,4,5,6,7,8,9,10,11,12,13,14,15,16,17,18.

30a 2.2 Categorical Pretreatment Standards

Language added; ref; (MPO) lines 644-646

When wastewater subject to a categorical Pretreatment Standard is mixed with wastewater not regulated by the same Standard, the Control Authority or the Industrial User with the written concurrence of the Control Authority shall impose an alternate limit in accordance with 40 CFR 403.6(e).

30a 2.4 CCRWTF Local Limits

Language added; ref; (MPO) lines 792-793

The Superintendent, and/or General Manager is authorized to establish Local Limits pursuant to 40 CFR 403.5(c).

30a 4.1 Industrial Waste Survey

Language added; ref; DWQ language addition with CCRWTF approval.

The questionnaire and BMR will include the information as stated in section 4.2 and additional information as needed to determine compliance with this ordinance and any applicable Pretreatment Standards.

Language added; ref; (MPO) line 977
and return to the CCRWTF within (90) days of the request

30a 4.3 Certification

Language change: user reports, and/or Non Permitted Industrial Users Reports, and of the user Form, of the industrial user

30a 5.3 Contents

Language added; Added language to section 30a5.3 (A).
Ref; 40 CFR 403.8 (f)(1)(B)(3)

30a 5.3 Contents

A.(3) including Best Management Practices, based on applicable general Pretreatment Standards in part 403 of the Code of Federal Regulations, categorical Pretreatment Standards,

A.(9) Control Authority or the Industrial User with the written concurrence of the Control Authority
[Please reference EPA Model Pretreatment Ordinance 1203]

30a 6 REPORTING REQUIREMENTS

Moved certification statement here.

30a 6.1 Baseline Monitoring Reports (BMR)

Language added: Section 30a 4.3. From, Section ~~30a-4.3~~ of this Ordinance.

30a 6.1 Baseline Monitoring Reports (BMR)

Language added: If the General Manager determines that a BMR is needed the information as stated in 4.2 must be submitted as well as any additional information required by the General Manger to determine compliance with this ordinance as well as the information provided below:

This statement was offered via communications with DWQ.

30a 6.1 Baseline Monitoring Reports (BMR)

Language added: [Please reference EPA Model Pretreatment Ordinance lines 1529 -1540

1. Samples should be taken immediately downstream from the regulated process if no pretreatment exists. If other wastewaters are mixed with the regulated wastewater prior to pretreatment the User should measure the flows and concentrations necessary to allow use of the combined

wastestream formula in 40 CFR 403.6 (e) to evaluate compliance with the Pretreatment Standards. Where an alternate concentration or mass limit has been calculated in accordance with 40 CFR 403.6 (e) this adjusted limit along with supporting data shall be submitted to the Control Authority;

2. Sampling and analysis shall be performed in accordance with section 30a 7.2 of this ordinance.

30a 6.4 Periodic Compliance Report

A. In cases where the Pretreatment Standard requires compliance with Best Management Practice (BMP) or pollution prevention alternative, the User must submit documentation required by the General manager or the Pretreatment Standard necessary to determine the compliance status of the User.
[Please reference EPA Model Pretreatment Ordinance 1615]

30a 6.6 Report of Potential Problem

Language change: Report of Potential Problem From, ~~Slug Discharge Report~~

30a 6.6 Report of Potential Problem

Language added in section (E) Ref: (MPO) Lines 1773-1774, section 6.6 (D) to (E).

Significant Industrial Users are required to notify the Superintendent, and/or General Manager immediately of any changes at its facility affecting the potential for a Slug Discharge.

30a 6.7 Non Permitted Industrial User Reports.

Enables user classification, and or preliminary inspections with industry that would not fall under the permitted categories as a Categorical Industrial User, (CIU), or Significant Industrial User, (SIU), Industrial User, (IU). Certification statement will be initiated.

30a 6.8 Repeat Sampling Report

Addition of language: Upon the POTW conducting a resample of the industrial users, and analytical results of the POTWs sample indicates a violation of the industrial users permit the POTW can require the industrial user to conduct a resample

30a6.11 Record Keeping.

of information obtained pursuant to any monitoring activities required by this ordinance, any additional records of information obtained pursuant to monitoring

activities undertaken by the User independent of such requirements, and documentation associated with Best Management Practices, and information required to be retained under this ordinance: records shall include the date, exact place, method, and time of sampling, and the name of the person(s) taking the samples; the dates analyses were performed who performed the analyses; the analytical techniques or methods used; and the results of such analyses. These
[Please reference EPA Model Pretreatment Ordinance 1909]

30a-7.1 Inspection

Language change: industrial user to ascertain From, ~~industrial user at reasonable times to ascertain~~

30a 7.2 Monitoring.

A. 24-hour [Please reference EPA Model Pretreatment Ordinance 1871]

must be used for pH, cyanide, total phenols, oil and grease, sulfide and volatile organic compounds for facilities for which historical sampling data does not exist; for facilities for which historical sampling data are available, the General Manager may authorize a lower minimum.

[Please reference EPA Model Pretreatment Ordinance 1890]

~~where the user demonstrates that this will provide a representative sample of the effluent being discharged.~~

the Industrial User is required to collect the number of grab samples necessary to assess and assure compliance by with applicable Pretreatment Standards and Requirements.

[Please reference EPA Model Pretreatment Ordinance 1894]

C. multiple grab samples collected during a 24-hour period may be composited prior to the analysis as follows: for cyanide, total phenols, and sulfides the samples may be composited in the laboratory or in the field; for volatile organics and oil and grease, the samples may be composited in the laboratory. Composite samples for other parameters unaffected by the compositing procedures as documented in approved EPA methodologies may be authorized by [the City], as appropriate.
[Please reference EPA Model Pretreatment Ordinance 1876]

30a 9.2 Significant Noncompliance

Language change/added: DEQ edits to sections; A,B,C,D,E, and H of 30a 9.2

30a 9.2 Significant Noncompliance

Language change/added: DEQ edits to sections;

A. or more of all of the measurements taken during a 6-month period exceed a numeric Pretreatment Standard or Requirement, including instantaneous limits, as defined in 30a-1.3 DD., for the same pollutant parameter by any amount;

- B. or more of all the measurements taken for the same pollutant parameter during a 6-month period equals or exceeds the product of the numeric Pretreatment Standard or Requirement including instantaneous limits, as defined in 30a-1.3 DD, multiplied by the applicable criteria [1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH];
- C. of a Pretreatment Standard or Requirement as defined in 30a-1.3 DD. (daily maximum, long-term average, instantaneous limit or narrative Standard) that the CCRWTF determines
- E. contained in a control mechanism
- H. or group of violations, which may include a violation of Best Management Practices,

30a 10.4 Compliance Orders

Language added: . A compliance order, and/or schedule can be initiated by the control authority for the installation of technology required to meet applicable Pretreatment Standards and Requirements a compliance order may not extend the deadline for compliance established for a Federal Pretreatment Standard or requirement, nor does a compliance order release the user of liability for any violation, including any continuing violation. Issuance of a compliance order shall not be a prerequisite to taking any other action against the user.

Ref: 40 CFR 403.8 (f) (1)(vi).

30a – 16- Effective Date.

Updated format per review by City Attorney Paul Bittmenn.

TABLE OF CONTENTS

Formatted

Page Number

SECTION 30A-1 - GENERAL PROVISIONS	1	Deleted: 1
30A-1.1 PURPOSE AND POLICY	1	Deleted: 1
30A-1.2 ADMINISTRATION	2	Deleted: 10
30A-1.3 DEFINITIONS	2	Deleted: 11
30A-1.4 ABBREVIATIONS	10	Deleted: 11
SECTION 30A-2 - GENERAL POTW USE REQUIREMENTS	11	Deleted: 14
30A-2.1 PROHIBITED DISCHARGE STANDARDS	11	Deleted: 14
30A-2.2 CATEGORICAL PRETREATMENT STANDARDS	14	Deleted: 14
30A-2.3 STATE PRETREATMENT REQUIREMENTS	14	Deleted: 15
30A-2.4 CCRWTF LOCAL LIMITS	14	Deleted: 15
30A-2.5 CEDAR CITY CORPORATION'S RIGHT OF REVISION	14	Deleted: 15
30A-2.6 SPECIAL AGREEMENT	14	Deleted: 15
30A-2.7 DILUTION	15	Deleted: 15
SECTION 30A-3 - PRETREATMENT OF WASTEWATER	15	Deleted: 18
30A-3.1 PRETREATMENT OPERATIONS	15	Deleted: 19
30A-3.2 SLUG LOAD CONTROL PLANS	18	Deleted: 19
30A-3.3 TENANT RESPONSIBILITY	19	Deleted: 19
30A-3.4 HALLED WASTEWATER	19	Deleted: 20
30A-3.5 VANDALISM	19	Deleted: 20
SECTION 30A-4 - WASTEWATER DISCHARGE PERMIT APPLICATION	20	Deleted: 20
30A-4.1 INDUSTRIAL WASTE SURVEY	20	Deleted: 20
30A-4.2 APPLICATION QUESTIONNAIRE CONTENTS	20	Deleted: 22
30A-4.3 CERTIFICATION	22	Deleted: 22
30A-4.4 GENERAL MANAGER EVALUATION	22	Deleted: 22
SECTION 30A-5 - WASTEWATER DISCHARGE PERMIT	22	Deleted: 22
30A-5.1 WASTEWATER DISCHARGE PERMIT REQUIREMENT	22	Deleted: 23
30A-5.2 CONNECTIONS	23	Deleted: 24
30A-5.3 CONTENTS	24	Deleted: 26
30A-5.4 MODIFICATION	26	Deleted: 27
30A-5.5 DURATION	27	Deleted: 27
30A-5.6 WASTEWATER DISCHARGE PERMIT APPEALS	27	Deleted: 27
30A-5.7 REVOCATION	28	Deleted: 28
SECTION 30A-6 - REPORTING REQUIREMENTS	29	Deleted: 29
30A-6.1 BASELINE MONITORING REPORTS (BMR)	29	Deleted: 29
30A-6.2 COMPLIANCE SCHEDULE PROGRESS REPORT	30	Deleted: 30
30A-6.3 CATEGORICAL PRETREATMENT STANDARD COMPLIANCE REPORT	30	Deleted: 30
30A-6.4 PERIODIC COMPLIANCE REPORT	31	Deleted: 31
30A-6.5 CHANGED CONDITIONS REPORT	31	Deleted: 31
30A-6.7 NONPERMITTED INDUSTRIAL USERS REPORTS	33	Deleted: 31
30A-6.8 REPEAT SAMPLING REPORT	33	Deleted: 33
		Deleted: 33

Exhibit A.

30A-6.9	HAZARDOUS WASTE DISCHARGE NOTIFICATION	33	Deleted: 33
30A-6.10	TIMING	34	Deleted: 34
30A-6.11	RECORD KEEPING	34	Deleted: 35
SECTION 30A-7 - COMPLIANCE MONITORING		35	Deleted: 35
30A-7.1	INSPECTION	35	Deleted: 35
30A-7.2	MONITORING	36	Deleted: 36
30A-7.3	OBSTRUCTIONS AND DELAYS	37	Deleted: 37
SECTION 30A-8 - CONFIDENTIAL INFORMATION		37	Deleted: 37
SECTION 30A-9 - ANNUAL PUBLICATION		38	Deleted: 38
30A-9.1	REQUIREMENT TO PUBLISH	38	Deleted: 38
30A-9.2	SIGNIFICANT NONCOMPLIANCE	38	Deleted: 39
SECTION 30A-10 - ADMINISTRATIVE ENFORCEMENT REMEDIES		39	Deleted: 39
30A-10.1	NOTIFICATION OF VIOLATION	39	Deleted: 40
30A-10.2	CONSENT ORDERS	40	Deleted: 40
30A-10.3	SHOW CAUSE HEARING	40	Deleted: 40
30A-10.4	COMPLIANCE ORDERS	40	Deleted: 41
30A-10.5	CEASE AND DESIST ORDERS	41	Deleted: 41
30A-10.6	ADMINISTRATIVE FINES	41	Deleted: 41
30A-10.7	EMERGENCY SUSPENSIONS	42	Deleted: 42
30A-10.8	TERMINATION OF DISCHARGE	43	Deleted: 43
SECTION 30A-11 - JUDICIAL ENFORCEMENT REMEDIES		43	Deleted: 43
30A-11.1	INJUNCTIVE RELIEF	43	Deleted: 43
30A-11.2	CIVIL FINE PASS THROUGH RECOVERY	44	Deleted: 44
30A-11.3	REFERRAL TO STATE OF UTAH FOR ACTION	44	Deleted: 44
30A-11.4	NONEXCLUSIVE REMEDIES	44	Deleted: 44
SECTION 30A-12 - SUPPLEMENTAL ENFORCEMENT ACTION		44	Deleted: 44
30A-12.1	PERFORMANCE BONDS	44	Deleted: 44
30A-12.2	LIABILITY INSURANCE	45	Deleted: 44
30A-12.3	WATER SUPPLY SEVERANCE	45	Deleted: 45
30A-12.4	PUBLIC NUISANCES	45	Deleted: 45
SECTION 30A-13 - AFFIRMATIVE DEFENSES		45	Formatted ... [1]
30A-13.1	UPSET	45	Deleted: 45
30A-13.2	GENERAL/SPECIFIC PROHIBITIONS	47	Deleted: 45
30A-13.3	BYPASS	47	Deleted: 45
SECTION 30A-14 - USER FEES		48	Deleted: 47
SECTION 30A-15 - MISCELLANEOUS PROVISIONS		48	Deleted: 47
30A-15.1	PRETREATMENT FEES	48	Deleted: 48
30A-15.2	SEVERABILITY	49	Deleted: 48
30A-15.3	CONFLICTS	49	Deleted: 48
SECTION 30A-16 - EFFECTIVE DATE		50	Deleted: 49
			Deleted: 49
			Deleted: 50
			Deleted: SECTION 30A-1 - ... [2]

SECTION 30A-1 - GENERAL PROVISIONS 1

30A-1.1 PURPOSE AND POLICY 1

30A-1.2 ADMINISTRATION 2

30A-1.3 DEFINITIONS 2

30A-1.4 ABBREVIATIONS 10

SECTION 30A-2 - GENERAL POTW USE REQUIREMENTS..... 11

30A-2.1 PROHIBITED DISCHARGE STANDARDS..... 11

30A-2.2 CATEGORICAL PRETREATMENT STANDARDS 14

30A-2.3 STATE PRETREATMENT REQUIREMENTS 14

30A-2.4 CCRWTF LOCAL LIMITS 14

30A-2.5 CEDAR CITY CORPORATION'S RIGHT OF REVISION..... 14

30A-2.6 SPECIAL AGREEMENT 15

30A-2.7 DILUTION..... 15

SECTION 30A-3 - PRETREATMENT OF WASTEWATER 15

30A-3.1 PRETREATMENT OPERATIONS 15

30A-3.2 SLUG LOAD CONTROL PLANS 18

30A-3.3 TENANT RESPONSIBILITY..... 19

30A-3.4 HAULED WASTEWATER 19

30A-3.5 VANDALISM..... 19

SECTION 30A-4 - WASTEWATER DISCHARGE PERMIT APPLICATION..... 20

30A-4.1 INDUSTRIAL WASTE SURVEY..... 20

30A-4.2 APPLICATION QUESTIONNAIRE CONTENTS..... 20

30A-4.3 CERTIFICATION 22

30A-4.4 GENERAL MANAGER EVALUATION..... 22

SECTION 30A-5 - WASTEWATER DISCHARGE PERMIT 22

30A-5.1 WASTEWATER DISCHARGE PERMIT REQUIREMENT 22

30A-5.2 CONNECTIONS 23

30A-5.3 CONTENTS 24

30A-5.4 MODIFICATION 26

30A-5.5 DURATION..... 27

30A-5.6 WASTEWATER DISCHARGE PERMIT APPEALS 27

30A-5.7 REVOCATION 28

SECTION 30A-6 - REPORTING REQUIREMENTS 29

30A-6.1 BASELINE MONITORING REPORTS (BMR) 29

30A-6.2 COMPLIANCE SCHEDULE PROGRESS REPORT 30

30A-6.3 CATEGORICAL PRETREATMENT STANDARD COMPLIANCE REPORT 30

30A-6.4 PERIODIC COMPLIANCE REPORT 31

30A-6.5 CHANGED CONDITIONS REPORT 31

30A-6.6 REPORT OF POTENTIAL PROBLEMERROR! BOOKMARK NOT DEFINED. 32

30A-6.7 NONPERMITTED INDUSTRIAL USERS REPORTS 33

30A-6.8 REPEAT SAMPLING REPORT 33

30A-6.9 HAZARDOUS WASTE DISCHARGE NOTIFICATION 33

30A-6.10 TIMING 34

30A-6.11 RECORD KEEPING 35

SECTION 30A-7 - COMPLIANCE MONITORING.....	35
30A-7.1 INSPECTION	35
30A-7.2 MONITORING	36
30A-7.3 OBSTRUCTIONS AND DELAYS	37
SECTION 30A-8 - CONFIDENTIAL INFORMATION	37
SECTION 30A-9 - ANNUAL PUBLICATION.....	38
30A-9.1 REQUIREMENT TO PUBLISH.....	38
30A-9.2 SIGNIFICANT NONCOMPLIANCE.....	38
SECTION 30A-10 - ADMINISTRATIVE ENFORCEMENT REMEDIES	39
30A-10.1 NOTIFICATION OF VIOLATION	39
30A-10.2 CONSENT ORDERS	40
30A-10.3 SHOW CAUSE HEARING	40
30A-10.4 COMPLIANCE ORDERS	40
30A-10.5 CEASE AND DESIST ORDERS	41
30A-10.6 ADMINISTRATIVE FINES	41
30A-10.7 EMERGENCY SUSPENSIONS.....	42
30A-10.8 TERMINATION OF DISCHARGE.....	43
SECTION 30A-11 - JUDICIAL ENFORCEMENT REMEDIES.....	43
30A-11.1 INJUNCTIVE RELIEF.....	43
30A-11.2 CIVIL FINE PASS THROUGH RECOVERY	44
30A-11.3 REFERRAL TO STATE OF UTAH FOR ACTION.....	44
30A-11.4 NONEXCLUSIVE REMEDIES	44
SECTION 30A-12 - SUPPLEMENTAL ENFORCEMENT ACTION.....	44
30A-12.1 PERFORMANCE BONDS	44
30A-12.2 LIABILITY INSURANCE	45
30A-12.3 WATER SUPPLY SEVERANCE	45
30A-12.4 PUBLIC NUISANCES	45
SECTION 30A-13 - AFFIRMATIVE DEFENSES.....	45
30A-13.1 UPSET.....	45
30A-13.2 GENERAL/SPECIFIC PROHIBITIONS	47
30A-13.3 BYPASS	47
SECTION 30A-14 - USER FEES.....	48
SECTION 30A-15 - MISCELLANEOUS PROVISIONS	48
30A-15.1 PRETREATMENT FEES	48
30A-15.2 SEVERABILITY	49
30A-15.3 CONFLICTS	49
SECTION 30A-16 - EFFECTIVE DATE.....	50

SECTION 30a-1 - GENERAL PROVISIONS

30a-1.1 Purpose and Policy

This ordinance sets forth uniform requirements for users of the Publicly Owned Treatment Works (POTW) for the Cedar City Regional Wastewater Treatment Facility (CCRWTF) of Cedar City Utah, and enables the CCRWTF to comply with all applicable State and Federal laws including the Clean Water Act (33 U.S.C. 1251 et seq.), the General Pretreatment Regulations found in the U.S. Code of Federal Regulations (CFR) 40 CFR Part 403, and the Utah Administrative Code R317-8-8. The objectives of this ordinance are:

- A. To prevent the introduction of pollutants into the POTW that will interfere with the operation of the POTW;
- B. To prevent the introduction of pollutants into the POTW which will pass through the POTW, inadequately treated, into receiving waters or otherwise be incompatible with the POTW;
- C. To ensure that the quality of the wastewater treatment plant sludge is maintained at a level which allows its use and disposal in compliance with applicable statutes and regulations found in 40 CFR Part 503;
- D. To protect POTW personnel who may be affected by wastewater and sludge in the course of their employment and to protect the general public;
- E. To improve the opportunity to recycle and reclaim wastewater and sludge from the POTW;
- F. To provide for fees for the equitable distribution of the cost of operation, maintenance and improvement of the POTW; and
- G. To enable the CCRWTF to comply with its Utah Pollution Discharge Elimination System Permit (UPDES) conditions, sludge use and disposal permit conditions and any other Federal or State laws to which the POTW is subject.

This ordinance shall apply to all users of the POTW. This ordinance authorizes issuance of wastewater discharge permits; authorizes monitoring, compliance and enforcement activities;

establishes administrative review procedures; requires industrial user reporting; and provides for the setting of fees for the equitable distribution of costs resulting from the program established herein.

30a-1.2 Administration

Except as otherwise provided herein, the General Manager of the Cedar City Regional Wastewater Treatment Facility (CCRWTF) shall administer, implement, and enforce the provisions of this ordinance. Any powers granted to or duties imposed upon the General Manager may be delegated by the General Manager to other CCRWTF personnel.

30a-1.3 Definitions

Unless a provision explicitly states otherwise, the following terms and phrases, as used in this ordinance, shall have the meanings hereinafter designated.

- A. Act. The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended, 33 U.S.C. 1251 et seq.
- B. Approval Authority. The Executive Secretary of the Water Quality Board as the authorized agent for the State of Utah, which has an approved State Pretreatment Program, or his designee.
- C. Authorized Representative of the Industrial User or Authorized Representative.
 - I. If the Industrial User is a corporation, Authorized Representative shall mean:
 - a. the president, secretary, treasurer, or a vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - b. the manager of one or more manufacturing, production, or operation facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiate and direct other comprehensive measures to assure long-term environmental compliance with

environmental laws and regulations; can ensure that the necessary systems are established or actions taken to gather complete and accurate information for individual wastewater discharge permit requirements; and employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second quarter 1980 dollars), if of which where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;

2. If the Industrial User is a partnership, or sole proprietorship, an Authorized Representative shall mean a general partner or proprietor, respectively;
 3. If the Industrial User is a Federal, State or local governmental facility, an Authorized Representative shall mean a director or highest official appointed or designated to oversee the operation and performance of the activities of the government facility, or his/her designee;
 4. The individuals described in paragraphs 1-3 above may designate another authorized Representative if the authorization is in writing, the authorization specifies the individual or position responsible for the overall operation of the facility from which the discharge originates or having overall responsibility for environmental matters for the company, and the written authorization is submitted to the CCRWTF.
- D. Biochemical Oxygen Demand (BOD). The quantity of oxygen utilized in the biochemical oxidation of organic matter under standard laboratory procedure, five (5) days at 20° centigrade expressed in terms of mass and concentration [milligrams per liter (mg/l)]. This test must be performed in accordance with approved procedures found in 40 CFR Part 136.
- E. Categorical Pretreatment Standard or Categorical Standard. Any regulation containing pollutant discharge limits promulgated by the U.S. EPA in accordance with Sections 307(b) and (c) of the Act (33 U.S.C. 1317) which apply to a specific category of industrial users and which appear in 40 CFR Chapter I, Subchapter N, Parts 405-471.
- F. Color. The optical density at the visual wave length of maximum absorption, relative to distilled water. One hundred percent (100%) transmittance is equivalent to zero (0.0) optical density.

- G. Composite Sample. The sample resulting from the combination of individual wastewater samples taken at selected intervals based on an increment of either flow or time, to minimize the effect or the variability of the individual samples. This sampling should be in accordance with 40 CFR Part 403 Appendix E Sub-part I - Composite Method.
- H. Environmental Protection Agency or EPA. The U.S. Environmental Protection Agency or, where appropriate, the term may also be used as a designation for the Regional Water Management Division Director or other duly authorized official of said agency.
- I. Existing Source. Any source of discharge, the construction or operation of which commenced prior to the publication of proposed categorical Pretreatment Standards which will be applicable to such source if the standard is thereafter promulgated in accordance with Section 307 of the Act.
- J. Food Establishment. Shall mean any location where a person or persons is/are primarily engaged in the activities of cooking, preparing, serving or otherwise making available for human consumption any form of food, and which uses one or more of the following cooking or preparation methods in connection with such activities: cooking or preparation by frying (all methods), baking (all methods), grilling, sautéing, rotisserie cooking, broiling (all methods), boiling, blanching, roasting, toasting, poaching, or any type of cooking or preparation that produces a hot non-potable product in or on a receptacle that requires washing, rinsing or other form of cleaning. Such establishments include, but are not limited to, restaurants, cafeterias, extended care facilities, juvenile, adult detention, and prisons, school cafeterias (public and private), and daycare facilities, (excluding private residential homes) where meals for more than (12) children are prepared, served or otherwise made available for human consumption on a daily basis.
- K. Governing Authority (CCRWTF Board). The Cedar City Regional Wastewater Treatment Facility Board is comprised of seven members, one which shall be the Cedar City Engineer, one which shall be the regional wastewater treatment plant Director, five of which shall be representatives from each of the Communities as follows: one (1) elected official from Cedar City, two (2) (one shall be an elected official) from Enoch, two (2) from the County (one shall be an elected official).
- L. Grab Sample. A sample which is taken from a waste stream on a one-time basis, not to exceed 15 minutes or less, without regard to the flow in the waste stream and without consideration of time. This sampling should be in accordance with 40 CFR Part 403 Appendix E Sub-part II - Grab Method.

- M. Grease, Oil, and Sand Interceptor. "Grease Interceptor" shall mean a device for separating and retaining waterborne fats, oil, and greases before the wastewater, which contains such grease, exits the grease interceptor into the city's wastewater collection system or POTW. The grease interceptor also collects settleable solids generated by or incidental to commercial, industrial and food preparation activities. The Grease Interceptor shall at a minimum be equipped with a two-cell construction and be constructed of impervious materials capable of withstanding abrupt and extreme changes in temperature. The interceptor shall be of substantial construction, water tight and equipped with easily removable covers which, when bolted in place, shall be gas and water tight.
- N. Oil/Water Separator. Shall mean an approved and industry standard system that is specifically designed for the removal of free oils (hydrocarbons and other petroleum products), and settleable oily coated solids from oil/water discharges associated with many types of industrial facilities. The source of the influent to the separator shall be gravity flow from storm water runoff, hydrocarbon spills, and/or cleaning/maintenance operations. The system shall allow the oil to be collected and removed on a regular basis as to prevent it from being discharged into the wastewater collection system. Only oil/water separators manufactured for that specific operation will be approved. Adequate support literature from the manufacturer will be required so as to allow a proper review by the CCRWTF.
- ~~Q. Grease Trap. Shall mean a device for separating and retaining waterborne fats, oil, and greases, it shall be installed under a sink as an accessory to an operating certified Grease Interceptor. The installation of grease traps on all new source commercial or industrial establishments, in lieu of the installation of a certified grease interceptor, will be strictly prohibited under any circumstances.~~
- P. Indirect Discharge (Discharge). The introduction of pollutants into the POTW from any non-domestic source. Regulated under section (a), (b), and (c) of the Act.
- Q. Industrial User (User). A source of Indirect Discharge.
- R. Instantaneous Maximum Allowable Discharge Limit. The maximum concentration (or loading) of a pollutant allowed to be discharged at any time, determined from the analysis of any grab or composite sample collected, independent of the industrial flow rate and the duration of the sampling event.

- S. Interference. A Discharge which, alone or in conjunction with a Discharge or Discharges from other sources both: 1) inhibits or disrupts the POTW, treatment processes or operations, or its sludge processes, use or disposal and 2) causes a violation of any of the CCRWTF's UPDES permit conditions or prevents sewage sludge use or disposal in compliance with any of the following statutory/state or local regulations: Section 405 of the Clean Water Act; the Solid Waste Disposal Act (SWDA), including Title II commonly referred to as the Resource Conservation and Recovery Act (RCRA); 40 CFR Part 503 governing the use and disposal of sewage sludge; the Clean Air Act; the Toxic Substances Control Act; and the Marine Protection, Research and Sanctuaries Act.
- T. Medical Waste. Isolation wastes, infectious agents, human blood and blood byproducts, pathological wastes, body parts, fomites, etiologic agents, contaminated bedding, surgical wastes, potentially contaminated laboratory wastes and dialysis wastes.
- U. New Source.
- I. Any building, structure, facility or installation from which there is or may be a discharge of pollutants, the construction of which commenced after the publication of proposed Pretreatment Standards under Section 307(c) of the Act which will be applicable to such source if such standards are thereafter promulgated in accordance with that section, provided that:
 - a. The building, structure, facility or installation is constructed at a site at which no other source is located; or
 - b. The building, structure, facility or installation totally replaces the process or production equipment that causes the discharge of pollutants at an existing source; or
 - c. The production or wastewater generating processes of the building, structure, facility or installation are substantially independent of an Existing Source at the same site. In determining whether these are substantially independent, factors such as the extent to which the new facility is integrated with the existing plant, and the extent to which the new facility is engaged in the same general type of activity as the existing source, should be considered.

2. Construction on a site at which an Existing Source is located results in a modification rather than a new source if the construction does not create a new building, structure, facility or installation meeting the criteria of Section (1)(b) or (c) above but otherwise alters, replaces, or adds to existing process or production equipment.
3. Construction of a new source as defined under this section has commenced if the owner or operator has:
 - a. begun, or caused to begin as part of a continuous on site construction program.
 - i. Any placement, assembly, or installation of facilities or equipment; or
 - ii. Significant site preparation work including clearing, excavation, or removal of existing buildings, structures, or facilities which is necessary for the placement, assembly, or installation of new source facilities or equipment; or
 - b. Entered into a binding contractual obligation for the purchase of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph.
- V. Non-contact Cooling Water. Water used for cooling which does not come into direct contact with any raw material, intermediate product, waste product, or finished product.
- W. Non-Domestic Wastewater. Any wastewater that is not produced as sanitary wastewater from restroom facilities, showers, or kitchens.
- ~~X. Pass Through. A discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the CCRWTF's UPDES permit (including an increase in the magnitude or duration of a violation).~~
- Y. Person. Any individual, partnership, copartnership, firm, company, corporation, association, joint stock company, trust, estate, governmental

Deleted: ¶

entity or any other legal entity, or their legal representatives, agents or assigns. This definition includes all Federal, State or local governmental entities.

- Z. pH. A measure of the acidity or alkalinity of a substance, expressed in standard units.
- AA. Pollutant. Any dredged spoil, solid waste, filter backwash, incinerator residue, sewage, garbage, sewage sludge, munitions, medical wastes, chemical wastes, industrial wastes, biological materials, radioactive materials, heat, wrecked or discharged equipment, rock, sand, cellar dirt, agricultural and industrial wastes, and the characteristics of the wastewater [i.e., pH, temperature, TSS, turbidity, color, BOD, Chemical Oxygen Demand, toxicity, odor].
- BB. Pretreatment. The reduction of the amount of Pollutants, the elimination of Pollutants, or the alteration of the nature of Pollutant properties in wastewater prior to or in lieu of introducing such pollutants into the POTW. The reduction or alteration may be obtained by physical, chemical or biological processes, process changes, or any other means, except as prohibited by 403.6 (d). Appropriate pretreatment technology includes control equipment, such as equalization tanks or facilities, for protection against surges or slug loadings that might interfere with or otherwise be incompatible with the POTW. However, where wastewater from a regulated process is mixed in an equalization facility with unregulated process, the effluent from the equalization facility must meet an adjusted pretreatment limit calculated in accordance with 403.6 (e).
- CC. Pretreatment Requirements: Any substantive or procedural requirement related to Pretreatment imposed on an Industrial User, other than a National Pretreatment Standard.
- DD. Pretreatment Standards or Standards. Pretreatment Standards shall mean prohibited discharge standards, categorical Pretreatment Standards, and Local Limits established by the CCRWTF.
- EE. Prohibited Discharge Standards or Prohibited Discharges. Absolute prohibitions against the discharge of certain substances or wastewater characteristics; these prohibitions appear in Section 30a-2.1 of this ordinance.
- FF. Publicly Owned Treatment Works (POTW). A treatment works which is owned by the State, a municipality, or other political subdivision of the State. This definition includes any devices or systems used in the collection,

Deleted: Pretreatment Standards shall mean Categorical Pretreatment Standards, State Pretreatment requirements, and Local Limits established by the CCRWTF

storage, treatment, recycling and reclamation of municipal/domestic sewage or industrial wastes of a liquid nature discharged into the stated system. Also included are any conveyances, such as pipelines, conduits or channels which convey wastewater to a treatment plant. The term also means the municipal entity having jurisdiction over the Indirect Dischargers to such a system and the discharges from the treatment works.

- GG. Septic Tank Waste. Any sewage from holding tanks such as vessels, chemical toilets, campers, trailers, and septic tanks.
- HH. Sewage. Human excrement and gray water (household showers, dish washing operations, etc).
- II. Significant Industrial User. Shall apply to: a) Industrial Users subject to Categorical Pretreatment Standards; and b) any other Industrial User that i) discharges an average of 25,000 gpd or more of process wastewater(excludes sanitary, Non-contact cooling and boiler blow-down wastewater, ii) contributes a process waste stream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the treatment Plant or, iii) is designated as significant by the CCRWTF on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standard or requirement.
- JJ. Slug Load/Discharge. Any discharge at a flow rate or concentration which could cause a violation of the Prohibited Discharge Standards in Section 2 of this Ordinance. A slug discharge is any discharge of a non-routine, episodic nature, including but not limited to, an accidental spill or a non-customary batch discharge, which has a reasonable potential to cause Interference or Pass Through, or in any other way violate the POTW's regulations, local limits or permit conditions.
- KK. Standard Industrial Classification (SIC) Code. A classification pursuant to the Standard Industrial Classification Manual issued by the U.S. Office of Management and Budget.
- LL. Storm Water. Any flow which occurs during, or following any form of natural precipitation, and results from such an event, including snow melt.
- MM. General Manager. The person designated by the CCRWTF to supervise the operation of the POTW, and who is charged with certain duties and responsibilities by this ordinance or his duly authorized representative.

- NN. Total Suspended Solids (TSS). The total suspended matter that floats on the surface of, or is suspended in, water, wastewater, or other liquid, and which is removable by laboratory filtering.
- OO. Toxic Pollutant. One of 126 pollutants, or combination of those pollutants, listed as toxic in regulations promulgated by the EPA under the provision of Section 307 (33 U.S.C. 1317) of the Act.
- PP. Treatment plant effluent. Any discharge from the POTW into waters of the State of Utah.
- QQ. Wastewater. Liquid and water-carried industrial wastes, and sewage from residential dwellings, commercial buildings, industrial and manufacturing facilities, and institutions, whether treated or untreated, which are contributed to the POTW.
- RR. Wastewater Treatment Plant or Treatment Plant. That portion of the POTW designed to provide treatment including recycling and reclamation of sewage and industrial waste.

Shall is mandatory; may is permissive or discretionary. The use of the singular shall be construed to include the plural and the plural shall include the singular as indicated by the context of its use.

30a-1.4 Abbreviations

The following abbreviations shall have the designated meanings. Some of the abbreviations are included in the definition section but are repeated here for the sake of clarity.

- BMR - Baseline Monitoring Report
- BOD - Biochemical Oxygen Demand
- CIU - Categorical Industrial User
- CFR - Code of Federal Regulations
- COD - Chemical Oxygen Demand
- CWA - Clean Water Act (P.L. 95-217 as amended)
- EPA - U.S. Environmental Protection Agency
- GPD - Gallons Per Day
- L - Liter
- MGD - Million Gallons per day
- mg - Milligrams
- mg/l - Milligrams Per Liter
- NPDES - National Pollutant Discharge Elimination System or the Utah Pollutant Discharge Elimination System

- O&M - Operation and Maintenance
- OSHA - Occupational Safety and Health Administration
- POTW - Publicly Owned Treatment Works
- RCRA - Resource Conservation and Recovery Act
- SIC - Standard Industrial Classification
- SWDA - Solid Waste Disposal Act (42 U.S.C. 6901, et seq.)
- TSS - Total Suspended Solids
- UPC - Unified Plumbing Code
- USC - United States Code

SECTION 30a-2 - GENERAL POTW USE REQUIREMENTS

30a-2.1 Prohibited Discharge Standards

A. General prohibitions. No industrial user shall introduce or cause to be introduced into the POTW any pollutant or wastewater which has a reasonable potential to cause pass through or interference, or in any other way violate the POTW's regulations, local limits or Permit conditions. These general prohibitions apply to all users of the POTW whether or not the source is subject to categorical Pretreatment Standards or any other National, State or local Pretreatment Standards or requirement.

Deleted:

B. Specific Prohibitions. No User shall introduce or cause to be introduced into the POTW the following pollutants, substances, or wastewater:

1. Pollutants which create a fire or explosive hazard in the POTW system, including, but not limited to waste streams with a closed-cup flash-point of less than 140°F (60°C) using the test methods specified in 40 CFR 261.21. At no time shall two readings on an explosion hazard meter at the point of discharge into the POTW, or at any point in the POTW, be more than 16% nor any single reading over 16% of the lower explosive limit (LEL) of the meter.
2. Any pollutants which will cause, but in no case discharges with a pH of less than 6.0 or more than 12.0, corrosive structural damage to the POTW or equipment, or endangering CCRWTF personnel.

3. Solid or viscous substances which will or may cause obstruction to the flow in a sewer or other interference with the operation of the wastewater treatment facilities such as, but not limited to: grease, garbage with particles greater than one-quarter inch (1/4") in any dimension, animal guts or tissues, paunch manure, bones, hair, hides, fleshings, entrails, whole blood, feathers, ashes, cinders, sand, spent lime, stone or marble dust, metal, straw, shavings, grass clippings, rags, spent grains, spent hops waste, paper, wood, plastic, gas, tar, asphalt residues, residues from refining or processing of fuel or lubricating oil, mud, glass grinding, or polishing wastes.
4. Any pollutants, including oxygen demanding pollutants (BOD, etc.) released in a single extraordinary discharge episode of such volume or strength as to cause interference to the POTW.
5. Any wastewater having a temperature greater than 140°F (40°C), or which will inhibit biological activity in the treatment plant resulting in interference, but in no case heat in such quantity that it causes the temperature at the treatment plant to exceed 140°F (40°C).
6. Any petroleum oil, non-biodegradable cutting oil or products of mineral oil origin in amounts which causes interference or pass-through.
7. Any wastewater which causes a hazard to human life or creates a public nuisance in the opinion of the POTW. This includes any pollutants which result in the presence of toxic gases, vapors or fumes within the POTW in a quantity that may cause acute or chronic worker health or safety problems.
8. Any trucked or hauled pollutants, except at discharge points designated by the CCRWTF in accordance with Section 30a-3.4 of this Ordinance.
9. Any noxious or malodorous liquids, gases, solids, or other wastewater which, either singly or by interaction with other wastes, are capable of creating a public nuisance or a hazard to life or are sufficient to prevent entry into the sewers for their maintenance and repair.
10. Any wastewater which imparts color which cannot be removed by the treatment process, such as, but not limited to, dye wastes and vegetable tanning solutions, which consequently imparts color to the treatment plant's effluent thereby violating the CCRWTF's UPDES

permit. Color (in combination with turbidity) shall not cause the treatment plant effluent to reduce the depth of the compensation point for photosynthetic activity by more than 10 percent from the seasonably established norm for aquatic life.

11. Any wastewater containing any radioactive wastes or isotopes except as specifically approved by the General Manager in compliance with applicable State or Federal regulations.
12. Storm water, surface water, ground water, artisan well water, roof runoff, subsurface drainage, swimming pool drainage, condensate, deionized water, Non-contact cooling water, and unpolluted industrial wastewater, unless specifically authorized by General Manager.
13. Any sludges, screening, or other residues from the pretreatment of industrial wastes.
14. Any medical wastes, except as specifically authorized by General Manager in a wastewater discharge permit.
15. Any wastewater causing the treatment plant effluent to fail a toxicity test.
16. Any wastes containing detergents, surface active agents, or other substances which may cause excessive foaming in the POTW.
17. Any wastes containing emulsifiers, enzymes, or bacteria for the specific purpose of eliminating solids and sludges from oil, grease, or sand separators.
18. Any discharge of fats, oils, or greases of animal or vegetable origin is limited to 100 mg/l.

Pollutants prohibited by this section shall not be processed or stored in such a manner that they could be discharged to the POTW. All floor drains located in process or materials storage areas must discharge to the industrial user's pretreatment facility before connecting with the POTW. If the industrial user storing the specified pollutant does not have a pretreatment facility, the floor drain shall be either plugged with concrete or valved. The valve shall be locked closed at all times and opened only with permission from the CCRWTF.

30a-2.2 Categorical Pretreatment Standards

The national categorical Pretreatment Standards found at 40 CFR Chapter I, Subchapter N, Parts 405-471 are hereby incorporated. When wastewater subject to a categorical Pretreatment Standard is mixed with wastewater not regulated by the same Standard, the Control Authority or the Industrial User with the written concurrence of the Control Authority shall impose an alternate limit in accordance with 40 CFR 403.6(e).

30a-2.3 State Pretreatment Requirements

State of Utah Pretreatment Standards contained in the Utah Administrative Code R317-8-8 are hereby incorporated.

30a-2.4 CCRWTF Local Limits

The Superintendent, and/or General Manager is authorized to establish Local Limits pursuant to 40 CFR 403.5(c). The pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing in excess of the limits as established and amended from time to time, and set forth in Section 4 of the Pretreatment Program.

Local limits apply at the point where the indirect discharge is introduced to the POTW before mixing with other wastewaters. All concentrations for metallic substances are for "total" metal unless indicated otherwise. In addition to, or in place of, concentration based limitations, the General Manager may impose mass limitations.

30a-2.5 Cedar City Corporation's Right of Revision

Cedar City Corporation reserves the right to establish, by ordinance or in wastewater discharge permits, more stringent standards or requirements on discharges to the POTW if deemed necessary to comply with the objectives presented in Section 30a-1.1 of this ordinance or the general and specific prohibitions in Section 30a-2.1 of this ordinance.

30a-2.6 Special Agreement

The CCRWTF reserves the right to enter into special agreements with industrial users setting out special terms under which they may discharge to the POTW. In no case will a special agreement waive compliance with a Pretreatment Standard or requirement. However, the industrial user may request a net gross adjustment of a categorical standard in accordance

with 40 CFR 403.15. They may also request, from EPA, a variance from the categorical Pretreatment Standard. Such a request will be approved only if the industrial user can prove that factors relating to its discharge are fundamentally different from the factors considered by EPA when establishing that particular Pretreatment Standard. An industrial user requesting a variance must comply with the procedural and substantive provisions in 40 CFR 403.13.

30a-2.7 Dilution

No industrial user shall increase the use of process water, or in any way attempt to dilute a discharge, as a partial or complete substitute for adequate treatment to achieve compliance with a discharge limitation unless expressly authorized by an applicable Pretreatment Standard or requirement. The General Manager may impose mass limitations on industrial users which are using dilution to meet applicable Pretreatment Standards or requirements, or in other cases when the imposition of mass limitations is appropriate.

SECTION 30a-3 - PRETREATMENT OF WASTEWATER

30a-3.1 Pretreatment Operations

- A. Industrial users shall provide wastewater treatment as needed to comply with this ordinance, and shall achieve compliance with all the prohibitions stated in Section 30a within the time limitations specified by the EPA, the State, or according to compliance schedules as specified by the General Manager -- whichever is more stringent. Any facilities necessary for compliance shall be provided, operated, and maintained at the industrial user's expense. Detailed plans showing the pretreatment facilities and operating procedures shall be submitted to the CCRWTF for review, and shall be acceptable to the CCRWTF before construction of the facility. The review of such plans and operating procedures shall in no way relieve the industrial user from the responsibility of modifying the facility as necessary to produce an acceptable discharge to the CCRWTF under the provisions of this ordinance.
- B. The General Manager may require industrial users to restrict their discharge during peak flow periods, designate certain wastewater be discharged only into specific sewers, relocate and/or consolidate points of discharge, separate municipal waste streams from industrial waste streams, and such other conditions as may be necessary to protect the POTW and secure the industrial user's compliance with the requirements of this ordinance.

- C. Grease, oil and sand interceptors, and or oil/water separators such as described by the International Plumbing Code, shall be provided when, in the opinion of the General Manager, they are necessary for the proper handling of wastewater containing liquid waste, floatable grease and oil, sand, or any flammable wastes; except that such interceptors shall not be required for, private living quarters, or dwelling units. All interceptor units shall be of type and capacity approved by the General Manager and shall be located as to be readily accessible for cleaning and inspection. In maintaining the interceptor, and/or oil/water separator the owner or any other person as a tenant under any rental or lease agreement set forth by the owner, shall be responsible for the proper removal and disposal by appropriate means of the captured material and shall maintain records of the dates and means of disposal, which are subject to review by the General Manager. Either or both parties may be held responsible for compliance with the provisions of this ordinance. A currently licensed waste disposal firm must perform any removal, and hauling of the collected material. Such interceptors shall be inspected and cleaned regularly at the owner's expense.
- D. All grease, oil and sand interceptors, and/or oil/water separators shall be constructed of impervious materials capable of withstanding abrupt and extreme changes in temperature. They shall be of substantial construction, water tight and equipped with easily removable covers which, when bolted in place, shall be gas and water tight.
- E. The installation of grease traps on all new source commercial or industrial establishments, in lieu of the installation of a certified grease interceptor, will be strictly prohibited under any circumstances.
- F. All new source commercial structures, strip malls, multi-tenant planned-occupied, or planned-un-occupied buildings will be required to install independent 6-inch wastewater discharge lines stubbed out within each designated future food establishment unit.

If a new source commercial structure, strip mall, or multi-tenant building has planned occupancy by one or more businesses approved through the General Manager to not need a grease interceptor and the owner of such strip mall, or multi-tenant structure does not facilitate the installation of independent 6-inch wastewater discharge lines then no future food establishments shall be permitted.

Independent unit discharge lines will have designation to future grease interceptor location of which will be sized, and/or verified by the General Manager. The Grease Interceptor shall be sized depending on future tenant

occupancy of the strip mall, and/or multi-tenant occupied building. Sizing of grease interceptor will be based on type of business, food establishment, etc.

- G. Regardless of the sizing method used, design shall comply with the effluent temperature range. The calculations for future grease interceptor capacity will be based on available tenant space, and/or flow through retention time. All related outsourced grease interceptor calculations are subject to review and approval by the General Manager, who will have the final decision on pumping frequency for all existing, and new source grease, oil, and sand interceptors. All 6-inch lines will be placed according to the engineering calculations, which will be sized and/or verified by the General Manager.
- H. Where a new source strip mall, multi-tenant building is planned-un-occupied, and the owner of such strip mall, or multi-tenant structure does not facilitate the installation of independent 6-inch wastewater lines to be designated for future food establishments, then no future food establishments shall be permitted.
- I. For existing commercial kitchens without grease traps or interceptors, the General Manager may require the installation of a new grease, oil, and sand interceptor that fully complies with this ordinance, or to modify, replace, or repair any noncompliant plumbing or existing grease trap or interceptor upon notice to the food establishment, and (or) commercial kitchen facility that one (1) or more of the following conditions exist:
- (1) The facility is found to be contributing fats, oils or grease in quantities sufficient to cause sewer line stoppages or to necessitate increased maintenance on the wastewater collection system; or
 - (2) Changes are made to the menu or kitchen equipment that, in the opinion of the General Manager, threatens to contribute fats, oils, or grease in quantities sufficient to cause line stoppages or necessitate increased maintenance on the wastewater collection system.
- J. Grease interceptors shall be required of all new source commercial or industrial establishments upon construction where deemed necessary. Any existing food establishment will be reviewed to determine if existing mechanical, building, plumbing and electrical systems will require upgrading. Any new kitchen, which shall meet the definition of a "food establishment", shall meet all the mechanical, building, plumbing and electrical requirements for a commercial kitchen.

- K. All existing commercial or industrial establishments shall have one year upon notification from the CCRWTF to install a grease interceptor where required.
- L. Industrial users with the potential to discharge flammable substances may be required to install and maintain an approved combustible gas detection meter.
- M. At no time shall two readings on an explosion hazard meter at the point of discharge into the POTW, or at any point in the POTW, be more than 10% nor any single reading over 20% of the lower explosive limit (LEL) of the meter.

30a-3.2 Slug Load Control Plans

The General Manager may require any industrial user to develop and implement a slug control plan. At least once every two years the General Manager shall evaluate whether each significant industrial user needs such a plan. Any industrial user required to develop and implement a slug control plan shall submit a plan which addresses, at a minimum, the following:

- A. Description of discharge practices, including non-routine batch discharges.
- B. Type and quantity of stored chemicals.
- C. Procedures for immediately notifying the POTW of any accidental or slug discharge. Such notification must also be given for any discharge which could violate any of the Prohibited Discharge Standards in Section 30a-2 of this ordinance.
- D. Procedures to prevent adverse impact from any accidental or slug discharge. Such procedures include, but are not limited to,
 - Inspection and maintenance of storage areas,
 - Handling and transfer of materials, loading and unloading operations,
 - Control of plant site run-off,
 - Worker training,
 - Building of containment structures or equipment,
 - Measures for containing toxic organic pollutants (including solvents), and/or
 - Measures and equipment for emergency response.

30a-3.3 **Tenant Responsibility**

Where an owner of property leases premises to any other person as a tenant under any rental or lease agreement, if either the owner or the tenant is an industrial, and/or commercial user as determined by the General Manager, either or both may be held responsible for compliance with the provisions of this ordinance. It shall be the duty of every property owner, and/or person as a tenant under any rental or lease agreement whom contracts, and/or performs work for the installation or repair of building, structure, mechanical or plumbing systems, for which this ordinance is applicable, to comply with this ordinance and to ensure all subcontracts under them also comply with this ordinance to include obtaining the required permits and ensuring the required inspections are completed.

30a-3.4 **Hauled Wastewater**

- A. Septic tank waste may be accepted into the POTW at a designated receiving structure within the treatment plant area, and at such times as are established by the General Manager, provided such wastes do not violate Section 30a-2 of this ordinance or any other requirements established or adopted by the CCRWTF. Wastewater discharge permits for individual vehicles to use such facilities shall be issued by the General Manager.
- B. The discharge of hauled industrial wastes as "industrial septage" requires prior approval and a hauler wastewater discharge permit from the CCRWTF. The General Manager shall have authority to prohibit the disposal of such wastes, if such disposal would interfere with the treatment plant operation or violate Section 30a-2 of this ordinance. Waste haulers are subject to all other sections of this ordinance.
- C. Fees for dumping septage will be established as part of the industrial user fee system as authorized in Section 30a-15 of this ordinance.

30a-3.5 **Vandalism**

No person shall maliciously, wilfully or negligently break, damage, destroy, uncover, deface, tamper with or prevent access to any structure, appurtenance or equipment, or other part of the POTW. Any person found in violation of this requirement shall be subject to the sanctions set out in Sections 30a-10 thru 30a-12 of this ordinance.

SECTION 30a-4 - WASTEWATER DISCHARGE PERMIT APPLICATION

30a-4.1 Industrial Waste Survey

When requested the by General Manager any or all industrial users must submit information on the nature and characteristics of their wastewater by completing a questionnaire and a baseline monitoring report prior to commencing discharge. The questionnaire and BMR will include the information as stated in section 4.2 and additional information as needed to determine compliance with this ordinance and any applicable Pretreatment Standards. The General Manager is authorized to prepare a form(s) (see Part 3A of Pretreatment Program) for this purpose and may periodically require industrial users to update the survey or baseline monitoring report. Failure to complete this application questionnaire and return to the CCRWTF within (90) days of the request shall be reasonable grounds for IU permit revocation or terminating service to the industrial user and shall be considered a violation of the ordinance.

30a-4.2 Application Questionnaire Contents

The General Manager shall approve a form to be used as a permit application. In order to be considered for a wastewater discharge permit, all industrial users required to have a wastewater discharge permit must submit the following information:

- A. Identifying Information: The name and address of the facility including the name of the operator and owners.
- B. Hours of Operation: Number and type of employees, hours of operation, either proposed or actual hours.
- C. Permits: A list of any environmental control permits held by or for the facility.
- D. Description of Operations: A description of the activities, facilities and processes on the premises, average rate of production, and standard industrial Classifications of the operation(s) carried out by the industrial user. This description should include a schematic process diagram which indicates all points of discharge to the POTW from the regulated processes.
- E. Facility Plans: The site plans, floor plans, mechanical and plumbing plans, and details to show all sewers, floor drains, and appurtenances by size, location, and elevation, and all points of discharge.

- F. Raw Materials: Type and amount of raw materials processes (average and maximum per day) and chemicals used or stored at the facility.
- G. Products: Each product produced by type, amount, process or processes, and rate of production.
- H. Pretreatment Standards: Identify the categorical Pretreatment Standards applicable to each regulated process.
- I. Pollutants: Submit the results of sampling and analysis identifying the nature and concentration (and/or mass, where required by the standard or by the CCRWTF) of regulated pollutants in the discharge from each regulated process. Instantaneous, daily maximum and long term average concentration (or mass, where required) shall be reported. The sample shall be representative of daily operations and shall be sampled and analyzed in accordance with procedures set out in Section 30a-6.
- J. Flow Measurement: Time, duration and quantity of discharge. In addition, measured average daily and maximum daily flow, in gallons per day, to the POTW from each waste stream, as necessary to allow use of the combined waste stream formula set out in 40 CFR 403.6(e).
- K. Certification: A statement reviewed by the industrial user's authorized representative and certified by a qualified professional, indicating whether Pretreatment Standards are being met on a consistent basis in accordance with section 30a-4.3 below. If not, state whether additional O & M and/or additional pretreatment is required to meet the Pretreatment Standards and requirements.
- L. Compliance Schedule. If additional pretreatment and/or O&M will be required to meet the Pretreatment Standards; the shortest schedule by which the industrial user will provide such additional pretreatment and/or O&M. The completion date in this schedule shall not be later than the compliance date established for the applicable Pretreatment Standard.
- M. Additional Information: Any other information as may be deemed necessary by the General Manager to evaluate the wastewater discharge permit application.

Incomplete or inaccurate applications will not be processed and shall be returned to the industrial user for revision. Should any of the information requested or supplied be considered by the industrial user to be of a confidential nature, the industrial user should request confidential status in accordance with Section 30a-8 of this Ordinance.

30a-4.3 Certification

All wastewater discharge permit applications, user reports, and/or Non Permitted Industrial Users Reports shall contain the following certification statement and be signed by an authorized representative of the user.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or people who manage the system, or those people directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

30a-4.4 General Manager Evaluation

The General Manager will evaluate the data furnished by the industrial user and may require additional information. Within Thirty (30) days of receipt of a complete wastewater discharge permit application, the General Manager will determine whether or not to issue a wastewater discharge permit. The General Manager may deny for cause any application for a wastewater discharge permit. The basis for denial shall be provided to the industrial user.

SECTION 30a-5 - WASTEWATER DISCHARGE PERMIT

30a-5.1 Wastewater Discharge Permit Requirement

- A. It shall be unlawful for any significant industrial user to discharge wastewater into the CCRWTF's POTW without first obtaining a wastewater discharge permit from the General Manager. Any violation of the terms and conditions of a wastewater discharge permit shall be deemed a violation of this ordinance and subjects the wastewater discharge permittee to the sanctions set out in Sections 30a-10 thru 30a-12. Obtaining a wastewater discharge permit does not relieve a permittee of its obligation to comply with all Federal and State Pretreatment Standards or requirements nor with any other requirements of Federal, State or local law.

- B. Within either 180 days after the effective date of a categorical Pretreatment Standard, or the final administrative decision on a categorical determination under 40 CFR 403.6(a)(4), whichever is later, existing significant industrial users subject to such categorical Pretreatment Standards, and currently discharging to or scheduled to discharge to the POTW, shall be required to obtain a wastewater discharge permit.
- C. At least ninety (90) days prior to commencement of their discharge, new sources, and sources that become categorical or significant industrial users subsequent to the issuance of this Ordinance, shall be required to submit to the CCRWTF an application for a wastewater discharge permit. A new source shall also be required to report the method of pretreatment it intends to use to meet applicable Pretreatment Standards. A new source shall also give estimates of its anticipated flow and quantity of pollutants discharged.
- D. The General Manager may require other industrial users, including liquid waste haulers, to obtain wastewater discharge permits as necessary to carry out the purposes of this ordinance.

30a-5.2

Connections

- A. Existing: Any significant industrial user which has an indirect discharge into the POTW prior to the effective date of this ordinance and who wishes to continue such discharges in the future, shall, within 60 days after said date, apply to the CCRWTF for a wastewater discharge permit in accordance with Sections 30a-4.2 and 30a-4.3, and shall not cause or allow discharges to the POTW to continue after 30 days of the effective date of this ordinance, except in accordance with a wastewater discharge permit issued by the General Manager.
- B. New: Any significant industrial user proposing to begin or recommence discharging industrial wastes into the POTW must obtain a wastewater discharge permit prior to the beginning or recommencing of such discharge. An application for this wastewater discharge permit must be filed at least 90 days prior to the date upon which any discharge will begin. The CCRWTF has the right to place conditions on new or increased contributions from existing users.
- C. Extra-jurisdictional
 - I. Any existing significant industrial user located outside the CCRWTF boundaries shall submit a wastewater discharge permit application, in accordance with Sections 30a-4.2 and 30a-4.3, within 60 days of the effective date of this ordinance. New significant industrial users

located beyond the CCRWTF limits shall submit such applications to the General Manager 90 days prior to any proposed discharge into the POTW.

2. Alternately, the General Manager may enter into an agreement with the neighboring jurisdiction in which the significant industrial user is located to provide for the implementation and enforcement of pretreatment program requirements against said industrial user.

30a-5.3 Contents

Wastewater discharge permits shall include such conditions as are reasonably deemed necessary by the General Manager to prevent pass through or interference, protect the quality of the water body receiving the treatment plant's effluent, protect worker health and safety, facilitate sludge management and disposal, protect ambient air quality, and protect against damage to the POTW.

- A. Wastewater discharge permits shall contain the following conditions:
 1. A statement that indicates wastewater discharge permit duration, which in no event shall exceed 5 years.
 2. A statement that the wastewater discharge permit is nontransferable without prior notification to and approval from the CCRWTF, and provisions for furnishing the new owner or operator with a copy of the existing wastewater discharge permit.
 3. Effluent limits, including Best Management Practices, based on applicable general Pretreatment Standards in part 403 of the Code of Federal Regulations, categorical Pretreatment Standards, local limits, and State and local law.
 4. Self monitoring, sampling, reporting criteria, notification of potential problems and noncompliance, and record keeping and retention requirements. These requirements shall include an identification of pollutants to be monitored, exact sampling location, sampling frequency, re-sampling conditions and sample type based on Federal, State, and local law.
 5. Statement of applicable civil, criminal, and administrative penalties for violation of Pretreatment Standards and requirements, and any applicable compliance schedule. Such schedule may not extend the

Deleted: applicable to the user, based on applicable Federal, State, and local law

time for compliance beyond that required by applicable Federal, State, or local law.

6. A statement that the wastewater discharge permit may be revoked upon violation of the terms and conditions of the permit as stated in section 30a-5.7 of this ordinance.
7. A statement that grants the General Manager the right of entry into all industrial user properties, facilities, buildings, etc. when wastewater is known or expected to be generated and/or discharged.
8. A statement that compliance with the wastewater discharge permit does not relieve the permittee of responsibility for compliance with all applicable Federal and State Pretreatment Standards, including those which become effective during the term of the wastewater discharge permit.
9. Requirements to control Slug Discharge, if determined by the Control Authority or the Industrial User with the written concurrence of the Control Authority, to be necessary

Formatted

Deleted: Superintendent

Formatted

B. Wastewater discharge permits may contain, but need not be limited to, the following:

1. Limits on the average and/or maximum rate of discharge, time of discharge, and/or requirements for flow regulation and equalization.
2. Limits on the instantaneous, daily and monthly average and/or maximum concentration, mass, or other measure of identified wastewater pollutants or properties.
3. A compliance schedule for the installation of pretreatment technology, pollution control, or construction of appropriate containment devices, designed to reduce, eliminate, or prevent the introduction of pollutants into the treatment works.
4. Development and implementation of spill control plans or other special conditions including management practices necessary to adequately prevent accidental, unanticipated, or routine discharges.
5. Development and implementation of waste minimization or pollution prevention plans to reduce the amount of pollutants discharged to the POTW.

6. The unit charge or schedule of industrial user charges and fees for the management of the wastewater discharged to the POTW.
7. Requirements for installation and maintenance of inspection and sampling facilities and equipment.
8. Other conditions as deemed appropriate by the General Manager to ensure compliance with this ordinance, and State and Federal laws, rules, and regulations.

30a-5.4 Modification

The General Manager may modify the wastewater discharge permit for good cause including, but not limited to, the following:

- A. To incorporate any new or revised Federal, State, or local Pretreatment Standards or requirement.
- B. To address significant alterations or additions to the industrial user's operation, processes, or wastewater volume or character since the time of wastewater discharge permit issuance.
- C. A change in the POTW that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- D. Information indicating that the permitted discharge poses a threat to the CCRWTF's POTW, CCRWTF personnel, or the receiving waters.
- E. Violation of any terms or conditions of the wastewater discharge permit.
- F. Misrepresentations or failure to fully disclose all relevant facts in the wastewater discharge permit application or in any required reporting.
- G. Revision of or a grant of variance from categorical Pretreatment Standards pursuant to 40 CFR 403.13.
- H. To correct typographical or other errors in the wastewater discharge permit.
- I. To reflect a transfer of the facility ownership and/or operation to a new owner/operator.

The filing of a request by the permittee for a wastewater discharge permit modification does not stay any wastewater discharge permit condition.

30a-5.5 Duration

- A. Expiration: Wastewater discharge permits shall be issued for a specified time period, not to exceed five (5) years. A wastewater discharge permit may be issued for a period less than five (5) years, at the discretion of the General Manager. Each wastewater discharge permit will indicate a specific date upon which it will expire.
- B. Reissuance: A significant industrial user shall apply for wastewater discharge permit reissuance by submitting a complete wastewater discharge permit application in accordance with Section 4 a minimum of 60 days prior to the expiration of the industrial user's existing wastewater discharge permit.
- C. Transfer: Wastewater discharge permits may be reassigned or transferred to a new owner and/or operator only if the permittee gives at least 30 days advance notice to the General Manager and the General Manager approves the wastewater discharge permit transfer. The notice to the General Manager must include a written certification by the new owner and/or operator which:
 - 1. States that the new owner and/or operator has no immediate intent to change facility's operations and processes.
 - 2. Identifies the specific date on which the transfer is to occur.
 - 3. Acknowledges full responsibility for complying with the existing wastewater discharge permit.

Failure to provide advance notice of a transfer renders the wastewater discharge permit voidable on the date of facility transfer.

30a-5.6 Wastewater Discharge Permit Appeals

Any person, including the industrial user, may petition the CCRWTF to reconsider the terms of a wastewater discharge permit within 15 days of its issuance.

- A. Failure to submit a timely petition for review shall be deemed to be a waiver of the administrative appeal.
- B. In its petition, the appealing party must indicate the wastewater discharge permit provisions objected to, the reasons for this objection, and the

alternative condition, if any, it seeks to place in the wastewater discharge permit.

- C. The effectiveness of the wastewater discharge permit shall not be stayed pending the appeal.
- D. If the CCRWTF fails to act within 15 days, a request for reconsideration shall be deemed to be denied. Decisions not to reconsider a wastewater discharge permit, not to issue a wastewater discharge permit, or not to modify a wastewater discharge permit, shall be considered final administrative action for purposes of judicial review.
- E. Aggrieved parties seeking judicial review of the final administrative wastewater discharge permit decision must do so by filing a complaint with the 5th Judicial District Court in and for Iron County, State of Utah.

30a-5.7 Revocation

Wastewater discharge permits may be revoked for the following reasons:

- A. Failure to notify the CCRWTF of significant changes to the wastewater prior to the changed discharge.
- B. Failure to provide prior notification to the CCRWTF of changed condition pursuant to Section 30a-6.5 of this ordinance.
- C. Misrepresentation or failure to fully disclose all relevant facts in the wastewater discharge permit application.
- D. Falsifying self-monitoring reports.
- E. Tampering with monitoring equipment.
- F. Refusing to allow the CCRWTF timely access to the facility premises and records.
- G. Failure to meet effluent limitations.
- H. Failure to pay fines.
- I. Failure to pay sewer charges.
- J. Failure to meet compliance schedules.

- K. Failure to complete a wastewater survey or the wastewater discharge permit application.
- L. Failure to provide advance notice of the transfer of a permitted facility.
- M. Violation of any Pretreatment Standard or requirement, or any terms of the wastewater discharge permit or the ordinance.

Wastewater discharge permits shall be voidable upon non-operation of permitted facility, cessation of operations, or transfer of business ownership.

SECTION 30a-6 - REPORTING REQUIREMENTS

All reports shall be accompanied by a certification statement, and be signed by an authorized representative of the industrial user as stated in 30a-4.3

30a-6.1 Baseline Monitoring Reports (BMR)

- A. The General Manager may require the submission of additional, more current BMRs from time to time from an industrial user. Revised BMRs should use historical data where the data provides information sufficient to determine the need for additional industrial pretreatment measures.
- B. The BMR shall indicate the time, date, and location of all sampling provided, methods of analysis, and shall certify that the sampling and analysis is representative of the normal work cycles and expected pollutant discharges to the POTW. All baseline monitoring reports must be signed and certified in accordance with Section 30a-4.3.
- C. If the General Manager determines that a BMR is needed the information as stated in 4.2 must be submitted as well as any additional information required by the General Manager to determine compliance with this ordinance as well as the information provided below:
 - 1. Samples should be taken immediately downstream from the regulated process if no pretreatment exists. If other wastewaters are mixed with the regulated wastewater prior to pretreatment the User should measure the

Comment [W1]: Jennifer, reference SUO lines 1529 through 1540. All other language is supplied within the ordinance 30a.

Comment [D2]: Include reference to 4.2 or include language similar to 1521-1547

flows and concentrations necessary to allow use of the combined wastestream formula in 40 CFR 403.6 (e) to evaluate compliance with the Pretreatment Standards. Where an alternate concentration or mass limit has been calculated in accordance with 40 CFR 403.6 (e) this adjusted limit along with supporting data shall be submitted to the Control Authority;

2. Sampling and analysis shall be performed in accordance with section 30a 7.2 of this ordinance.

Comment [W3]: Jennifer, reference SUO lines 1529 through 1540. All other language is supplied within the ordinance 30a.

30a-6.2 Compliance Schedule Progress Report

The following conditions shall apply to the compliance schedule required by the Wastewater Discharge Permit Application Section 30a-4.2(L). The schedule shall contain progress increments in the form of dates for the commencement and completion of major events leading to the construction and operation of additional pretreatment required for the user to meet the applicable Pretreatment Standards (such events include hiring an engineer, completing preliminary and final plans, executing contracts for major components, commencing and completing construction, beginning and conducting routine operation). No increment referred to above shall exceed nine (9) months. The industrial user shall submit a progress report to the General Manager no later than 14 days following each date in the schedule, and the final date of compliance, including, as a minimum, whether or not it complied with the increment of progress, the reason for any delay, and, if appropriate, the steps being taken by the industrial user to return to the established schedule. In no event shall more than nine (9) months elapse between such progress reports to the General Manager.

30a-6.3 Categorical Pretreatment Standard Compliance Report

Within ninety (90) days following the date for final compliance with applicable categorical Pretreatment Standards, or in the case of a new source following commencement of the introduction of wastewater into the POTW, any categorical industrial user subject to such Pretreatment Standards and requirements shall submit to the CCRWTF a report containing flow measurement, sampling, and analysis of pollutants regulated in the industrial users wastewater discharge permit. For categorical industrial users subject to equivalent mass or concentration limits established in accordance with the procedures in 40 CFR 403.6(c), this report shall contain a reasonable measure of the categorical industrial user's long term production rate. For all other industrial users subject to categorical Pretreatment Standards expressed in terms of allowable pollutant discharge per unit of production (or other measure of operation), this report shall include the industrial user's actual production during the

appropriate sampling period. All compliance reports must be signed and certified in accordance with Section 30a-4.3.

30a-6.4 Periodic Compliance Report

- A. Any significant industrial user subject to a Pretreatment Standard shall, at a frequency determined by the General Manager but in no case less than twice per year (in June and December), submit a report indicating the nature and concentration of pollutants in the discharge which are limited by such Pretreatment Standards, the measured or estimated average, and maximum daily flows for the reporting period. All periodic compliance reports must be signed and certified accordance with Section 30a-4.3. In cases where the Pretreatment Standard requires compliance with Best Management Practice (BMP) or pollution prevention alternative, the user must submit documentation required by the General Manager or the Pretreatment Standard necessary to determine the compliance status of the user.
- B. All wastewater samples must be representative of the industrial user's discharge. Wastewater monitoring and flow measurement facilities shall be properly operated, kept clean, and maintained in good working order at all times. Failure of an industrial user to keep its monitoring facility in good working order shall not be grounds for the industrial user to claim that sample results are not representative of its discharge.
- C. If an industrial user, subject to the reporting requirement in and of this Section, monitors any pollutant more frequently than required by the POTW, using the procedures prescribed in Section 30a-7.2 of this ordinance, the monitoring results shall be included in the report.

30a-6.5 Changed Conditions Report

Each industrial user is required to notify the General Manager of any planned changes to the industrial user's operations or system which might alter the nature, quality or volume of its wastewater at least 30 days before the change.

- A. The General Manager may require the industrial user to submit such information as may be deemed necessary to evaluate the changed condition, including the submission of a wastewater discharge permit application under Section 30a-4.

- B. The General Manager may issue a wastewater discharge permit under Section 30a-4.4 or modify an existing wastewater discharge permit under Section 30a-5.4.
- C. No industrial user shall implement the planned changed condition(s) until and unless the General Manager has approved the industrial user's change.
- D. For purposes of this requirement, flow increases of ten percent (10%) or greater, and the discharge of any previously unreported pollutants, shall require a changed condition report.

30a-6.6

Report of Potential Problem

- A. In the case of any discharge including, but not limited to, accidental discharges, discharges of a non-routine, episodic nature, a non-customary batch discharge, or a slug load which may cause potential problems for the POTW (including a violation of the prohibited discharge standards in Section 30a-2.1 of this ordinance), it is the responsibility of the industrial user to immediately telephone and notify the General Manager, or his designee of the incident. This notification shall include the location of discharge, type of waste, concentration and volume, if known, and corrective actions taken by the industrial user.
- B. Within five (5) days following such discharge, the industrial user shall, unless waived by the General Manager, submit a detailed written report describing the cause(s) of the discharge and the measures to be taken by the industrial user to prevent similar future occurrences. Such notification shall not relieve the industrial user or any expense, loss, damage, or other liability which may be incurred as a result of damage to the POTW, natural resources, or any other damage to person or property; nor shall such notification relieve the industrial user of any fines, civil penalties, or other liability which may be imposed by this ordinance.
- C. Failure to notify the CCRWTF of potential problem discharges shall be deemed a separate violation of this ordinance.
- D. A notice shall be permanently posted on the industrial user's bulletin board or other prominent place advising employees whom to call in the event of a discharge described in paragraph A, above. Employers shall ensure that all employees, who may cause or suffer such a discharge to occur, are advised of the emergency notification procedure.

E. Significant Industrial Users are required to notify the Superintendent, and/or General Manager immediately of any changes at its facility affecting the potential for a Slug Discharge.

30a-6.7 Nonpermitted Industrial Users Reports

All industrial users not subject to categorical Pretreatment Standards, not classified as a CIU or SIU, and not required to obtain a wastewater discharge permit shall provide appropriate reports to the CCRWTF as the General Manager may require.

30a-6.8 Repeat Sampling Report

If sampling performed by an industrial user indicates a violation, the industrial user must notify the CCRWTF within 24 hours of becoming aware of the violation. The industrial user shall also repeat the sampling and analysis within 30 days after becoming aware of the violation and submit the results of the repeat analysis to the CCRWTF. The industrial user is not required to re-sample if the POTW performs monitoring at the industrial user's at least once a month, or if the POTW performs sampling between the industrial user's initial sampling and when the industrial user receives the results of this sampling. Upon the POTW conducting a sample of the industrial users, and analytical results of the POTW's sample indicates a violation of the industrial users permit, the POTW can require the industrial user to conduct a resample.

30a-6.9 Hazardous Waste Discharge Notification

- A. Any industrial user who commences the discharge of hazardous waste shall notify the POTW, the EPA Regional Waste Management Division Director, and the State Department of Environmental Quality, Division of Solid and Hazardous Waste authorities in writing of any discharge into the POTW of a substance which, if otherwise disposed of, would be a hazardous waste under 40 CFR Part 261 . Such notification must include the name of the hazardous waste as set forth in 40 CFR Part 261, the EPA hazardous waste number, and the type of discharge (continuous, batch, or other). If the industrial user discharges more than 10 kilograms of such waste per calendar month to the POTW, the notification shall also contain the following information to the extent such information is known and readily available to the industrial user: an identification of the hazardous constituents contained in the wastes, and estimation of the mass and concentration of such constituents in the waste stream discharged during the calendar month, and an estimation of the mass

of constituents in the waste stream expected to be discharged during the following twelve (12) months. All notifications must take place no later than 30 days after the discharge commences. Any notification under this paragraph need be submitted only once for each hazardous waste discharged. However, notifications of changed discharges must be submitted under Section 30a-6.5, above. The notification requirement in this section does not apply to pollutants already reported under the self-monitoring requirements of sections 30a-6.1, 6.3, and 6.4, above.

- B. Dischargers are exempt from the requirements of paragraph (1) of this section during a calendar month in which they discharge no more than fifteen (15) kilograms of hazardous wastes, unless the wastes are acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e). Discharge of more than fifteen (15) kilograms of non-acute hazardous wastes in a calendar month, or of any quantity of acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e), requires a one-time notification.
- C. In the case of any new regulations under Section 3001 of RCRA identifying additional characteristics of hazardous waste or listing any additional substance as a hazardous waste, the industrial user must notify the POTW, the EPA Regional Waste Management Waste Division Director, and State Department of Environmental Quality, Division of Solid and Hazardous Waste authorities of the discharge of such substance within 90 days of the effective date of such regulations.
- D. In the case of any notification made under this section, the industrial user shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical.

30a-6.10 Timing

Written reports will be deemed to have been submitted on the date postmarked. For reports which are not mailed, postage prepaid, into a mail facility serviced by the U.S. Postal Service, the date of receipt of the report shall govern.

30a-6.11 Record Keeping

Industrial users shall retain, and make available for inspection and copying, all records of information obtained pursuant to any monitoring activities required by this ordinance, any additional records of information obtained pursuant to monitoring activities undertaken by the user independent of such requirements, and documentation associated with Best Management Practices, and information required to be retained under this ordinance. These records shall include the date, exact place, method, and time of sampling, and the name of the person(s) taking the samples; the dates analyses were performed; who performed the analyses; the analytical techniques or methods used; and the results of such analyses. These records shall remain available for a period of at least three (3) years. This period shall be automatically extended for the duration of any enforcement action concerning compliance with this ordinance, or where the industrial user has been specifically notified of a longer retention period by the General Manager.

SECTION 30a-7 - COMPLIANCE MONITORING

30a-7.1 Inspection

- A. Right to Enter: The CCRWTF shall have the right to enter the facilities of any industrial user, to ascertain whether the purpose of this ordinance, and any permit or order issued hereunder, is being met and whether the industrial user is complying with all requirements thereof. Industrial users shall allow the General Manager or his representatives ready access to all parts of the premises for the purposes of inspection, sampling, records examination and copying, and the performance of any additional duties.

Deleted: at reasonable times

Where an industrial user has security measures in force which require proper identification and clearance before entry into its premises, the industrial user shall make necessary arrangements with its security guards so that, upon presentation of suitable identification, personnel from the CCRWTF, state, and EPA will be permitted to enter without delay, for the purposes of performing their specific responsibilities.

- B. Search Warrants: If the General Manager has been refused access to a building, structure or property or any part thereof, and if the General Manager has demonstrated probable cause to believe that there may be a violation of this ordinance or that there is a need to inspect as part of a routine inspection program designed to verify compliance with this ordinance or any permit or order issued hereunder, or to protect the overall public health, safety and welfare of the community, then upon application by the CCRWTF Attorney, the District Court Judge of Iron County shall issue a search and/or seizure

warrant describing therein the specific location subject to the warrant. The warrant shall specify what, if anything, may be searched and/or seized on the property described. Such warrant shall be served at reasonable hours by the General Manager in the company of a uniformed officer of Cedar City or Iron County. In the event of an emergency affecting public health and safety, inspections shall be made without the issuance of a warrant.

30a-7.2 Monitoring

- A. Sample Collection: Samples for oil and grease, temperature, pH, cyanide, phenols, toxicity, sulfides, and volatile organic chemicals must be obtained using grab collection techniques. All other wastewater samples shall be collected using 24-hour flow proportional composite sampling procedures. In the event flow proportional sampling is infeasible, the General Manager may authorize the use of time proportional sampling, or a minimum of four (4) grab samples must be used for pH, cyanide, total phenols, oil and grease, sulfide and volatile organic compounds for facilities for which historical sampling data does not exist; for facilities for which historical sampling data are available, the General Manager may authorize a lower minimum, where the user demonstrates that this will provide a representative sample of the effluent being discharged. The Industrial User is required to collect the number of grab samples necessary to assess and assure compliance by with applicable Pretreatment Standards and Requirements. In addition, grab samples may be required to show compliance with instantaneous discharge limits.
- B. Monitoring Equipment: The CCRWTF, State, and EPA shall have the right to set up on the industrial user's property, or require installation of, such devices as are necessary to conduct sampling and/or metering of the user's operations.

The CCRWTF may require the industrial user to install monitoring equipment as necessary. The facility's sampling and monitoring equipment shall be maintained at all times in a safe and proper operating condition by the industrial user at its own expense. All devices used to measure wastewater flow and quality shall be calibrated weekly to ensure their accuracy.

- C: Analytical Requirements: All pollutant analyses, including sampling techniques, to be submitted as part of a wastewater discharge permit application or for any of the reports required in Section 6 shall be performed in accordance with the techniques prescribed in 40 CFR Part 136, unless otherwise specified in an applicable categorical Pretreatment Standard. If 40

CFR Part 136 does not contain sampling or analytical techniques for the pollutant in question, sampling and analyses must be performed in accordance with procedures approved by the EPA. Multiple grab samples collected during a 24-hour period may be composited prior to the analyses as follows: for cyanide, total phenols, and sulfides, the samples may be composited in the laboratory or in the field; for volatile organics and oil and grease, the samples may be composited in the laboratory. Composited samples for other parameters unaffected by the compositing procedures as documented in approved EPA methodologies may be authorized by the General Manager as appropriate.

- D. Determination of Noncompliance: The General Manager may use a grab sample(s) to determine noncompliance with Pretreatment Standards. The decision to use this method is at the discretion of the General Manager and would not be announced in advance to the industrial user.

30a-7.3 Obstructions and Delays

- A. Any temporary or permanent obstruction to safe and easy access to the industrial facility to be inspected and/or sampled shall be promptly removed by the industrial user at the written or verbal request of the General Manager and shall not be replaced. The costs of clearing such access shall be born by the industrial user.
- B. Delays in allowing CCRWTF personnel access to the industrial user's premises shall be a violation of this ordinance.

SECTION 30a-8 - CONFIDENTIAL INFORMATION

Information and data on an industrial user obtained from reports, surveys, wastewater discharge permit applications, wastewater discharge permits, and monitoring programs, and from CCRWTF inspection and sampling activities, shall be available to the public without restriction unless the industrial user specifically requests, and is able to demonstrate to the satisfaction of the CCRWTF, that the release of such information would divulge information, processes or methods of production entitled to protection as trade secrets under applicable State law. When requested and demonstrated by the industrial user furnishing a report that such information should be held confidential, the portions of a report which might disclose trade secrets or secret processes shall not be made available for inspection by the public, but shall immediately be made available, upon request, to governmental agencies for uses related to the UPDES program or pretreatment program, and in enforcement proceedings involving

the person furnishing the report. Wastewater constituents and characteristics and other "effluent data" as defined by 40 CFR 2.302 will not be recognized as confidential information and will be available to the public without restriction. The CCRWTF will provide a secure facility to maintain documentation considered confidential.

SECTION 30a-9 - ANNUAL PUBLICATION

30a-9.1 Requirement to Publish

The CCRWTF shall publish annually, in the largest daily newspaper published in the municipality where the POTW is located, a list of the industrial users which, during the previous 12 months, were in significant noncompliance with applicable Pretreatment Standards and requirements.

30a-9.2 Significant Noncompliance

The term significant noncompliance shall mean:

- A. Chronic Violations: Chronic violations of wastewater discharge limits, defined here as those in which sixty-six percent (66%) or more of all of the measurements taken during a 6-month period exceed a numeric Pretreatment Standard or Requirement, including instantaneous limits, as defined in 30a-1.3 DD., for the same pollutant parameter by any amount;
- B. TRC Violations: Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent (33%) or more of all the measurements taken for the same pollutant parameter during a 6-month period equals or exceeds the product of the numeric Pretreatment Standard or Requirement including instantaneous limits, as defined in 30a-1.3 DD, multiplied by the applicable criteria [1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH];
- C. Discharge Violations: Any other violation of a Pretreatment Standard or Requirement as defined in 30a-1.3 DD. (daily maximum, long-term average, instantaneous limit or narrative Standard) that the CCRWTF determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of CCRWTF personnel or the general public);

- D. Endangerment: Any discharge of a pollutant that has caused imminent endangerment to the public or to the environment, or has resulted in the CCRWTF's exercise of its emergency authority to halt or prevent such a discharge;
- E. Failure to Comply: Failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a control mechanism or enforcement order for starting construction, completing construction, or attaining final compliance;
- F. Failure to Report: Failure to provide within 30 days after the due date, any required reports, including baseline monitoring reports, 90 day compliance reports, periodic self-monitoring reports, and reports on compliance with compliance schedules;
- G. Failure to accurately report noncompliance;
- H. Other Violations: Any other violation or group of violations, which may include a violation of Best Management Practices, which the CCRWTF determines will adversely affect the operation or implementation of the local pretreatment program.

SECTION 30a-10 - ADMINISTRATIVE ENFORCEMENT REMEDIES

30a-10.1 Notification of Violation

Whenever the General Manager finds that any user has violated or is violating this ordinance, a wastewater discharge permit or order issued hereunder, or any other pretreatment requirement, the General Manager or his agent may serve upon said user a written Notice of Violation. Such written notice shall be served in person or by certified mail where a receipt is obtained. Within thirty (30) days of the receipt of this notice, an explanation of the violation and a plan for the satisfactory correction and prevention thereof, to include specific required actions, shall be submitted by the user to the General Manager. Submission of this plan in no way relieves the user of liability for any violations occurring before or after receipt of the Notice of Violation. Nothing in this section shall limit the authority of the CCRWTF to take any action, including emergency actions or any other enforcement action, without first issuing a Notice of Violation.

30a-10.2 Consent Orders

The General Manager is hereby empowered to enter into consent orders, assurances of voluntary compliance, or other similar documents establishing an agreement with any user responsible for noncompliance. Such orders will include specific action to be taken by the order. Consent Orders shall have the same force and effect as administrative orders issued pursuant to Sections 30a-10.4 and 30a-10.5 below and shall be judicially enforceable.

30a-10.3 Show Cause Hearing

The General Manager may order any user which causes or contributes to violation(s) of this ordinance, wastewater discharge permits, or orders issued hereunder, or any other Pretreatment Standard or requirement, to appear before the General Manager and show cause why a proposed enforcement action should not be taken. Notice shall be served on the user specifying the time and place for the meeting, the proposed enforcement action, the reasons for such action, and a request that the user show cause why this proposed enforcement action should not be taken. Such written notice shall be served in person or by certified mail where a receipt is obtained. The notice of the meeting shall be served personally or by registered or certified mail (return receipt requested) at least seven (7) days prior to the hearing. Such notice may be served on any authorized representative of the user. Whether or not the user appears as ordered, immediate enforcement action may be pursued following the hearing date. A show cause hearing shall not be a prerequisite for taking any other actions against the user.

30a-10.4 Compliance Orders

When the General Manager finds that a user has violated or continues to violate the ordinance, wastewater discharge permits, or orders issued hereunder, or any other Pretreatment Standard or requirement, he may issue an order to the user responsible for the discharge directing that the user come into compliance within thirty (30) days. If the user does not come into compliance within thirty (30) days, sewer service may be discontinued. Compliance orders may also contain other requirements to address the noncompliance, including additional self-monitoring, and management practices designed to minimize the amount of pollutants discharged to the sewer. A compliance order, and/or schedule can be initiated by the control authority for the installation of technology required to meet applicable Pretreatment Standards and Requirements; a compliance order may not extend the deadline for compliance established for a Federal Pretreatment Standard or requirement, nor does a compliance order release the user of liability for any violation, including any continuing

violation. Issuance of a compliance order shall not be a prerequisite to taking any other action against the user.

30a-10.5 Cease and Desist Orders

When the General Manager finds that a user is violating this ordinance, the user's wastewater discharge permit, any order issued hereunder, or any other Pretreatment Standard or requirement, or that the user's past violations are likely to recur, the General Manager may issue an order to the user directing it to cease and desist all such violations and directing the user to:

- A. Immediately comply with all requirements.
- B. Take such appropriate remedial or preventive action as may be needed to properly address a continuing or threatened violation, including halting operations and/or terminating the discharge.

Issuance of a cease and desist order shall not be a prerequisite to taking any other action against the user.

30a-10.6 Administrative Fines

- A. Notwithstanding any other section of this ordinance, any user found to have violated any provision of this ordinance, its wastewater discharge permit, and orders issued hereunder, or any other Pretreatment Standard or requirement may be fined in an amount not to exceed \$1,000. Such fines shall be assessed on a per violation, per day basis. In the case of monthly or other long-term average discharge limits, fines shall be assessed for each day during the period of violation. The CCRWTF may add the costs of preparing administrative enforcement actions such as notices and orders to the fine.
- B. Assessments may be added to the user's next scheduled sewer service charge and the General Manager shall have such other collection remedies as may be available for other service charges and fees.
- C. Unpaid charges, fines, and penalties shall, after sixty (60) calendar days, be assessed an additional penalty of ten (10) percent of the unpaid balance and interest shall accrue thereafter at a rate of 1% per month. A lien against the individual user's property will be sought for unpaid charges, fines, and penalties.

- D. Users desiring to dispute such fines must file a written request for the General Manager to reconsider the fine along with full payment of the fine amount within thirty (30) days of being notified of the fine. Where a request has merit, the General Manager shall convene a hearing on the matter within fourteen (14) days of receiving the request from the industrial user. In the event the user's appeal is successful, the payment together with any interest accruing thereto shall be returned to the industrial user.
- E. Issuance of an administrative fine shall not be a prerequisite for taking any other action against the user.

30a-10.7 Emergency Suspensions

The General Manager may immediately suspend a user's discharge (after informal notice to the user) whenever such suspension is necessary in order to stop an actual or threatened discharge which reasonably appears to present or cause an imminent or substantial endangerment to the health or welfare of any people. The General Manager may also suspend a user's discharge (after notice and opportunity to respond) that threatens to interfere with the operation of the POTW, or which presents or may present an endangerment to the environment.

Any user notified of a suspension of its discharge shall immediately stop or eliminate its contribution. In the event of a user's failure to immediately comply voluntarily with the suspension order, the General Manager shall take such steps as deemed necessary, including immediate severance of the sewer connection, to prevent or minimize damage to the POTW, its receiving stream, contamination of sludge, or endangerment to any individuals. The General Manager shall allow the user to recommence its discharge when the user has demonstrated to the satisfaction of the CCRWTF that the period of endangerment has passed, unless the termination proceedings set forth in Section 30a-10.8 is initiated against the user.

A user that is responsible, in whole or in part, for any discharge presenting imminent endangerment shall submit a detailed written statement describing the causes of the harmful contribution and the measures taken to prevent any future occurrence to the General Manager, prior to the date of any show cause or termination of discharge hearing under Sections 30a-10.3 and 30a-10.8.

Nothing in this section shall be interpreted as requiring a hearing prior to any emergency suspension under this section.

30a-10.8 **Termination of Discharge**

In concert with the wastewater discharge permit revocation provisions in Section 30a-5.7 of this ordinance, any user that violates any of the following conditions of this ordinance, wastewater discharge permits, or orders issued hereunder, is subject to discharge termination.

- A. Violation of wastewater discharge permit conditions.
- B. Failure to accurately report the wastewater constituents and characteristics of its discharge.
- C. Failure to report significant changes in operations or wastewater volume, constituents and characteristics prior to discharge.
- D. Refusal of reasonable access to the user's premises for the purpose of inspection, monitoring or sampling.
- E. Violation of the standards in Section 30a-2 of this ordinance.

The Industrial user will be notified of the proposed termination of its discharge and be offered an opportunity to show cause under Section 30a-10.3 of this ordinance why the proposed action should not be taken.

SECTION 30a-11 - JUDICIAL ENFORCEMENT REMEDIES

30a-11.1 **Injunctive Relief**

Whenever a user has violated a Pretreatment Standard or requirement or continues to violate the provisions of this ordinance, wastewater discharge permits or orders issued hereunder, or any other pretreatment requirement, the General Manager may petition the 5th Judicial District Court in and for Iron County, State of Utah through the CCRWTF's Attorney for the issuance of a temporary or permanent injunction, as appropriate, which restrains or compels the specific performance of the wastewater discharge permit, order, or other requirement imposed by this ordinance on activities of the industrial user. In addition, the CCRWTF may recover reasonable attorney's fees, court costs, and other expenses of litigation by appropriate legal action against the user found to have violated any provision herein, or any other rules, regulations, permits, or agreements issued herein. Such other action as appropriate for legal and/or equitable relief may also be sought by the CCRWTF. A petition for injunctive relief need not be filed as a prerequisite to taking any other action against a user.

30a-11.2 Civil Fine Pass Through Recovery

In the event that an industrial user discharges such pollutants which cause the CCRWTF to violate any conditions of its UPDES Permit and the CCRWTF is fined by EPA or the State of Utah for such violations, then such industrial users shall be fully liable for the total amount of the fines and civil penalties assessed against the CCRWTF by EPA or the State of Utah and administrative costs incurred.

30a-11.3 Referral to State of Utah for Action

The CCRWTF will refer to the State of Utah criminal violations of any Pretreatment Standards or permit conditions. The Attorney General's office for Utah will offer the city wherein the violation occurred the option to prosecute the violator. Should the local entity decline, the State, at its discretion, may initiate appropriate criminal action. The CCRWTF will assist the Attorney General's office any way it can with appropriate support for the action taken.

30a-11.4 Nonexclusive Remedies

The provisions in Sections 30a-9-12 are not exclusive remedies. The CCRWTF reserves the right to take any, all, or any combination of these actions against a non-compliant user. Enforcement of pretreatment violations will generally be in accordance with the CCRWTF's enforcement response plan. However, the CCRWTF reserves the right to take other action against any user when the circumstances warrant. Further, the CCRWTF is empowered to take more than one enforcement action against any non-compliant user. These actions may be taken concurrently.

SECTION 30a-12 - SUPPLEMENTAL ENFORCEMENT ACTION

30a-12.1 Performance Bonds

The General Manager may decline to reissue a wastewater discharge permit to any user which has failed to comply with the provisions of this ordinance, any orders, or a previous wastewater discharge permit issued hereunder, unless such user first files a satisfactory bond, payable to the CCRWTF, in a sum not to exceed a value determined by the General Manager to be necessary to achieve consistent compliance.

30a-12.2 Liability Insurance

The General Manager may decline to reissue a wastewater discharge permit to any user which has failed to comply with the provisions of this ordinance, any order, or a previous wastewater discharge permit issued hereunder, unless the user first submits proof that it has obtained financial assurances sufficient to restore or repair damage to the POTW caused by its discharge.

30a-12.3 Water Supply Severance

Whenever a user has violated or continues to violate the provisions of this ordinance, orders, or wastewater discharge permits issued hereunder, water service to the user may be severed. Service will only recommence, at the user's expense, after it has satisfactorily demonstrated its ability to comply.

30a-12.4 Public Nuisances

Any violation of this ordinance, wastewater discharge permits, or orders issued hereunder, is hereby declared a public nuisance and shall be corrected or abated as directed by the General Manager or his designee. Any person(s) creating a public nuisance shall be subject to the provisions of the Cedar City Ordinance, Chapter 25 governing such nuisances, including reimbursing the City for any costs incurred in removing, abating or remedying said nuisance.

SECTION 30a-13 - AFFIRMATIVE DEFENSES

30a-13.1 Upset

- A. For the purposes of this section, "upset" means an exceptional incident in which there is unintentional and temporary noncompliance with categorical Pretreatment Standards because of factors beyond the reasonable control of the industrial user. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

- B. An upset shall constitute an affirmative defense to an action brought for noncompliance with categorical Pretreatment Standards if the requirements of paragraph (30a-13.1C) are met.
- C. An industrial user who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - 1. An upset occurred and the industrial user can identify the cause(s) of the upset;
 - 2. The facility was at the time being operated in a prudent and workmanlike manner and in compliance with applicable operation and maintenance procedures;
 - 3. The industrial user has submitted the following information to the POTW and treatment plant operator within 24 hours of becoming aware of the upset [if this information is provided orally, a written submission must be provided within five (5) days]:
 - (i) A description of the indirect discharge and cause of noncompliance.
 - (ii) The period of noncompliance, including exact dates and times or, if not corrected, the anticipated time the noncompliance is expected to continue.
 - (iii) Steps being taken and/or planned to reduce, eliminate and prevent recurrence of the noncompliance.
- D. In any enforcement proceeding, the industrial user seeking to establish the occurrence of an upset shall have the burden of proof.
- E. Industrial users will have the opportunity for a judicial determination on any claim of upset in an enforcement action brought for noncompliance with categorical Pretreatment Standards.
- F. The industrial user shall control production of all discharges to the extent necessary to maintain compliance with categorical Pretreatment Standards upon reduction, loss, or failure of its treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost or has failed.

30a-13.2 General/Specific Prohibitions

An industrial user shall have an affirmative defense to an enforcement action brought against it for noncompliance with the general and specific prohibitions in Section 30a-2.1 of this ordinance if it can prove that it did not know or have reason to know that its discharge, along or in conjunction with discharges from other sources, would cause pass through or interference and that either: (a) a local limit exists for each pollutant discharged and the industrial user was in compliance with each limit directly prior to, and during, the pass through or interference, or (b) no local limit exists, but the prior discharge when the CCRWTF was regularly in compliance with its UPDES permit, and in the case of interference, was in compliance with applicable sludge use or disposal requirements.

30a-13.3 Bypass

- A. (1) "Bypass" means the intentional diversion of waste streams from any portion of an industrial user's treatment facility.
- (2) "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- B. An industrial user may allow any bypass to occur which does not cause Pretreatment Standards or requirements to be violated, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of paragraphs (C) and (D) of this section.
- C. (1) If an industrial user knows in advance of the need for a bypass, it shall submit prior notice to the POTW, at least ten days before the date of the bypass if possible.
- (2) An industrial user shall submit oral notice of an unanticipated bypass that exceeds applicable Pretreatment Standards to the POTW within 24 hours from the time it becomes aware of the bypass. A written submission shall also be provided within 5 days of the time that the industrial user becomes aware of the bypasses. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and

prevent recurrence of the bypass. The POTW may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

- D. (1) Bypass is prohibited, and the POTW may take enforcement action against an industrial user for a bypass, unless;
- (i) Bypass was unavoidable to prevent loss of life, personal injury, or sever property damage;
 - (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (iii) The industrial user submitted notices as required under paragraph (C) of this section.
- (2) The POTW may approve an anticipated bypass, after considering its adverse effects, if the POTW determines that it will meet the three conditions listed in paragraph (D)(1) of this section.

SECTION 30a-14 - USER FEES

User fees should be assessed whenever there is a need to recover the cost of treating wastewater. These fee calculations are found in Addendum A of this Ordinance.

SECTION 30a-15 - MISCELLANEOUS PROVISIONS

30a-15.1 Pretreatment Fees

The CCRWTF may impose fees that may include, but not limited to, the following:

- (A) Fees for all costs, including maintenance and operation;

- (B) Fees for reimbursement of costs of setting up and operating the Pretreatment Program;
 - (C) Fees for monitoring, inspections, and surveillance procedures to include, but not limited to, laboratory analysis;
 - (D) Fees for reviewing accidental discharge procedures and construction;
 - (E) Fees for permit applications;
 - (F) Fees for filing appeals;
 - (G) Fees for consistent removal (by the POTW) of pollutants otherwise subject to Federal Pretreatment Standards;
 - (H) Fees for connection;
 - (I) Fees for repairs and disconnection;
 - (J) Fees for inspections and surveys;
 - (K) Fees for development and expansion;
- Other fees as the CCRWTF may deem necessary.

30a-15.2 Severability

If any provision of this ordinance is invalidated by any court of competent jurisdiction, the remaining provisions shall not be effected and shall continue in full force and effect.

30a-15.3 Conflicts

All other ordinances and parts of other ordinances inconsistent or conflicting with any part of this ordinance, are hereby repealed to the extent of the inconsistency or conflict.

SECTION 30a-16 - EFFECTIVE DATE

This ordinance shall be in full force and effect immediately following its passage, approval and publication, as provided by law.

Dated this _____ day of _____, 2008

Gerald R. Sherratt
Mayor

[Seal]

Attest

Renon Savage
Recorder