



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

March 5, 2014

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Eureka City Wastewater Treatment Facility
MAILING ADDRESS: P.O. Box 156, Eureka City, UT 84628
TELEPHONE NUMBER: (435) 433-6915
FACILITY LOCATION: 1.7 miles southwest of Eureka City
UPDES PERMIT NO.: UT0024601
PERMITTED OUTFALLS 001A
RECEIVING WATER: Eureka Creek (dry wash)

BACKGROUND

The Eureka Wastewater Treatment Facility (EWTF) is a discharging lagoon system. The facility was expanded and upgraded in 1986 to a total area of 360 feet by 720 feet. The average design flow is 0.20 MGD and has a design population equivalent of 800 people. Disinfection is accomplished through chlorination.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on April 6, 2014. Written public comments can be submitted to: Dave Wham, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dwham@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit reissuance, revise it, or abandon it.

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Dave Wham at 801-536-4337.