# Great Salt Lake Minerals Corporation Ogden, Utah

# Steam Generation Plant Level I Anti-Degradation Review

**OCTOBER 2012** 



# **Table of Contents**

G	Great Salt Lake Minerals Level I Antidegradation Review	3
	Introduction	3
	Beneficial Use	
	Water Quality Standards	
	Discharge Water Characteristics	
	Metals	6
	Boiler Treatment Materials	8
	Pollutants of Concern	10

# **APPENDICES**

- Appendix A Permit Application
- Appendix B Fact Sheets & MSD Sheets for Boiler Treatment Materials
- Appendix C Bear River Bay Water Quality Summary
- Appendix D Source Water Sampling Results
- Appendix E Weber Basin Water Conservancy District Consumer Confidence Report, February 2012

# **Great Salt Lake Minerals Level I Antidegradation Review**

# Introduction

Great Salt Lake Minerals Corporation (GSLM) has been operating on the shores of the Great Salt Lake near Ogden, Utah since about 1970. The primary product produced by GSLM is potassium sulfate ( $K_2SO_4$ ), a fertilizer commonly known as sulfate of potash. Sulfate of potash (SOP) is the most effective fertilizer for supplying vital potassium and sulfur nutrition for high crop yields and constant quality in agriculture products. Unlike other potassium sources, SOP contains virtually no chloride which can cause crop damage. GSLM also produces 2 types of salt products – sodium chloride (NaCl) and magnesium chloride (MgCl<sub>2</sub>).

GSLM uses the sun as its primary energy source to naturally produce SOP. The SOP is produced by drawing brine from Gunnison Bay. The brine is diverted into solar evaporation ponds which are used to precipitate potassium salts. The sun provides the majority of the energy used to evaporate the water and produce SOP. However, additional heat in the form of steam is required to convert the potassium salts into the final SOP product. PacifiCorp, through its Little Mountain Power Plant, provides GSLM with the required steam to produce the final SOP product (in addition to supplying steam to GSLM's Magnesium Chloride Production Facility).

PacifiCorp has informed GSLM that it shall abandon the Little Mountain Power Plant rather than replace its aging equipment, and therefore shall no longer supply steam to GSLM. Thus, GSLM needs to construct and operate its own steam generation plant to continue its operations and the production of SOP (and magnesium chloride). The proposed steam generation plant replaces 40-year-old, less efficient equipment that was owned and operated by PacifiCorp.

GSLM is purchasing two (2) boilers each having a heat input capacity of 110 mmBtu/hr and an output capacity of 90,000 lb/hr steam. Both boilers will be fired with clean-burning natural gas. A discharge permit application has been submitted to the State of Utah Division of Water Quality (UDWQ). The permit application is for the wastewater generated from water pretreatment and the boiler operations.

In any boiler operation, pretreatment of the water supply source prior to input into the boiler is critical; this prevents adverse mechanical/thermal & maintenance issues to the boiler. Such is the case with the GSLM boilers and the water supply source. The water shall be supplied from the Weber Basin Water Conservancy District. This culinary-quality supply water shall undergo a 3-stage pretreatment prior to input into the boilers. The 3 stages shall be: water softening, carbon filtration, and reverse osmosis (RO). These 3 stages shall collectively provide demineralization, solids removal, and purification of the water. After input of the pretreated source water into the boiler, the boiler recycle/condensate stream shall be treated with conventional boiler treatment materials for scale control and corrosion inhibition.

A portion of the proposed wastewater discharge will come from backwashing the water softener and the carbon filters. Also the RO system is anticipated to have about a 10% reject rate and this flow will be

combined with the backwash wastewater. This wastewater will normally be consumed in the SOP production process when the SOP plant is operating.

Following pretreatment, the water will then be used in the boilers to generate the steam. A portion of the boiler water will be continually bled off to control the concentration of salts that will build up in the boiler system. This wastewater is referred to as blowdown water. In addition to the trace elements from the source water, the blowdown water is expected to contain trace amounts of the ingredients from the scaling controls and corrosion inhibitors. These ingredients include: sodium bisulfite corrosion inhibitor, sodium hydroxide buffering agent, and a polymeric dispersant with molybdate tracer – all of which are aqueous solutions and water soluble.

The peak discharge flow from water supply pretreatment and boiler operations is estimated to be 90,000 gals/day (0.09 MGD); the average discharge flow is estimated to be 53,000 gals/day (0.05 MGD). This discharge shall be to the facility's existing drainage ditch leading to Outfall 001. The facility's existing average effluent flow to Outfall 001 is 3.8 MGD (from CY2011 UPDES data). Thus, the daily flow contribution from the water supply pre-treatment and boiler operations shall be approximately 2% of the facility's existing effluent flow. Outfall 001 is located within the Bear River Bay of the Great Salt Lake.

GSLM will own and operate the new steam generation plant. The new steam generation plant is essential to the company's continued operations as the GSLM facility ...

- keeps hundreds of Utah citizens employed,
- generates millions of dollars for Utah's economy,
- generates ~\$7 million/year in royalty payments to Utah,
- exports ~\$40 million in SOP, thereby helping with the country's trade deficit,
- provides a beneficial fertilizer and soil nutrient for USA farmers,
- provides a useful product for controlling dust from unpaved roads and construction sites, and
- provides a valuable product for maintaining winter roadway safety.

This Level I Anti-Degradation Review evaluates the environmental impact the proposed steam plant wastewater discharge will have upon the Great Salt Lake and whether this discharge will impair any of the Lake's existing beneficial uses that are protected by state and federal regulations.

# **Beneficial Use**

The Great Salt Lake has its own dedicated beneficial use. The Great Salt Lake is listed as a Class 5 water body (UAC R317-2, 2012). The Great Salt Lake is comprised of the five following areas: Bear River Bay, Farmington Bay, Gilbert Bay, Gunnison Bay, and the associated Great Salt Lake fringe including adjacent wetlands. The area of the Great Salt Lake where the proposed steam generation plant discharge is going to be located is within the Bear River Bay area. The Great Salt Lake / Bear River Bay beneficial use category is listed as 5C and is defined as:

Protected for infrequent primary and secondary contact recreation, waterfowl, shore birds and other water-oriented wildlife including their necessary food chain. (Utah Administrative Code R317-2-6.5.c)

Water quality standards are typically developed with the intent to protect the designated beneficial uses of a surface water body, such as the Class 5C beneficial use for Great Salt Lake / Bear River Bay.

# **Water Quality Standards**

In most waters of Utah there are both numeric water quality standards and narrative standards. The sole numeric water quality standard that has been developed to date for the Great Salt Lake is a numerical criterion for selenium within the Gilbert Bay area of the Lake.

In the Bear River Bay area of the Great Salt Lake there is only a narrative water quality standard. The current narrative standard is:

It shall be unlawful, and a violation of these regulations, for any person to discharge or place any waste or other substance in such a way as will be or may become offensive such as unnatural deposits, floating debris, oil, scum or other nuisances such as color, odor or taste; or cause conditions which produce undesirable aquatic life or which produce objectionable tastes in edible aquatic organisms; or result in concentrations or combinations of substances which produce undesirable physiological responses in desirable resident fish, or other desirable aquatic life, or undesirable human health effects, as determined by bioassay or other tests performed in accordance with standard procedures. (Utah Administrative Code R317-2-7.2)

A conventional Level I review would compare the numeric water quality standards to the proposed discharge. Because there are no current numeric standards for the comparison, a different approach will be used in which the beneficial uses of the Great Salt Lake will be evaluated for potential impact from the proposed discharge.

# **Discharge Water Characteristics**

Since the new boilers have not been constructed, it was not possible to test for the 126 priority pollutants per 40 CFR 122.21(k)(5). The engineering calculations done for this Level I ADR meet the intent of 40 CFR 423.15(j)(3) and 40 CFR 122.21(k)(5).

The previously-submitted permit application is reproduced in Appendix A. The mass balance for both the design peak flow and the average flow are included in the application. As noted previously, materials are added in the process to protect the boilers from scale and corrosion. The Material Safety Data Sheets (MSDS) and associated "Fact Sheets" for these materials are included in Appendix B. The process used to pretreat the boiler water and the blowdown from the boiler may concentrate the trace contaminants in the source water to a higher level. Therefore, a major part of this review is to look at the potential concentration of the contaminants in the wastewater discharge stream. The principal contaminants are metals inherently present in the Weber Basin source water in trace concentrations.

The wastewater discharge from the boilers will empty into an open ditch and flow over two miles before discharging through Outfall 001 into Bear River Bay. Because of the time needed for the wastewater to traverse this distance and the ability of the ground and air to cool the wastewater during its travel, the temperature of the boiler wastewater is expected to be ambient upon reaching the Bear River Bay.

# Metals

Over many years of sampling the Bear River Bay, the UDWQ has compiled a database of laboratory analyses documenting the background concentrations for metals of concern. This ADR assumes that the list of metals analyzed and compiled in the database represents the metals of concern for protecting the beneficial use of the Bear River Bay area. Accordingly, the effluent from the steam plant will be compared to this list.

The determination of the steam plant's effluent concentrations is based on a simple mass balance from the influent water to the steam generation plant. The influent water is the facility's potable water supply from the Weber Basin Water Conservancy District, so a sample was taken from a cold water sink faucet in the administration building's break room. A separate sample, to be analyzed for mercury, was also collected for an EPA Method 1631 analysis, including a transportation blank. The break room sample was not analyzed for all background metals contained in UDWQ's database for Bear River Bay. To fill in the gap, two additional water samples were obtained from potable water sink dispensers at the existing PacifiCorp power plant and also from GSLM's Magnesium Chloride Plant. These samples were not taken using the procedure compatible with EPA Method 1631, so an ultra-low mercury analysis was not performed. Due to an oversight, potassium and nickel were not analyzed in any of the potable water samples. The results are summarized in the following table. The analytical results can be found in Appendix D.

Table 1 – GSLM Source Water Sample Results Summary

	Admin Break Room Sink (mg/L)	Power Plant Sink (mg/L)	Mag Plant Sink (mg/L)	Minimum Reporting Limit (mg/L)	Average <sup>1</sup> (mg/L)
Aluminum		ND	ND	0.05	ND
Arsenic	0.0011	0.0009	0.0010	0.0005	0.001
Boron		ND	ND	0.05	ND
Calcium		69.5	63.0	0.2	66.3
Cadmium	7 <u>. II</u> 11 = _	ND	ND	0.0005	ND
Chromium	0.0026	0.0037	0.0044	0.0005	0.0036
Copper	0.0086	0.0155	0.0997	0.001	0.0413
Iron		0.10	ND	0.02	0.06
Lead	ND	0.0041	ND	0.0005	0.0017
Mercury	0.0000012			0.000005	0.0000012
Magnesium		17.7	16.0	0.2	16.9
Manganese		0.0083	0.0039	0.0005	0.0061

Selenium	0.0025	0.0018	0.0021	0.0005	0.0021
Silver		ND	ND	0.0005	ND
Sodium		30.9	27.8	0.5	29.4
Zinc	0.03	0.37	ND	0.01	0.14

ND - Non-Detectable

(1) The MRL value was substituted for ND in the averaging for values above the MRL

The water pretreatment system for the steam generation plant has water softeners which may remove some of the metal ions and exchange these for sodium ions. However, for the mass balance it is assumed that the mass from the background trace contaminants are all discharged through the wastewater stream. The flow into the boiler pretreatment system is assumed to be 433 gpm. The combined wastewater from the pretreatment system and boiler blowdown will be about 37 gpm and is assumed to contain all of the potable water's metal contaminants.

**Table 2 – Steam Plant's Mass Balance for Metals** 

· · · · · · · · · · · · · · · · · · ·	Table 2 – Steam Flant 5 Wass balance for Wetais					
Q <sup>1</sup>	Potable Water Influent (mg/L)	Wastewater (RO Discharge) <sup>1</sup> (mg/L)	Wastewater Mass Loading <sup>2</sup> (lb/day)			
Aluminum	ND					
Arsenic	0.001	0.012	0.0052			
Boron	ND					
Calcium	66.3	775	345			
Cadmium	ND					
Chromium	0.0036	0.042	0.019			
Copper	0.0413	0.483	0.215			
Iron	0.06	0.70	0.31			
Lead	0.0017	0.020	0.0088			
Mercury	0.0000012	0.000014	0.0000062			
Magnesium	16.9	197	87.7			
Manganese	0.0061	0.071	0.032			
Selenium	0.0021	0.025	0.011			
Silver	ND					
Sodium	29.4	343	153			
Zinc	0.14	1.6	0.71			

ND – Non-Detectable

The collection of UDWQ sample results for Bear River Bay have been compiled and sorted in Appendix C. The average was used to represent the background concentration for Bear River Bay. In calculating the average, one-half of the detection limits were assumed for non-detects, provided the sample set

<sup>(1)</sup> Wastewater Concentration = Influent Concentration \* 433 gpm/37 gpm

<sup>(2)</sup> Mass Loading (lb/day) = WW Conc x 37 gpm x 60 min/hr x 24 hr/day x (3.785 L/gal) x (1 lb/453,600 mg)

included at least one analytical result above the detection limit. The data is summarized in the following table, along with the expected concentrations from the proposed steam plant discharge.

Table 3 – Comparison of Bear River Bay Background Concentrations to Proposed Discharge

Metal	Bear River Bay Background Concentration (ug/L) <sup>1</sup>	Steam Plant Discharge Concentration (ug/L) <sup>1</sup>
Aluminum	132	ND
Arsenic	87	12.9
Barium	138	936 <sup>2</sup>
Boron	33175	ND
Cadmium	2	ND
Calcium	129 mg/L	775 mg/L
Chromium	55	42
Copper	41	483
Iron	31	700
Lead	7	20
Magnesium	3191 mg/L	197 mg/L
Manganese	92	71
Mercury	0.106	0.014
Nickel	ND	(Not Analyzed)
Potassium	1790 mg/L	(Not Analyzed)
Selenium	21.9	25
Silver	4	ND
Sodium	17043 mg/L	343 mg/L
Zinc	82	1600

ND - Non-detectable

From the mass balance data, the only metals discharged from the steam plant that are expected to be above the background concentration of Bear River Bay are barium, calcium, copper, iron, lead, selenium, and zinc.

# **Boiler Treatment Materials**

The boiler recycle/condensate stream shall be treated with conventional boiler treatment materials for scale control and corrosion inhibition. The principal agents are: OptiSperse ADJ561 (sodium hydroxide buffering agent), CorTrol IS3000 (sodium bisulfate corrosion inhibitor), and OptiSperse AP0200 (polymeric dispersant with molybdate tracer) – all of which are aqueous solutions and water soluble. MSD Sheets and associated "Fact Sheets" for these materials are provided in Appendix B.

OptiSperse ADJ561 is an alkaline water-based buffering agent containing sodium hydroxide as the active ingredient. This product is designed to prevent build-up of scale within the boiler tubes. It is expected that the pH level of the boiler blowdown will be approximately 9; when coupled with the backwash from

<sup>(1)</sup> Units of measure in ug/L (ppb) unless otherwise noted

<sup>(2)</sup> Barium analysis used was from Weber Basin South's reported value (Appendix E)

the water softening and carbon filtration pretreatment systems and the reverse osmosis (RO) reject water, the pH value of the effluent from the steam generation plant is expected to be <9 and within the facility's existing UPDES pH effluent limitation of 6.5 - 9.0. The effluent pH shall be protective to the water quality of the Great Salt Lake / Bear River Bay.

CorTrol IS3000 is an oxygen scavenger agent containing sodium bisulfate as the active ingredient. This product is designed to inhibit corrosion within the boiler tubes. It is expected that the dissolved oxygen level of the boiler blowdown may be reduced as a result of use of this product. However, when coupled with the backwash from the water softening and carbon filtration pretreatment systems and RO reject water, the dissolved oxygen level of the effluent from the steam generation plant is expected to be protective to the water quality of the Great Salt Lake / Bear River Bay.

OptiSperse AP0200 is polymeric dispersant agent containing molybdate as a tracer. This product is designed to prevent the formation of sludge and hardness deposits within the boiler tubes. It is expected that the boiler blowdown may contain de minimis levels of molybdenum as a result of use of this product. When coupled with the backwash from the water softening and carbon filtration pretreatment systems and RO reject water, the molybdenum concentration of the effluent from the steam generation plant is expected to be de micromis and protective to the water quality of the Great Salt Lake / Bear River Bay.

The peak discharge flow from water supply pretreatment and boiler operations is estimated to be 90,000 gals/day (0.09 MGD) with approximately 13,000 gals/day (0.013 MGD) attributed to boiler blowdown; the average discharge flow is estimated to be 53,000 gals/day (0.05 MGD) with approximately 9,000 gals/day (0.009 MGD) attributed to boiler blowdown. This discharge shall be to the facility's existing drainage ditch leading to Outfall 001. The facility's existing average effluent flow to Outfall 001 is 3.8 MGD (from CY2011 UPDES data). Thus, the daily flow contribution from the water supply pre-treatment and boiler operations shall be approximately 2% of the facility's existing effluent flow. The impact of the above boiler treatment materials and the influence on pH, dissolved oxygen, and potentially detectable levels of molybdenum shall be minimized by the facility's existing effluent flow.

# COD

The key ingredient in CorTrol 3000 ultimately becomes sulfite (SO3<sup>-2</sup>) and reacts with oxygen. The stoichiometry of the reaction is 1 ppm oxygen per 5 ppm sulfite. It is assumed the maximum concentration of sulfite will be 60 mg/l at the discharge of the boilers. This will require the addition of 12 ppm of oxygen to meet the oxygen demand. The average sulfite concentration should be around 30 mg/l, which will require the addition of 6 ppm of oxygen to meet the oxygen demand. In addition it is assumed that aeration will be required to increase the dissolved oxygen to 4-5 ppm prior to discharge. This will be accomplished with a re-aeration system.

# **Pollutants of Concern**


Based on this Level I anti-degradation review, there are a few pollutants/parameters of potential concern. These are primarily associated with the boiler treatment materials. The subject pollutants / parameters are listed below:


- 1. pH already monitored within facility's existing UPDES permit and this should continue.
- 2. Dissolved Oxygen (DO) potentially reduced DO levels in the effluent should require monitoring to affirm and if affirmed, consideration should be given to aeration of effluent to increase DO to acceptable level.
- 3. Molybdate / molybdenum potentially detectable levels of this metal in its oxidized state should require monitoring to affirm and if affirmed, comparison be made to background concentrations in the Bear River Bay of the Great Salt Lake. This may require sampling within the Bear River Bay to establish background concentrations.

Appendix A
Permit Application

FORM	te type, i.e., 12 char			ONMENTAL F	ROT				EDA LD MI			30 01 02
	TOA .			RAL INF		the second second second second		S	EPA I.D. NU	WIDE		T/A C
1   <del>                                   </del>	PA			idated Pe				F	UTD041	5710	92 [	D
GENERAL				eral Instru				) 1	2		13	14 15
LABEL ITEMS								lf a	GENERAL a preprinted la			
I. EPA I.D. NUMBER								affi	ix it in the designment	nated s	pace.	Review the
III. FACILITY NAME	I. EPA I.D. NUMBER  III. FACILITY NAME  III. FACILITY NAME								till-in area ited data is the lehel			
V. FACILITY MAILING LIST	PLEASE	PLA	CE	LABEL	IN	THIS S	PACE	spa ap in	ace <i>lists the</i> pear), please t area(s) below.	informa provide If the	<i>tion t</i> it in the label is	proper fill- complete
VI. FACILITY LOCATION								if r ins	d correct, you ll, V, and V(e) mpleted regard to label has be tructions for d for the legal and the	(cept Villess). (cept villesss). (cept villess). (cept villess). (cept villess). (cept villess	Comple red. R item d ation u	te all items efer to the escriptions nder which
II. POLLUTANT CHARA	ACTERISTICS			AND ESTA	NAME OF			thi	s data is collec	ted.		
INSTRUCTIONS: Complete questions, you must submit the supplemental form is attacexcluded from permit requirer	A through J to deternish form and the sup ched. If you answer	mine w plement "no" to C of the	hether tal fron each o	you need to n listed in the question, you ctions. See a	subi pare nee	mit any permenthesis follo d not submit Section D of	nit application of the quality of the instruction o	on forms uestion. se forms tions for	s to the EPA. Mark "X" in the You may an definitions of b	f you are box in swer "no	iswer " the thi o" if you	yes" to any rd column if ur activity is
SPECIFIC QUEST			MARI	( "X"		STONE WAS DUSSELLE	ECIFIC QUI				MARK	("X"
		YES	NO	FORM ATTACHED						YES	NO	FORM ATTACHED
A. Is this facility a publicly own which results in a discharg U.S.? (FORM 2A)	ed treatment works the to waters of the		X		B.	proposed) i feeding o production	nclude a peration facility which	concent or aqu h results	in a discharge		X	
C. Is this facility which co	urrently results in	16	17	18	D.		al facility (of	ther than t	hose described	19 X	20	21  X
discharges to waters of t those described in A or B abo	ve? (FORM 2C)	22	23	24		to waters of	the U.S.? (F	ORM 2D		25	26	27
E. Does or will this facility treat, hazardous wastes? (FORM	, store, or dispose of 3)		X		F.	municipal eff containing, v bore, underg	fluent below within one a	the lower	lity industrial or ermost stratum ile of the weil rinking water?		X	
G. Do you or will you inject	at this facility any	28	29	30	Н.	(FORM 4) Do you or wil	l you inject a	at this faci	lity fluids for	31	32	33
produced water other fluids with a surface in connection with natural gas production, injury enhanced recovery of oil or	h conv entional oil or lect fluids used for natural gas, or inject		X			special proce Frasch proce situ combusti geothermal e	sses such asss, solution r ion of fossil f	s mining of mining of fuel, or re	of suifer by the minerals, in		X	
fluids for storage of lic (FORM 4)  I. Is this facility a proposed		34	35	36		la 41- 40				37	38	39
which is one of the 28 indus in the instructions and which 100 tons per year of any ai under the Clean Air Act a	trial categories listed will potentially emit poliutant regulated and may affect or be		X		J.	which is NO listed in the emit 250 to requiated un	Tone of the instructions a per year der the Clea	28 indus and which ar of an	ionary source strial categories will potentially y air pollutant and may affect		X	
lil. NAME OF FACILITY	a? (FORM 5)	40	41	42		or be located	in an attain	ment are	? (FORM 5)	43	44	45
C SKIP Creat	Salt Lake	Mine	ral	s Corn	ora	ation				n-last-		
15 16-29 30	sare Eane		Lai	p corb		ACTOII		100 TO 100	eur meen westellen		69	
IV. FACILITY CONTAC		Mix dig										
C Howick, Bry	NAME & TITLE (las						801	73	area code & no	191		
2 HOWICK, BLY	all; Mallage	t E	145	art Extraces	10000		46 48	6509P	51 52			
V. FACILITY MAILING												
c 765 North 10	A.STREET OR F 0500 West	P.O. BO	X									
15   16 B. (	CITY OR TOWN				C. :	STATE	D. ZIP CO	ODE				
C Ogden						JT	84404	-				
15 16				40	41	42	47	51				
VI. FACILITY LOCATION	OUTE NO. OR OTH	ER SPE	CIFIC	IDENTIFIER	1							
c 765 North												
15 16	5   15   16   45											
Weber	COUNTY NAME											
46	OITY OF TOWAL		TO THE	70		D ATT		710.00	SET E COLU	m57.5.5	~=-	
COccion	CITY OR TOWN				10.5%	D. STATE	-	ZIP COI 34404		HY CO	DE	
6 Ogden		R. Dabrino	WHO S	40		UT 41 42	W0000	94404	900	54		

VII. SIC CODES (4-digit, in order of priority)		1 12 A 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		The second secon
A. FIRST			B. SECOND	
7 2819 (specify) Inorganic Chemical	g 7 7	(spe	ecify)	
15 16 17	15	16 19		
C. THIRD (specify)	7	I (spe	D. FOURTH	
7 (5,55,7)	7	16 19	33,	
VIII. OPERATOR INFORMATION	1000	IO IB		的目录更具的主题。 1
6	NAME			B. Is the name listed in Item
8 Great Salt Lake Minerals	Corporati	on		VIII-A also the owner?
18 19 C. STATUS OF OPERATOR (Enter the appropriate letter in	nto the answer bo	(; if "Other," specify.)	D. PHON	IE (area code & no.)
F = FEDERAL M = PUBLIC (other than federal or state) S = STATE O = OTHER (specify)	P (specif		C	Ta. 2100
P = PRIVATE	56		A 801	731 3100
E. STREET OR PO BOX	1 30 1		1 10 10 10 1	119 21 22 25
765 N 10500 W				
26 F. CITY OR TOWN	G. STATE	H. ZIP CODE	IX. INDIAN LAN	ID Telephone
C Oqden	UT	84404	Is the facility located	on Indian lands?
15 16 40		47 51	☐ YES	☑ NO
X. EXISTING ENVIRONMENTAL PERMITS	D DOD (4)	New York	and Section 1	
A. NPDES (Discharges to Surface Water)	C T 8	Emissions from Prop		
9 N UT0000647	9 P 15 16 17	5700001002	2 30	
B. UIC (Underground Injection of Fluids		E. OTHER (specif		Specify)
9 U	9 T 8			
15 16 17 18 30 C. RCRA (Hazardous Wastes)	15 16 17	E. OTHER (specif	30	Specify)
C T II NA	C T 8	L. OTTILIT (Specif	/ Republication of the Control of th	opecity)
9 R NA 15 16 17 18 30	9 15 16 17	18	30	
XI. MAP  Attach to this application a topographic map of the				<b>的现在分类</b>
show the outline of the facility, the location of a hazardous waste treatment, storage, or disposal rivers and other surface water bodies in the map a XII. NATURE OF BUSINESS (provide a brief of	facilities, and earea. See instru	ach well where it in	njects fluids undergre	
Great Salt Lake Minerals Corpor	ration (GS	L) operates	a mineral re	ecovery facility
on the eastern shore of the so	uth arm of	the Great	Salt Lake nea	ar Oqden, Utah in
Weber County. This facility p	roduces so	dium chlori	de (NaCl), si	ilfate of notash
(SOP) (K2SO4), and magnesium cl				=
		•	-	-
salts, including halite (sodium				5 1
sulfate and magnesium sulfate :		_	-	
washed, wet-screened, dried, co	ooled, dry	-screened,	packaged, and	d shipped. The
mixed salt is washed, slurried	, thickene	d, crystall	ized, and con	nverted to K2SO4
which is then filtered, dried,	screened,	half granu	lated/compact	ted, and shipped
as sulfate of potash.	•	~		± ±
The same of possist.				
I certify under penalty of law that I have personall all attachments and that, based on my inquiry of the application, I believe that the information is t submitting false information, including the possibility.	those persons in true, accurate al lity of fine and in	mmediately respor nd complete. I an aprisonment.	nsible for obtaining th	ne information contained in re significant penalties for
A. NAME & OFFICIAL TITLE (type or print)	B. SIGNATUR	RE .		C. DATE SIGNED
2 12				
COMMENTS FOR OFFICIAL USE ONLY				
C				
46 40				






#EA/210/N2
3 07/39/15 88 18A BB
WO DVLE DESCRI DRYNN CHECKED
OBLIGHAFF


Compass Minerals, Ogden, Utah

AERIAL PHOTO STEAM GENERATION FACILITY PROPOSED OUTFALL LOCATION









Compass Minerals, Ogden, Utah

AERIAL PHOTO OUTFALL LOCATIONS



F-6

Please type or print in the unshaded areas only

EPA ID Number (Copy from Item 1 of Form 1) UTD041571092 Form Approved OMB No. 2040-0086 Approval expires 7-31-88

Form

2D NPDES



# New Sources and New Dischargers Application for Permit to Discharge Process Wastewater

# I. Outfall Location

For this outfall, list the latitude and longitude, and name of the receiving water(s)

Outfall		Latitude		Longitude Deg Min Sec			Receiving Water (name)	
Number (list)	Deg	Min	Sec			Sec	7	
001-B	41	16	43	112	13	57	Great Salt Lake, Through existing outfall 001-A	
				ı				

II. Discharge Date (When do you expect to begin discharging?))

# III. Flows, Sources of Pollution, and Treatment Technologies

A. For each outfall, provide a description of (1) all operations contributing wastewater to the effluent, including process wastewater, sanitary wastewater, cooling water, and stormwater runoff; (2) the average flow contributed by each operation; and (3) the treatment received by the wastewater. Continue on additional sheets if necessary.

Outfall . Number	Operations Contributing Flow     (list)	Average Flow (include units)	3. Treatment (Description of list Codes from Table 2D-1)
001-B	Boiler Ops. Discharge	(mondo dimo)	4 - A
			T A
			100
<b>-</b>			
	*		

В.	contributing wastewater to the effluent, and treatment units labeled to correspond to the more detailed descriptions in Item III-A. Construct a water balance on the line drawing by showing average flows between intakes, operations, treatment units, and outfalls. If a water balance cannot be determined (e.g., for certain mining activities), provide a pictorial description of the nature and amount of any sources of water and any collection or treatment measures. (See Sheets F1 and F2)							
C.	C. Except for storm runoff, leaks, or spills, will any of the discharges described in Item III-A be intermittent or seasonal?							or
		Yes (comp	lete the following ta		(go to Item IV) quency	T	2. Flow	
		Outfall Number		a. Days Per Week	b. Months Per Year	a. Maximum Daily Flow	b. Maximum Total Volume	c. Duration
		Number		(specify average)	(specify) average)	Rate (in mgd)	(specify with units)	(in days)
	oduction							
prod	duction lev	el, not designed	l), expressed in the	nt guideline or NSPS, for terms and units used in t also submit alternative es	he applicable effluent o	uideline or NSPS.	roduction (projecti for each of the fir	on of actual st 3 years of
Y	ear	a. Quantity Per Day	b. Units of Measure		c. Operation, Produc	ct, Material, etc <i>(sp</i>	ecify)	

	CONTINUED FROM THE FRONT	EPA ID Number (cop from Item 1 of Form 1) UTD041571092	Outfall Number 1A
1	V Effluent Characteristics		

A and B: These items require you to report estimated amounts (both concentration and mass) of the pollutants to be discharged from each of your outfalls. Each part of this item addresses a different set of pollutants and should be completed in accordance with the specific instruction for that part. Data for each outfall should be on a separate page. Attach additional sheets of paper if necessary.

General Instructions (See Table 2D-2 for Pollutants)

Each part of this item requests you to provide an estimated daily maximum and average for certain pollutants and the source of information. Data for all pollutants in Group A, for all outfalls, must be submitted unless waived by the permitting authority. For all outfalls, data for pollutants in Group B should be reported only for pollutants which you believe will be present or are limited directly by an effluent limitations guideline or NSPS or indirectly through

limitations on an indicator pollutant.

limitations on an indicator pollutant.  1. Pollutant	2. Maximum Daily Value (include units)	3. Average Daily Value (include units)	4. Source (see instructions)
BOD	0	0	
COD	12 mg/l	6 mg/l	Boiler Protection Chemicals
TOC	4.32 lbs	2.88 lbs	Boiler Water Treatment
TSS	0	0	
Flow	90,088 gpd	53,345 gpd	Boiler Water Treatment
Temperature (winter)	40 C	20 C	
Temperature (summer)	40 C	20 C	
рн	9	8	
Magnesium	96.68 lbs	63.7 lbs	From source water
Barium	0.32 lbs	0.21 lbs	From source water
Sulfate	420 lbs	279 lbs	From source water
Nitrate	2.1 lbs	1.4 lbs	From source water
Sulfite	17.9 lbs	11.5 lbs	Boiler Water Treatment
Molybdate	0.14 lbs	0.09 lbs	Boiler Water Treatment
State Co. 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 19			
			52 8
	177		

CONTINUED FROM THE FRONT	EPA ID Number (cop from Item 1 of Form 1) UTD041571092						
C. Use the space below to list any of the pollutants listed in Table 2D-3 of the instructions which you know or have reason to believe will be discharged from any outfall. For every pollutant you list, briefly describe the reasons you believe it will be present.							
Pollutant	2. Reason for Discharge						
	2. Negavirui Discharge						
VI. Engineering Report on Wastewater Tre	atment						
If there is any technical evaluation concern appropriate box below.      Report Available	ing your wastewater treatment, including engineering reports or pilot plant studies, check the  No Report  If any existing plant(s) which, to the best of your knowledge, resembles this						
production facility with respect to page Name	roduction processes, wastewater constituents, or wastewater treatments.  Location						

EPA ID Number (cop from Item 1 of Form 1) UTD041571092

VII. Other Information (Optional)	学和对于 医外侧侧 医二种
Use the space below to expand upon any of the above questions or to bring to the attention	n of the reviewer any
other information you feel should be considered in establishing permit limitations for the pro	posed facility. Attach
additional sheets if necessary.	
See the attached page labeled - VII. Other Information	
	1
	1
	3
	1
	1
VIII. Certification	<b>阿里米多斯</b> 法教及第二個產業董
I Certify under penalty of law that this document and all attachments were prepared u	
supervision in accordance with a system designed to assure that qualified personnel	properly gather and
evaluate the information submitted. Based on my inquiry of the person or persons who me	
those persons directly responsible for gathering the information, the information submitted	
knowledge and belief, true, accurate, and complete. I am aware that there are sign submitting false information, including the possibility of fine and imprisonment for knowing	
A. Name and Official Title (type or print)	VIOIATIONS.  B. Phone No.
Since Since (Appe or printy)	( )
C. Signature	D. Date Signed
· · ·	

# VII. Other Information

The basis for the boilers in this permit application is the generation of steam in support of sulfate of potash (SOP) and magnesium chloride plant operations. The Little Mountain Power Plant, owned and operated by PacifiCorp, previously supplied steam to the Great Salt Lake Minerals (GSLM) facility under a long-term supply agreement. PacifiCorp is terminating its supply agreement with GSLM and permanently shutting down the Little Mountain Power Plant. This will require GSLM to install and operate boilers to sustain the steam supply needs of its facility.

GSLM shall purchase two (2) boilers each having a heat input capacity of 110 mmBtu/hr and an output capacity of 90,000 lb/hr steam. Both boilers will be fired with clean-burning natural gas.

Input streams to the boilers shall be supply water and natural gas. Output streams from the boilers shall be steam, excess water (i.e., blowdown), and emission products from natural gas combustion. GSLM has already submitted to the Utah Department of Environmental Quality, Division of Air Quality, the necessary paperwork for the air quality emissions. Issuance of that Approval Order is presently pending.

In any boiler operation, pretreatment of the water supply source prior to input into the boiler is critical; this prevents adverse mechanical/thermal & maintenance issues to the boiler. Such is the case with the GSLM boilers and the water supply source. The water shall be supplied from the Weber Basin Water Conservancy District. The supply water shall undergo a 3-stage pretreatment prior to input into the boilers. The 3 stages shall be: water softening, carbon filtration, and reverse osmosis. These 3 stages shall collectively provide demineralization, solids removal, and purification of the water. After input of the pretreated source water into the boiler, the boiler recycle/condensate stream shall be treated with conventional buffering agents for scale control and corrosion inhibition within the boiler.

The peak discharge flow from water supply pretreatment and boiler operations is estimated to be 90,000 gals/day (0.09 MGD); the average discharge flow is estimated to be 53,000 gals/day (0.05 MGD). This discharge shall be to the facility's existing drainage ditch leading to Outfall 001. The facility shall have the capability to sample and monitor the discharge from water supply pretreatment and boiler operations prior to the confluence with the outfall drainage ditch. The facility's existing average effluent flow to Outfall 001 is 3.8 MGD (from CY2011 UPDES data). Thus, the daily flow contribution from the water supply pretreatment and boiler operations shall be approximately 2% of the facility's existing effluent flow.

In comparison to the age of the Little Mountain Power Plant and its boilers (reportedly 40+ years-old), the new GSLM boilers shall be manufactured and equipped with contemporary technological advancements & controls. As a result, though not specifically quantified, it is expected that the air emissions and water discharges shall be significantly improved in terms of reduced rates and concentrations. The Anti-Degradation Review document provides more detail of such environmentally-beneficial reductions.

# Appendix B Fact Sheets & MSD Sheets for Boiler Treatment Materials



# GE Water & Process Technologies

# Material Safety Data Sheet

# **OPTISPERSE ADJ561**

Issue Date: 25-JAN-2012 Supercedes: 21-SEP-2011

# 1 Identification

Identification of substance or preparation OPTISPERSE ADJ561

Product Application Area Internal boiler treatment.

Company/Undertaking Identification GE Betz, Inc. 4636 Somerton Road Trevose, PA 19053 T 215 355-3300, F 215 953 5524

Emergency Telephone (800) 877-1940

Prepared by Product Stewardship Group: T 215-355-3300 Prepared on: 25-JAN-2012

# 2 Hazard(s) identification

### EMERGENCY OVERVIEW

## DANGER

Corrosive to skin. Corrosive to the eyes. Mists/aerosols cause irritation to the upper respiratory tract.

DOT hazard: Corrosive to skin Odor: Mild; Appearance: Colorless, Liquid

Fire fighters should wear positive pressure self-contained breathing apparatus(full face-piece type). Proper fire-extinguishing media: dry chemical, carbon dioxide, foam or water

# POTENTIAL HEALTH EFFECTS

# ACUTE SKIN EFFECTS:

Primary route of exposure; Corrosive to skin.

# ACUTE EYE EFFECTS:

Corrosive to the eyes.

# ACUTE RESPIRATORY EFFECTS:

Mists/aerosols cause irritation to the upper respiratory tract.

# INGESTION EFFECTS:

### Toxic;

May cause severe irritation or burning of mouth, throat, and gastrointestinal tract with severe chest and abdominal pain, nausea, vomiting, diarrhea, lethargy and collapse. Possible death when ingested in very large doses.

# TARGET ORGANS:

Prolonged or repeated exposures may cause primary irritant dermatitis and/or tissue necrosis.

### MEDICAL CONDITIONS AGGRAVATED:

Not known.

### SYMPTOMS OF EXPOSURE:

Causes severe irritation, burns or tissue ulceration with subsequent scarring.

# 3 Composition / information on ingredients

Information for specific product ingredients as required by the U.S. OSHA HAZARD COMMUNICATION STANDARD is listed. Refer to additional sections of this MSDS for our assessment of the potential hazards of this formulation.

### HAZARDOUS INGREDIENTS:

Cas# Chemical Name Range(w/w%)

1310-73-2 SODIUM HYDROXIDE 40-70

Corrosive; toxic (by ingestion)

# 4 First-aid measures

# SKIN CONTACT:

URGENT! Wash thoroughly with soap and water. Remove contaminated clothing. Get immediate medical attention. Thoroughly wash clothing before reuse.

# EYE CONTACT:

URGENT! Immediately flush eyes with plenty of low-pressure water for at least 20 minutes while removing contact lenses. Hold eyelids apart. Get immediate medical attention.

# INHALATION:

If nasal, throat or lung irritation develops - remove to fresh air and get medical attention.

### INGESTION:

Do not feed anything by mouth to an unconscious or convulsive victim. Do not induce vomiting. Immediately contact physician. Rinse mouth with plenty of water. Dilute contents of stomach using 4-10 fluid ounces (120-300 mL) of milk or water.

# NOTES TO PHYSICIANS:

Material is corrosive. It may not be advisable to induce vomiting. Possible mucosal damage may contraindicate the use of gastric lavage.

# 5 Fire-fighting measures

### FIRE FIGHTING INSTRUCTIONS:

Fire fighters should wear positive pressure self-contained breathing apparatus (full face-piece type).

### EXTINGUISHING MEDIA:

dry chemical, carbon dioxide, foam or water HAZARDOUS DECOMPOSITION PRODUCTS:

none identifed

FLASH POINT:

> 200F > 93C SETA(CC)

### MISCELLANEOUS:

Corrosive to skin

UN 1824; Emergency Response Guide #154

# 6 Accidental release measures

### PROTECTION AND SPILL CONTAINMENT:

Ventilate area. Use specified protective equipment. Contain and absorb on absorbent material. Place in waste disposal container. Flush area with water. Wet area may be slippery. Spread sand/grit. DISPOSAL INSTRUCTIONS:

Water contaminated with this product may be sent to a sanitary sewer treatment facility, in accordance with any local agreement, a permitted waste treatment facility or discharged under a permit. Product as is - Incinerate or land dispose in an approved landfill.

# 7 Handling and storage

# HANDLING:

Alkaline. Corrosive(Skin/eyes). Do not mix with acidic material.  $\ensuremath{\mathtt{STORAGE}}$ :

Keep containers closed when not in use. Do not freeze. If frozen, thaw and mix completely prior to use.

# 8 Exposure controls / personal protection

EXPOSURE LIMITS

## CHEMICAL NAME

SODIUM HYDROXIDE

PEL (OSHA): 2 MG/M3

TLV (ACGIH): TWA (Ceiling) = 2 MG/M3

### ENGINEERING CONTROLS:

Adequate ventilation to maintain air contaminants below exposure limits.

# PERSONAL PROTECTIVE EQUIPMENT:

Use protective equipment in accordance with 29CFR 1910 Subpart I RESPIRATORY PROTECTION:

A RESPIRATORY PROTECTION PROGRAM THAT MEETS OSHA'S 29 CFR 1910.134 AND ANSI Z88.2 REQUIREMENTS MUST BE FOLLOWED WHENEVER WORKPLACE CONDITIONS WARRANT A RESPIRATOR'S USE.

USE AIR PURIFYING RESPIRATORS WITHIN USE LIMITATIONS ASSOCIATED WITH THE EQUIPMENT OR ELSE USE SUPPLIED AIR-RESPIRATORS.

If air-purifying respirator use is appropriate, use any of the following particulate respirators: N95, N99, N100, R95, R99, R100, P95, P99 or P100.

### SKIN PROTECTION:

gauntlet-type rubber, butyl or neoprene gloves, chemical resistant apron -- Wash off after each use. Replace as

### EYE PROTECTION:

splash proof chemical goggles, face shield

# 9 Physical and chemical properties

Spec. Grav. (70F, 21C) 1.527 Vapor Pressure (mmHG) Freeze Point (F) ~ 50 Vapor Density (air=1) < 1.00 Freeze Point (C) Viscosity(cps 70F,21C) % Solubility (water) 100.0

Odor Mild Appearance Colorless Physical State Liquid Flash Point SETA(CC) > 200F > 93C pH 5% Sol. (approx.) 13.4 Evaporation Rate (Ether=1) < 1.00 Percent VOC: 0.0

NA'= not applicable ND = not determined

# 10 Stability and reactivity

## CHEMICAL STABILITY:

Stable under normal storage conditions.

# POSSIBILITY OF HAZARDOUS REACTIONS:

Contact with strong acids may cause a violent reaction releasing

# INCOMPATIBILITIES:

May react with acids.

# DECOMPOSITION PRODUCTS:

none identifed

# 11 Toxicological information

Oral LD50 RAT: 280 mg/kg

NOTE - Calculated value according to GHS additivity formula

Dermal LD50 RABBIT: 2700 mg/kg

NOTE - Calculated value according to GHS additivity formula

Inhalation LC50 RAT: >40 mg/m3/hr
Skin Irritation Score RABBIT: CORROSIVE

NOTE - DOT HM181 Packing Group II: corrosive to skin in 60 minutes

but not 3 minutes

Eye Irritation Score RABBIT: CORROSIVE

NOTE - Estimated value

# 12 Ecological information

## AQUATIC TOXICOLOGY

Ceriodaphnia 48 Hour Static Acute Bioassay (pH adjusted)
LC50= 2480; 10% Mortality= 1785 mg/L

Daphnia magna 48 Hour Static Screen
100% Mortality= 500; 5% Mortality= 100 mg/L

Daphnia magna 48 Hour Static Screen (pH adjusted)
100% Mortality= 10000; 5% Mortality= 5000 mg/L

Fathead Minnow 96 Hour Static Bioassay with 48-Hour Renewal
100% Mortality= 200; 0% Mortality= 50 mg/L

Fathead Minnow 96 Hour Static Bioassay with 48-Hour Renewal (pH adjusted)
45% Mortality= 10000; 0% Mortality= 5000 mg/L

Rainbow Trout 96 Hour Static Bioassay with 48-Hour Renewal (pH adjusted)
0% Mortality= 10000 mg/L

### BIODEGRADATION

Product contains only inorganics that are not subject to typical biological degradation. Assimilation by microbes may occur in waste treatment or the environment.

# 13 Disposal considerations

If this undiluted product is discarded as a waste, the US RCRA hazardous waste identification number is : D002=Corrosive(pH).

Please be advised; however, that state and local requirements for waste disposal may be more restrictive or otherwise different from federal regulations. Consult state and local regulations regarding the proper disposal of this material.

# 14 Transport information

Transportation Hazard: Corrosive to skin

DOT: SODIUM HYDROXIDE SOLUTION

8, UN1824, PG II, RQ

DOT EMERGENCY RESPONSE GUIDE #: 154

Note: Some containers may be DOT exempt, please check BOL for

exact container classification

IATA: SODIUM HYDROXIDE SOLUTION

8, UN1824, PG II

IMDG: SODIUM HYDROXIDE SOLUTION

8, UN1824, PG II

# 15 Regulatory information

TSCA:

All components of this product are included on or are in compliance with the U.S. TSCA regulations.

CERCLA AND/OR SARA REPORTABLE QUANTITY (RQ):

157 gallons due to SODIUM HYDROXIDE;

FOOD AND DRUG ADMINISTRATION:

ALL ingredients in this product are authorized in 21CFR173.310

for use as boiler water additives where the steam may contact food.

# NSF Registered and/or meets USDA (according to 1998 Guidelines):

Registration number: 140699

Category Code(s):

- Gl General
- G5 Cooling and retort water treatment products all food processing areas
- G6 Boiler treatment products all food processing areas/food contact

### SARA SECTION 312 HAZARD CLASS:

Immediate(acute); Delayed(Chronic); Reactive

SARA SECTION 302 CHEMICALS:

No regulated constituent present at OSHA thresholds

SARA SECTION 313 CHEMICALS:

No regulated constituent present at OSHA thresholds  ${\bf CALIFORNIA}$   ${\bf REGULATORY}$   ${\bf INFORMATION}$ 

CALIFORNIA SAFE DRINKING WATER AND TOXIC

ENFORCEMENT ACT (PROPOSITION 65):

No regulated constituents present

### MICHIGAN REGULATORY INFORMATION

No regulated constituent present at OSHA thresholds

# 16 Other information

HMIS VII COI	Œ	TRANSLATION
--------------	---	-------------

Health	3	Serious Hazard
Fire	0 =	Minimal Hazard
Reactivity	1	Slight Hazard
Special	CORR	DOT corrosive
(1) Protective Equipment	D	Goggles, Face Shield, Gloves, Apron

<sup>(1)</sup> refer to section 8 of MSDS for additional protective equipment recommendations.

# CHANGE LOG

	EFFECTIVE		
	DATE	REVISIONS TO SECTION:	SUPERCEDES
MSDS status:	26-FEB-1997		** NEW **
	18-MAR-1997	15	26-FEB-1997
	03-OCT-1997	8	18-MAR-1997
	01-MAY-1998	15;EDIT:9	03-OCT-1997
	02-JUN-2000	12	01-MAY-1998
	11-OCT-2001	4,16	02-JUN-2000
	26-MAY-2006	8	11-OCT-2001
	13-MAY-2009	4,8	26-MAY-2006
	26-MAY-2009	4,5,8,10	13-MAY-2009
	17-JUN-2009	15	26-MAY-2009
	21-SEP-2011	11	17-JUN-2009
	25-JAN-2012	3,16	21-SEP-2011



# GE Water & Process Technologies

# Material Safety Data Sheet

# **OPTISPERSE AP0200**

Issue Date: 17-JUN-2009 Supercedes: 15-MAY-2009

# 1 Identification

Identification of substance or preparation OPTISPERSE AP0200

Product Application Area
Water based internal boiler treatment chemical.

Company/Undertaking Identification GE Betz, Inc. 4636 Somerton Road Trevose, PA 19053 T 215 355-3300, F 215 953 5524

Emergency Telephone (800) 877-1940

Prepared by Product Stewardship Group: T 215-355-3300 Prepared on: 17-JUN-2009

# 2 Hazard(s) identification

### EMERGENCY OVERVIEW

### CAUTION

May cause slight irritation to the skin. May cause slight irritation to the eyes. Mists/aerosols may cause irritation to upper respiratory tract.

DOT hazard is not applicable Odor: Mild; Appearance: Light Yellow To Amber, Liquid

Fire fighters should wear positive pressure self-contained breathing apparatus(full face-piece type). Proper fire-extinguishing media: dry chemical, carbon dioxide, foam or water

# POTENTIAL HEALTH EFFECTS

### ACUTE SKIN EFFECTS:

Primary route of exposure; May cause slight irritation to the skin.

# ACUTE EYE EFFECTS:

May cause slight irritation to the eyes.

# ACUTE RESPIRATORY EFFECTS:

Mists/aerosols may cause irritation to upper respiratory tract.

### INGESTION EFFECTS:

May cause slight gastrointestinal irritation.

### TARGET ORGANS

No evidence of potential chronic effects.

### MEDICAL CONDITIONS AGGRAVATED:

Not known.

### SYMPTOMS OF EXPOSURE:

May cause redness or itching of skin.

# 3 Composition / information on ingredients

Information for specific product ingredients as required by the U.S. OSHA HAZARD COMMUNICATION STANDARD is listed. Refer to additional sections of this MSDS for our assessment of the potential hazards of this formulation.

### HAZARDOUS INGREDIENTS:

This product is not hazardous as defined by OSHA regulations.

No component is considered to be a carcinogen by the National Toxicology Program, the International Agency for Research on Cancer, or the Occupational Safety and Health Administration at OSHA thresholds for carcinogens.

# 4 First-aid measures

# SKIN CONTACT:

Wash thoroughly with soap and water. Remove contaminated clothing. Get medical attention if irritation develops or persists.

### EYE CONTACT:

Remove contact lenses. Hold eyelids apart. Immediately flush eyes with plenty of low-pressure water for at least 15 minutes. Get medical attention if irritation persists after flushing.

### INHALATION:

If nasal, throat or lung irritation develops - remove to fresh air and get medical attention.

### INGESTION:

Do not feed anything by mouth to an unconscious or convulsive victim. Do not induce vomiting. Immediately contact physician. Dilute contents of stomach using 2-8 fluid ounces (60-240 mL) of milk or water.

# NOTES TO PHYSICIANS:

No special instructions

# 5 Fire-fighting measures

### FIRE FIGHTING INSTRUCTIONS:

Fire fighters should wear positive pressure self-contained breathing apparatus (full face-piece type).

### EXTINGUISHING MEDIA:

dry chemical, carbon dioxide, foam or water
HAZARDOUS DECOMPOSITION PRODUCTS:

oxides of carbon

FLASH POINT:

> 200F > 93C P-M(CC)

# 6 Accidental release measures

### PROTECTION AND SPILL CONTAINMENT:

Ventilate area. Use specified protective equipment. Contain and absorb on absorbent material. Place in waste disposal container. Flush area with water. Wet area may be slippery. Spread sand/grit. DISPOSAL INSTRUCTIONS:

Water contaminated with this product may be sent to a sanitary sewer treatment facility, in accordance with any local agreement, a permitted waste treatment facility or discharged under a permit. Product as is - Incinerate or land dispose in an approved landfill.

# 7 Handling and storage

### HANDLING:

Normal chemical handling.

### STORAGE:

Keep containers closed when not in use. Reasonable and safe chemical storage. Protect from freezing.

# 8 Exposure controls / personal protection

# EXPOSURE LIMITS

This product is not hazardous as defined by OSHA regulations.

# ENGINEERING CONTROLS:

adequate ventilation

# PERSONAL PROTECTIVE EQUIPMENT:

Use protective equipment in accordance with 29CFR 1910 Subpart I RESPIRATORY PROTECTION:

A RESPIRATORY PROTECTION PROGRAM THAT MEETS OSHA'S 29 CFR 1910.134 AND ANSI Z88.2 REQUIREMENTS MUST BE FOLLOWED WHENEVER WORKPLACE CONDITIONS WARRANT A RESPIRATOR'S USE.

USE AIR PURIFYING RESPIRATORS WITHIN USE LIMITATIONS ASSOCIATED WITH THE EQUIPMENT OR ELSE USE SUPPLIED AIR-RESPIRATORS.

If air-purifying respirator use is appropriate, use any of the following particulate respirators: N95, N99, N100, R95, R99, R100, P95, P99 or P100.

### SKIN PROTECTION:

rubber, butyl, viton or neoprene gloves -- Wash off after each use. Replace as necessary.

# EYE PROTECTION:

splash proof chemical goggles

# 9 Physical and chemical properties

Specific Grav. (70F, 21C) 1.085 Vapor Pressure (mmHG) ~ 18.0 Freeze Point (C) 19
Viscosit Vapor Density (air=1) < 1.00 Viscosity(cps 70F, 21C) 31 % Solubility (water) 100.0 Odor Appearance Light Yellow To Amber Physical State Liquid Flash Point P-M(CC) > 200F > 93C pH As Is (approx.) 11.2 Evaporation Rate (Ether=1) < 1.00 Percent VOC: ND

NA = not applicable ND = not determined

# 10 Stability and reactivity

CHEMICAL STABILITY:
Stable under normal storage conditions.

POSSIBILITY OF HAZARDOUS REACTIONS:
Contact with strong acids may cause a violent reaction releasing heat.

INCOMPATIBILITIES:
May react with strong oxidizers.

DECOMPOSITION PRODUCTS:
oxides of carbon

# 11 Toxicological information

```
Oral LD50 RAT: >2,000 mg/kg
NOTE - Estimated value

Dermal LD50 RABBIT: >2,000 mg/kg
NOTE - Estimated value
```

# 12 Ecological information

```
AQUATIC TOXICOLOGY

Ceriodaphnia 48 Hour Static Acute Bioassay

LC50= 5460; 0% Mortality= 4000 mg/L

Daphnia magna 48 Hour Static Screen

0% Mortality= 5000 mg/L

Fathead Minnow 96 Hour Static Bioassay with 48-Hour Renewal

0% Mortality= 5000 mg/L

BIODEGRADATION

BOD-28 (mg/g): 0
```

BOD-28 (mg/g): 0 BOD-5 (mg/g): 0 COD (mg/g): 339 TOC (mg/g): 91

# 13 Disposal considerations

If this undiluted product is discarded as a waste, the US RCRA hazardous waste identification number is:
Not applicable.

Please be advised; however, that state and local requirements for waste disposal may be more restrictive or otherwise different from federal regulations. Consult state and local regulations regarding the proper disposal of this material.

# 14 Transport information

DOT HAZARD:

Not Applicable

PROPER SHIPPING NAME:

DOT EMERGENCY RESPONSE GUIDE #: Not applicable
Note: Some containers may be DOT exempt, please check BOL for
exact container classification

# 15 Regulatory information

TSCA:

All components of this product are included on or are in compliance with the U.S. TSCA regulations.

CERCLA AND/OR SARA REPORTABLE QUANTITY (RQ):

No regulated constituent present at OSHA thresholds FOOD AND DRUG ADMINISTRATION:

This product can be used as a boiler water additive in applications requiring compliance with FDA regulation 21CFR173.310

NSF Registered and/or meets USDA (according to 1998 Guidelines):
Registration number: 141068

Category Code(s):

G5 Cooling and retort water treatment products - all food processing areas

G6 Boiler treatment products - all food processing areas/food contact

SARA SECTION 312 HAZARD CLASS:

Product is non-hazardous under Section 311/312

SARA SECTION 302 CHEMICALS:

No regulated constituent present at OSHA thresholds SARA SECTION 313 CHEMICALS:

No regulated constituent present at OSHA thresholds CALIFORNIA REGULATORY INFORMATION

CALIFORNIA SAFE DRINKING WATER AND TOXIC ENFORCEMENT ACT (PROPOSITION 65):

This product contains one or more ingredients at trace levels known to the state of California to cause cancer and reproductive toxicity.

MICHIGAN REGULATORY INFORMATION

No regulated constituent present at OSHA thresholds

# 16 Other information

HMIS VII CODE TRANSLATION

Health	1	Slight Hazard
Fire	1	Slight Hazard
Reactivity	0	Minimal Hazard
Special	NONE	No special Hazard
(1) Protective Equipment	В	Goggles, Gloves

(1) refer to section 8 of MSDS for additional protective equipment recommendations.

### CHANGE LOG

	EFFECTIVE		
	DATE	REVISIONS TO SECTION:	SUPERCEDES
		$\frac{1}{2} \left( \frac{1}{2} \left$	
MSDS status:	29-JAN-1997		** NEW **
	18-MAR-1997	15	29-JAN-1997
	16-APR-1997	15	18-MAR-1997
	08-OCT-1999	12	16-APR-1997
	21-OCT-1999	12	08-OCT-1999
	05-MAY-2000	15	21-OCT-1999
	17-AUG-2000	15	05-MAY-2000
	09-AUG-2001	4	17-AUG-2000
	09-NOV-2005	15	09-AUG-2001
	20-JUN-2007	5,8,10	09-NOV-2005
	15-MAY-2009	4,15	20-JUN-2007
	17-JUN-2009	15	15-MAY-2009



# GE Water & Process Technologies

Issue Date: 15-SEP-2011 Supercedes: 19-JUN-2009

# Material Safety Data Sheet

### CORTROL IS3000

# 1 Identification

Identification of substance or preparation CORTROL IS3000

Product Application Area
Water based dissolved oxygen scavenger.

Company/Undertaking Identification GE Betz, Inc. 4636 Somerton Road Trevose, PA 19053 T 215 355-3300, F 215 953 5524

Emergency Telephone (800) 877-1940

Prepared by Product Stewardship Group: T 215-355-3300 Prepared on: 15-SEP-2011

# 2 Hazard(s) identification

### EMERGENCY OVERVIEW

### WARNING

May cause slight irritation to the skin. Skin sensitizer. Severe irritant to the eyes. May cause irritation to mucous membranes. Repeated exposure may result in respiratory sensitization.

DOT hazard: Environmentally hazardous substance: RQ Odor: Strong; Appearance: Pink, Liquid

\*\*\*\*\*\*\*\*\*\*\*

Fire fighters should wear positive pressure self-contained breathing apparatus(full face-piece type). Proper fire-extinguishing media: dry chemical, carbon dioxide, foam or water

### POTENTIAL HEALTH EFFECTS

### ACUTE SKIN EFFECTS:

Primary route of exposure; May cause slight irritation to the skin. Skin sensitizer.

### ACUTE EYE EFFECTS:

Severe irritant to the eyes.

### ACUTE RESPIRATORY EFFECTS:

May cause irritation to mucous membranes. Repeated exposure may

result in respiratory sensitization.

### INGESTION EFFECTS:

May cause gastrointestinal irritation. Very large doses may cause diarrhea, depression, colic and death. May also cause severe allergic reactions in sensitive individuals.

### TARGET ORGANS:

Prolonged or repeated exposures may cause primary irritant dermatitis, skin sensitization, and/or allergic respiratory reactions.

### MEDICAL CONDITIONS AGGRAVATED:

Asthma.

### SYMPTOMS OF EXPOSURE:

May cause local irritation or a sensitization reaction upon direct contact with skin or respiratory tract.

# 3 Composition / information on ingredients

Information for specific product ingredients as required by the U.S. OSHA HAZARD COMMUNICATION STANDARD is listed. Refer to additional sections of this MSDS for our assessment of the potential hazards of this formulation.

### HAZARDOUS INGREDIENTS:

Cas# Chemical Name Range(w/w%)

7631-90-5 SODIUM BISULFITE 30-60

May be corrosive in aqueous solutions; irritant; sensitizer (skin and respiratory); may generate SO2; IARC=3 (carcinogen status not classifiable)

# 4 First-aid measures

### SKIN CONTACT:

Wash thoroughly with soap and water. Remove contaminated clothing. Thoroughly wash clothing before reuse. Get medical attention if irritation develops or persists.

### EYE CONTACT:

Remove contact lenses. Hold eyelids apart. Immediately flush eyes with plenty of low-pressure water for at least 15 minutes. Get immediate medical attention.

### INHALATION:

Remove to fresh air. If breathing is difficult, give oxygen. If breathing has stopped, give artificial respiration. Get immediate medical attention.

### INGESTION:

Do not feed anything by mouth to an unconscious or convulsive victim. Do not induce vomiting. Immediately contact physician. Dilute contents of stomach using 2-8 fluid ounces (60-240 mL) of milk or water.

### NOTES TO PHYSICIANS:

No special instructions

# 5 Fire-fighting measures

### FIRE FIGHTING INSTRUCTIONS:

Fire fighters should wear positive pressure self-contained breathing apparatus (full face-piece type).

### EXTINGUISHING MEDIA:

dry chemical, carbon dioxide, foam or water

### HAZARDOUS DECOMPOSITION PRODUCTS:

elemental oxides

### FLASH POINT:

> 200F > 93C P-M(CC)

### MISCELLANEOUS:

Environmentally hazardous substance: RQ NA 3082; Emergency Response Guide #171

# 6 Accidental release measures

### PROTECTION AND SPILL CONTAINMENT:

Ventilate area. Use specified protective equipment. Contain and absorb on absorbent material. Place in waste disposal container. Flush area with water. Wet area may be slippery. Spread sand/grit. DISPOSAL INSTRUCTIONS:

Water contaminated with this product may be sent to a sanitary sewer treatment facility, in accordance with any local agreement, a permitted waste treatment facility or discharged under a permit. Product as is - Incinerate or land dispose in an approved landfill.

# 7 Handling and storage

### HANDLING:

Vent carefully before opening. Sulfur dioxide can be formed during the normal use and handling of this product.

### STORAGE:

Keep containers closed when not in use. Protect from freezing. If frozen, thaw and mix completely prior to use. Shelf life 180 days.

# 8 Exposure controls / personal protection

### EXPOSURE LIMITS

### CHEMICAL NAME

### SODIUM BISHLFITE

PEL (OSHA): LIMITS HAVE NOT BEEN ESTABLISHED BY US OSHA. TLV (ACGIH): TWA = 5 MG/M3; A4

### ENGINEERING CONTROLS:

Adequate ventilation to maintain air contaminants below exposure limits.

### PERSONAL PROTECTIVE EQUIPMENT:

Use protective equipment in accordance with 29CFR 1910 Subpart I RESPIRATORY PROTECTION:

A RESPIRATORY PROTECTION PROGRAM THAT MEETS OSHA'S 29 CFR 1910.134 AND ANSI 288.2 REQUIREMENTS MUST BE FOLLOWED WHENEVER WORKPLACE CONDITIONS WARRANT A RESPIRATOR'S USE.
USE AIR PURIFYING RESPIRATORS WITHIN USE LIMITATIONS ASSOCIATED

WITH THE EQUIPMENT OR ELSE USE SUPPLIED AIR-RESPIRATORS. If air-purifying respirator use is appropriate, use a respirator with acid gas cartridges and dust/mist prefilters.

SKIN PROTECTION:

gauntlet-type rubber, butyl or neoprene gloves, chemical resistant apron -- Wash off after each use. Replace as necessary.

EYE PROTECTION:

splash proof chemical goggles, face shield

# 9 Physical and chemical properties

Spec. Grav. (70F, 21C) 1.261 Vapor Pressure (mmHG) Freeze Point (F) 18 Vapor Density (air=1) Freeze Point (C) -8 Viscosity(cps 70F,21C) % Solubility (water) 100.0

Odor Strong Appearance Pink Physical State Liquid Flash Point > 200F > 93C pH As Is (approx.) 3.2 Evaporation Rate (Ether=1) < 1.00 Percent VOC:

NA = not applicable ND = not determined

# 10 Stability and reactivity

CHEMICAL STABILITY:

Stable under normal storage conditions. POSSIBILITY OF HAZARDOUS REACTIONS:

No known hazardous reactions.

INCOMPATIBILITIES:

May react with strong oxidizers.

DECOMPOSITION PRODUCTS:

elemental oxides

# 11 Toxicological information

Oral LD50 RAT: 3030 mg/kg

NOTE - Calculated value according to GHS additivity formula

Skin Irritation Score RABBIT: 0-2.95

NOTE - Repeated studies indicate little or no irritation; not DOT

corrosive

Eye Irritation Score RABBIT: 2.0

NOTE - Maximum score at 1 hour; completely reversible by 48 hours

# 12 Ecological information

### AQUATIC TOXICOLOGY

Daphnia magna 48 Hour Static Screen
100% Mortality= 500; 0% Mortality= 100 mg/L
Fathead Minnow 96 Hour Acute Toxicity (Estimated)
LC50= 210; No Effect Level= 150 mg/L
Rainbow Trout 48 Hour Static Screen
100% Mortality= 1000; 0% Mortality= 500 mg/L

BIODEGRADATION

No Data Available.

# 13 Disposal considerations

If this undiluted product is discarded as a waste, the US RCRA hazardous waste identification number is : Not applicable.

Please be advised; however, that state and local requirements for waste disposal may be more restrictive or otherwise different from federal regulations. Consult state and local regulations regarding the proper disposal of this material.

# 14 Transport information

Transportation Hazard: Environmentally hazardous substance: RQ
DOT: ENVIRONMENTALLY HAZARDOUS SUBSTANCES, LIQUID, N.O.S.(SODIUM
BISULFITE SOLUTION)

9, NA 3082, PG III, RQ

DOT EMERGENCY RESPONSE GUIDE #: 171

Note: Some containers may be DOT exempt, please check BOL for

exact container classification

IATA: Not Regulated

IMDG: Not Regulated

# 15 Regulatory information

TSCA:

All components of this product are included on or are in compliance with the  $U.S.\ TSCA$  regulations.

CERCLA AND/OR SARA REPORTABLE QUANTITY (RQ):

1,443 gallons due to SODIUM BISULFITE;

FOOD AND DRUG ADMINISTRATION:

ALL ingredients in this product are authorized in 21CFR173.310 for use as boiler water additives where the steam may contact food.

NSF Registered and/or meets USDA (according to 1998 Guidelines):

Registration number: 141465

Category Code(s):

- G8 Cooling and retort water treatment products all food processing areas except meat and poultry
- G9 Boiler treatment products all food processing areas except meat and poultry/food contact

SARA SECTION 312 HAZARD CLASS:

Immediate(acute);Delayed(Chronic)

SARA SECTION 302 CHEMICALS:

No regulated constituent present at OSHA thresholds  ${\bf SARA\ SECTION\ 313\ CHEMICALS:}$ 

No regulated constituent present at OSHA thresholds CALIFORNIA REGULATORY INFORMATION

CALIFORNIA SAFE DRINKING WATER AND TOXIC ENFORCEMENT ACT (PROPOSITION 65):

No regulated constituents present MICHIGAN REGULATORY INFORMATION

No regulated constituent present at OSHA thresholds

# 16 Other information

## HMIS VII CODE TRANSLATION

Health	2	Moderate Hazard
Fire	0	Minimal Hazard
Reactivity	0	Minimal Hazard
Special	NONE	No special Hazard
(1) Protective Equipment	D	Goggles, Face Shield, Gloves, Apron

(1) refer to section 8 of MSDS for additional protective equipment recommendations.

### CHANGE LOG

	EFFECTIVE		
	DATE	REVISIONS TO SECTION:	SUPERCEDES
	~		
MSDS status:	28-JAN-1997		** NEW **
	18-MAR-1997	15	28-JAN-1997
	25-SEP-1997	15	18-MAR-1997
	15-JUN-2000	4	25-SEP-1997
	22-JUN-2004	16	15-JUN-2000
	16-JUN-2006	7,16	22-JUN-2004
	13-JUN-2008	2,5,14	16-JUN-2006
	17-JUN-2009	10,15	13-JUN-2008
	19-JUN-2009	8	17-JUN-2009
	15-SEP-2011	11	19-JUN-2009

# Appendix C Bear River Bay Water Quality Summary

Result Detection or Quantitation Limit Type Method Detection Level Lower Quantitation Limit		/8n		or Quantitation Limit Measure 33( 18( 18(  19(  19(  14(  14(  14(  14(  14(  14	Condition  Not Detected  Not Detected	Unit ug/l ug/l ug/l ug/l ug/l	Value 480 290 290		Detection Limit 165 90 90 45 45 48 480 95 25 26 276 290 290 113 113 113 113 115 115 115
Lower Reporting Limit		/gn			Not Detected	-   -   -			
Lower Reporting Limit	n	l/gr			ot Detected	z	Z	Z	
Lower Quantitation Limit		l/gr			Detected	Not	Not	Not	
Lower Quantitation Limit		l/gr	-	3	etected	Not D	Not D	Not D	
Lower Quantitation Limit		l/gr	$\vdash$	. 10	etected	Not De	Not De	Not De	
Lower Quantitation Limit		l/gr		1	etected	Not De	Not De	Not De	
Lower Quantitation Limit		l/gr		2	tected	Not De	Not De	Not De	
Lower Quantitation Limit		l/gr			ected	Not Det	Not Det	Not Det	
Lower Quantitation Limit		l/gr	-		tected	Not De	Not Det	Not Det	
Lower Quantitation Limit		l/gr	$\longrightarrow$		ected	Not Det	Not Det	Not Det	
Lower Quantitation Limit		l/gr			tected	Not De	Not De	Not Dei	
Lower Quantitation Limit		l/gr		Π	ected	Not Det	Not Det	Not Det	
							l/gn		290
Lower Quantitation Limit		l/gr	$\rightarrow$	H	tected	Not Dei	Not De	Not De	
							l/gn	-	276
Lower Quantitation Limit		l/gn		2	tected	Not De	Not De	Not De	
Lower Quantitation Limit		l/gn	$\rightarrow$	<b>—</b>	tected	Not De	Not De	Not De	
							l/gn		480
Lower Quantitation Limit		l/gn			tected	Not De	Not De	Not De	
Lower Quantitation Limit		l/gn			ected	Not Det	Not Det	Not Det	
Lower Quantitation Limit		l/Bn		Ē.	ected	Not Det			l/gn
Lower Quantitation Limit		l/gn	_	H	ected	Not Det	Not Det	Not Det	
Lower Quantitation Limit		l/gn	$\rightarrow$	П	ected	Not Det			l/gn
Method Detection Level		ng/l	$\rightarrow$	3	ected	Not Det			l/gn
Quantitation Limit Type			u	Limit Measur	dition	Con		Unit	Value Unit
Result Detection or	Qualifier	Unit		or Quantitatio		Result	Result		Result
	Result Qualifier	Unit	2	Result Detection	Result Detection				

	Result Result Detection or Qualifier Quantitation Limit Type	12	Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit				Lower Quantitation Limit	Lower Quantitation Limit		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit											~
	Unit	l/gn	l/gn	l/gn	l/gn				l/gn	l/gn		l/gn	l/gn	l/gn		ng/l	l/gn	l/gn	l/gn											
Result Detection	or Quantitation Limit Measure	50	20	13	120	¥1			55	105		120	25	45		20	20	12	130			3								
Result	Detection	Not Detected	Not Detected	Not Detected	Not Detected				Not Detected	Not Detected		Not Detected	Not Detected	Not Detected		Not Detected	Not Detected	Not Detected	Not Detected											
	Unit	l/gn	l/gn		l/gn	l/Bn	l/gn	l/gn			ug/l				l/Bn					l/gn	l/gn	ug/l	l/Bn	ng/l	ug/l	ng/l	ug/l	ng/l	l/gn	-
	Result					130	70	25			148				22.2					249	6.2	15.3	10.6	9.51	12	20.6	113	123	637	000
Result or 1/2	the Detection	25	10	7	09	130	70	25	28	53	148	09	13	23	22.2	10	25	9	65	249	6.2	15.3	10.6	9.51	12	20.6	113	123	637	000
	Activity Start Date	11/10/1999	1/4/2000	2/17/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	5/14/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	1/27/2004	2/5/2004	4/13/2004	7/9/2009	7/9/2009	7/30/2009	8/21/2009	8/21/2009	9/9/2009	0000,0,0
	Characteristic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	Arsenic	

						Result			
		Result or 1/2 the				Detection or Quantitation			Result Detection or
Characteristic	Activity	Detection	Result	. <u>:</u>	Recult Detection Condition	Limit	i.	Result	Quantitation Limit
Barium	11/10/1999	60	2	1/Mn	Not Detected	120	+		Method Detection Level
Barium	1/4/2000	45		l/gn	Not Detected	06	1		Lower Quantitation Limit
Barium	2/17/2000	85	85	l/gn					
Barium	8/23/2000	160	160	l/gn					
Barium	10/3/2000	170	170	l/gn					
Barium	11/2/2000	126.5	126.5	l/gn					
Barium	1/23/2001	120	120	l/gn					
Barium	5/3/2001	110	110	l/gn					
Barium	7/18/2001	145	145	l/gn					
Barium	10/2/2001	178	178	l/gn					
Barium	11/6/2001	181	181	l/gn					
Barium	1/22/2002	123	123	l/gn	E.				
Barium	5/14/2002	75			Not Detected	150	l/gn		Lower Quantitation Limit
Barium	10/31/2002	85	85	l/gn					
Barium	12/10/2002	38			Not Detected	75	l/gn		Lower Quantitation Limit
Barium	2/4/2003	48			Not Detected	95	l/gn		Lower Quantitation Limit
Barium	3/12/2003	54	54	l/gn					
Barium	5/28/2003	164	164	l/gn					
Barium	9/4/2003	83			Not Detected	165	l/gn		Lower Quantitation Limit
Barium	1/27/2004	20			Not Detected	100	l/gn		Lower Quantitation Limit
Barium	2/5/2004	20		l/gn	Present Below Quantification Limit	100			Lower Quantitation Limit
Barium	4/13/2004	50			Not Detected	100	l/gn		Lower Quantitation Limit
Barium	7/9/2009	126	126	l/gn					
Barium	7/30/2009	425	425	l/gn					
Barium	8/21/2009	599	599	l/gn					
Barium	9/9/2009	233	233	l/gn					
	Average	138	181	l/gn					

Characteristic	Activity	Result	Result	Result Detection	Result Detection or Quantitation Limit		Result	Result Detection or
Name	Start Date	Value	Unit	Condition	Measure	Onit	Qualifier	Quantitation timit iype
Boron	7/9/2009	1540 ug/l	ng/l					
Boron	7/30/2009	3160 ug/l	l/gn					
Boron	8/21/2009	15000	l/gn					
Boron	9/9/2009	113000	ng/l					
	Average	33175 ug/l	l/gn		Sur			

		Result or 1/2				Result Detection or			ri.
Characteristic	Activity Start	the Detection	Result		Result Detection	Quantitation Limit		Result	Result Detection or
Name	Date	Limit	Value	Unit	Condition	Measure	Onit	Qualifier	Quantitation Limit Type
Cadmium	11/10/1999	4		l/gn	Not Detected	∞	l/gn		Method Detection Level
Cadmium	1/4/2000	1		l/gn	Not Detected	2	ug/l		Lower Quantitation Limit
Cadmium	2/17/2000	3			Not Detected	5	l/gn		Lower Quantitation Limit
Cadmium	8/23/2000	2		l/gn	Not Detected	4	l/gn		Lower Quantitation Limit
Cadmium	10/3/2000	3			Not Detected	5	l/gn		Lower Quantitation Limit
Cadmium	11/2/2000	1			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	1/23/2001	6	6	l/gn					
Cadmium	5/3/2001	1			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	7/18/2001	1			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	10/2/2001	1			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	11/6/2001	T			Not Detected	2	ug/l		Lower Quantitation Limit
Cadmium	1/22/2002	П			Not Detected	1	l/gn		Lower Quantitation Limit
Cadmium	5/14/2002	Т			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	10/31/2002	П			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	12/10/2002	Т			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	2/4/2003	Т			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	3/12/2003	1			Not Detected	П	l/gn		Lower Quantitation Limit
Cadmium	5/28/2003	1			Not Detected	2	ug/l		Lower Quantitation Limit
Cadmium	9/4/2003	T			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	1/27/2004	1			Not Detected	1	ug/l		Lower Quantitation Limit
Cadmium	2/5/2004	9			Not Detected	11	ug/l		Lower Quantitation Limit
Cadmium	4/13/2004	1			Not Detected	2	l/gn		Lower Quantitation Limit
Cadmium	7/9/2009	0			Not Detected	0.5	l/gn	n	Lower Reporting Limit
Cadmium	7/30/2009	1			Not Detected	<b>~</b>	l/gn	n	Lower Reporting Limit
Cadmium	8/21/2009	5			Not Detected	10	l/gn	n	Lower Reporting Limit
Cadmium	9/9/2009	5			Not Detected	10	l/gn	n	Lower Reporting Limit
	Average	2	6	l/Bn					
	,								

on or	Limit																																-
Result Detection or	Quantitation Limit	lype																															
	Result	Qualifier																															
V	4.9	Unit						-								ï																	
Result Detection or	Quantitation	Limit Measure																															
Result	Detection	Condition																															
		Unit	mg/l	mg/l	mg/l	l/gm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	l/gm	l/8m	l/gm	l/gm	mg/l	l/8m	mg/l	l/gm	mg/l	l/gm	mg/l	mg/l	mg/l	l/gm	mg/l	l/gm	mg/l	mg/l	mg/l	mg/l	1/200
	Result	Value	92.6	9.68	76.6	97	146	113	158	115	79.5	84.9	170	1.18	265	92.6	83.7	115	193	45.8	47.4	97.7	71.8	194	296	301	201	207	67.9	80.4	70.6	27.6	22.0
	Activity	Start Date	9/2/1999	11/10/1999	1/4/2000	2/17/2000	6/20/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	2/19/2002	5/14/2002	6/25/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	6/27/2003	9/4/2003	9/30/2003	12/9/2003	1/27/2004	2/5/2004	2/24/2004	3/23/2004	1/12/2004
	Characteristic	Name	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	Calcium	

					Result			
				Result	Detection or	n		Result Detection or
Characteristic	Activity	Result		Detection	Quantitation		Result	Quantitation Limit
Name	Start Date	Value	Unit	Condition	Limit Measure	Unit	Unit Qualifier	Туре
Calcium	5/4/2004	128	128 mg/l					
Calcium	7/9/2009	50.6	50.6 mg/l					
Calcium	7/30/2009	182	l/gm					
Calcium	8/21/2009	250	mg/l					
Calcium	9/9/2009	318	l/gm					
	Average	129	l/gm					

	Result Detection or	Quantitation Limit Type	Method Detection Level	Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit				Lower Quantitation Limit		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit		Lower Quantitation Limit	Lower Reporting Limit	Lower Reporting Limit	Lower Reporting Limit	Lower Reporting Limit								
	Result	Qualifier																							D	D	D	D	
		Unit	ng/l	ng/l	ug/I	ug/l	l/gn				l/gn		ug/l	ug/l	ug/l		ug/I	ug/I	ug/l	l/gn	l/gn	ug/l	ug/I	ug/l	ug/I	ug/l	ng/l	l/gn	
Result Detection	or Quantitation	Limit Measure	390	80	65	70	120				70		80	30	25		30	85	10	09	155	5	55	10	10	20	200	200	
Result	Detection	Condition	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected				Not Detected		Not Detected	Not Detected	Not Detected		Not Detected	Not Detected	Not Detected	Not Detected	Not Detected								
		Unit	l/gn	l/gn		l/Bn		l/gn	l/gn	l/gn		l/gn				l/gn													l/gn
	Result	Value						99	11	240		106				113													107.2
Result or 1/2 the	Detection	Limit	195	40	33	35	09	99	11	240	35	106	40	15	13	113	15	43	5	30	78	3	28	5	5	10	100	100	55
	Activity	Start Date	11/10/1999	1/4/2000	2/17/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	5/14/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	1/27/2004	2/5/2004	4/13/2004	7/9/2009	7/30/2009	8/21/2009	9/9/2009	Average
	Characteristic	Name	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	Chromium	

		Result or							
	•	1/2 the			Result	Result Detection or			***************************************
Characteristic	Activity Start Date	Detection	Result	Init	Detection	Quantitation Limit	Unit	Result Oualifier	Result Detection or Ouantitation Limit Type
	11/10/1999	15	3	ug/l	Not Detected	30	l/gn		Method Detection Level
	1/4/2000	25		l/gn	Not Detected	50	l/gn		Lower Quantitation Limit
	2/17/2000	9			Not Detected	12	l/gn		Lower Quantitation Limit
	8/23/2000	25		l/gn	Not Detected	50	l/gn		Lower Quantitation Limit
	10/3/2000	45			Not Detected	06	l/gn		Lower Quantitation Limit
	11/2/2000	9			Not Detected	12	l/gn		Lower Quantitation Limit
	1/23/2001	75	75	l/gn					
Copper	5/3/2001	203	203	l/gn					
Copper	7/18/2001	9			Not Detected	12	l/gn		Lower Quantitation Limit
	10/2/2001	9			Not Detected	12	ng/l		Lower Quantitation Limit
	11/6/2001	38			Not Detected	75	ng/l		Lower Quantitation Limit
	1/22/2002	125	125	ng/l					
Copper	5/14/2002	9			Not Detected	12	l/gn		Lower Quantitation Limit
	10/31/2002	15.2	15.2	l/gn					
	12/10/2002	80			Not Detected	160	l/gn		Lower Quantitation Limit
	2/4/2003	38			Not Detected	75	ng/l		Lower Quantitation Limit
	3/12/2003	9	G#		Not Detected	12	ng/l		Lower Quantitation Limit
	5/28/2003	48			Not Detected	95	ng/l		Lower Quantitation Limit
Copper	9/4/2003	30			Not Detected	09	l/gn		Lower Quantitation Limit
	1/27/2004	9			Not Detected	12	l/gn		Lower Quantitation Limit
	2/5/2004	65			Not Detected	130	l/gn		Lower Quantitation Limit
	4/13/2004	12			Not Detected	24	l/gn		Lower Quantitation Limit
	7/9/2009	3			Not Detected	5	l/gn	D	Lower Reporting Limit
	7/30/2009	5			Not Detected	10	ng/l	<b>D</b>	Lower Reporting Limit
	8/21/2009	50			Not Detected	100	l/gn	כ	Lower Reporting Limit
	9/9/2009	119	119	l/gn					
	A	11	107	1/211					

		er Quantitation Limit Type														Lower Quantitation Limit		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit	Lower Reporting Limit	Lower Reporting Limit	Lower Reporting Limit	Lower Reporting Limit					
	Result	Qualifier																							ם	D	⊃	D	
		Unit														l/gn	l/gn	ng/l	l/gn	l/gn		l/gn	l/gn	l/gn	l/gn	l/gn	l/gn	l/gn	
Result Detection or	Quantitation	Limit Measure														20	20	20	20	20		20	20	20	40	20	200	80	
Result	Detection	Condition														Not Detected		Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected					
		Unit	l/gn	ng/l	ug/I	ng/l	ug/I	ng/l	ng/l	ng/l	ng/l	ng/l	l/gn	ng/l	ng/l						l/gn								ug/l
	Result	Value	28.2	21	26.6	76.1	53.6	53.3	26.7	41.3	36.1	9.02	31.3	33.6	43.8						20.3								40
Result or 1/2 the	Detection	Limit	28.2	21	26.6	76.1	53.6	53.3	26.7	41.3	36.1	70.6	31.3	33.6	43.8	10	10	10	10	10	20.3	10	10	10	20	10	100	40	31
	Activity	Start Date	11/10/1999	1/4/2000	2/17/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	5/14/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	1/27/2004	2/5/2004	4/13/2004	7/9/2009	7/30/2009	8/21/2009	9/9/2009	Average
	Characteristic	Name	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	Iron	

Characteristic         Activity           Name         Start Date           Lead         11/10/1999           Lead         2/17/2000           Lead         10/3/2000           Lead         11/2/2000           Lead         11/2/2000           Lead         1/23/2001           Lead         5/3/2001           Lead         1/18/2001           Lead         1/18/2001           Lead         1/16/2001           Lead         1/22/2001           Lead         1/22/2002		1/2 the				Result Detection			
11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	ity	Detection	Result	÷	Result Detection	or Quantitation	. <del>.</del>	Result	Result Detection or
2 1 1 1 1 1 1	1999	4	۸۵۱۵۲	ug/l	Not Detected	8	ug/		Method Detection Level
1 1 1 7 1 1 1 8 2	2000	28		ug/I	Not Detected	55	l/gn		Lower Quantitation Limit
	2000	10		j	Not Detected	20	l/gn		Lower Quantitation Limit
	2000	4		l/gn	Not Detected	7	l/gn		Lower Quantitation Limit
	2000	3			Not Detected	9	l/gn		Lower Quantitation Limit
	2000	55	55	l/gn					
	2001	20	20	ng/I					
	2001	2			Not Detected	3	ng/l		Lower Quantitation Limit
	2001	2			Not Detected	3	ng/l		Lower Quantitation Limit
	2001	2			Not Detected	3	ng/l		Lower Quantitation Limit
	2001	2			Not Detected	3	ug/l		Lower Quantitation Limit
	2002	8			Not Detected	5	ug/l		Lower Quantitation Limit
Lead 5/14/2002	2002	2			Not Detected	3	ug/I		Lower Quantitation Limit
Lead 10/31/2002	2002	2			Not Detected	3	ng/l		Lower Quantitation Limit
Lead 12/10/2002	2002	2			Not Detected	3	l/gn		Lower Quantitation Limit
Lead 2/4/2003	2003	2			Not Detected	3	ng/l		Lower Quantitation Limit
Lead 3/12/2003	2003	2			Not Detected	3	l/gn		Lower Quantitation Limit
Lead 5/28/2003	2003	00			Not Detected	15	ng/I		Lower Quantitation Limit
Lead 9/4/2003	2003	4			Not Detected	7	l/gn		Lower Quantitation Limit
Lead 1/27/2004	2004	2			Not Detected	3	l/gn		Lower Quantitation Limit
Lead 2/5/2004	2004	18			Not Detected	35	ug/l		Lower Quantitation Limit
Lead 4/13/2004	2004	r			Not Detected	9	ng/I		Lower Quantitation Limit
Lead 7/9/2009	5000	0			Not Detected	0.5	l/gn	n	Lower Reporting Limit
Lead 7/30/2009	5000	П			Not Detected	-	ng/I	n	Lower Reporting Limit
Lead 8/21/2009	5003	5			Not Detected	10	l/gn	n	Lower Reporting Limit
Lead 9/9/2009	5000	5			Not Detected	10	l/gn	n	Lower Reporting Limit
Average	d)	7	37.5	l/gn					

				Result	Result Detection or			
Characteristic	Activity	Result	ţ	Detection	Quantitation	Unit	Result	Result Detection or
Magnesium	9/2/1999	814	mg/l		3		3	
Magnesium	11/10/1999	713	mg/l					
Magnesium	1/4/2000	549	l/gm					
Magnesium	2/17/2000	1480	mg/l					
Magnesium	6/20/2000	1920	mg/l					
Magnesium	8/23/2000	2670	mg/l					
Magnesium	10/3/2000	2980	l/gm		3			
Magnesium	11/2/2000	1600	mg/l					
Magnesium	1/23/2001	401	mg/l					
Magnesium	5/3/2001	745	mg/l					
Magnesium	7/18/2001	3110	mg/l					
Magnesium	10/2/2001	22.2	mg/l					
Magnesium	11/6/2001	4910	mg/l					
Magnesium	1/22/2002	457	mg/l					
Magnesium	2/19/2002	101	mg/l					
Magnesium	5/14/2002	1070	mg/l					
Magnesium	6/25/2002	4000	mg/l					
Magnesium	10/31/2002	367	mg/l					
Magnesium	12/10/2002	306	mg/l					
Magnesium	2/4/2003	11.3	mg/l					
Magnesium	3/12/2003	614	mg/l					
Magnesium	5/28/2003	3420	mg/l					
Magnesium	6/27/2003	5030	mg/l					
Magnesium	9/4/2003	5810	mg/l					
Magnesium	9/30/2003	32000	mg/l					
Magnesium	12/9/2003	636	mg/l	-				
Magnesium	1/27/2004	105	mg/l					
Magnesium	2/5/2004	607	l/gm					
Magnesium	2/24/2004	158	mg/l					
Magnesium	3/23/2004	147	mg/l					

Result Detection or						
Result						
; <u>t</u>						
Result Detection or Quantitation						
Result Detection						
:	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
Result	152	1960	387	1100	4130	30400
Activity Start Date	4/13/2004	5/4/2004	7/9/2009	7/30/2009	8/21/2009	6/02/6/6
Characteristic	Magnesium	Magnesium	Magnesium	Magnesium	Magnesium	Magnesium

	Result Result Detection or nit Qualifier Quantitation Limit Type		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit		Lower Quantitation Limit		Lower Quantitation Limit				Lower Quantitation Limit		Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit	Lower Quantitation Limit		U Lower Reporting Limit	U Lower Reporting Limit	U Lower Reporting Limit	_				
	n re Unit	-	55 ug/l	20 ug/l	80 ug/l		17 ug/l		120 ug/l				30 ug/l	55 ug/l	25 ug/l	25 ug/l	35 ug/l		130 ug/l	105 ug/l	5 ug/l	55 ug/l		25 ug/l	50 ug/l	500 ug/l	
Result	Quantitation Limit Measure								1										-	H							
	Result Detection Condition		Not Detected	Not Detected	Not Detected		Not Detected		Not Detected				Not Detected		Not Detected	Not Detected	Not Detected	Not Detected		Not Detected	Not Detected	Not Detected					
	Unit	l/gn	l/gn		l/gn	ug/l		ug/l		l/gn	l/gn	ng/l						ug/l					ug/l				
	Result Value	670				230		25		150	173	179						25.3					14.8				
Recult or 1/2	the Detection	029	27.5	10	40	230	8.5	25	09	150	173	179	15	27.5	12.5	12.5	17.5	25.3	9	52.5	2.5	27.5	14.8	12.5	25	250	
	Activity Start Date	11/10/1999	1/4/2000	2/17/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	5/14/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	1/27/2004	2/5/2004	4/13/2004	7/9/2009	7/30/2009	8/21/2009	
	Characteristic	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	Manganese	

	t Result Detection or	≥	Lower Quantitation Limit	Lower Reporting Limit		Lower Reporting Limit																									
	Result	3																						D	D	D	D	D	D	_	D
	Linit	l/gn	l/gn	l/gn	ng/l	ng/l	l/gn	l/gn	ng/l	ng/l	l/gn	ng/l	ng/l	l/gn	l/gn	l/gn	l/gn	ng/l	l/gn	ug/l		l/gn									
Result Detection or	Quantitation	0.2	0.2	0.2	0.2	0.5	0.2	0.2	0.5	0.5	0.5	0.5	0.5	0.2	0.2	0.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.5	0.2	0.2		0.5
	Result Detection	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected		Not Detected
	ţ	ug/l	l/gn		l/gn																									ng/l	
	Result	5																												0.276	,
Result or 1/2 the	Detection	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.100	0.276	0.100
	Activity Ctart Data	11/10/1999	1/4/2000	2/17/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	5/14/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	1/27/2004	2/5/2004	4/13/2004	7/9/2009	7/9/2009	7/30/2009	7/30/2009	8/21/2009	8/21/2009	9/9/2009	9/9/2009
	Characteristic	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury	Mercury

					Result			
				Result	Detection or			
Characteristic   Activity	Activity	Result		Detection	Quantitation		Result	Result Detection or
Name	Start Date	Value	Unit	Condition	Limit Measure	Unit	Qualifier	Quantitation Limit Type
Nickel	2/9/2009			Not Detected	25	25 ug/l	Ω	Lower Reporting Limit
Nickel	7/30/2009			Not Detected	20	50 ug/l	D	Lower Reporting Limit
Nickel	8/21/2009			Not Detected	200	1/gn   005	Ω	Lower Reporting Limit
Nickel	9/9/2009			Not Detected	200	500 ug/l	Ω	Lower Reporting Limit

t or tion	be																															
Result Detection or Quantitation	Limit Type																															
Result	Qualifier																															
	Unit			22								æ																				3
Result Detection or Quantitation	Limit Measure																															
Result Detection	Condition																															
	Unit	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mø/l
Result	Value	909	468	328	913	1250	1610	1860	927	265	561	1950	13.2	2980	311	74.5	701	2300	233	188	6.77	308	1970	3390	17100	452	65.7	341	8.66	91.3	87.1	1090
Activity	Start Date	9/2/1999	11/10/1999	1/4/2000	2/17/2000	6/20/2000	8/23/2000	10/3/2000	11/2/2000	1/23/2001	5/3/2001	7/18/2001	10/2/2001	11/6/2001	1/22/2002	2/19/2002	5/14/2002	6/25/2002	10/31/2002	12/10/2002	2/4/2003	3/12/2003	5/28/2003	9/4/2003	9/30/2003	12/9/2003	1/27/2004	2/5/2004	2/24/2004	3/23/2004	4/13/2004	5/4/2004
Characteristic	Name	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium	Potassium

Result	Detection or	Quantitation	Limit Type					
		Result	Qualifier					
			Unit				2	
Result	Detection or	Quantitation	Limit Measure					
	Result	Detection	Condition					
			Unit	l/gm	545 mg/l	2330 mg/l	l/gm	1790 mg/l
		Result	Value	230	545	2330	17000 mg/l	1790
		Activity	Start Date	7/9/2009	7/30/2009	8/21/2009	9/9/2009	Average
		Characteristic	Name	Potassium	Potassium	Potassium	Potassium	

	Result Detection or	Quantitation Limit Type						
	Result	Qualifier						
		Unit				€		
Result	Quantitation	Limit Measure						
Rocult	Detection	Condition						
		Unit	l/gn	ng/l	l/gn	l/gn	l/gn	1/0/1
	Result	Value	20	14.3	2.7	27.6	_	0.40
	Activity	Start Date	1/23/2001	10/31/2002	1/27/2004	7/9/2009	7/30/2009	
	Characteristic	Name	Selenium	Selenium	Selenium	Selenium	Selenium	

				Result	Result Detection			Result Detection or
Characteristic	Activity	Result	Result	Detection	or Quantitation	:	Result	Quantitation
Name	Start Date	Value	Unit	Condition	Limit Measure	Unit	Qualitier	Limit Type
Sodium	7/9/2009	1620	mg/l					
Sodium	7/30/2009	4090	mg/l					
Sodium	8/21/2009	16400	mg/l					
Sodium	9/9/2009	78900	l/gm					
Sodium	9/2/1999	0606	mg/l			<b>a</b>		
Sodium	11/10/1999	7400	mg/l					
Sodium	9/4/2003	54700	l/gm				:	
Sodium	12/10/2002	1690	mg/l					
Sodium	5/4/2004	10800	mg/l					
Sodium	2/24/2004	893	mg/l					
Sodium	3/23/2004	852	mg/l					
Sodium	4/13/2004	802	mg/l					
Sodium	12/9/2003	4780	mg/l					
Sodium	1/27/2004	677	mg/l					
Sodium	1/23/2001	3590	mg/l					
Sodium	10/31/2002	3110	mg/l					
Sodium	1/22/2002	0299	mg/l					
Sodium	1/4/2000	4570	mg/l					
Sodium	2/4/2003	98.4	mg/l					
Sodium	9/30/2003	77300	l/gw					
Sodium	11/2/2000	13600	mg/l					
Sodium	6/25/2002	71500	mg/l					
Sodium	8/23/2000	25500	mg/l					
Sodium	10/3/2000	28700	mg/l					
Sodium	11/6/2001	47700	mg/l					
Sodium	7/18/2001	31900	mg/l					
Sodium	2/19/2002	1060	mg/l					
Sodium	3/12/2003	4390	mg/l					
Sodium	10/2/2001	215	mg/l					
Sodium	5/3/2001	8170	mg/l					

						mg/l	17043 mg/l	Average	
$\neg$						mg/l	14600 mg/l	2/17/2000	Sodium
						mg/l	3400	2/5/2004	Sodium
						mg/l	29700	5/28/2003	Sodium
						mg/l	18300	6/20/2000	Sodium
	Limit Type	Qualifier	Unit	Limit Measure	Condition	Unit	Value	Start Date	Name
	Quantitation	Result		or Quantitation	Detection	Result	Result	Activity	Characteristic
	Detection or			Result Detection	Result				
	Result								
9									

		Result or 1/2			Receipt	Result Detection			
Characteristic Ac	Activity	Detection	Result		Detection	or Quantitation	-	Result	Result Detection or
	Start Date	Limit	Value	Unit	Condition	Limit Measure	Unit	Qualifier	Quantitation Limit Type
11/1	11/10/1999	95		l/gn	Not Detected	190	l/gn		Method Detection Level
1/	1/4/2000	30		l/gn	Not Detected	09	l/gn		Lower Quantitation Limit
2/1	2/17/2000	15			Not Detected	30	ng/l		Lower Quantitation Limit
8/2	8/23/2000	35		l/gn	Not Detected	70	l/gn		Lower Quantitation Limit
10/	10/3/2000	40			Not Detected	80	ng/l		Lower Quantitation Limit
11/	11/2/2000	15			Not Detected	30	ng/l		Lower Quantitation Limit
1/2	1/23/2001	80	80	l/gn					
5/	5/3/2001	28			Not Detected	55	ng/l		Lower Quantitation Limit
7/1	7/18/2001	15			Not Detected	30	ng/l		Lower Quantitation Limit
10/	10/2/2001	30	30	l/gn					
11/	11/6/2001	20			Not Detected	100	l/gn		Lower Quantitation Limit
1/2	1/22/2002	230	230	ng/l					
5/1	5/14/2002	15			Not Detected	30	ng/l		Lower Quantitation Limit
10/3	10/31/2002	15			Not Detected	30	l/gn		Lower Quantitation Limit
12/1	12/10/2002	30			Not Detected	09	l/gn		Lower Quantitation Limit
2/	2/4/2003	30			Not Detected	09	l/gn		Lower Quantitation Limit
3/1	3/12/2003	15			Not Detected	30	l/gn		Lower Quantitation Limit
5/2	5/28/2003	63			Not Detected	125	l/gn		Lower Quantitation Limit
16	9/4/2003	23			Not Detected	45	l/gn		Lower Quantitation Limit
1/2	1/27/2004	15			Not Detected	30	l/gn		Lower Quantitation Limit
2/	2/5/2004	165			Not Detected	330	l/gn		Lower Quantitation Limit
4/1	4/13/2004	30			Not Detected	09	l/gn		Lower Quantitation Limit
1/	7/9/2009	25			Not Detected	50	l/gn	D	Lower Reporting Limit
7/3	7/30/2009	92			Not Detected	100	l/gn	D	Lower Reporting Limit
8/2	8/21/2009	200			Not Detected	1000	l/gn	D	Lower Reporting Limit
/6	9/9/2009	200			Not Detected	1000	l/gn	D	Lower Reporting Limit
Average	-age	82	113	l/gn					

# Appendix D Source Water Sampling Results



6/19/2012

Work Order: 1205242

Great Salt Lake Minerals Corp.

Attn: Rod Smith

765 North 10500 West

Ogden, UT 84404

Client Service Contact: Linda Daniels 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director

6100 South Stratter Street

Мигтау, Utah 84107

801.262.7299 Main

801.262.7378 Fax

www.chemtechford.com



# **Certificate of Analysis**

Lab Sample No.: 1205242-01

Name: Great Salt Lake Minerals Corp.

Sample Date: 6/15/2012 11:40 AM

Sample Site: Boiler Supply

Receipt Date: 6/15/2012 1:25 PM

Comments: Breakroom Sink

Sampler: Rod Smith

Sample Matrix: Water

Project:

Parameter	Sample Result	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	CAS No.	Flag
Metals								
Mercury, Total	1.2	0.5	ng/L	6/18/2012 12:00	PNM	EPA 1631	7439-97-6	



# **Certificate of Analysis**

Lab Sample No.: 1205242-02

Name: Great Salt Lake Minerals Corp. Sample Date: 6/15/2012 11:40 AM

Sample Site: Transfer Blank Receipt Date: 6/15/2012 1:25 PM

Comments: Breakroom Sink Sampler: Rod Smith

Sample Matrix: Water Project:

Parameter	Sample Result	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	CAS No.	Flag
Metals	NAME OF TAXABLE	- N	1660					
Mercury, Total	0.5	0.5	ng/L	6/18/2012 12:00	PNM	EPA 1631	7439-97-6	



#### **Abbreviations**

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one inicrogram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Flag Descriptions



6/19/2012

### Work Order: 1205227

Great Salt Lake Minerals Corp.

Attn: Rod Smith

765 North 10500 West

Ogden, UT 84404

Client Service Contact: Linda Daniels 801,262,7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director

6100 South Stratter Street

Murray, Utah 84107

801.262.7299 Main

801.262.7378 Fax

www.chemtechford.com



Lab Sample No.: 1205227-01

6/15/2012 10:07 AM

Name: Great Salt Lake Minerals Corp.

10.0

Sample Date: 6/15/2012 7:45 AM

Sample Site:Boiler SupplyReceipt Date:Comments:Breakroom SinkSampler:

0.03

Sampler: Rod Smith

Sample Matrix: Water

Zinc, Total

Project:

PNM

EPA 200.7

7440-66-6

Parameter	Sample Result	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	CAS No.	Flag
Metals								White
Arsenic, Total	0.0011	0.0005	mg/L	6/18/2012 15:40	МЈВ	EPA 200.8	7440-38-2	AND SOCIETY
Chromium, Total	0.0026	0.0005	mg/L	6/18/2012 15:40	MJB	EPA 200.8	7440-47-3	
Copper, Total	0.0086	0.0010	mg/L	6/18/2012 15:40	MJB	EPA 200.8	7440-50-8	
Lead, Total	ND	0.0005	mg/L	6/18/2012 15:40	MJB	EPA 200.8	7439-92-1	
Mercury, Total	ND	0.0002	mg/L	6/19/2012 12:00	AKL	EPA 245 1	7439-97-6	
Selenium, Total	0.0025	0.0005	mg/L	6/18/2012 15:40	МЈВ	EPA 200.8	7782-49-2	

mg/L

6/19/2012 13:36



#### **Abbreviations**

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Flag Descriptions



7/6/2012

Work Order: 1205775

Great Salt Lake Minerals Corp.
Attn: Rod Smith
765 North 10500 West
Ogden, UT 84404

Client Service Contact: Linda Daniels 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director



Lab Sample No.: 1205775-01

Name: Great Salt Lake Minerals Corp.

Sample Date: 7/2/2012 10:45 AM

Sample Site: Power Plant Sink

Receipt Date: 7/2/2012 1:20 PM

Comments:

Sampler: Rod Smith

Sample Matrix: Water

Project: WW

Parameter	Sample Result	Minimum Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	CAS No.	Flag
Metals			10000		1000			1000
Aluminum, Total	ND	0.05	mg/L	7/3/2012 14:12	МЈВ	EPA 200.7	7429-90-5	
Arsenic, Total	0.0009	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7440-38-2	
Boron, Total	ND	0.05	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7440-42-8	
Calcium, Total	69.5	0.2	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7440-43-9	
Cadmium, Total	ND	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7440-43-9	
Chromium, Total	0.0037	0.0005	mg/L	7/3/2012 17:31	МЈВ	EPA 200.8	7440-47-3	
Copper, Total	0.0155	0.0010	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7440-50-8	
Iron, Total	0.10	0.02	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7439-89-6	
Lead, Total	0.0041	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7439-92-1	
Mercury, Total	ND	0.0002	mg/L	7/6/2012 14:30	AKL	EPA 245.1	7439-97-6	
Magnesium, Total	17.7	0.2	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7439-95-4	
Manganese, Total	0.0083	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7439-96-5	
Selenium, Total	0.0018	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7782-49-2	
Silver, Total	ND	0.0005	mg/L	7/3/2012 17:31	MJB	EPA 200.8	7440-22-4	
Sodium, Total	30.9	0.5	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7440-23-5	
Zinc, Total	0.37	0.01	mg/L	7/3/2012 14:12	MJB	EPA 200.7	7440-66-6	



Lab Sample No.: 1205775-02

Sample Date: 7/2/2012 11:00 AM

Receipt Date: 7/2/2012 1:20 PM

Sampler: Rod Smith

Project: WW

Name: Great Salt Lake Minerals Corp.

Sample Site: Mag Plant Sink

Comments:

Sample Matrix: Water

				Minimum						
	Parameter		Sample Result	Reporting Limit	Units	Analysis Date/Time	Analyst Initials	Analytical Method	CAS No.	Flag
	Vietals	- 2 2 2	2000							100
	Aluminum, Total		ND	0.05	mg/L	7/3/2012 14:24	МЈВ	EPA 200.7	7429-90-5	401
	Arsenic, Total		0.0010	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7440-38-2	
]	Boron, Total		ND	0.05	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7440-42-8	
- 1	Calcium, Total		63.0	0.2	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7440-43-9	
-	Cadmium, Total		ND	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7440-43-9	
(	Chromium, Total		0.0044	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7440-47-3	
(	Copper, Total		0.0997	0.0010	mg/L	7/3/2012 17:34	МЈВ	EPA 200.8	7440-50-8	
	ron, Total		ND	0.02	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7439-89-6	
1	Lead, Total		ND	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7439-92-1	
	Mercury, Total		ND	0.0002	mg/L	7/6/2012 14:30	AKL	EPA 245.1	7439-97-6	
1 1	Magnesium, Total		16.0	0.2	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7439-95-4	
	Manganese, Total		0.0039	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7439-96-5	
	Selenium, Total		0.0021	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7782-49-2	
	Silver, Total		ND	0.0005	mg/L	7/3/2012 17:34	MJB	EPA 200.8	7440-22-4	
	Sodium, Total		27.8	0.5	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7440-23-5	
	Zinc, Total		ND	0.01	mg/L	7/3/2012 14:24	MJB	EPA 200.7	7440-66-6	



#### **Abbreviations**

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Flag Descriptions

# Appendix E Weber Basin Water Conservancy District Consumer Confidence Report, February 2012



### WEBER BASIN WATER CONSERVANCY DISTRICT

2837 East Highway 193 \* Layton, Utah 84040 \* Phone (801) 771-1677 \* (SLC) 359-4494 \* Fax (801) 544-0103

## Consumer 2011 Confidence REPORT

### Thirteenth Edition February 2012

This report is intended to be a snapshot of drinking water quality delivered during 2011. Included in this report are details about where your water comes from, what it contains, what we are doing to protect your water sources and how it compares to EPA and State of Utah standards. Weber Basin Water Conservancy District is committed to providing you with safe, high quality drinking water that meets or exceeds all state and federal regulations. Weber Basin Water Conservancy District is committed to providing you with reliable and accurate information because informed customers are our best allies.


### WHERE DOES OUR WATER COME FROM?

### Surface water and groundwater

The Weber Basin Water Conservancy District's (District) drinking water supply comes from the Weber River and from several creeks along the Wasatch Front. Groundwater, primarily from the Delta Aquifer, is used to supplement surface water sources.

### How drinking water gets to you?

Although a portion of drinking water originates as groundwater and is extracted from deep wells, the majority of the drinking water supply begins as surface water from the headwaters of the Weber River. Water is directed into a large canal by a diversion dam. The water then flows through this canal whereupon it enters two large aqueducts. Several creeks along the Wasatch Front can also feed into this aqueduct system. From there, water is transported to each of the District's water treatment plants. After complete treatment, water is delivered to the cities or water improvement districts for final distribution to individual users.



#### Atención! Muy Importante!

Este reporte de Calidad del Agua potable contiene valiosa información sobre la calidad del agua que usted consume. Por favor, que alguien de su confianza se lo traduzca.


### LARGE SCALE WATER STORAGE

### Why water storage is necessary?

Storage reservoirs on the Weber and Ogden river systems play a critical role in ensuring adequate and constant water supply to all water users throughout the year. Dams have been built to store water during the annual spring runoff of winter snow. Without this storage, those of us living downstream along the rivers and streams would experience extreme high flows during the runoff periods and extreme low flows in the late summer months. There would be much more flooding due to unregulated flows in the river during the spring, and there would be insufficient water to provide for drinking and irrigation needs during the late summer and fall.




Reservoirs have allowed growth to continue within the District's service area, which otherwise could not have occurred due to the lack of sufficient and consistent available water.



Reservoirs also play a vital role in reducing the effects of drought. During the past decade the effects of multi-year drought periods have been felt throughout the country. With the available water storage projects

these effects have been greatly minimized, whereas without these reservoirs it could have been devastating. Storage reservoirs also have other useful functions in generating hydro-electric power, economic benefits through tourism, habitat for wildlife, and many forms or recreational activities. They have allowed for many communities to thrive and prosper, while continuing to ensure adequate water for agricultural irrigation, industry, commercial uses and all residential uses.






### **SOURCE WATER PROTECTION**

#### **Protection Plan**

The District has completed a Drinking Water Source Protection Plan for all of its surface public drinking water sources. The Drinking Water Source Protection program includes identification of the area from which the drinking water source receives water, an assessment of the potential contamination threats to the source within this area, and management programs to help control both existing and future potential sources of contamination. Copies of this plan may be obtained from the District office for a nominal fee. The State Division of Drinking Water also has a copy on file.

Each significant potential source of contamination has been analyzed and assigned a qualitative susceptibility rating according to its potential to impact the water supply. This rating includes such factors as the likelihood of a release of potential contaminants, the ability of the potential contaminant to travel to the river or stream, and the ability of the intake to bypass contamination. Significant potential sources of contamination located within the area tributary to the District's surface water sources include from greatest potential risk to surface water to least potential risk to surface water: transportation of hazardous materials along roadways and railroads; industrial manufacturers and related companies and large commercial production and maintenance operations; rural residential



areas; agricultural activities; mineral producers; sewage treatment facilities; camping areas and other recreational activities; and underground fuel storage. Based upon this qualitative susceptibility rating, the Weber River Watershed was ranked "high" due to the presence of many potential sources of contamination. The Wasatch Front creeks were ranked "moderate to low" due to the presence of a few to no potential sources of contamination.

#### Wellhead Protection Plan

A Wellhead Protection Plan has been written and implemented for all of the District's groundwater sources. These plans define the protection zones for each of the wells, list the potential contamination sources within the zones, and identify what safeguards are in place to protect the aquifer (natural underground water storage formations made of silts, sands, gravels, and cobbles) from the contamination sources. The wellhead protection plans also consist of steps to further monitor the contamination sources and educate those businesses or industries that may become sources. Copies of these plans may be obtained from the office for a nominal fee. The State Division of Drinking Water also has a copy of each protection plan on file

### You Can Help Prevent Water Pollution

The water you drink comes from reservoirs and pumped from deep wells. Residents can help to prevent water pollution by employing best management practices when storing, using, and discarding fertilizers, pesticides, and other household hazardous wastes. The following best management practices should be employed when utilizing fertilizers and pesticides to reduce the risk of surface and groundwater contamination:

- Only purchase the amount and kind of fertilizer or pesticide needed and store in locked, dry cabinets.
- Keep fertilizers and pesticides on separate shelves.
- Do not allow fertilizer and pesticide spills to be washed off into the storm drain system.
- Pesticides and fertilizers should always be applied in accordance with manufacturer's directions.
- Dry pesticide and fertilizer spills should be swept up and later applied at the rate specified on an area where needed.
- Liquid pesticide and fertilizer spills should be soaked up using absorbent material (such as soil, saw dust, and cat litter) and then taken to a household hazardous waste collection site.
- Never apply fertilizers near wells.
- Do not spray or apply pesticides near walks or driveways to prevent pesticides from washing off into the storm drain system.

Household hazardous wastes (HHWs) are discarded materials that are ignitable, corrosive, reactive, toxic or otherwise listed as hazardous by the EPA. Paint, used motor oil, gasoline, antifreeze, or lawn and garden chemicals that you dispose of in the gutter or your backyard can migrate to the rivers or filter down through the ground and pollute aquifers. The following best management practices should be employed when handling HHWs:



- Return unused portions to community household hazardous waste collection programs.
- Do not flush HHWs down the toilet, pour HHWs down the sink, pour HHWs down a storm drain, or pour HHWs on the ground.

Protect Our Wate

Please don't spoil the water supply for yourself and everyone else! Dispose of paint, used motor oil, and othe: hazardous chemicals in a proper and safe manner. You can call the Division of Environmental Health at 801-944-6697 for the nearest location for hazardous waste disposal.

If you would like additional information on best management practices, please visit the Utah Division of Drinking Water website at <a href="http://www.drinkingwater.utah.gov/source">http://www.drinkingwater.utah.gov/source</a> protection intro.htm for links to Fact Sheets describing ways to minimize the impact of potential contamination sources on our water resources.

### POSSIBLE CONTAMINANTS IN THE WATER

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of our drinking water include rivers, streams, reservoirs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Below are some of these contaminants that may be present in source water.

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.


Pesticides and herbicides may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants can be naturally-occurring or be the result of oil and gas production and mining activities.

### CONTAMINANT REMOVAL FROM OUR WATER

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.



Raw water typically contains varying amounts of dissolved constituents and suspended particles. Complete water treatment is simply the process of trying to remove these dissolved constituents and suspended particles.

The District operates three water treatment plants. The basic stages of water treatment employed at each of these plants are coagulation and flocculation, sedimentation, filtration and disinfection.

Coagulation and flocculation is the first stage in water treatment. The goal of this stage is to bind up the suspended particles included in the raw water by adding a coagulant to the raw water as it first enters the water treatment plant. Floc, which is a tuft-like aggregate, is produced from the mixing of the coagulant in the raw water. This process is called flocculation. Over time, as more suspended matter is bound, the smaller aggregates of floc become larger particles of floc.

Sedimentation is the second stage of water treatment. The objective of this stage is to remove the floc. This is accomplished as the floc settles out of the water in long sedimentation basins. The cleaner water is drained off the surface of the sedimentation basin and sent to filtration.

**Filtration** is the third stage of water treatment. The purpose of this stage is to remove the remaining suspended particles and dissolved constituents. This is accomplished by passing the water through a filter composed of different layers of sand and gravel.

**Disinfection** is the final stage of water treatment. A small amount of chlorine, or other disinfecting chemical, is added. This is used to kill any remaining germs and to keep the water safe as it travels to the public.

### SPECIAL PRECAUTIONS TO CONSIDER

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infections by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

### WATER QUALITY INSIDE YOUR HOME

Weber Basin delivers water that is cleaner than required by state and federal law. However, once the water passes from our system and through your meter, you become a partner with us inmaking sure it stays that way. Here are some things to consider:

#### **Water Heaters**

Check the temperature setting for your water heater. Water that is too hot can create a burn hazard, while water that is too cool can create a perfect environment for bacteria to grow. You may also want to consider installing a pressure regulator to prevent any sudden surges to your water heater. These can be found at any general plumbing supply store, or you can have a plumber install one for you.

#### Filters and Purifiers


All types of filters and purifiers (point of use devices) need to be properly maintained and monitored. Neglected devices may not work as intended, can become a haven for microbial growth, or shed filter material into your home's tap water. Even the filter in the door of your refrigerator needs to be properly maintained to protect your family.

#### Water Softeners

Since the hardness of your water can range anywhere from 1 to 12 grains per gallon, it is important to monitor the settings on your water softener regularly to make sure that you are treating your water properly. Over treating your water is wasted money, while under treating is not effective.

#### **Unused Rooms**

If you have a kitchen or bathroom that rarely gets used, you should make a point of running water through the faucets on a frequent basis. Stagnant pipes and fixtures are susceptible to microbial growth. Flushing unused water lines regularly will help prevent this.



### WATER QUALITY INFORMATION

The water treated and provided by Weber Basin Water Conservancy District meets and exceeds all state and federal regulations for water quality.

The tables on the following pages list all of the regulated and unregulated drinking water contaminants that we detected during this year. Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Some of our data, though representative, are more than one year old. Because the concentrations of certain contaminants do not change frequently, the state allows less frequent monitoring. Note that the presence of contaminants in the water does not necessarily indicate that the water poses a health risk.

The detected contaminants tables have been divided into three different groups representing the District's three culinary distribution systems. These systems are **Weber Basin NORTH** (covers the area north of Ogden City), **Weber Basin CENTRAL** (the area from Ogden City south to Farmington), and **Weber Basin SOUTH** (the area from Centerville to North Salt Lake).

### Important Drinking Water Definitions:

Detected Contaminant - Any contaminant detected at or above its minimum detection limit (MDL).

Minimum Detection Limit - The lowest level at which a particular contaminant is detected with a specified degree of certainty.

MCL - Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG - Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

NA - Not applicable - there is no Federal or State MCL and/or MCLG.

ND - Not detected.

NTU - Nephelometric Turbidity Unit - a measure of the cloudiness of the water.

ppm - parts per million, or milligrams per liter (mg/l).

ppb - parts per billion, or micrograms per liter ( $\mu g/l$ ).

pCi/L - picocuries per liter (a measure of radioactivity).

#### Results of cryptosporidium monitoring

Cryptosporidium and giardia are microbial pathogens found in surface water throughout the U.S. Although filtration removes cryptosporidium and giardia, the most commonly-used filtration methods cannot guarantee 100 percent removal. Monitoring conducted by the District indicates the presence of cryptosporidium and giardia in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Due to these results, the District does use UV light in water treatment which inhibits these organisms from reproducing and causing sickness. Ingestion of cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

### Results of radon monitoring

Radon is a radioactive gas that you can't see, taste, or smell. If is found throughout the U.S. At this time, radon monitoring is not required by the EPA; however, the EPA is considering making radon monitoring a requirement. The proposed MCL for radon is 4,000 pCi/L for systems which have a public education program for radon. For additional information, call your state radon program or call EPA's Radon Hotline (800-SOS-RADON)

#### **Get Involved**

The District has regularly scheduled Board of Trustee meetings. These meetings are typically held at the District headquarters in Layton, Utah. If you would like to attend, please call for information about the meeting schedule and location. The District is open each standard working day and welcomes public input. You may call us at (801)-771-1677, write to us at Weber Basin Water Conservancy District, 2837 East Highway 193, Layton, Utah, 84040, or visit our web site at:


http://www.weberbasin.com.

#### **Contact Person**

If you have any questions concerning the content of this report please contact Brad Nelson at 801-771-1677 or speak to one of our receptionists

Water Web Sites:

www.weberbasin.com www.drinkingwater.utah.gov www.epa.gov/safewater



### REGULATED INORGANIC CONTAMINANTS

### Weber Basin NORTH - This data is derived from samples collected from 2005 through 2011.

Range

Contaminants (units)	Average	Low	High	MCL	MCLG	Typical Source
Arsenic (ppb)	0.6	ND	1,2	10	NA	Erosion of natural deposits; runoff from orchards
Barium (ppm)	0.07	0.05	0.097	2	2	Erosion of natural deposits; discharge of drilling wastes
Total Chromium (ppm)	0.0004	ND	0.001	0.2	0.1	
Fluoride 3* (ppm)	0.1	0.1	0.2	4	4	Erosion of natural deposits
Nitrate (ppm)	1.0	0.3	1.9	10	10	Runoff from fertilizer use; erosion of natural deposits
Selenium (ppb)	0.7	0	1.2	50	50	Erosion of natural deposits; discharge from mines
Sodium (ppm)	13.4	12.5	14.3	NA <sup>1</sup>	NA	Erosion of natural deposits
Sulfate (ppm)	9.2	5	12	1,000²	NA	Erosion of natural deposits
Total Dissolved Solids (ppm)	209	188	249	2,000²	NA	Erosion of natural deposits

### Weber Basin CENTRAL - This data is derived from samples collected from 2005 through 2011.

Range

Contaminants (units)	Average	Low	High	MCL	MCLG	Typical Source
Antimony (ppb)	0.6	ND	0.6	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	0.6	ND	1.2	10	NA	Erosion of natural deposits; runoff from orchards
Barium (ppm)	0.15	0.08	0.26	2	2	Erosion of natural deposits; discharge of drilling wastes
Fluoride <sup>4*</sup> (ppm)	0.71	0.5	1.1	4	4	Erosion of natural deposits
Nitrate (ppm)	0.5	0.1	1.6	10	10	Runoff from fertilizer use; erosion of natural deposits
Selenium (ppb)	1.1	0.6	2.1	50	50	Erosion of natural deposits; discharge from mines
Sodium (ppm)	29.1	19.6	38.6	NA <sup>1</sup>	NA	Erosion of natural deposits
Sulfate (ppm)	38.7	25	48	1,000²	NA	Erosion of natural deposits
Thallium (ppb)	0.6	ND	1.0	2	0.5	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Total Dissolved Solids (ppm)	372	315	416	2,000²	NA	Erosion of natural deposits

### Weber Basin SOUTH - This data is derived from samples collected from 2005 through 2011.

Range

Contaminants (units)	Average	Low	High	MCL	MCLG	Typical Source
Arsenic (ppb)	0.5	0	1.1	10	NA	Erosion of natural deposits; runoff from orchards
Barium (ppm)	0.08	0.06	0.1	2	2	Erosion of natural deposits; discharge of drilling wastes
Total Chromium (ppm)	0.003	ND	0.01	0.1	0.1	
Fluoride <sup>4</sup> (ppm)	0.7	0.2	0.9	4	4	Erosion of natural deposits
Nitrate (ppm)	1.8	0.1	3.4	10	10	Runoff from fertilizer use; erosion of natural deposits
Selenium (ppb)	1.3	0.001	3.3	50	50.	Erosion of natural deposits; discharge from mines
Sodium (ppm)	49.3	33.4	80.2	NA <sup>1</sup>	NA	Erosion of natural deposits
Sulfate (ppm)	34.8	28	39.0	1,000 <sup>2</sup>	NA	Erosion of natural deposits
Thallium (ppb)	0.2	ND	0.7	2	0.5	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Total Dissolved Solids (ppm)	361	290	432	2,000²	NA	Erosion of natural deposits

- 1) The State of Utah requires monitoring for sodium even though no MCL has been established.
- 2) The MCL for sulfate and total dissolved solids is established by the State of Utah.
- 3) This value represents naturally occurring flouride consentrations.
- 4) Fluoride levels in Davis County have been adjusted to an optimal level of 0.7 ppm.

<sup>\*</sup> The District does not add fluoride to water deliverd to Weber County

### REGULATED ORGANIC CONTAMINANTS - Disinfection Byproducts

### Weber Basin CENTRAL - This data is derived from samples collected in 2011.

Range<sup>2</sup>

Contaminants (units)	RRA <sup>1</sup>	Low	High	MCL	MCLG	Typical Source
Total Trihalomethanes (ppb)	27.6	21.1	36.5	80	NA	By-product of drinking water chlorination
Haloacetic Acids (ppb)	25.2	16.5	27.7	60	NA	By-product of drinking water chlorination

### Weber Basin SOUTH - This data is derived from samples collected in 2011.

Range<sup>2</sup>

Contaminants (units)	RRAi	Low	High	MCL	MCLG	Typical Source
Total Trihalomethanes (ppb)	24.1	15.6	38.5	80	NA	By-product of drinking water chlorination
Haloacetic Acids (ppb)	23.6	13.1	34.2	60	NA	By-product of drinking water chlorination

- 1) This value represents the highest running annual average for 2011.
- 2) Values in the "Range" columns are actual concentrations measured in ppb and reflect the range of detected levels.

### REGULATED RADIOLOGIC CHEMICALS

### Weber Basin CENTRAL - This data is derived from samples collected from 2005 through 2011

Range

Contaminants (units)	Average	Low	High	MCL	Melg	Typical Source
Gross Alpha Particles (pCi/L)	2.7	0.8	3.6	15	0	Erosion of natural deposits
Combined Radium (pCi/L)	0.7	0.6	1.0	5	0	Erosion of natural deposits

### Weber Basin SOUTH - This data is derived from samples collected from 2005 through 2011.

Range

Contaminants (units)	Average	Low	High	MCL	MCLG	Typical Source					
Gross Alpha Particles (pCi/L)	5.8	3.2	8.3	15	0	Erosion of natural deposits					
Combined Radium (pCi/L)	1.0	0.2	2.4	5	0	Erosion of natural deposits					

### REGULATED MICROBIOLOGICAL CONTAMINANTS

### Weber Basin CENTRAL

Contaminant	Percentage	Average	High <sup>3</sup>	MCL
Turbidity (Weber South WTP)	100%²	0.03 NTU	0.11 NTU	0.3 NTU
Turbidity (Davis North WTP)	100 %²	0.04 NTU	0.12 NTU	0.3 NTU

### Weber Basin SOUTH

Contaminant	Percentage	Average	High <sup>3</sup>	MCL
Turbidity (Davis South WTP)	100 %²	0.05 NTU	0.09 NTU	0.3 NTU

- 1) This value represents the highest percentage of positive samples collected within the distribution system in any one month during 2011.
- 2) This value represents the lowest monthly percentage of combined filter readings meeting less than 0.3 NTU in at least 95% of the measurements taken each month during 2011.
- 3) This value represents the highest single measurement of combined filter readings taken every four hours during 2011.

### WATER CONSERVATION

With ever increasing growth and the nature of the regional climate, there is no question that we will encounter future drought years. Future drought cycles will have an even greater effect than pervious drought because of the increased population and higher demands on water systems. Conservation and improved water efficiency needs to become a way of life for all of us by incorporating better water use practices and valuing this precious resource more than ever.

Weber Basin Water Conservancy District has a goal of reducing per capita water use 25% by the year 2050. Our thanks to those who have made and are making any effort to improve efficiency and conserve our water resources. It is still necessary to continue this effort to conserve water by educating ourselves on proper irrigation practices and changing attitudes and behaviors to reduce water waste.

Conservation alone will not meet future water needs and the District will continue to develop water supplies, build new infrastructure and maintain the current infrastructure. However, future water projects are costly and limited so we all need to be more efficient with our current water supply which will help delay these costly future projects while maintaining your current lifestyle. If we each save a little, we all save a lot!





### **Conservation Programs and Resources**

Weber Basin Water Conservancy District offers services and resources for the general public to help improve water efficiency especially with regards to landscape water use. Programs available include:

- The Water Conservation Learning Garden
- Free Water Checks
- Free Landscape Classes
- Brochures and Educational Information
- Participant in Slow the Flow and Statewide Governor's Conservation Team
- Slow the Flow



Visit our website www.weberbasin.com/conservation for more information on any of these programs.

Visit the Water Conservation Learning Garden for great ideas and learn how easy it is to have a beautiful yard while still being very water efficient. The Learning Garden is open daily 8:00 am to 8:00 pm from May through October and open 8:00 am to 5:00 pm through the winter months. The Learing Garden is easy to find, located at 2837 E. Highway 193 in Layton. Come and visit us, and participate in free classes, garden fairs, or just come for a leisurly walk. Don't miss it. For more information please visit www.weberbasin.com or call 801-771-1677.