

D Supplemental Application Information

FACILITY NAME AND PERMIT NUMBER:

Form Approved 1/14/99
OMB Number 2040-0086

SUPPLEMENTAL APPLICATION INFORMATION

PART D. EXPANDED EFFLUENT TESTING DATA

Refer to the directions on the cover page to determine whether this section applies to the treatment works.

Effluent Testing: 1.0 mgd and Pretreatment Treatment Works. If the treatment works has a design flow greater than or equal to 1.0 mgd or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information and any other information required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analyses conducted using 40 CFR Part 136 methods. In addition, these data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. Indicate in the blank rows provided below any data you may have on pollutants not specifically listed in this form. At a minimum, effluent testing data must be based on at least three pollutant scans and must be no more than four and one-half years old.

Outfall number: _____ (Complete once for each outfall discharging effluent to waters of the United States.)

| POLLUTANT | MAXIMUM DAILY DISCHARGE | | | | AVERAGE DAILY DISCHARGE | | | | | ANALYTICAL METHOD | ML/ MDL | |
|---|------------------------------|-------|------|-------|-------------------------|-------|------|-------|-------------------|-------------------|---------|--|
| | Conc. | Units | Mass | Units | Conc. | Units | Mass | Units | Number of Samples | | | |
| METALS (TOTAL RECOVERABLE), CYANIDE, PHENOLS, AND HARDNESS. | | | | | | | | | | | | |
| ANTIMONY | See attached Water Chemistry | | | | | | | | | | | |
| ARSENIC | | | | | | | | | | | | |
| BERYLLIUM | | | | | | | | | | | | |
| CADMIUM | | | | | | | | | | | | |
| CHROMIUM | | | | | | | | | | | | |
| COPPER | | | | | | | | | | | | |
| LEAD | | | | | | | | | | | | |
| MERCURY | | | | | | | | | | | | |
| NICKEL | | | | | | | | | | | | |
| SELENIUM | | | | | | | | | | | | |
| SILVER | | | | | | | | | | | | |
| THALLIUM | | | | | | | | | | | | |
| ZINC | | | | | | | | | | | | |
| CYANIDE | | | | | | | | | | | | |
| TOTAL PHENOLIC COMPOUNDS | | | | | | | | | | | | |
| HARDNESS (AS CaCO ₃) | | | | | | | | | | | | |
| Use this space (or a separate sheet) to provide information on other metals requested by the permit writer. | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Expanded Effluent Data
GILBERT BAY GREAT SALT LAKE OUTFALL
 Outfall # 1
 Southwest Jordan Valley Groundwater Project
 Jordan Valley Water Conservancy District

| Parameter | Maximum Daily Concentration @ 1.0 MGD (d,f) | | | | | Concentration |
|----------------------------|---|---------------|------|----------|----------|---------------|
| | Concentration | Units | Note | Load (e) | Mass/Day | |
| Temperature | 16 | oC | (a) | | | |
| pH | 7 | pH | (a) | | | |
| Alkalinity | 2,985 | mg/L as CaCO3 | (a) | 11,291 | kg | |
| Total Hardness | 6,471 | mg/L as CaCO3 | (a) | 24,479 | kg | |
| Calcium Hardness | 3,881 | mg/L as CaCO3 | (a) | 14,678 | kg | |
| Total Dissolved Solids | 10,746 | mg/L | (a) | 40,648 | kg | |
| Total Suspended Solids | 18 | mg/l | (a) | 68 | kg | |
| Total Organic Carbon | 6.0 | mg/L | (a) | 23 | kg | |
| Aluminum | 0 | mg/L | (a) | 1 | g | |
| Antimony | 1.5 | ug/l | (a) | 6 | g | |
| Arsenic | 36 | ug/l | (b) | 135 | g | |
| Barium | 418 | ug/l | (a) | 1,581 | g | |
| Beryllium | 2.99 | ug/l | (b) | 11 | g | |
| Bicarbonate | 3,636 | mg/L | (a) | 13,752 | kg | |
| Cadmium | 1.49 | ug/l | (b) | 6 | g | |
| Calcium | 1,552 | mg/L | (a) | 5,871 | kg | |
| Carbon Dioxide | 137 | mg/L | (a) | 519 | kg | |
| Carbonate | 3.6 | mg/L | (a) | 14 | kg | |
| Chloride | 1,373 | mg/L | (a) | 5,194 | kg | |
| Chromium, Hexavalent | 36 | ug/l | (b) | 135 | g | |
| Chromium, Trivalent | 14.925 | ug/l | (b) | 56 | g | |
| Copper | 0.015 | ug/l | (b) | 0 | g | |
| Cyanide | 0.030 | ug/l | (b) | 0 | g | |
| Fluoride | 3.5 | mg/L | (a) | 13 | kg | |
| Hydrogen Sulfide | NA | mg/L | (a) | NA | kg | |
| Iron | 1.0 | mg/L | (a) | 4 | kg | |
| Lead | 3.6 | ug/l | (b) | 14 | g | |
| Magnesium | 597 | mg/L | (a) | 2,258 | kg | |
| Manganese | 11.9 | ug/l | (a) | 45 | g | |
| Mercury (total) | 0.07 | ug/l | (b) | 0.265 | g | |
| Nickel | 14.9 | ug/l | (b) | 56 | g | |
| Phenolic Compounds (Total) | ND | ug/l | (b) | NA | g | |
| Potassium | 78 | mg/L | (a) | 294 | kg | |
| Selenium | 55.0 | ug/l | (b) | 208 | g | |
| Silica (Total) | 155 | mg/L as SiO2 | (a) | 587 | kg | |
| Silver | 1.49 | ug/l | (b) | 6 | g | |
| Sodium | 1,254 | mg/L | (a) | 4,742 | kg | |
| Strontium | 555 | ug/l | (a) | 2,100 | g | |
| Sulfate | 4,537 | mg/L | (a) | 17,162 | kg | |
| Thallium | 1.49 | ug/l | (b) | 6 | mg | |
| Zinc | 30 | ug/l | (b) | 113 | g | |
| Acid-Extractable Compounds | ND | mg/L | (b) | 0 | kg | |
| Base-Neutral Compounds | ND | mg/L | (b) | 0 | kg | |
| Volatile Organic Compounds | ND | mg/L | (b) | 0 | kg | |
| | | | | | | |
| | | | | | | |

- Notes:
- (a) Unless otherwise noted, the source of information is design documents for the SWGWTP drawing G-10. Worst case source
 - (b) Values are from water quality sampling during well pump testing. Samples measuring below the detection limit (i.e. Non-Detect)
 - (c) NA=Not Available ND=Non Detect
 - (d) Maximum daily concentrations calculated from worst case by-product discharges with all shallow RO trains off. Maximum d
 - (e) Daily mass calculations assume flow weighted average among four shallow well RO trains and two deep well RO trains.
 - (f) Concentration and mass values assume a 99.5% membrane rejection and a 1.2 engineering factor.
 - (g) Multiply kg/day by 2.0 to obtain lbs/day.

| Parameter | Jordan River |
|----------------------------|---------------------------------------|
| | 80th Percentile Ambient Concentration |
| Temperature | 17 |
| pH | 8 |
| Alkalinity | 308 |
| Total Hardness | 665 |
| Calcium Hardness | n/a |
| Total Dissolved Solids | 1,406 |
| Total Suspended Solids | 78 |
| Total Organic Carbon | n/a |
| Aluminum | 0.015 |
| Antimony | n/a |
| Arsenic | 13 |
| Barium | 63 |
| Beryllium | n/a |
| Bicarbonate | 364 |
| Cadmium | 0.50 |
| Calcium | 151 |
| Carbon Dioxide | 4 |
| Carbonate | 8.0 |
| Chloride | 301 |
| Chromium, Hexavalent | 3 |
| Chromium, Trivalent | n/a |
| Copper | 6.000 |
| Cyanide | n/a |
| Fluoride | n/a |
| Hydrogen Sulfide | n/a |
| Iron | 10.0 |
| Lead | 1.5 |
| Magnesium | 70 |
| Manganese | 29.7 |
| Mercury (total) | 0.1 |
| Nickel | 5.0 |
| Phenolic Compounds (Total) | n/a |
| Potassium | 17 |
| Selenium | 4.5 |
| Silver | 1.00 |
| Sodium | 223 |
| Strontium | n/a |
| Sulfate | 377 |
| Thallium | n/a |
| Zinc | n/a |
| Acid-Extractable Compounds | n/a |
| Base-Neutral Compounds | n/a |
| Volatile Organic Compounds | n/a |

| Maximum Daily Discharge | | |
|-------------------------|---------------|------|
| Concentration | Units | Note |
| 16 | oC | (a) |
| 7 | pH | (a) |
| 302 | mg/L as CaCO3 | (a) |
| 634 | mg/L as CaCO3 | (a) |
| 378 | mg/L as CaCO3 | (a) |
| 1,100 | mg/L | (a) |
| 4 | mg/l | (a) |
| 1.2 | mg/L | (a) |
| 0.06 | mg/L | (h) |
| 0.3 | ug/l | (a) |
| 7 | ug/l | (a) |
| 24 | ug/l | (a) |
| 0.60 | ug/l | (a) |
| 368 | mg/L | (a) |
| 0.30 | ug/l | (a) |
| 151 | mg/L | (a) |
| 22 | mg/L | (a) |
| 0.2 | mg/L | (a) |
| 262 | mg/L | (a) |
| 3.0 | ug/l | (a) |
| 3.0 | ug/l | (a) |
| 0.003 | ug/l | (a) |
| 0.006 | ug/l | (a) |
| 0.7 | mg/L | (a) |
| 0.000 | mg/L | (a) |
| 0.1 | mg/L | (a) |
| 0.3 | ug/l | (a) |
| 59 | mg/L | (a) |
| 2.4 | ug/l | (a) |
| 0.008 | ug/l | (a) |
| 3.0 | ug/l | (a) |
| 0.000 | ug/l | (a) |
| 8 | mg/L | (a) |
| 7.9 | ug/l | (a) |
| 0.30 | ug/l | (a) |
| 143 | mg/L | (a) |
| 95 | ug/l | (a) |
| 322 | mg/L | (a) |
| 0.30 | ug/l | (a) |
| 6 | ug/l | (a) |
| 0 | mg/L | (a) |
| 0 | mg/L | (a) |
| 0 | mg/L | (a) |

- (a) Unless otherwise noted, the source of information is design documents for the SWGWTP drawing G-10. Worst
- (b) Values are from water quality sampling during well pump testing. Samples measuring below the detection limit
- (c) NA=Not Available ND=Non Detect
- (d) Maximum discharge is during a power failure with plant off line and all wells continuing to operate.
- (e) Daily mass calculations assume shallow well feed only to this outfall.
- (f) Concentration and mass values assume a 99.5% membrane rejection and a 1.2 engineering factor.

E Jordan River Discharge Flow Scenarios

Jordan Valley Water Conservancy District
Jordan River Discharge
Flow Scenarios

| Scenario | Objective | Strategy | Frequency | Flow Rate (MGD) | Duration (hours) |
|-----------------------------------|---|--|--|-----------------|------------------|
| Normal Operation | <p>Optimize the life of the reverse osmosis membranes through a best management practice of maintaining a constant feed flow rate to each train of membranes.</p> <p>Maintain the wells in good operating condition through a best management practice of rotating well operation on a regular frequency.</p> | <p>This project includes more wells than required for the treatment process; the additional wells provide redundancy for anticipated pump and motor maintenance.</p> <p>Operation of the wells will rotate monthly to meet the well operation objective. Selecting a combination of wells which will result in a feed flow rate slightly higher than necessary will meet the membrane treatment objective.</p> | 365 | 1.0 | 24.0 |
| Well Start-up | Prevent particles found in the water during well start-up from damaging the treatment plant membranes. | The wells are to be pumped to storm drain systems during initial start-up to purge the well casings of suspended solids. | monthly | 3.6 | 2.0 |
| Treatment Plant Membrane Cleaning | Maintain the membranes through a best management practice of cleaning at a regular frequency to prevent formation of irreversible scale or fouling. | The membranes will be cleaned at a regular frequency which is estimated to vary between monthly to every four months. The cleaning will typically be completed through a soak and flush process using a weak acid. | one to six times per month | 3.6 | 30.0 |
| Treatment Plant Maintenance | Maintain the treatment and instrumentation equipment to ensure consistent production of high quality drinking water on a continual basis. | During reactive maintenance work which requires shutting down the treatment process for a duration of less than two hours the wells continue to operate. Scheduled preventive maintenance work will be completed during a membrane cleaning event. | estimated to occur four times per year | 3.6 | 2.0 |