



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

August 24, 2011

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-104 AND 107, UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING THE TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303 (d) OF THE FEDERAL CLEAN WATER ACT (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Moroni Feed Company.
MAILING ADDRESS: P.O. Box 308, Moroni, UT 84646
TELEPHONE NUMBER: (435) 436-8211
FACILITY LOCATION: 350 South 300 West, Moroni, UT 84646
UPDES PERMIT NO.: UT0020222
OUTFALLS: 001 and 002
RECEIVING WATERS: San Pitch River and thence into the Sevier River

BACKGROUND

The Moroni City Water Reclamation Facility (MWRf) consists of the following unit processes: mechanical screen, primary clarifier, pre-aeration basin then to the membrane bioreactor system with UV disinfection. The MWRf permit consists of biosolids and storm water components included with the standard permit. The facility has been in service since 1974 with a design capacity of 1.1 Million Gallons per Day.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on September 26, 2011. Written public comments can be submitted to: Jennifer Robinson, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: jenrobinson@utah.gov. After considering public comment the Utah Water Quality Board may execute the permit reissuance, revise it, or abandon it.

The permit is available for public review under "Public Notices" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Jennifer Robinson at 801-536-4383.