

Governor

GREG BELL Lieutenant Governor

Department of **Environmental Quality**

Amanda Smith Executive Director

DIVISION OF WATER QUALITY Walter L. Baker, P.E. Director

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Neola Improvement District

MAILING ADDRESS: P.O. Box 246 435-353-4582 TELEPHONE NUMBER:

Duchesne County, Near the south slope of the FACILITY LOCATION:

Uintah Mountains

UPDES PERMIT NO.: UT0023001

PERMITTED OUTFALLS 001

RECEIVING WATER: Irrigation Class E Ditch

BACKGROUND

Neola Wastewater Treatment Facility Lagoons (NWTF) was upgraded in 1971 as a result of high ground water infiltrating the lagoon. The upgraded facility has five lagoons with a total of 15.5 acres. The system was intended to be a non-discharging facility but sees the need to discharge during times of the year when ground water infiltration of the system is high.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on April 18, 2013. Written public comments can be submitted to: Matthew Garn, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mgarn@utah.gov . After considering public comment the Director of the Division of Water Quality may execute the permit issuance, revise it, or abandon it.

FURTHER INFORMATION

permit is available for public review under "Public Participation" www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.