



INTERLOCK DESCRIPTION	
303-2	SHUTDOWN PUMP AND CLOSE INLET VALVE
303-4	LOW LEVEL CLOSES OUTLET VALVE UNLESS MANUAL OVERRIDE AND SHUTDOWN PUMP.

REVISIONS							REVISIONS						
NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR		
1	ISSUED FOR CONSTRUCTION	07-07-89	MU	IBR	JV	4	ADDED DEDICATED SERVICE	05-07-02	KL				
2	AS BUILT UPDATE	12-30-93	DCP										
3	ADDED TSH & PRESSURE ALARMS	11-10-98	CRM										
4	AS BUILT	9-27-00	GVC										
5	ADD DEDICATED SERVICE	04-26-02	KL										

APPROVALS

DRAWN	BY	DATE
CHECKED	DCP	12-30-93
ELEC		
MECH		
STRUCT		
PROJECT ENG		
ENGINEERING MGR		
AS BUILT		

REGISTERED PROFESSIONAL ENGINEER
DATE: 5-7-02

SAFETY-KLEEN (ARAGONITE), INC.
1800 NORTH APTUS ROAD, ARAGONITE, UT. 84209

TITLE: **UTAH ENVIRONMENTAL SERVICE CENTER
INCINERATION PLANT FOR INDUSTRIAL WASTES
P&ID FEED TANKS SHEET 2**

FOR: TOOELE SITE
SCALE: _____
JOB NO: _____

CAD NO: I1550N
SAFETY-KLEEN DWG NO: D-034-PI-304
REV: 4