



NOTE:  
1. INLET CONNECTION ON TOP OF TANK

INTERLOCK DESCRIPTION

303-2	SHUTDOWN PUMP AND CLOSE INLET VALVE
303-4	LOW LEVEL CLOSES OUTLET VALVE UNLESS MANUAL OVERRIDE AND SHUTDOWN PUMP.

REVISIONS

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
1	ISSUED FOR CONSTRUCTION	07-07-89	MU	IRB	JV
2	AS BUILT UPDATE	12-30-93	DCP		
3	ADDED PRESSURE ALARMS	11-09-98	CRM		
4	AS BUILT	9-27-00	GVC		
5	ADD DEDICATED SERVICE	04-26-02	KL		

REVISIONS

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
1	ADDED DEDICATED SERVICE	05-07-02	KL		

APPROVALS

	BY	DATE
DRAWN	CRM	11-09-98
CHECKED		
ELEC		
MECH		
STRUCT		
PROJECT ENG		
ENGINEERING MGR		
AS BUILT		



**SAFETY-KLEEN (ARAGONITE), INC.**  
1600 NORTH APTUS ROAD, ARAGONITE, UT. 84209

TITLE: **UTAH ENVIRONMENTAL SERVICE CENTER  
INCINERATION PLANT FOR INDUSTRIAL WASTES  
P&ID LIQUIDS STORAGE**

FOR: **TOOLEE SITE** CAD NO. **I15470**

SCALE: **AS BUILT** JOB NO. **SAFETY-KLEEN DWG NO** **D-034-PI-306** REV **4**

REGISTERED PROFESSIONAL ENGINEER  
DATE: **5-7-02**