



NOTE:  
1. INLET CONNECTION ON TOP OF TANK

INTERLOCK DESCRIPTION		REVISIONS					REVISIONS					APPROVALS	
NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	BY	DATE
303-2	SHUTDOWN PUMP AND CLOSE INLET VALVE					1	ISSUED FOR CONSTRUCTION	07-07-89	MU	IRB	JV	DCP	07-02-98
303-4	LOW LEVEL CLOSES OUTLET VALVE UNLESS MANUAL OVERRIDE AND SHUTDOWN PUMP.					2	AS BUILT UPDATE	12-30-93	DCP				
						3	AS BUILT CORRECTION	01-04-95	DCP				
						4	AS BUILT	01-22-97	CRM				
						5	CHANGED DRAWING # FROM 311 TO 310	06-09-97	CRM				
						6	ADDED PRESSURE ALARMS	11-03-98	CRM				
						7	ADD DEDICATED SERVICE	04-26-02	KL				
						8	ADDED DEDICATED SERVICE	05-07-02	KL				
						9	REMOVED CONNECTION TO DEDICATED HEADER	27 JAN 10	BAD				
						10							

**S SAFETY-KLEEN (ARAGONITE), INC.**  
1600 NORTH 4000 ROAD, ARAGONITE, UT 84003

TITLE: **UTAH ENVIRONMENTAL SERVICE CENTER INCINERATION PLANT FOR INDUSTRIAL WASTES P&ID LIQUIDS STORAGE TANKS**

FOR TOOELE SITE  
SCALE: \_\_\_\_\_ JOB NO: \_\_\_\_\_

CAD NO: **1H754T**  
SAFETY-KLEEN DWG NO: **D-034-PI-309** REV: **7**

REGISTERED PROFESSIONAL ENGINEER  
DATE: \_\_\_\_\_