



- NOTES:**
- 6-SLOT ANALYZER CONVERTER RACK  
AIT-3040, 3041 & 3042 ARE LOCATED IN THIS RACK.
  - LOCATE COMB. SENSORS (AE-3041 & AE-3042) WITHIN 6" OF THE FLOOR NEAR VENTILATION EXHAUST LOUVERS.
  - LOCATE SENSORS AE-3040 AND AE-4092 NEAR LIQUID TRANSFER PUMPS.
  - ANALYZER RACK ALARM INPUT.
  - HEAT TRACE RELIEF VALVE BODY. INSULATE ENTIRE UNIT, INCLUDING A REMOVABLE LID TO ALLOW OPERATOR ACCESS.

INTERLOCK DESCRIPTION	REVISIONS									REFERENCE DRAWINGS		APPROVALS		CURRENT DRAWING STATUS	
	NO	DESCRIPTION	DATE	BY	CHK	ELEC	MECH	STR	PROJ MGR	DRAWING NO	TITLE	BY	DATE	BY	DATE
	1	ISSUED FOR BID	11-12-92	GJR											
	2	ISSUED FOR CONSTRUCTION	11-25-92	GJR											
	3	AS BUILT CONSTRUCTION	01-29-93	GJR											
	4	AS BUILT UPDATE	06-07-93	DCP											
	5	ADDED 4092 TRUCK UNLOADING	03-14-02	LCC											
	6	ADDED O2 SENSORS TO E15 & E16	09-10-03	LCC											
	7	REPLACED AIR HORNS WITH ELEC HORNS													



UTAH ENVIRONMENTAL SERVICE CENTER  
TANK FARM & TRUCK UNLOADING AREAS  
P&ID VENT SYSTEM & COMBUSTIBLES ANALYZERS

FOR TOOOE SITE      CAD DSK FILE      AP342C  
SCALE      JOB NO      ENG. DWG NO      APTUS DWG NO      REV  
D-800-PI-317      6