

MODULE III - MANAGEMENT OF CONTAINERS

III.A. APPLICABILITY

III.A.1. The requirements of this Permit module pertain to the operation of hazardous waste container storage areas at the Hill AFB Hazardous Waste Storage Facility (HWSF). The Permittee shall comply with UAC R315-8-9-264-170 and all the Conditions of this Module. ~~The Conditions of this Module specify the storage requirements that apply to all containers of hazardous waste at~~For the purposes of this Permit, the HWSF consists of Building 898 and Building 888 located at Hill AFB.

III.B. PERMITTED AND PROHIBITED WASTE IDENTIFICATION

III.B.1. The Permittee may store, in containers only, the hazardous wastes listed identified by EPA hazardous waste codes in Attachment 2 (Waste Analysis Plan) of this Permit, ~~by EPA hazardous waste codes, in containers at the HWSF and the non-hazardous wastes listed in Conditions II.D.1.b. – e.,~~ subject to the terms of this Permit.

III.B.2. The Permittee ~~may not store~~is prohibited from storing hazardous waste not identified in Condition III.B.1 and those hazardous wastes identified in Condition II.D.32 of this Permit. Any addition of hazardous waste to Condition III.B.1 requires a modification to the Permit in accordance with Condition I.D.

III.B.3. The Permittee may store, in containers only, materials in the HWSF. Materials may be a substance or mixture of substances that are not solid or hazardous waste. Materials may include, but are not limited to, recyclable materials and commercial chemical products. Materials stored in the HWSF will be subject to the HWSF container management requirements as specified in the following conditions.

III.C. CONDITION OF CONTAINERS

III.C.1. If a container that is used for storage of hazardous or non-hazardous waste or materials is not in good condition (e.g., severe rusting, apparent structural defects) or if it begins to leak, the Permittee shall transfer the contents, or the container itself, to a container that is in good condition or manage the waste in some other way that complies with the requirements of UAC R315-264-171. This shall be completed, as soon as possible, but not later than 24 hours from the time the problem was discovered and noted in the Operating Record. Containers of hazardous waste shall be labeled in accordance with UAC R315-262-17.

III.C.2. The Permittee shall ensure that the replacement containers referenced in Condition III.C.1. are sufficiently labeled to allow identification and tracking of the waste while it is managed at the facility.

III.D. COMPATIBILITY OF WASTE WITH CONTAINERS

III.D. 1. The Permittee shall use only containers that are in good condition and comply with the requirements of this Permit and shall assure that the ability of the container to contain the ~~hazardous~~-waste or material is not impaired.

III.D.2. The Permittee shall assure that any ~~hazardous~~-waste or material is compatible with the container in which the waste or material is stored as required by UAC R315-8-9.3264-172.

III.E. MANAGEMENT OF CONTAINERS

III.E.1 The Permittee shall keep all containers closed, except when it is necessary to add, remove, or sample waste, and shall not open, handle, or store containers in a manner which may rupture the container or cause it to leak as required by UAC R315-8-9.4264-173.

III.E.2. The Permittee shall manage containers in accordance with the Container Management Plan in Attachment 9 of this Permit.

III.E.3. The Permittee shall ensure that the following conditions are met for all containers stored in Buildings 888 and 898:

III.E.3.a. All containers of materials and hazardous and non-hazardous waste shall be maintained within adequate secondary containment as described in Condition III.F with the exception of containers with volumes greater than 2 cubic yards that do not contain free liquids.

III.E.3.b. All containers of hazardous waste and other materials shall be placed on pallets or shelves.

III.E.4. The Permittee shall comply with Condition II.J.6 of this Permit regarding maintaining required aisle space for storage of hazardous waste and other materials.

~~III.E.5. The Permittee shall place all containers of hazardous waste and other materials on pallets or shelves.~~

III.E.65. The Permittee may store containers of hazardous waste and other materials in ~~yellow~~-the flammable cabinets located in Building 888.

III.E.76. The Permittee shall maintain on-site, ~~85-85~~-gallon (or other applicable size) overpack drums at the HWSF.

III.E.87. The Permittee shall comply with [UAC R315-13-1-268](#) for all hazardous waste and other materials in Buildings 888 and 898.

III.E.98. The Permittee shall unload any transport vehicle hauling containers of hazardous waste for storage within 24 hours following arrival of the vehicle carrying the waste at the HWSF. The day of arrival shall be recorded in the Operating Record.

III.E.109. The Permittee shall verify and document in the Operating Record that waste from each container consolidated into outside bulk waste storage does not contain free liquids.

III.F. CONTAINMENT SYSTEMS

III.F.1. [The Permittee shall construct, maintain and operate the containment systems in accordance with Attachment 9 \(Container Management Plan\).](#) The secondary containment systems shall be operated and maintained according to the requirements of [UAC R315-8-9-6264-175](#).

III.F.2. Container management areas shall be inspected for the presence of free liquids in accordance with Attachment 4 ([General Inspection Requirements](#)) of this Permit. If liquids are discovered, the Permittee shall record the location and estimated volume of the liquids in the inspection log.

III.G. CONTAINER STORAGE AREA CAPACITY

III.G.1. The [combined](#) permitted storage capacity of Building 898 [for waste and materials](#) is ~~4,870~~[16,830](#) gallons ([306 55-gallon drums](#)) as described in Attachment 9 ([Container Management Plan](#)) of this Permit.

III.G.2. The [combined](#) permitted storage capacity Building 888 [for waste and materials](#) is 128,040 gallons ([2,328 55-gallon drums](#)) as described in Attachment 9 ([Container Management Plan](#)) of this Permit.

III.G.3. Materials and hazardous waste shall be stored in separate clearly marked areas [based on compatibility](#). The labels or equivalent marking on all containers of materials and hazardous waste alcoves shall be clearly visible without moving containers.

III.G.4. For purposes of this Permit, all containers stored within buildings 888 and 898 shall be considered full to their respective capacities with liquid hazardous waste.

III.H. SPECIAL REQUIREMENTS FOR IGNITABLE OR REACTIVE WASTE

III.H. 1. The Permittee shall not store containers holding ignitable or reactive waste within 15 meters (50 feet) of the Facility property line in accordance with [UAC R315-8-9-7264-176](#).

III.H.2. The Permittee shall take precautions to prevent accidental ignition or reaction of ignitable or reactive waste and follow the procedures required in

Attachments 9-7 (Contingency Plan and Emergency Procedures) and 10-9 (Container Management Plan) of this Permit in accordance with UAC R315-8-2.8(a)264-17 and UAC R315-8-9.7264-176.

III.L. SPECIAL LOCATION REQUIREMENTS FOR IGNITABLE MATERIALS AND WASTE

III.L.1. The Permittee shall store ignitable materials and waste only in Bays Z11, Z13, Z14 and Z16 and in alcoves Z12 and Z15 (See Figure 9-1 of Attachment 9 (Container Management Plan) of this Permit). These bays are designed as "hazardous storage bays" to accommodate the hazards associated with highly flammable and combustible materials. For the purposes of this Condition, ignitable materials shall be defined as any material with a flash point less than 140 °F.

III.I. SPECIAL REQUIREMENTS FOR INCOMPATIBLE WASTE

III.I.1. The Permittee shall not place incompatible wastes, or incompatible wastes and materials, in the same container, in accordance with UAC R315- ~~8-9.8264-177~~(a).

III.I.2. The Permittee shall not place ~~hazardous~~-waste in an unwashed container that previously held an incompatible waste or material, in accordance with UAC R315- ~~8-9.8264-177~~(b), unless the container has been triple rinsed, or the container is empty and fitted with a compatible disposable liner. The Permittee shall follow the plan for cleaning of containers in Attachment 10-9 (Container Management Plan) of this Permit.

III.I.3. A container holding a ~~hazardous~~-waste that is incompatible with any waste or other materials stored nearby, shall be separated from the other materials or protected from them by means of a dike, berm, wall, or other device in accordance with UAC R315- ~~8-9.8264-177~~(c).

III.J. CONTAINER LOCATION/TRACKING

III.J.1. The Permittee shall record in the Operating Record the location of each container accepted into Buildings 898 and 888 in accordance with Attachment 2 (Waste Analysis Plan) of this Permit.

III.K. INSPECTION SCHEDULES AND PROCEDURES

III.K.1. The Permittee shall inspect the container storage area weekly, in accordance with the Inspection Schedule in Attachment 4 (General Inspection Requirements) of this Permit and UAC R315-8-9.5-264-174 to detect leaking containers and deterioration of containers and the secondary containment system caused by corrosion and other factors.-

~~III.K.2. If problems are observed during the inspections, the Permittee shall correct the problem in accordance with R315-8-2.6(c) and record the remedial action~~

~~taken in the Operating Record in accordance with R315-8-2.6(d) and Attachment 4 of this Permit.~~

III.K.32. The Permittee shall inspect the container storage area on each day when loading and unloading activities are occurring in accordance with UAC R315-264-15(b)(4).

~~III.K.3. If problems are observed during the inspections, the Permittee shall correct the problem in accordance with UAC R315- 264-15(c) and Condition II.G and record the remedial action taken in the Operating Record in accordance with UAC R315- 264-15(d) and Attachment 4 (General Inspection Requirements) of this Permit.~~

~~III. L. SPECIAL REQUIREMENTS FOR IGNITABLE MATERIALS AND WASTE~~

~~III.L.1. The Permittee shall store ignitable materials and waste only in Bays Z11, Z13, Z14 and Z16 and in alcoves Z12 and Z15 (See Figure 9-1 of Attachment 9 of this Permit). These bays are designed as "hazardous storage bays" to accommodate the hazards associated with highly flammable and combustible materials. For the purposes of this Condition, ignitable materials shall be defined as any material with a flash point less than 140 °F.~~

III.M. ORGANIC AIR EMISSION STANDARDS

III.M.1. The Permittee shall control air emissions from each container ~~or tank~~ of hazardous waste stored in the HWSF in accordance with the applicable provisions of UAC R315-8-22264-179.

III.M.2. The requirements of Condition III.M.1 do not apply to a container that has a design capacity less than or equal to 0.1 m³ (26.4 gallons).

III.M.3. The following containers are also exempt from Condition III.M.1:

III.M.3.a. A container in which the hazardous waste has an average volatile organic (VO) concentration at the point of waste origination of less than 500 parts per million by weight (ppmw). The average VO concentration shall be determined in accordance with UAC R315-8-22264-1083(a)-(40 CFR 264.1083(a)). The Permittee shall review and update, as necessary, this VO determination at least once every 12 months following the date of the initial determination for each type of waste managed in containers at the HWSF. The initial review shall be conducted within 30 days of the effective date of this Permit. The Permittee shall conduct a new waste determination whenever changes to the process generating or treating the waste stream are reasonably likely to cause the average VO concentrations to increase to a level such that that applicable treatment conditions specified in UAC R315-264-1082(c)(2) are not achieved. The reviews shall be documented in the Operating Record.

III.M.3.b. A container in which the organic ~~constituent content~~ of the hazardous waste has been reduced by an organic destruction method or removal process that achieves any one of the conditions in UAC R315-8-22 264-1082(c)(2)(40

~~CFR 264.1082(e)(2))~~. For these wastes, the necessary determinations to demonstrate organic destruction or removal shall be made using the applicable procedures specified in UAC R315-8-22264-1083(b) ~~(40 CFR 264.1083(b))~~.

III.M.3.c. A container in which the hazardous waste: (a) meets the numerical concentration limits for organic constituents applicable to the hazardous waste as specified in UAC R315-13-1268, or (b) the organic hazardous constituents in the waste have been treated by the treatment technology established by the EPA for the waste in UAC R315-13-1-268 or an equivalent method of treatment approved by the ~~Executive Secretary~~Director pursuant to UAC R315-13-1268.

III.M.4. The ~~Executive Secretary~~Director may at any time perform or request that the Permittee perform an average VO concentration determination of a hazardous waste managed in a container exempted from using air emission controls under Conditions III.M.2. and III.M.3 ~~(40 CFR 264.UAC R315-264-1082(d))~~.

III.M.5. For containers of hazardous waste in the HWSF having a design capacity greater than 0.1 m³ (26.4 gallons) and less than or equal to 0.46 m³ (121.5 gallons), the Permittee shall control air pollutant emissions from the containers in accordance with ~~40 CFR 264.1086~~UAC R315-264-1086, (level 1 standards).

III.M.6. The Permittee shall comply with the applicable recordkeeping and reporting requirements contained in this Permit as part of the Operating Record.

III.N. CLOSURE

~~At closure of the HWSF, the~~The Permittee shall close the HWSF ~~remove all hazardous waste and hazardous waste residues as specified in accordance with UAC R315-264-110, in UAC R315-8-9.9264-178, Condition II.N., and in accordance with~~ the procedures in Attachment 8, Closure Plan, of this Permit.