

ATTACHMENT 21

HYDROLYSIS SYSTEM INSTRUMENT LIST

Attachment 21
Hydrolysis System Instrument List

Tag Number	Description	Units
YB_003_O615	Enclosure Alarm Buzzer	on/off
HIS_651_O611	Station 5-8 Rotation	on/off
HIS_751_O610	Station 5-8 Rotation	on/off
HIS_660_O600	Push Air Blower	on/off
YS_961_I1401	Scrubber Alarm	on/off
YS_960_I1400	Scrubber Running	on/off
FS_800_I514	Low Exhaust System Flow Switch	on/off
PS_150_I513	Low Plant Air Pressure Switch	on/off
YS_750_I512	Conductivity Over Range	on/off
LS_850_I510	High Containment Pan Level	on/off
YS_600_I507	High NaOH Storage Tank Level Alarm	on/off
YS_002_I501	Emergency Stop Relay	on/off
HIS_710_I107	Manual Stop	on/off
AIT_750_I1205	Station 3-4 Conductivity	mS/cm
PT_150_I1204	Plant Air Pressure	psi
AIT_910_I1203	Hydrogen Analyzer	% of 4%LEL
FT_200_I1202	Cooling Fan	on/off
LT_600_I1201	NaOH Storage Tank Level	gallons
LT_952_I305	Scrubber Sump Level	inches
LT_650_I304	Station 5-8 Level	gallons
PDT_950_I303	Scrubber Differential Pressure	"H ₂ O
LT_750_I301	Station 3-4 Level	gallons
TE_800_I1603	Ventilation Gas Temp	°F
TE_650_I701	Station 5-8 Bath Temp	°F
TE_750_I700	Station 3-4 Bath Temp	°F