

- SHRED TOWER AREA NOTES:**
1. THERE ARE 8 SAFETY SHOWERS IN THE SHRED TOWER AREA.
 - A. TWO (2) SAFETY SHOWERS @ 100'0"
 - B. ONE (1) SAFETY SHOWER @ 128'7"
 - C. ONE (1) SAFETY SHOWER @ 147'0"
 - D. ONE (1) SAFETY SHOWER @ 157'0"
 - E. ONE (1) SAFETY SHOWER @ 166'2"
 2. THERE ARE 13 FIRE EXTINGUISHERS IN THE SHRED TOWER AREA.
 - A. TWO (2) FIRE EXTINGUISHERS @ 100'0"
 - B. ONE (1) FIRE EXTINGUISHER @ 118'7"
 - C. ONE (1) FIRE EXTINGUISHER @ 128'7"
 - D. ONE (1) FIRE EXTINGUISHER @ 137'9"
 - E. TWO (2) FIRE EXTINGUISHERS @ 147'0"
 - F. ONE (1) FIRE EXTINGUISHER @ 157'0"
 - G. FOUR (4) FIRE EXTINGUISHERS @ 166'2"
 - H. ONE (1) ADDITIONAL FIRE EXTINGUISHER BETWEEN EL. 137'9" AND EL. 147'0"

GENERAL NOTES:

THIS DRAWING SHOWS MINIMUM EQUIPMENT. ADDITIONAL SAFETY ITEMS MAY BE INSTALLED AT OPTION OF AREA MANAGEMENT.

NO SMOKING ON PLANT SITE EXCEPT IN POSTED AREAS.

LIGHTED ENT SIGNS AND EMERGENCY LIGHTS ABOVE DOORS IN BUILDINGS PER UNIFORM BUILDING CODE.



"DANGER - UNAUTHORIZED PERSONNEL KEEP OUT" SIGNS ON PERIMETER FENCE CORNERS AND EVERY 200'.

SEE DRAWING NO. D-034-P-002 FOR UNDERGROUND FIREWATER PIPE & HYDRANT LOCATIONS.

MULTIPLE PHONES IN ADMINISTRATION, MAINTENANCE, MOTOR CONTROL, CENTER, AND RECEIVING SERVICES BUILDINGS.

CONTAINMENT TRAILER STORAGE AREA WILL HAVE THE PLACED EYE WASH STATIONS, SPILL KITS, FIRE EXTINGUISHERS AND SAFETY SHOWERS ONLY WHEN THERE IS HAZARDOUS WASTE ON TRAILERS IN THE STORAGE AREA.

- LEGEND**
- FIRE HOSE & CONNECTION
 - AREA FIRE SPRINKLER SYSTEM
 - ▲ FIRE EXTINGUISHER - WALL MOUNTED - CLASS D (METALS)
 - FIRE EXTINGUISHER - WALL MOUNTED
 - ▲ AREA FIRE SPRINKLER RISER WITH FLOW ALARM
 - FIRE ALARM PULL STATION
 - FIRST AID ROOM
 - SPILL KIT (300 MOUNTED)
 - SAFETY SHOWER & EYEWASH STATION
 - TRAFFIC STOP SIGN
 - TELEPHONE
 - KEY BOX
 - EMERGENCY SHUTOFF - VEHICLE REFUELING STATION
- PRIMARY EVACUATION ROUTE
 - - - SECONDARY EVACUATION ROUTE



PLOT PLAN

REFERENCE DRAWINGS		REVISIONS						REVISIONS						APPROVALS	
DRAWING NO	TITLE	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	BY	DATE
		1	ADDED SHRED TOWER AREA AND SAFETY EQUIPMENT AND ADDED SHRED TOWER AREA NOTES	03-12-21	KB	TH	SS	1	EXTEND ROAD TO NEW SOUTH FENCE LINE AS-BUILT (WAREHOUSE EXPANSION)	05-19-22	KB	TH	KB	CPM	12-31-22
		2	ADDED EXPLOSIVES MAGAZINES	04-06-21	KB	TH	MM	2	ADD PARTITION WALL & FIRE HOSE & CONN. IN E-8	01-10-23	KB	TH	JSC		
		3	AS-BUILT (MODULAR BUILDINGS)	12-10-21	KEI	TH	KB	3	MOVE TELEPHONE IN E2	02-14-20	JWR	TH	JWR		
		4	EXTEND S. FENCE LINE, ADD TRAILER CONT. EQUIP.	01-31-22	KB	TH	KB	4	MOVE BLDG 68, 69, ADD BLDG 70, 71, ADD TO LGND	03-03-21	KB	MM	TH	KB	AS BUILT

CleanHarbors
 ARAGONITE LLC

THIS DRAWING IS THE PROPERTY OF ARAGONITE LLC. ANY REPRODUCTION OR USE WITHOUT WRITTEN PERMISSION OF ARAGONITE LLC IS PROHIBITED.

TITLE: UTAH ENVIRONMENTAL SERVICE CENTER INCINERATION PLANT FOR INDUSTRIAL WASTES SAFETY EQUIPMENT PLAN

FOR: TOOLE SITE CAD NO. MK969

REGISTERED PROFESSIONAL ENGINEER DATE: APTUS DWG NO. D-034-M-005 REV 29