



INTERLOCK DESCRIPTION	
M	MASTER INTERLOCK SYSTEM
213-1	LOSS OF BRINE SOLUTION PRESSURE
	OPEN EMERGENCY SUPPLY
213-2	AUTOMATIC FILL SEQUENCE
213-3	VALVE OPENS ON PLANT AIR LOSS/ SHUTS DOWN ID FAN

REVISIONS											
NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
1	ISSUED FOR CONSTRUCTION	07-19-90	FJM	JV		1	AS BUILT	10-4-00	GVC		
2	REPLACE AIR COMP. WITH AIR AMP.	02-01-94	DCP	GW		2	ADDED BLOCK VALVE	12-4-00	GVC		
3	ADDED 2ND AIR AMP. & FSL 2081	06-04-96	DCP			3	ADDED CHEMICAL FEED PUMP	04-11-01	GVC		
4	TO CORRECT DRAFTING ERRORS	04-08-98	CRM			4	ADDED AIR TO COMPRESSORS, UPDATED LOGO	06-29-16	MJM	LB	
5	ADDED PUMP 216 & RELATED PIPING	07/20/99	EJH	TLW							

APPROVALS	
DRAWN	BY DCP
CHECKED	DATE 06-01-98
ELEC	
MECH	
STRUCT	
PROJECT ENG	
ENGINEERING MGR	
AS BUILT	

**Clean Harbors**  
ARIZONA LLC

TITLE: UTAH ENVIRONMENTAL SERVICE CENTER  
INCINERATION PLANT FOR INDUSTRIAL WASTES  
P&ID EMERGENCY AIR / WATER

FOR: TOOELE SITE      CAD NO. 0681000  
SCALE:      JOB NO.      APTUS DWG NO. D-034-PI-213      REV 8

REGISTERED PROFESSIONAL ENGINEER  
DATE: \_\_\_\_\_

07/20/99 16:02  
Filename: D-034-PI-213-1-A