



NOTE:
1. INLET CONNECTION ON TOP OF TANK

NO	DESCRIPTION
303-1	ONLY ONE TANK CAN BE TRANSFERRED AND/OR FED TO THE INCINERATOR AT A TIME
303-2	SHUTDOWN PUMP AND CLOSE INLET VALVE
303-4	LOW LEVEL CLOSES OUTLET VALVE UNLESS MANUAL OVERRIDE AND SHUTDOWN PUMP.

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
1	ISSUED FOR CONSTRUCTION	07-07-89	MU	IRB	JV
2	AS BUILT UPDATE	12-30-93	DCP		
3	AS BUILT CORRECTION	01-04-95	DCP		
4	AS BUILT	01-22-97	CRM		
5	ADDED BLOCK VALVES	06-03-97	CRM		

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
6	ADDED TSH & PRESSURE ALARMS	11-04-98	CRM		
7	ADD DEDICATED SERVICE	04-26-02	KL		
8	ADDED DEDICATED SERVICE	05-07-02	KL		

APPROVALS		BY	DATE
DRAWN	CHECKED	CRM	06-03-97
ELEC			
MECH			
STRUCT			
PROJECT ENG			
ENGINEERING MGR			
AS BUILT			

REGISTERED PROFESSIONAL ENGINEER
No. 189797
LAYNE D. JENSEN
STATE OF UTAH
REGISTERED PROFESSIONAL ENGINEER
DATE: 7-7-02

SAFETY-KLEEN (ARAGONITE), INC.
1600 NORTH APTUS ROAD, ARAGONITE, UT. 84209

TITLE: **UTAH ENVIRONMENTAL SERVICE CENTER
INCINERATION PLANT FOR INDUSTRIAL WASTES
P&ID LIQUIDS STORAGE TANKS**

FOR: TOOELE SITE
SCALE: JOB NO:
CAD NO.: I1548P
SAFETY-KLEEN DWG NO: D-034-PI-308
REV: 6