



NOTES:
1. INLET CONNECTION ON TOP OF TANK

NO	DESCRIPTION
303-1	ONLY ONE TANK CAN BE TRANSFERRED AND/OR FED TO THE INCINERATOR AT A TIME
303-2	SHUTDOWN PUMP AND CLOSE INLET VALVE
303-4	LOW LEVEL CLOSES OUTLET VALVE UNLESS MANUAL OVERRIDE AND SHUTDOWN PUMP.
310-1	SUMP WATER CAN ONLY TRANSFERRED TO ONE TANK AT A TIME.

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
1	ISSUED FOR CONSTRUCTION	07-07-89	MJ	IRB	JV
2	AS BUILT UPDATE	12-30-93	DCP		
3	UPDATE DECANT LINE SIZE	01-04-95	DCP		
4	AS BUILT	01-22-97	CRM		
5	ADDED FLOW METER & BLOCK VALVES	06-03-97	CRM		

NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
6	TO CORRECT DRAFTING ERRORS	04-08-98	CRM		
7	ADDED PIPE	08-13-98	CRM		
8	ADDED TSH & PRESSURE ALARMS	11-03-98	CRM		
9	ADDED ZSC4041	7-12-00	GVC		
10	310-1 WAS 310-4	9-7-00	GVC		

APPROVALS		BY	DATE
DRAWN		CRM	06-03-97
CHECKED			
ELEC			
MECH			
STRUCT			
PROJECT ENG			
ENGINEERING MGR			
AS BUILT			



SAFETY-KLEEN (ARAGONITE), INC.
1600 NORTH APTUS ROAD, ARAGONITE, UT, 84029

UTAH ENVIRONMENTAL SERVICE CENTER
INCINERATOR PLANT FOR INDUSTRIAL WASTES
P&ID LIQUIDS STORAGE TANKS

FOR TOOLE SITE CAD NO. H549V
SCALE JOB NO SAFETY-KLEEN DWG NO D-034-PI-310
DATE: SEP 25 2000 REV 9