



INTERLOCK DESCRIPTION	
601-1	HIGH-HIGH LEVEL PUMP SHUTDOWN
601-2	VALVE MUST BE OPEN TO RUN PUMP
601-3	PUMP TO SHUT DOWN ON HIGH TEMPERATURE

REVISIONS					
NO	DESCRIPTION	BY	CHK	DATE	ENG MGR
1	ISSUED FOR CONSTRUCTION	07-04-89	MU		
2	MOVED PRESSURE SWITCHES & SOLENOID VALVES	11-17-98	CRM		
3	AS BUILT	09-20-00	GVC		
4	ADDED TRUCK PUMP DELIVERY	05-15-02	KL		
5	ADDED FUEL OIL HEATER	02-06-06	KL		

REVISIONS					
NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
5	ADDED T305 TANK FEED LINE AND VALVE	08-06-09	BAD		
6	CORRECTED FOR AS BUILT	27JAN10	BAD		
7	ADDED PRESS CONTRL LOOP	02-06-14	LCC		
8	LINE MODIFICATION, DWG REF CHANGED	07-06-16	MM	CP	

APPROVALS	
BY	DATE
MMG	11-09-87
AS BUILT	

REGISTERED PROFESSIONAL ENGINEER
DATE: _____

CleanHarbors
ARAGONITE, LLC

THIS DRAWING IS THE PROPERTY OF CLEAN HARBORS ARAGONITE, LLC. ANY INFORMATION CONTAINED HEREON MAY NOT BE COPIED OR USED WITHOUT WRITTEN PERMISSION OF CLEAN HARBORS ARAGONITE, LLC.

TITLE: UTAH ENVIRONMENTAL SERVICE CENTER
INCINERATION PLANT FOR INDUSTRIAL WASTES
P&ID FUEL OIL/OUTSIDE STORAGE TANKS/PUMPS

FOR: TOOELE SITE
SCALE: NONE
JOB NO: _____

CAD NO. H782
SAFETY-KLEEN DWG NO D-034-PI-601
REV 8