



CAPACITIES (BY LOCATION)		
BUILDING	55 GALLON CONTAINERS	GALLONS
E1	1048	57,640
E2	1,524	83,820
E3	2,930	161,150
E4	1,644	90,420
E5	1160	63,800
E6	2,096	115,280
E7	2,792	153,560
E2 (WS1-WS3) (each)	4	220
E4 REPACK	4	220
E4 DECANT	4	220
E1 & E5 DOCKS (each)	100	5,500
E1 & E5 DOCKS (each) (2 refrigerated trailers)	168	9,240
E1 & E5 DOCKS (each) (bulk container)	1	4,888
CYLINDER STORAGE	800	
LABORATORY COOLER	2	110
BLDG #68	56	3,080
BLDG #69	56	3,080
E8	2304	126,720
E8 DOCKS (each) (bulk container)	1	4,888
E8 DOCKS (5 refrigerated trailers)	420	23,100
E8 DOCKS	200	11,000
BLDG #70 EAST	32	1,760
BLDG #70 WEST	32	1,760
BLDG #71 EAST	32	1,760
BLDG #71 WEST	32	1,760

- DESIGN CRITERIA:**
- 6" MINIMUM CURB AT EXTERIOR OPENINGS
 - BUILDING E6 "H" ROW IS ONLY ONE LEVEL HIGH IN SPACES 1 THROUGH 4.
 - 6" RAMP AT FIREWALLS.
 - PALLETS ARE SHOWN FOR ILLUSTRATION ONLY.
 - EXITS PER U.B.C.
 - ALL CONVEYORS & DECANT STATIONS INSIDE CONTAINER PROCESSING BUILDING WILL BE FLOOR MOUNTED.
 - DOCKS 1, 2, 3, & 4 CAN EACH STORE A REFRIGERATED TRAILER, SIMULTANEOUSLY.
 - PIPING FURNISHED TO PROCESSING AREA:
 - 3 LINES TO TANK FARM.
 - COMPRESSED AIR
 - NITROGEN
 - PLANT WATER & FIRE PROTECTION WATER
 - PENETRATION FOR EQUIP. VENT TO ATMOSPHERE
 - ROLL UP DOOR WITH TWO FUSIBLE LINKS ON EACH FIRE WALL PENETRATION.
 - DIMENSIONS ARE NOMINAL INSIDE DIMENSIONS.
 - E6 ROW D&F 24 ONLY 2 HIGH DUE TO DUCT. E7 F 21 ONLY 2 HIGH DUE TO DUCT.



FIRE RATINGS:

4 HR. FIREWALL	—
2 HR. FIREWALL	—
UNRATED WALL	—



NOTES:
 (1) ROWS "A" IN STORAGE BLDGS. E2, E3, E6, & E7 MAY HAVE CONTAINERS IN EITHER PERMANENT OR TEMPORARY STORAGE OR BOTH.

APPROVALS

BY	DATE
DRW	08/21/17
CHEK	07-31-01
ELEC	
MESH	
STRUC	
PROJECT ENG	
ENGINEERING MGR	
AS BUILT	

REFERENCE DRAWINGS		REVISIONS					REVISIONS						
DRAWING NO	TITLE	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR	NO	DESCRIPTION	DATE	BY	CHK	ENG MGR
		1	AS-BUILT (MODULAR BUILDINGS)	12-10-21	KB	TH	KB	1	E1 & E5 LAYOUT, CORRECT BLDG STORAGE, AS BUILT	07-02-20	KB	TH	KB
		2	AS-BUILT (WAREHOUSE EXPANSION)	11-08-22	KB	TH	JSC	2	ADDED BLDG STORAGE, CHNG LOCATIONS, ADD NOTES	07-21-20	KB	TH	KB
		3	MODIFY E-8 NW EGRESS, MODIFY STORAGE LAYOUT	01-11-23	KB	TH	KB	3	ADDED BLDG STORAGE, CHNG LOCATIONS, ADD NOTES	02-22-21	KB	TH	MM
		4	ADD NORTH & SOUTH DESIGNATION TO BLDG 69	03/27/12	TJK			4	ADD E-8 BLDG, ADD E1/E5 DOCKS, UPDATE TABLE	03-25-21	KB	TH	MM
		5	MOVE WS1 & WS2 ADD BIN WASHING SYSTEM	12/21/17	JWR			5	ADD FIRE DOORS TO FORKLIFT CORRIDORS	07-12-21	KB	TH	SS

CleanHarbors ASSOCIATE LLC
 THE COMPANY IS THE PROPERTY OF CLEAN HARBORS AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

TITLE: UTAH ENVIRONMENTAL SERVICE CENTER INCINERATION PLANT FOR INDUSTRIAL WASTES CONTAINER STORAGE BUILDING PLAN

FOR: TOOELE SITE **CAD NO.:** MA300

SCALE: 1"=20'-0" **JOB NO.:** **SAFETY-KLEEN DWG NO.:** D-800-M-402

REGISTERED PROFESSIONAL ENGINEER: **DATE:** **REV:** 15