



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

December 7, 2020

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to reissue a Utah Pollutant Discharge Elimination System (UPDES) permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES permit and statement of basis (including the Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Air Products Manufacturing Corp.
MAILING ADDRESS: 745 Frontage Road
Centerville, Utah 84014
TELEPHONE NUMBER: 801.298.4881
FACILITY LOCATION: 745 Frontage Road
Centerville, Utah 84014
UPDES PERMIT NO.: UT0024210
PERMITTED OUTFALLS 001
RECEIVING WATER: Stone Creek

BACKGROUND

Air Products and Chemicals, Inc. liquefies atmospheric gases via compression and cooling process for industrial, medical and scientific purposes. The resulting liquid gases are oxygen, nitrogen and argon totaling approximately 22 tons per day. Wastewater from Air Products consists of non-contact blowdown water from the cooling tower, as well as any storm water runoff from the facility. Both are captured in a single onsite pond that is approximately 75 feet by 45 feet with an average depth of 3 feet. The pond regularly discharges to a storm water culvert at an average daily flow rate of 0.504 MGD which flows to Stone Creek near Centerville, Utah.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **January 7, 2021**. Written public comments can be submitted to: Sarah Ward, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: sarahward@utah.gov. After considering public comment, the Division of Water Quality may reissue, revise, or abandon it. The permit is available for public review under "Public Participation" at <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Ward at 385.332.9574.

DWQ-2020-023672