



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

November 23, 2017

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF REISSUANCE OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to reissue a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Cedar City Wastewater Reclamation Facility
MAILING ADDRESS: 10 N. Main, Cedar City, UT 84720
TELEPHONE NUMBER: (435) 867-9426
FACILITY LOCATION: 7218 N 2300 W, Cedar City UT 84720
UPDES PERMIT NO.: UT0024970
OUTFALLS: 001
RECEIVING WATERS: No Discharges to surface waters

BACKGROUND

The Cedar City Wastewater Reclamation Facility (CCWRF) consists of one mechanical rotomat, one manual barscreen, two aerated grit chambers, two primary clarifiers, two trickling filters, two final clarifiers, two anaerobic digesters, two chlorine contact basins, and twelve drying beds. CCWRF has an influent design flow of 4.4 million gallons per day. CCWRF services Cedar City, Enoch City, and other parts of Iron County, Utah and is located at latitude 37° 48' 36" and longitude 113° 05' 25". The CCWRF does not discharge to surface waters of the State, but rather to a permitted land application site partially owned by Cedar City and by private individuals with whom there is an agreement to discharge onto their property. Although the CCWRF does not discharge to surface waters of the State, a UPDES permit was originally issued at the request of Cedar City in order to allow them to administer the Utah Model Industrial Pretreatment Program, as well as the Biosolids and Stormwater programs combined into one permit. This renewal is a continuation of that permit with no significant changes proposed.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on December 22, 2017. Written public comments can be submitted to: Jeff Studenka, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at jstudenka@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Jeff Studenka at 801-536-4395.