



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UDPES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Centerfield Regional Culinary Water Treatment Plant
MAILING ADDRESS: P.O. Box 220200, Centerfield City, UT 84622
TELEPHONE NUMBER: 435-528-3296
FACILITY LOCATION: 1600 N. Hwy 137, Mayfield, UT 84643
UPDES PERMIT NO.: UT0025704
PERMITTED OUTFALLS: 001
RECEIVING WATER: Twelve Mile Creek

BACKGROUND

Centerfield City presently operates and maintains a culinary water treatment plant (plant), which is a small reverse osmosis facility, with some water sources previously known to have nitrate concentrations that exceed the 10 mg/L maximum for drinking water standards. Small amounts of water from higher nitrate sources can be blended with Centerfield City's spring, which is a lower nitrate source, to provide acceptable drinking water. Centerfield City intends to operate this plant when needed for the purpose of providing a potable water source to blend with other sources with elevated nitrate levels. Operation of the plant will be intermittent as needed. The plant will only be operated during peak demand periods when significant volumes are required to meet the demand. To date, the plant has not been operating to the point of discharging any wastewater. The SIC code is 4941 and the NAICS code is 22131 for water supply. The discharge point from the facility to Twelve Mile Creek is Outfall 001 which is located at latitude 39°07'21" and longitude 111°42'42".

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **April 30, 2018**. Written public comments can be submitted to: Jeff Studenka, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: jstudenka@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Jeff Studenka at 801-536-4395.

DWQ-2018-002926

195 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 536-4300 • Fax (801) 536-4301 • T.D.D. (801) 536-4284

www.deq.utah.gov

Printed on 100% recycled paper