



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

March 17, 2020

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF MODIFICATION OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Central Davis Sewer District
MAILING ADDRESS: 2200 South Sunset Drive, Kaysville, Utah 84037
TELEPHONE NUMBER: (801) 451-2190
FACILITY LOCATION: 2200 South Sunset Drive, Kaysville, Utah 84037
UPDES PERMIT NO.: UT0020974
PERMITTED OUTFALLS: 001
RECEIVING WATERS: Great Salt Lake Farmington Bay

BACKGROUND

The Central Davis Sewer District (CDS) wastewater treatment facility was originally placed in service in 1961. The plant was constructed with one trickling filter, two rectangular clarifiers and an anaerobic digester. The plant was upgraded in the 1970's with an additional secondary trickling filter, two circular clarifiers and additional digestion. In the 1980's a major upgrade was made which included a new headworks, the addition of an oxidation ditch and two final clarifiers, new chlorination equipment, contact basin and additional solids handling facilities including gravity belt thickeners and presses. In the 1990's CDS expanded to meet the maximum population of the service area. This expansion included a second oxidation ditch, two clarifiers, additional chlorine equipment, a second contact basin and additional solids handling equipment.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **April 16, 2020**. Written public comments can be submitted to: Sarah Leavitt Ward, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: sleavitt@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <http://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Leavitt at 801-536-4320.

DWQ-2020-00457