



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

December 14, 2018

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF REISSUANCE OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to reissue a Utah Pollutant Discharge Elimination System (UPDES) permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES permit and statement of basis (including the Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Coalville City Corporation Wastewater Treatment Facility
MAILING ADDRESS:	PO Box 188
TELEPHONE NUMBER:	435-901-2257
FACILITY LOCATION:	50 West 100 North, Coalville, Utah
UPDES PERMIT NO:	UT0025976
OUTFALLS:	001
RECEIVING WATERS:	Unnamed tributary to Chalk Creek

BACKGROUND

The Coalville City Wastewater Treatment Plant (CWWT) serves the City of Coalville. The facility has a maximum monthly design flow of 0.58 MGD with an average daily flow rate of 0.32 MGD. The facility consists of screening and grit removal, two parallel Modified Luzack-Ettinger (MLE) process trains, two secondary clarifiers and UV disinfection prior to discharge to an unnamed tributary to Chalk Creek in the Upper Weber River watershed. Biosolids are hauled to an offsite facility located at the Three Mile Canyon Landfill.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **January 14, 2019**. Written public comments can be submitted to Sarah Leavitt, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake city, Utah 84114-4870 or by email at sleavitt@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Leavitt at (801) 536-4320.

DWQ-2018-013302