



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
Erica Brown Gaddis, PhD  
Director

**April 14, 2021**

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE OF ISSUING AN OPERATING PERMIT  
PUBLIC COMMENT PERIOD EXTENSION

**PURPOSE OF PUBLIC NOTICE**

The purpose of this public notice is to declare the State of Utah's intention to issue a new Operating permit under the authority of Utah Administrative Code R317-1, R317-3 and R317-13. The Public Comment Period has been extended to June 1, 2021.

**PERMIT INFORMATION**

PERMITTEE NAME: Emery Valley Sewer  
MAILING ADDRESS: 3212 North University Ave. #411  
Provo, UT 84604  
TELEPHONE NUMBER: 435.319.0421  
FACILITY LOCATION: TBD on the east side of the Emery Valley property in the Bryce Area  
OPERATING PERMIT NO.: UTOP9004  
PERMITTED OUTFALLS: 001  
RECEIVING WATER: Non-discharging

**BACKGROUND**

Emery Valley Sewer will consist of a head works, followed by a Sequencing Batch Reactor (SBR) system to treat the wastewater from the hotels, RV resort, restaurants, cabins, and retail stores. The system will be able to perform primary and secondary treatment. Waste sludge will be held in a holding tank, dewatered and landfilled. The effluent from the SBR will be disinfected and sent to the winter storage pond where it will be either pumped to the land application site (during the growing season) or stored (during the winter). The design flow of the facility will be 60,000 gallons per day. The treatment facility will be located on the far east side of the property.

**PUBLIC COMMENTS**

Public comments are invited any time prior to the deadline of the close of business on **June 1, 2021**. Written public comments can be submitted to: Sarah Ward, Individual Permitting Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870, electronically by email at: [sarahward@utah.gov](mailto:sarahward@utah.gov) or at <https://deq.utah.gov/water-quality/water-quality-electronic-submissions>.

A public hearing may be held if written requests are received within the first 15 days of this public comment period that demonstrate significant public interest and substantive issues exist to warrant holding a hearing. After considering public comment, the Division of Water Quality may reissue, revise, or abandon it.

The permit is available for public review under “Public Participation” at <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Ward at 385.332.9574.

**RELATED DOCUMENTS**

Draft Permit: DWQ-2021-002669

Draft Fact Sheet and Statement of Basis: DWQ-2021-002667

DWQ-2021-007152