

**Utah Division of Water Quality**  
**Statement of Basis**  
**ADDENDUM**  
**Wasteload Analysis and Antidegradation Level I Review**

**Date:** June 26, 2019

**Prepared by:** Dave Wham   
Standards and Technical Services

**Facility:** Henefer Lagoons, UPDES Permit No. UT0020192

**Receiving water:** Weber River, 1C, 2B, 3A, 4

This addendum summarizes the wasteload analysis that was performed to determine water quality based effluent limits (WQBEL) for this discharge. Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses (UAC R317-2-8). Projected concentrations are compared to numeric water quality standards to determine acceptability. The numeric criteria in this wasteload analysis may be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

Discharge

001 Lagoon Discharge 0.35 MGD

Receiving Water

Per UAC R317-2-13.4(a), the designated beneficial uses of the Weber River and tributaries, from Stoddard diversion to headwaters are 1C, 2B, 3A, 4.

- *Class 1C - Protected for domestic purposes with prior treatment by treatment processes as required by the Utah Division of Drinking Water.*
- *Class 2B - Protected for infrequent primary contact recreation. Also protected for secondary contact recreation where there is a low likelihood of ingestion of water or a low degree of bodily contact with the water. Examples include, but are not limited to, wading, hunting, and fishing.*
- *Class 3A - Protected for cold water species of game fish and other cold water aquatic life, including the necessary aquatic organisms in their food chain.*
- *Class 4 - Protected for agricultural uses including irrigation of crops and stock watering.*

**Utah Division of Water Quality  
Wasteload Analysis  
Henefer Lagoons  
UPDES Permit No. UT0020192**

**Flow**

Typically, the critical flow for the wasteload analysis is considered the lowest stream flow for seven consecutive days with a ten year return frequency (7Q10). The 7Q10 flow was calculated using daily mean flow data from USGS monitoring station #10132000, WEBER RIVER AT ECHO, UT for the period 1998-2018. Seasonal critical low values are presented in Table 1.

**Table 1. Seasonal Critical Low Flow Values, Weber River**

Season	Flow (cfs)
Winter	0.74
Spring	0.89
Summer	142.71
Fall	0.47

Ambient receiving water quality was characterized using data from DWQ monitoring station # 4926000, WEBER R AB HENEFER LAGOONS for the period 2006-2016.

TMDL

According to the Utah's 2016 303(d) Water Quality Assessment Report, the receiving water for the discharge, Weber River between confluence of Lost Creek and Echo Reservoir (UT16020101-004\_00) is listed as impaired for: OE Bioassessment and total phosphorus (Use Class 3A). A TMDL addressing these impairments has not been completed.

Mixing Zone

The maximum allowable mixing zone is 15 minutes of travel time for acute conditions, not to exceed 50% of stream width, and for chronic conditions, per UAC R317-2-5. Water quality standards must be met at the end of the mixing zone.

Based on the results of the mixing zone modeling, plume width was 96.2% of the river at 2500 feet. 96.2 % of the seasonal critical low flow was used to calculate chronic limits. Acute limits were calculated using 50% of the seasonal critical low flow.

Parameters of Concern

Total phosphorous was identified as a potential parameter of concern for the discharge based on review of the impairment status of the receiving water and review of the previous permit.

WET Limits

The percent of effluent in the receiving water in a fully mixed condition, and acute and chronic dilution in a not fully mixed condition are calculated in the WLA in order to generate WET limits. The LC<sub>50</sub> (lethal concentration, 50%) percent effluent for acute toxicity and the IC<sub>25</sub> (inhibition concentration, 25%) percent effluent for chronic toxicity, as determined by the WET test, needs to be below the WET limits, as determined by the WLA. The WET limit for LC<sub>50</sub> is typically 100% effluent and does not need to be determined by the WLA.

IC25 WET limits for Outfall 002 should be based on .4 % effluent (summer season).

**Utah Division of Water Quality**  
**Wasteload Analysis**  
**Henefer Lagoons**  
**UPDES Permit No. UT0020192**

Wasteload Allocation Methods

Effluent limits were determined for conservative constituents using a simple mass balance mixing analysis (UDWQ 2012). The mass balance analysis is summarized in the Wasteload Addendums.

The water quality standard for chronic ammonia toxicity is dependent on temperature and pH, and the water quality standard for acute ammonia toxicity is dependent on pH. The AMMTOX Model developed by University of Colorado and adapted by Utah DWQ and EPA Region VIII was used to determine ammonia effluent limits (Lewis et al. 2002). The analysis is summarized in the Wasteload Addendum.

Models and supporting documentation are available for review upon request.

Antidegradation Level I Review

The objective of the Level I ADR is to ensure the protection of existing uses, defined as the beneficial uses attained in the receiving water on or after November 28, 1975. No evidence is known that the existing uses deviate from the designated beneficial uses for the receiving water. Therefore, the beneficial uses will be protected if the discharge remains below the WQBELs presented in this wasteload.

A Level II Antidegradation Review (ADR) is not required for this facility. The proposed permit is a simple renewal of an existing UPDES permit. No increase in flow or concentration of pollutants over those authorized in the the existing permit is being requested.

Documents:

WLA Document: *HeneferLagoons\_WLADoc\_6-26-19.docx*

Wasteload Analysis and Addendums: *HeneferLagoons\_WLA\_6-26-19.xlsm*

References:

Utah Division of Water Quality. 2012. *Utah Wasteload Analysis Procedures Version 1.0.*

Utah Division of Water Quality  
Salt Lake City, Utah

WASTELOAD ANALYSIS [WLA]  
Addendum: Statement of Basis

24-Jun-19

Facilities: Henefer Lagoons  
Discharging to: Weber River  
Design Flow: 0.35 MGD

UPDES No: UT-20192

**THIS IS A DRAFT DOCUMENT**

**I. Introduction**

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated interms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

**II. Receiving Water and Stream Classification**

Weber River:	1C, 2B, 3A, 4
Antidegradation Review:	Level I review completed. Level II review not required.

**III. Numeric Stream Standards for Protection of Aquatic Wildlife**

Total Ammonia (TNH3)	Varies as a function of Temperature and pH Rebound. See Water Quality Standards
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average)
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average) 5.00 mg/l (7Day Average) 4.00 mg/l (1 Day Average)
Maximum Total Dissolved Solids	1200.0 mg/l

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Acute and Chronic Heavy Metals (Dissolved)**

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aluminum	87.00 ug/l**	0.254 lbs/day	750.00	ug/l	2.193 lbs/day
Arsenic	190.00 ug/l	0.556 lbs/day	340.00	ug/l	0.994 lbs/day
Cadmium	1.88 ug/l	0.005 lbs/day	4.95	ug/l	0.014 lbs/day
Chromium III	200.32 ug/l	0.586 lbs/day	4191.06	ug/l	12.255 lbs/day
ChromiumVI	11.00 ug/l	0.032 lbs/day	16.00	ug/l	0.047 lbs/day
Copper	22.49 ug/l	0.066 lbs/day	36.94	ug/l	0.108 lbs/day
Iron			1000.00	ug/l	2.924 lbs/day
Lead	11.80 ug/l	0.035 lbs/day	302.91	ug/l	0.886 lbs/day
Mercury	0.0120 ug/l	0.000 lbs/day	2.40	ug/l	0.007 lbs/day
Nickel	124.67 ug/l	0.365 lbs/day	1121.31	ug/l	3.279 lbs/day
Selenium	4.60 ug/l	0.013 lbs/day	20.00	ug/l	0.058 lbs/day
Silver	N/A ug/l	N/A lbs/day	22.25	ug/l	0.065 lbs/day
Zinc	286.74 ug/l	0.838 lbs/day	286.74	ug/l	0.838 lbs/day

\* Allowed below discharge

\*\*Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO3

Metals Standards Based upon a Hardness of 280.08 mg/l as CaCO3

**Organics [Pesticides]**

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aldrin			1.500	ug/l	0.004 lbs/day
Chlordane	0.004 ug/l	3.200 lbs/day	1.200	ug/l	0.004 lbs/day
DDT, DDE	0.001 ug/l	0.744 lbs/day	0.550	ug/l	0.002 lbs/day
Dieldrin	0.002 ug/l	1.414 lbs/day	1.250	ug/l	0.004 lbs/day
Endosulfan	0.056 ug/l	41.675 lbs/day	0.110	ug/l	0.000 lbs/day
Endrin	0.002 ug/l	1.712 lbs/day	0.090	ug/l	0.000 lbs/day
Guthion			0.010	ug/l	0.000 lbs/day
Heptachlor	0.004 ug/l	2.828 lbs/day	0.260	ug/l	0.001 lbs/day
Lindane	0.080 ug/l	59.536 lbs/day	1.000	ug/l	0.003 lbs/day
Methoxychlor			0.030	ug/l	0.000 lbs/day
Mirex			0.010	ug/l	0.000 lbs/day
Parathion			0.040	ug/l	0.000 lbs/day
PCB's	0.014 ug/l	10.419 lbs/day	2.000	ug/l	0.006 lbs/day
Pentachlorophenol	13.00 ug/l	9674.615 lbs/day	20.000	ug/l	0.058 lbs/day
Toxephene	0.0002 ug/l	0.149 lbs/day	0.7300	ug/l	0.002 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

**IV. Numeric Stream Standards for Protection of Agriculture**

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			100.0 ug/l	lbs/day
Boron			750.0 ug/l	1.10 lbs/day
Cadmium			10.0 ug/l	0.01 lbs/day
Chromium			100.0 ug/l	lbs/day
Copper			200.0 ug/l	lbs/day
Lead			100.0 ug/l	lbs/day
Selenium			50.0 ug/l	lbs/day
TDS, Summer			1200.0 mg/l	1.75 tons/day

**V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)**

Metals	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			50.0 ug/l	37.210 lbs/day
Barium			1000.0 ug/l	744.201 lbs/day
Cadmium			10.0 ug/l	7.442 lbs/day
Chromium			50.0 ug/l	37.210 lbs/day
Lead			50.0 ug/l	37.210 lbs/day
Mercury			2.0 ug/l	1.488 lbs/day
Selenium			10.0 ug/l	7.442 lbs/day
Silver			50.0 ug/l	37.210 lbs/day
Fluoride (3)			1.4 ug/l	1.042 lbs/day
to			2.4 ug/l	1.786 lbs/day
Nitrates as N			10.0 ug/l	7.442 lbs/day

**Chlorophenoxy Herbicides**

2,4-D	100.0 ug/l	74.420 lbs/day
2,4,5-TP	10.0 ug/l	7.442 lbs/day
Endrin	0.2 ug/l	0.149 lbs/day
cyclohexane (Lindane)	4.0 ug/l	2.977 lbs/day
Methoxychlor	100.0 ug/l	74.420 lbs/day
Toxaphene	5.0 ug/l	3.721 lbs/day

**VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]**

Toxic Organics	Maximum Conc., ug/l - Acute Standards			
	Class 1C [2 Liters/Day for 70 Kg Person over 70 Yr.]		Class 3A, 3B [6.5 g for 70 Kg Person over 70 Yr.]	
Acenaphthene	1200.00 ug/l	893.04 lbs/day	2700.0 ug/l	2009.34 lbs/day
Acrolein	320.00 ug/l	238.14 lbs/day	780.0 ug/l	580.48 lbs/day
Acrylonitrile	0.06 ug/l	0.04 lbs/day	0.7 ug/l	0.49 lbs/day
Benzene	1.20 ug/l	0.89 lbs/day	71.0 ug/l	52.84 lbs/day
Benzidine	0.00012 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Carbon tetrachloride	0.25 ug/l	0.19 lbs/day	4.4 ug/l	3.27 lbs/day
Chlorobenzene	680.00 ug/l	506.06 lbs/day	21000.0 ug/l	15628.22 lbs/day
1,2,4-Trichlorobenzene				
Hexachlorobenzene	0.00075 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Dichloroethane	0.38 ug/l	0.28 lbs/day	99.0 ug/l	73.68 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

1,1,1-Trichloroethane				
Hexachloroethane	1.90 ug/l	1.41 lbs/day	8.9 ug/l	6.62 lbs/day
1,1-Dichloroethane				
1,1,2-Trichloroethane	0.61 ug/l	0.45 lbs/day	42.0 ug/l	31.26 lbs/day
1,1,2,2-Tetrachloroethane	0.17 ug/l	0.13 lbs/day	11.0 ug/l	8.19 lbs/day
Chloroethane			0.0 ug/l	0.00 lbs/day
Bis(2-chloroethyl) ether	0.03 ug/l	0.02 lbs/day	1.4 ug/l	1.04 lbs/day
2-Chloroethyl vinyl ether	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2-Chloronaphthalene	1700.00 ug/l	1265.14 lbs/day	4300.0 ug/l	3200.06 lbs/day
2,4,6-Trichlorophenol	2.10 ug/l	1.56 lbs/day	6.5 ug/l	4.84 lbs/day
p-Chloro-m-cresol			0.0 ug/l	0.00 lbs/day
Chloroform (HM)	5.70 ug/l	4.24 lbs/day	470.0 ug/l	349.77 lbs/day
2-Chlorophenol	120.00 ug/l	89.30 lbs/day	400.0 ug/l	297.68 lbs/day
1,2-Dichlorobenzene	2700.00 ug/l	2009.34 lbs/day	17000.0 ug/l	12651.42 lbs/day
1,3-Dichlorobenzene	400.00 ug/l	297.68 lbs/day	2600.0 ug/l	1934.92 lbs/day
1,4-Dichlorobenzene	400.00 ug/l	297.68 lbs/day	2600.0 ug/l	1934.92 lbs/day
3,3'-Dichlorobenzidine	0.04 ug/l	0.03 lbs/day	0.1 ug/l	0.06 lbs/day
1,1-Dichloroethylene	0.06 ug/l	0.04 lbs/day	3.2 ug/l	2.38 lbs/day
1,2-trans-Dichloroethylene	700.00 ug/l	520.94 lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dichlorophenol	93.00 ug/l	69.21 lbs/day	790.0 ug/l	587.92 lbs/day
1,2-Dichloropropane	0.52 ug/l	0.39 lbs/day	39.0 ug/l	29.02 lbs/day
1,3-Dichloropropylene	10.00 ug/l	7.44 lbs/day	1700.0 ug/l	1265.14 lbs/day
2,4-Dimethylphenol	540.00 ug/l	401.87 lbs/day	2300.0 ug/l	1711.66 lbs/day
2,4-Dinitrotoluene	0.11 ug/l	0.08 lbs/day	9.1 ug/l	6.77 lbs/day
2,6-Dinitrotoluene	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Diphenylhydrazine	0.04 ug/l	0.03 lbs/day	0.5 ug/l	0.40 lbs/day
Ethylbenzene	3100.00 ug/l	2307.02 lbs/day	29000.0 ug/l	21581.83 lbs/day
Fluoranthene	300.00 ug/l	223.26 lbs/day	370.0 ug/l	275.35 lbs/day
4-Chlorophenyl phenyl ether				
4-Bromophenyl phenyl ether				
Bis(2-chloroisopropyl) ether	1400.00 ug/l	1041.88 lbs/day	170000.0 ug/l	126514.19 lbs/day
Bis(2-chloroethoxy) methane	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methylene chloride (HM)	4.70 ug/l	3.50 lbs/day	1600.0 ug/l	1190.72 lbs/day
Methyl chloride (HM)	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methyl bromide (HM)	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Bromoform (HM)	4.30 ug/l	3.20 lbs/day	360.0 ug/l	267.91 lbs/day
Dichlorobromomethane	0.27 ug/l	0.20 lbs/day	22.0 ug/l	16.37 lbs/day
Chlorodibromomethane	0.41 ug/l	0.31 lbs/day	34.0 ug/l	25.30 lbs/day
Hexachlorobutadiene(c)	0.44 ug/l	0.33 lbs/day	50.0 ug/l	37.21 lbs/day
Hexachlorocyclopentadiene	240.00 ug/l	178.61 lbs/day	17000.0 ug/l	12651.42 lbs/day
Isophorone	8.40 ug/l	6.25 lbs/day	600.0 ug/l	446.52 lbs/day
Naphthalene				
Nitrobenzene	17.00 ug/l	12.65 lbs/day	1900.0 ug/l	1413.98 lbs/day
2-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dinitrophenol	70.00 ug/l	52.09 lbs/day	14000.0 ug/l	10418.82 lbs/day
4,6-Dinitro-o-cresol	13.00 ug/l	9.67 lbs/day	765.0 ug/l	569.31 lbs/day
N-Nitrosodimethylamine	0.00069 ug/l	0.00 lbs/day	8.1 ug/l	6.03 lbs/day
N-Nitrosodiphenylamine	5.00 ug/l	3.72 lbs/day	16.0 ug/l	11.91 lbs/day
N-Nitrosodi-n-propylamine	0.01 ug/l	0.00 lbs/day	1.4 ug/l	1.04 lbs/day
Pentachlorophenol	0.28 ug/l	0.21 lbs/day	8.2 ug/l	6.10 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

Phenol	2.10E+04 ug/l	1.56E+04 lbs/day	4.6E+06 ug/l	3.42E+06 lbs/day
Bis(2-ethylhexyl)phthala	1.80 ug/l	1.34 lbs/day	5.9 ug/l	4.39 lbs/day
Butyl benzyl phthalate	3000.00 ug/l	2232.60 lbs/day	5200.0 ug/l	3869.85 lbs/day
Di-n-butyl phthalate	2700.00 ug/l	2009.34 lbs/day	12000.0 ug/l	8930.41 lbs/day
Di-n-octyl phthlate				
Diethyl phthalate	23000.00 ug/l	17116.63 lbs/day	120000.0 ug/l	89304.13 lbs/day
Dimethyl phthlate	3.13E+05 ug/l	2.33E+05 lbs/day	2.9E+06 ug/l	2.16E+06 lbs/day
Benzo(a)anthracene (P/	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(a)pyrene (PAH)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(b)fluoranthene (F	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(k)fluoranthene (F	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Chrysene (PAH)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Acenaphthylene (PAH)				
Anthracene (PAH)	9600.00 ug/l	7144.33 lbs/day	0.0 ug/l	0.00 lbs/day
Dibenzo(a,h)anthracene	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Indeno(1,2,3-cd)pyrene	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Pyrene (PAH)	960.00 ug/l	714.43 lbs/day	11000.0 ug/l	8186.21 lbs/day
Tetrachloroethylene	0.80 ug/l	0.60 lbs/day	8.9 ug/l	6.62 lbs/day
Toluene	6800.00 ug/l	5060.57 lbs/day	200000 ug/l	148840.22 lbs/day
Trichloroethylene	2.70 ug/l	2.01 lbs/day	81.0 ug/l	60.28 lbs/day
Vinyl chloride	2.00 ug/l	1.49 lbs/day	525.0 ug/l	390.71 lbs/day
			0.0	0.00 lbs/day
			0.0	0.00 lbs/day
<b>Pesticides</b>				
Aldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Dieldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Chlordane	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDT	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDE	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDD	0.0008 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
alpha-Endosulfan	0.9300 ug/l	0.69 lbs/day	2.0 ug/l	1.49 lbs/day
beta-Endosulfan	0.9300 ug/l	0.69 lbs/day	2.0 ug/l	1.49 lbs/day
Endosulfan sulfate	0.9300 ug/l	0.69 lbs/day	2.0 ug/l	1.49 lbs/day
Endrin	0.7600 ug/l	0.57 lbs/day	0.8 ug/l	0.60 lbs/day
Endrin aldehyde	0.7600 ug/l	0.57 lbs/day	0.8 ug/l	0.60 lbs/day
Heptachlor	0.0002 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Heptachlor epoxide				
<b>PCB's</b>				
PCB 1242 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1254 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1221 (Arochlor 122	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1232 (Arochlor 123	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1248 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1260 (Arochlor 126	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1016 (Arochlor 10	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
<b>Pesticide</b>				
Toxaphene	0.000750 ug/l	0.00	0.0 ug/l	0.00 lbs/day
<b>Dioxin</b>				
Dioxin (2,3,7,8-TCDD)	1.30E-08 ug/l	0.00 lbs/day	1.40E-08	0.00



**Utah Division of Water Quality  
Salt Lake City, Utah**

**Metals**

Antimony	14.0 ug/l	10.42 lbs/day		
Arsenic	50.0 ug/l	37.21 lbs/day	4300.00 ug/l	3200.06 lbs/day
Asbestos	7.00E+06 ug/l	5.21E+06 lbs/day		
Beryllium				
Cadmium				
Chromium (III)				
Chromium (VI)				
Copper				
Cyanide	1.30E+03 ug/l	967.46 lbs/day	2.2E+05 ug/l	163724.25 lbs/day
Lead	700.0 ug/l	520.94 lbs/day		
Mercury			0.15 ug/l	0.11 lbs/day
Nickel			4600.00 ug/l	3423.33 lbs/day
Selenium	0.1 ug/l	0.10 lbs/day		
Silver	610.0 ug/l	453.96 lbs/day		
Thallium			6.30 ug/l	4.69 lbs/day
Zinc				

**There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.**

**VII. Mathematical Modeling of Stream Quality**

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

**Utah Division of Water Quality  
Salt Lake City, Utah**

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al.  
Harper Collins Publisher, Inc. 1987, pp. 644.

**VIII. Modeling Information**

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

Flow, Q, (cfs or MGD)	D.O. mg/l
Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH3-N, mg/l
BOD5, mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

**Other Conditions**

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

**Model Inputs**

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

**Current Upstream Information**

	<b>Stream</b>								
	<b>Critical Low</b>								
	<b>Flow</b>	<b>Temp.</b>	<b>pH</b>	<b>T-NH3</b>	<b>BOD5</b>	<b>DO</b>	<b>TRC</b>	<b>TDS</b>	
	<b>cfs</b>	<b>Deg. C</b>		<b>mg/l as N</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>
Summer (Irrig. Season)	142.71	16.4	8.4	0.10	1.00	7.23	0.00	273.0	
Fall	0.47	6.0	8.3	0.10	1.00	---	0.00	454.0	
Winter	0.74	3.0	8.1	0.10	1.00	---	0.00	588.0	
Spring	0.89	9.6	8.5	0.10	1.00	---	0.00	415.0	
Dissolved	Al	As	Cd	CrIII	CrVI	Copper	Fe	Pb	
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
All Seasons	5.00	1.71	0.05	3.21	3.975*	1.47	10.0	0.28	
Dissolved	Hg	Ni	Se	Ag	Zn	Boron			
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l			
All Seasons	0.0000	2.50	0.60	0.25	12.82	61.3			

\* ~80% MDL

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Projected Discharge Information**

Season	Flow, MGD	Temp.
Summer	0.35000	12.0
Fall	0.35000	8.0
Winter	0.35000	2.4
Spring	0.35000	9.3

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

**IX. Effluent Limitations**

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

**Effluent Limitation for Flow based upon Water Quality Standards**

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

Season	Daily Average	
Summer	0.350 MGD	0.541 cfs
Fall	0.350 MGD	0.541 cfs
Winter	0.350 MGD	0.541 cfs
Spring	0.350 MGD	0.541 cfs

**Flow Requirement or Loading Requirement**

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 0.35 MGD. If the discharger is allowed to have a flow greater than 0.35 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

**Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy**

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	100.0% Effluent	[Acute]
	IC25 >	0.4% Effluent	[Chronic]

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Effluent Limitation for Biological Oxygen Demand (BOD) based upon Water Quality Standards or Regulations**

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent BOD limitation as follows:

Season	Concentration	
Summer	25.0 mg/l as BOD5	73.0 lbs/day
Fall	25.0 mg/l as BOD5	73.0 lbs/day
Winter	25.0 mg/l as BOD5	73.0 lbs/day
Spring	25.0 mg/l as BOD5	73.0 lbs/day

**Effluent Limitation for Dissolved Oxygen (DO) based upon Water Quality Standards**

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent D.O. limitation as follows:

Season	Concentration
Summer	5.50
Fall	5.50
Winter	5.50
Spring	5.50

**Effluent Limitation for Total Ammonia based upon Water Quality Standards**

In-stream criteria of downstream segments for Total Ammonia will be met with an effluent limitation (expressed as Total Ammonia as N) as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	266.18 mg/l as N	776.8 lbs/day
	1 Hour Avg. - Acute	224.5 mg/l as N	655.2 lbs/day
Fall	4 Day Avg. - Chronic	3.4 mg/l as N	9.9 lbs/day
	1 Hour Avg. - Acute	4.7 mg/l as N	13.8 lbs/day
Winter	4 Day Avg. - Chronic	5.0 mg/l as N	14.5 lbs/day
	1 Hour Avg. - Acute	7.3 mg/l as N	21.4 lbs/day
Spring	4 Day Avg. - Chronic	3.3 mg/l as N	9.6 lbs/day
	1 Hour Avg. - Acute	5.3 mg/l as N	15.3 lbs/day

Acute limit calculated with an Acute Zone of Initial Dilution (ZID) to be equal to 50.0%.

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Effluent Limitation for Total Residual Chlorine based upon Water Quality Standards**

In-stream criteria of downstream segments for Total Residual Chlorine will be met with an effluent limitation as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	2.546 mg/l	7.43 lbs/day
	1 Hour Avg. - Acute	2.387 mg/l	6.96 lbs/day
Fall	4 Day Avg. - Chronic	0.019 mg/l	0.06 lbs/day
	1 Hour Avg. - Acute	0.027 mg/l	0.08 lbs/day
Winter	4 Day Avg. - Chronic	0.024 mg/l	0.07 lbs/day
	1 Hour Avg. - Acute	0.031 mg/l	0.09 lbs/day
Spring	4 Day Avg. - Chronic	0.027 mg/l	0.08 lbs/day
	1 Hour Avg. - Acute	0.034 mg/l	0.10 lbs/day

**Effluent Limitations for Total Dissolved Solids based upon Water Quality Standards**

Season		Concentration	Load
Summer	Maximum, Acute	245529.4 mg/l	358.28 tons/day
Fall	Maximum, Acute	197823.3 mg/l	288.67 tons/day
Winter	Maximum, Acute	162504.9 mg/l	237.13 tons/day
Spring	Maximum, Acute	208102.5 mg/l	303.66 tons/day

Colorado Salinity Forum Limits                      Determined by Permitting Section

**Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards**

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 280.08 mg/l):

	4 Day Average		1 Hour Average		Load
	Concentration	Load	Concentration	Load	
Aluminum*	N/A	N/A	98,929.8	ug/l	289.3 lbs/day
Arsenic*	47,909.04 ug/l	90.4 lbs/day	44,921.6	ug/l	131.4 lbs/day
Cadmium	464.62 ug/l	0.9 lbs/day	651.1	ug/l	1.9 lbs/day
Chromium III	50,154.34 ug/l	94.6 lbs/day	556,086.5	ug/l	1626.0 lbs/day
Chromium VI*	1,791.37 ug/l	3.4 lbs/day	1,600.7	ug/l	4.7 lbs/day
Copper	5,350.16 ug/l	10.1 lbs/day	4,711.6	ug/l	13.8 lbs/day
Iron*	N/A	N/A	131,467.2	ug/l	384.4 lbs/day
Lead	2,932.35 ug/l	5.5 lbs/day	40,184.7	ug/l	117.5 lbs/day
Mercury*	3.05 ug/l	0.0 lbs/day	318.7	ug/l	0.9 lbs/day
Nickel	31,086.25 ug/l	58.6 lbs/day	148,564.1	ug/l	434.4 lbs/day
Selenium*	1,018.33 ug/l	1.9 lbs/day	2,576.6	ug/l	7.5 lbs/day
Silver	N/A ug/l	N/A lbs/day	2,921.4	ug/l	8.5 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

Zinc	69,707.76 ug/l	131.5 lbs/day	36,385.5	ug/l	106.4 lbs/day
Cyanide*	1,323.06 ug/l	2.5 lbs/day	2,921.3	ug/l	8.5 lbs/day

\*Limits for these metals are based on the dissolved standard.

**Effluent Limitations for Heat/Temperature based upon  
Water Quality Standards**

Summer	100.0 Deg. C.	212.0 Deg. F
Fall	9.7 Deg. C.	49.5 Deg. F
Winter	7.7 Deg. C.	45.9 Deg. F
Spring	14.9 Deg. C.	58.8 Deg. F

**Effluent Limitations for Organics [Pesticides]  
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Organics [Pesticides] will be met with an effluent limit as follows:

	4 Day Average		1 Hour Average		
	Concentration	Load	Concentration		Load
Aldrin			1.5E+00	ug/l	6.79E-03 lbs/day
Chlordane	4.30E-03 ug/l	1.25E-02 lbs/day	1.2E+00	ug/l	5.43E-03 lbs/day
DDT, DDE	1.00E-03 ug/l	2.92E-03 lbs/day	5.5E-01	ug/l	2.49E-03 lbs/day
Dieldrin	1.90E-03 ug/l	5.54E-03 lbs/day	1.3E+00	ug/l	5.65E-03 lbs/day
Endosulfan	5.60E-02 ug/l	1.63E-01 lbs/day	1.1E-01	ug/l	4.98E-04 lbs/day
Endrin	2.30E-03 ug/l	6.71E-03 lbs/day	9.0E-02	ug/l	4.07E-04 lbs/day
Guthion	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	4.52E-05 lbs/day
Heptachlor	3.80E-03 ug/l	1.11E-02 lbs/day	2.6E-01	ug/l	1.18E-03 lbs/day
Lindane	8.00E-02 ug/l	2.33E-01 lbs/day	1.0E+00	ug/l	4.52E-03 lbs/day
Methoxychlor	0.00E+00 ug/l	0.00E+00 lbs/day	3.0E-02	ug/l	1.36E-04 lbs/day
Mirex	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	4.52E-05 lbs/day
Parathion	0.00E+00 ug/l	0.00E+00 lbs/day	4.0E-02	ug/l	1.81E-04 lbs/day
PCB's	1.40E-02 ug/l	4.09E-02 lbs/day	2.0E+00	ug/l	9.05E-03 lbs/day
Pentachlorophenol	1.30E+01 ug/l	3.79E+01 lbs/day	2.0E+01	ug/l	9.05E-02 lbs/day
Toxephene	2.00E-04 ug/l	5.84E-04 lbs/day	7.3E-01	ug/l	3.30E-03 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Effluent Targets for Pollution Indicators  
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

	<b>1 Hour Average</b>	
	Concentration	Loading
Gross Beta (pCi/l)	50.0 pCi/L	
BOD (mg/l)	5.0 mg/l	14.6 lbs/day
Nitrates as N	4.0 mg/l	11.7 lbs/day
Total Phosphorus as P	0.05 mg/l	0.1 lbs/day
Total Suspended Solids	90.0 mg/l	263.2 lbs/day

Note: Pollution indicator targets are for information purposes only.

**Effluent Limitations for Protection of Human Health [Toxics Rule]  
Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)**

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

	<b>Maximum Concentration</b>	
	Concentration	Load
<b>Toxic Organics</b>		
Acenaphthene	3.17E+05 ug/l	9.27E+02 lbs/day
Acrolein	8.47E+04 ug/l	2.47E+02 lbs/day
Acrylonitrile	1.56E+01 ug/l	4.56E-02 lbs/day
Benzene	3.17E+02 ug/l	9.27E-01 lbs/day
Benzidine	ug/l	lbs/day
Carbon tetrachloride	6.61E+01 ug/l	1.93E-01 lbs/day
Chlorobenzene	1.80E+05 ug/l	5.25E+02 lbs/day
1,2,4-Trichlorobenzene		
Hexachlorobenzene	1.98E-01 ug/l	5.79E-04 lbs/day
1,2-Dichloroethane	1.01E+02 ug/l	2.93E-01 lbs/day
1,1,1-Trichloroethane		
Hexachloroethane	5.03E+02 ug/l	1.47E+00 lbs/day
1,1-Dichloroethane		
1,1,2-Trichloroethane	1.61E+02 ug/l	4.71E-01 lbs/day
1,1,2,2-Tetrachloroethane	4.50E+01 ug/l	1.31E-01 lbs/day
Chloroethane		
Bis(2-chloroethyl) ether	8.20E+00 ug/l	2.39E-02 lbs/day
2-Chloroethyl vinyl ether		
2-Chloronaphthalene	4.50E+05 ug/l	1.31E+03 lbs/day
2,4,6-Trichlorophenol	5.56E+02 ug/l	1.62E+00 lbs/day
p-Chloro-m-cresol		
Chloroform (HM)	1.51E+03 ug/l	4.40E+00 lbs/day
2-Chlorophenol	3.17E+04 ug/l	9.27E+01 lbs/day
1,2-Dichlorobenzene	7.14E+05 ug/l	2.08E+03 lbs/day
1,3-Dichlorobenzene	1.06E+05 ug/l	3.09E+02 lbs/day

**Utah Division of Water Quality  
Salt Lake City, Utah**

1,4-Dichlorobenzene	1.06E+05 ug/l	3.09E+02 lbs/day
3,3'-Dichlorobenzidine	1.06E+01 ug/l	3.09E-02 lbs/day
1,1-Dichloroethylene	1.51E+01 ug/l	4.40E-02 lbs/day
1,2-trans-Dichloroethylene1		
2,4-Dichlorophenol	2.46E+04 ug/l	7.18E+01 lbs/day
1,2-Dichloropropane	1.38E+02 ug/l	4.02E-01 lbs/day
1,3-Dichloropropylene	2.65E+03 ug/l	7.72E+00 lbs/day
2,4-Dimethylphenol	1.43E+05 ug/l	4.17E+02 lbs/day
2,4-Dinitrotoluene	2.91E+01 ug/l	8.49E-02 lbs/day
2,6-Dinitrotoluene		
1,2-Diphenylhydrazine	1.06E+01 ug/l	3.09E-02 lbs/day
Ethylbenzene	8.20E+05 ug/l	2.39E+03 lbs/day
Fluoranthene	7.94E+04 ug/l	2.32E+02 lbs/day
4-Chlorophenyl phenyl ether		
4-Bromophenyl phenyl ether		
Bis(2-chloroisopropyl) ether	3.70E+05 ug/l	1.08E+03 lbs/day
Bis(2-chloroethoxy) methane		
Methylene chloride (HM)	1.24E+03 ug/l	3.63E+00 lbs/day
Methyl chloride (HM)		
Methyl bromide (HM)		
Bromoform (HM)	1.14E+03 ug/l	3.32E+00 lbs/day
Dichlorobromomethane(HM)	7.14E+01 ug/l	2.08E-01 lbs/day
Chlorodibromomethane (HM)	1.08E+02 ug/l	3.17E-01 lbs/day
Hexachlorocyclopentadiene	6.35E+04 ug/l	1.85E+02 lbs/day
Isophorone	2.22E+03 ug/l	6.49E+00 lbs/day
Naphthalene		
Nitrobenzene	4.50E+03 ug/l	1.31E+01 lbs/day
2-Nitrophenol		
4-Nitrophenol		
2,4-Dinitrophenol	1.85E+04 ug/l	5.40E+01 lbs/day
4,6-Dinitro-o-cresol	3.44E+03 ug/l	1.00E+01 lbs/day
N-Nitrosodimethylamine	1.83E-01 ug/l	5.33E-04 lbs/day
N-Nitrosodiphenylamine	1.32E+03 ug/l	3.86E+00 lbs/day
N-Nitrosodi-n-propylamine	1.32E+00 ug/l	3.86E-03 lbs/day
Pentachlorophenol	7.41E+01 ug/l	2.16E-01 lbs/day
Phenol	5.56E+06 ug/l	1.62E+04 lbs/day
Bis(2-ethylhexyl)phthalate	4.76E+02 ug/l	1.39E+00 lbs/day
Butyl benzyl phthalate	7.94E+05 ug/l	2.32E+03 lbs/day
Di-n-butyl phthalate	7.14E+05 ug/l	2.08E+03 lbs/day
Di-n-octyl phthlate		
Diethyl phthalate	6.09E+06 ug/l	1.78E+04 lbs/day
Dimethyl phthlate	8.28E+07 ug/l	2.42E+05 lbs/day
Benzo(a)anthracene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Benzo(a)pyrene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Benzo(b)fluoranthene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Benzo(k)fluoranthene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Chrysene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Acenaphthylene (PAH)		
Anthracene (PAH)		
Dibenzo(a,h)anthracene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day
Indeno(1,2,3-cd)pyrene (PAH)	7.41E-01 ug/l	2.16E-03 lbs/day



**Utah Division of Water Quality  
Salt Lake City, Utah**

Pyrene (PAH)	2.54E+05 ug/l	7.41E+02 lbs/day
Tetrachloroethylene	2.12E+02 ug/l	6.18E-01 lbs/day
Toluene	1.80E+06 ug/l	5.25E+03 lbs/day
Trichloroethylene	7.14E+02 ug/l	2.08E+00 lbs/day
Vinyl chloride	5.29E+02 ug/l	1.54E+00 lbs/day

**Pesticides**

Aldrin	3.44E-02 ug/l	1.00E-04 lbs/day
Dieldrin	3.70E-02 ug/l	1.08E-04 lbs/day
Chlordane	1.51E-01 ug/l	4.40E-04 lbs/day
4,4'-DDT	1.56E-01 ug/l	4.56E-04 lbs/day
4,4'-DDE	1.56E-01 ug/l	4.56E-04 lbs/day
4,4'-DDD	2.20E-01 ug/l	6.41E-04 lbs/day
alpha-Endosulfan	2.46E+02 ug/l	7.18E-01 lbs/day
beta-Endosulfan	2.46E+02 ug/l	7.18E-01 lbs/day
Endosulfan sulfate	2.46E+02 ug/l	7.18E-01 lbs/day
Endrin	2.01E+02 ug/l	5.87E-01 lbs/day
Endrin aldehyde	2.01E+02 ug/l	5.87E-01 lbs/day
Heptachlor	5.56E-02 ug/l	1.62E-04 lbs/day
Heptachlor epoxide		

**PCB's**

PCB 1242 (Arochlor 1242)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1254 (Arochlor 1254)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1221 (Arochlor 1221)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1232 (Arochlor 1232)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1248 (Arochlor 1248)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1260 (Arochlor 1260)	1.16E-02 ug/l	3.40E-05 lbs/day
PCB-1016 (Arochlor 1016)	1.16E-02 ug/l	3.40E-05 lbs/day

**Pesticide**

Toxaphene	1.93E-01 ug/l	5.64E-04 lbs/day
-----------	---------------	------------------

**Metals**

Antimony	3703.98 ug/l	10.81 lbs/day
Arsenic	12777.80 ug/l	37.29 lbs/day
Asbestos	1.85E+09 ug/l	5.40E+06 lbs/day
Beryllium		
Cadmium		
Chromium (III)		
Chromium (VI)		
Copper	343941.06 ug/l	1003.76 lbs/day
Cyanide	185199.03 ug/l	540.49 lbs/day
Lead	0.00	0.00
Mercury	37.04 ug/l	0.11 lbs/day
Nickel	161387.73 ug/l	471.00 lbs/day
Selenium	0.00	0.00
Silver	0.00	0.00
Thallium	449.77 ug/l	1.31 lbs/day
Zinc		

**Utah Division of Water Quality  
Salt Lake City, Utah**

**Dioxin**

Dioxin (2,3,7,8-TCDD)

3.44E-06 ug/l

1.00E-08 lbs/day

**Metals Effluent Limitations for Protection of All Beneficial Uses  
Based upon Water Quality Standards and Toxics Rule**

	<b>Class 4 Acute Agricultural ug/l</b>	<b>Class 3 Acute Aquatic Wildlife ug/l</b>	<b>Acute Toxics Drinking Water Source ug/l</b>	<b>Acute Toxics Wildlife ug/l</b>	<b>1C Acute Health Criteria ug/l</b>	<b>Acute Most Stringent ug/l</b>	<b>Class 3 Chronic Aquatic Wildlife ug/l</b>
Aluminum		98929.8				98929.8	N/A
Antimony			3704.0	1137651.2		3704.0	
Arsenic	26457.0	44921.6	12777.8			12777.8	47909.0
Barium					264570.0	264570.0	
Beryllium						0.0	
Cadmium	2632.5	651.1				651.1	464.6
Chromium (III)		556086.5				556086.5	50154.3
Chromium (VI)	25610.9	1600.7				1600.71	1791.37
Copper	52526.6	4711.6	343941.1			4711.6	5350.2
Cyanide		2921.3	58205409.5			2921.3	1323.1
Iron		131467.2				131467.2	
Lead	26383.2	40184.7				26383.2	2932.3
Mercury		318.68	37.0	39.69		37.04	3.051
Nickel		148564.1	161387.7	1217022.2		148564.1	31086.3
Selenium	13070.4	2576.6				2576.6	1018.3
Silver		2921.4				2921.4	
Thallium			449.8	1666.8		449.8	
Zinc		36385.5				36385.5	69707.8
Boron	182270.7					182270.7	
Sulfate	529140.1					529140.1	

**Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]**

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

	<b>WLA Acute ug/l</b>	<b>WLA Chronic ug/l</b>	
Aluminum	98929.8	N/A	
Antimony	3703.98		
Arsenic	12777.8	47909.0	Acute Controls
Asbestos	1.85E+09		
Barium			
Beryllium			
Cadmium	651.1	464.6	
Chromium (III)	556086.5	50154	
Chromium (VI)	1600.7	1791.4	Acute Controls
Copper	4711.6	5350.2	Acute Controls

**Utah Division of Water Quality  
Salt Lake City, Utah**

Cyanide	2921.3	1323.1	
Iron	131467.2		
Lead	26383.2	2932.3	
Mercury	37.037	3.051	
Nickel	148564.1	31086	
Selenium	2576.6	1018.3	
Silver	2921.4	N/A	
Thallium	449.8		
Zinc	36385.5	69707.8	Acute Controls
Boron	182270.69		
Sulfate	529140.1		N/A at this Waterbody

Other Effluent Limitations are based upon R317-1.

E. coli 126.0 organisms per 100 ml

**X. Antidegradation Considerations**

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required. The proposed permit is a simple renewal, with no increase in flow or concentration over that which was approved in the existing permit.

**XI. Colorado River Salinity Forum Considerations**

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value.

**XII. Summary Comments**

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.