



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Interim Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

September 6, 2019

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Henefer Town Wastewater Lagoons Facility
MAILING ADDRESS: PO Box 112, Henefer, UT 84033
TELEPHONE NUMBER: (435) 336-5365
FACILITY LOCATION: 150 West Center St., Henefer, UT (Town Office)
UPDES PERMIT NO.: UT0020192
PERMITTED OUTFALL: 001
RECEIVING WATER: Weber River

BACKGROUND

Henefer Town, with a current population of approximately 850 is served by a four-cell lagoon domestic sewage treatment system comprising 15.59 acres total (facility). The facility is located approximately 0.6 miles northwest of Henefer Town along the Weber River, with latitude 41°01 '24" and longitude 111°30'24" coordinates. The original three lagoon cells were constructed in 1974, while the fourth cell and ultraviolet disinfection unit were added in 1988. The facility's influent average design flow is 0.15 million gallons per day (MGD) for continuous discharge, while the effluent average flow is 0.35 MGD and is typically an intermittent discharge during a few months of each year. Upon review of all available permit information, there are no significant changes being proposed for this permit renewal effort.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **October 7, 2019**. Written public comments can be submitted to: Jeff Studenka, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: jstudenka@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Jeff Studenka at 801-536-4395.

DWQ-2019-010363