

**Utah Division of Water Quality
Statement of Basis
Wasteload Analysis for Jordan River POTWs**

Date: October 8, 2021

Prepared by: Nicholas von Stackelberg, P.E., Watershed Protection Section
Chris Shope, Ph.D., Standards and Technical Services Section
Suzan Tahir, Standards and Technical Services Section

Facility: Jordan River Publicly Owned Treatment Works (POTW)

Receiving water: Jordan River and State Canal

This addendum summarizes the wasteload analysis that was performed to determine water quality based effluent limits (WQBEL) for this discharge. Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also considers downstream designated uses (UAC R317-2-8). Projected concentrations are compared to numeric water quality standards to determine acceptability. The numeric criteria in this wasteload analysis may be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

Discharges

The following dischargers are considered in this combined wasteload analysis for discharge to the Jordan River:

1. Jordan Basin Water Reclamation Facility (WRF) - UT0025852
2. South Valley Water Reclamation Facility (WRF) - UT0024384
3. Central Valley Water Reclamation Facility (WRF) - UT0024392
4. South Davis Sewer District South Wastewater Treatment Plant (WWTP) - UT0021628
5. South Davis Sewer District North Wastewater Treatment Plant (WWTP) - UT0021636

The receiving water and the maximum monthly average discharges used in this wasteload allocation are summarized in Table 1. The projected 5-year monthly average discharge was estimated by multiplying the current average discharge (2016-2021) by 10% to account for growth in the service district. Jordan Basin WRF was assumed to operate at design capacity.

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

Table 1: Receiving waters and discharge rate

| Facility | Receiving Water | Monthly Ave (MGD) | |
|--------------------|---|-------------------|----------------|
| | | Design Capacity | Projected 5-YR |
| Jordan Basin WRF | Jordan River, from confluence with Little Cottonwood Creek to Narrows Diversion | 15 | 15 |
| South Valley WRF | Jordan River, from confluence with Little Cottonwood Creek to Narrows Diversion | 50 | 21.7 |
| Central Valley WRF | Jordan River, from North Temple Street to confluence with Little Cottonwood Creek | 75 | 55.7 |
| SDSD South WWTP | Jordan River, from Farmington Bay to North Temple Street | 4 | 3.8 |
| SDSD North WWTP | State Canal, from Farmington Bay to confluence with the Jordan River | 12 | 8.1 |

Effluent water quality data were obtained from UDWQ monitoring, Jordan River/Farmington Bay Water Quality Council (JRFBWQC) monitoring, and Discharge Monitoring Reports (DMR) and Monthly Operating Reports (MOR) from each facility.

Receiving Waters

The receiving waters for this wasteload allocation are Jordan River and State Canal.

Per UAC R317-2-14, the designated beneficial uses for the Jordan River and State Canal are shown in Table 2.

Table 2: Beneficial uses for receiving waters

| POTW | Assessment Unit | Assessment Unit Description | Assessment Unit ID | Beneficial Uses |
|------------|-----------------------------|---|--------------------|-----------------|
| SDSDN WWTP | State Canal ^a | State Canal from Farmington Bay to confluence with the Jordan River | UT16020204-034_00 | 2B, 3B*, 3D, 4 |
| SDSDS WWTP | Jordan River-1 ^a | Jordan River from Farmington Bay upstream contiguous with the Davis County line | UT16020204-001_00 | 2B, 3B*, 3D, 4 |
| CVWRF | Jordan River-4 | Jordan River from 2100 South to the confluence with Little Cottonwood Creek | UT16020204-004_00 | 2B, 3B*, 4 |
| SVWRF | Jordan River-5 | Jordan River from the confluence with Little Cottonwood Creek to 7800 South | UT16020204-005_00 | 2B, 3B, 4 |
| JBWRF | Jordan River-6 | Jordan River from 7800 South to Bluffdale at 14600 South | UT16020204-006_00 | 2B, 3B, 4 |

* Site specific criteria for dissolved oxygen. See UAC R317.2.14 Table 2.14.5.

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

Per UAC R317-2-6, the following is the description for each beneficial use listed in Table 2.

- *Class 2B - Protected for infrequent primary contact recreation. Also protected for secondary contact recreation where there is a low likelihood of ingestion of water or a low degree of bodily contact with the water. Examples include, but are not limited to, wading, hunting, and fishing.*
- *Class 3B - Protected for warm water species of game fish and other warm water aquatic life, including the necessary aquatic organisms in their food chain.*
- *Class 3D - Protected for waterfowl, shore birds and other water-oriented wildlife not included in Classes 3A, 3B, or 3C, including the necessary aquatic organisms in their food chain.*
- *Class 4 - Protected for agricultural uses including irrigation of crops and stock watering.*

Typically, the critical flow for the wasteload analysis is considered the lowest stream flow for seven consecutive days with a ten-year return frequency (7Q10). The seasonal 7Q10 flows calculated in the *Jordan River Low Flow Analysis* report (Hansen Allen and Luce, 2021) were used for the critical low flows for the POTWs, tributaries and diversions along the Jordan River. The critical low flows are summarized in Table 3.

Table 3: Critical low flows along Jordan River

| QUAL2Kw Segment No(s) | Source/Diversion Name | 7Q10 | | | |
|--------------------------|---------------------------------|------------|------------|------------|------------|
| | | WINTER | SPRING | SUMMER | FALL |
| 31 | Jordan Narrows (Total) | 3.2 | 7.7 | 222 | 6.4 |
| 31-32 | Groundwater Segment | 3 | 3 | 223 | 3 |
| 32 | JVWCD Pumps | 3 | 3 | 207 | 3 |
| 32 | ULDC North & South | 3 | 3 | 180 | 3 |
| 32 | Utah & Salt Lake Canal | 3 | 3 | 117 | 3 |
| 32 | East Jordan Canal | 2.9 | 2.8 | 76.7 | 3.4 |
| 32 | Jordan River Station No 1 | 2.9 | 2.8 | 76.7 | 3.4 |
| 32-51 | Groundwater Segment | 23 | 24 | 82 | 17 |
| 37 | Jordan & Salt Lake Canal | 23 | 24 | 67 | 17 |
| 37 | South Jordan Canal | 23 | 24 | 27 | 17 |
| 47 | Rose Creek | 23 | 24 | 27 | 17 |
| 51 | Jordan Basin WRF | 35 | 36 | 37 | 28 |
| 51-76 | Groundwater Segment | 62 | 64 | 44 | 46 |
| 54 | Corner Canyon Creek | 62 | 65 | 44 | 46 |
| 59 | Riverton 126th Pump Station | 62 | 65 | 44 | 46 |
| 65 | Midas Creek | 62 | 65 | 44 | 47 |
| 66 | Willow Creek | 63 | 66 | 45 | 47 |
| 74 | North Jordan Canal | 27 | 32 | 27 | 23 |
| 74 | Dry Creek | 27 | 32 | 28 | 23 |
| 76 | Jordan River at 9000 South | 27 | 32 | 28 | 23 |
| 76-84 | Groundwater Segment | 39 | 40 | 43 | 36 |
| 76 | 9000 South Drain | 39 | 40 | 43 | 36 |
| 81 | Bingham Creek | 40 | 40 | 47 | 37 |
| 84 | South Valley WRF | 71 | 71 | 80 | 68 |
| 84-111 | Groundwater Segment | 112 | 97 | 130 | 110 |
| 85 | 7200 South Drain | 112 | 97 | 130 | 110 |
| 97 | Little Cottonwood Creek | 113 | 98 | 139 | 112 |
| 98 | Brighton Canal | 113 | 98 | 139 | 112 |
| 100 | Big Cottonwood Creek | 119 | 106 | 161 | 123 |
| N/A | Mill Creek above Central Valley | 3 | 10 | 21 | 10 |
| 111 | Mill Creek at Jordan River | 122 | 116 | 182 | 133 |

Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs

| QUAL2Kw Segment No(s) | Source/Diversion Name | 7Q10 | | | |
|--------------------------|----------------------------------|--------|--------|--------|------|
| | | WINTER | SPRING | SUMMER | FALL |
| 111 | Central Valley WRF | 191 | 188 | 255 | 200 |
| 111-115 | Groundwater Segment | 197 | 192 | 263 | 206 |
| 112 | Decker Lake Outfall | 197 | 192 | 265 | 207 |
| 115 | Jordan River above Surplus Canal | 197 | 192 | 265 | 207 |
| 115-118 | Groundwater Segment | 200 | 195 | 267 | 210 |
| 116 | Surplus Canal | 25 | 11 | 26 | 89 |
| 118 | Jordan River at 1700 South | 25 | 11 | 26 | 89 |
| 118-133 | Groundwater Segment | 37 | 48 | 104 | 92 |
| 122 | 1300 South Conduits | 39 | 50 | 121 | 93 |
| 130 | City Creek/N Temple Conduit | 40 | 52 | 123 | 93 |
| 133 | Jordan River at 500 North | 40 | 52 | 123 | 93 |
| 133-151 | Groundwater Segment | 51 | 64 | 134 | 104 |
| 151 | South Davis South WRF | 55 | 67 | 137 | 107 |
| 151-162 | Groundwater Segment | 62 | 74 | 144 | 114 |
| 162 | State Canal | 21 | 25 | 48 | 38 |
| 162-171 | Groundwater Segment | 26 | 31 | 54 | 44 |
| 162 | A-1 Drain | 26 | 31 | 54 | 44 |
| 169 | South Davis North WRF | 34 | 39 | 62 | 52 |
| 171 | Mill Creek (Davis County) | 34 | 38 | 62 | 51 |
| 171-172 | Groundwater Segment | 35 | 40 | 63 | 52 |
| 172 | Stone Creek | 36 | 41 | 63 | 53 |

Receiving and tributary water quality data were obtained from UDWQ and WFWQC monitoring sites. The average seasonal value was calculated for each constituent with available data in the receiving water for the period 2006 - 2021.

TMDL

The 303(d) list of impairments of the Jordan River, Mill Creek, and State Canal in *Utah's Final 2016 303(d) Water Quality Assessment Report dated December 7, 2016* (Utah DWQ 2016) is summarized in Table 4. The table also includes changes in the *Utah Combined 2018/2020 303(d) Water Quality Assessment Report dated February 9, 2021*, which has not been approved to date. The dissolved oxygen impairment in the lower Jordan River (below Surplus Canal) was addressed by the *Jordan River Total Maximum Daily Load Water Quality Study – Phase 1* (Cirrus Ecological Solutions and Stantec Consultants 2013), which identified organic matter as the pollutant of concern and recommended additional studies to determine the sources and allocation [CS1]. The E. coli impairment in the Jordan River watershed is currently being identified and addressed through a Total Maximum Daily Load Study within Utah DWQ.

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

Table 4: List of impairments of Jordan River and State Canal

| Assessment Unit | Assessment Unit Description | Assessment Unit ID | Impaired Parameter |
|---|---|---------------------------|---|
| State Canal | State Canal from Farmington Bay to confluence with the Jordan River | UT16020204-034_00 | Total Ammonia as N Min Dissolved Oxygen Total Dissolved Solids |
| Jordan River-1 | Jordan River from Farmington Bay upstream contiguous with the Davis County line | UT16020204-001_00 | E. coli *DissolvedCopper Min Dissolved Oxygen Total Dissolved Solids Bioassessment/Macroinv |
| Jordan River 2 | Jordan River from Davis County line upstream to North Temple Street | UT16020204-002_00 | E. coli Min Dissolved Oxygen *Total Dissolved Solids Bioassessment/Macroinv |
| Jordan River-3 | Jordan River from North Temple to 2100 South | UT16020204-003_00 | E. coli Total Phosphorus as P Min Dissolved Oxygen Bioassessment/Macroinv |
| Jordan River-4 | Jordan River from 2100 South to the confluence with Little Cottonwood Creek | UT16020204-004_00 | E. coli Total Dissolved Solids Bioassessment/Macroinv |
| Jordan River-5 | Jordan River from the confluence with Little Cottonwood Creek to 7800 South | UT16020204-005_00 | E. coli Max Temperature Total Dissolved Solids |
| Jordan River-6 | Jordan River from 7800 South to Bluffdale at 14600 South | UT16020204-006_00 | *Dissolved Selenium Max Temperature Total Dissolved Solids Bioassessment/Macroinv |
| Jordan River-7 | Jordan River from Bluffdale at 14600 South to Narrows | UT16020204-007_00 | Max Temperature **Total Dissolved Solids Bioassessment/Macroinv |
| Jordan River-8 | Jordan River from Narrows to Utah Lake | UT16020201-008_00 | Arsenic Total Dissolved Solids |
| * impaired parameter in 2016 IR but not in 2018/2020 IR ** impaired as of 2018/2020 IR | | | |

Mixing Zone

The maximum allowable mixing zone is 15 minutes of travel time for acute conditions, not to exceed 50% of stream width, and 2,500 feet for chronic conditions, per UAC R317-2-5. Water quality standards must be met at the end of the mixing zone.

The mixing zone was presumed to remain within the maximum allowable mixing zone dimensions for each discharge. Acute limits were calculated using 50% of the seasonal critical low flow.

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

Parameters of Concern

The parameters of concern considered in this wasteload allocation are total ammonia (TAN) and total recoverable metals. Due to ongoing studies related to the TMDL, this wasteload allocation does not address parameters related to dissolved oxygen, including biochemical oxygen demand (BOD), dissolved oxygen (DO), total nitrogen (TN), and total phosphorus (TP).

Water Quality Modeling

A QUAL2Kw model of the Jordan River was populated and calibrated as part of the DO TMDL study (Stantec Consulting 2010, UDWQ 2010). The model was subsequently validated to a synoptic survey conducted by UDWQ and the Jordan River/Farmington Bay Water Quality Council (JRFBWQC) during July 2014 (UDWQ 2015). The model validation identified areas for future improvement of the model; however, the model was considered suitable for application to the wasteload allocation for ammonia.

The TMDL model of the Jordan River extends 52.4 miles from the outlet of Utah Lake to Burton Dam. For the purposes of the WLA, the model was split at Burnham Dam (approximately 1.7 miles upstream of Burton Dam) and extended down State Canal to the Farmington Bay Waterfowl Management Area (approximately 3.5 miles downstream from Burnham Dam). The following point sources were added to the State Canal: A-1 Drain, South Davis Sewer District North WWTP, and outlet channel from Bountiful Pond (Mill Creek and Stone Creek). In addition, the Jordan Basin WRF discharge was added to the Jordan River, as this discharge was not active at the time of the model calibration.

The Jordan River WLA QUAL2Kw model was used for determining the WQBEL for ammonia. Effluent concentrations were adjusted up to the current permit limits so that water quality criteria were not exceeded in the receiving water. Background conditions for each plant were characterized by assuming each upstream plant was operating at the low flow rate with average ammonia concentration in the effluent. For calculating the chronic ammonia criterion, fish early life stages (ELS) were assumed to be present during all seasons except downstream of the CVWRF and SDSD plants, where ELS were assumed to be present from March through October. Per UAC R317-2-14, Table 2.14.2, the site specific standard for ammonia for the Jordan River from Mill Creek to 900 South was applied.

A mass balance mixing analysis was used to calculate the seasonal WLA for conservative constituents such as metals. Each wastewater treatment plant was granted a full allocation at the point of discharge. Background condition in the Jordan River for each plant was characterized by either a single or combined, multiple monitoring location data.

The calibration, validation and wasteload models are available for review by request.

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

WET Limits

The percent of effluent in the receiving water in a fully mixed condition, and acute and chronic dilution in an incompletely mixed condition are calculated in the WLA in order to generate WET limits. The LC₅₀ (lethal concentration, 50%) percent effluent for acute toxicity and the IC₂₅ (inhibition concentration, 25%) percent effluent for chronic toxicity, as determined by the WET test, needs to be below the WET limits, as determined by the WLA (Table 5). The WET limit for LC₅₀ is typically 100% effluent and does not need to be determined by the WLA.

Table 5: WET Limits for IC₂₅

| Season | Percent Effluent |
|--------------------|-------------------------|
| Jordan Basin WRF | 46% |
| South Valley WRF | 62% |
| Central Valley WRF | 39% |
| SDSD South WWTP | 21% |
| SDSD North WWTP | 63% |

Effluent Limits

The water quality based effluent limits determined as part of this combined wasteload allocation are summarized in Table 6.

Since the DO impairment of the Jordan River is being addressed through the TMDL process, limits were not calculated for DO, BOD/CBOD, or nutrients. The permit limits for DO and BOD/CBOD were calculated in a previous permit issued prior to the impairment of the Jordan River and are carried forward in this WLA.

Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs

Table 6: Water Quality Based Effluent Limits Summary

| Effluent Constituent | Averaging Period | Jordan Basin | South Valley | Central Valley | SDSD South WWTP | SDSD North WWTP |
|--|------------------|------------------|------------------|-------------------|------------------|------------------|
| Flow (MGD) | Monthly | 15 | 50 | 75 | 4 | 12 |
| Ammonia Acute (mg/L) | Daily | | | | | |
| Summer (Jun-Aug) | | 6.0 | 6.0 | 13.1 | 30.0 | 24.0 |
| Fall (Sep-Nov) | | 6.0 | 9.0 | 15.9 | 40.0 | 16.2 |
| Winter (Dec-Feb) | | 9.0 | 9.4 | 12.3 | 17.0 | 13.0 |
| Spring (Mar-May) | | 8.0 | 7.4 | 15.9 | 26.0 | 15.0 |
| Ammonia Chronic (mg/L) | Monthly | | | | | |
| Summer (Jun-Aug) | | 3.0 | 1.5 | 3.7 | 8.0 | 5.5 |
| Fall (Sep-Nov) | | 2.5 | 3.0 | | 20.0 | 7.5 |
| (Sep-Oct) | | | | 4.5 | | |
| (Nov) | | | | 5.9 | | |
| Winter (Dec-Feb) | | 3.0 | 4.0 | 5.8 | 14.0 | 6.5 |
| Spring (Mar-May) | 2.5 | 3.0 | 5.3 | 12.0 | 6.0 | |
| TRC Acute (mg/L) | Daily | | | | | |
| Summer (Jul-Sep) | | N/A ^b | 0.028 | N/A ^b | 0.321 | 0.066 |
| Fall (Oct-Dec) | | N/A ^b | 0.022 | N/A ^b | 0.253 | 0.057 |
| Winter (Jan-Mar) | | N/A ^b | 0.028 | N/A ^b | 0.134 | 0.045 |
| Spring (Apr-Jun) | | N/A ^b | 0.023 | N/A ^b | 0.163 | 0.048 |
| DO (mg/L) | Minimum | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 |
| BOD ₅ /CBOD ₅ (mg/L) | Monthly | BOD ₅ | BOD ₅ | CBOD ₅ | BOD ₅ | BOD ₅ |
| Summer (Jul-Sep) | | 15.0 | 15.0 | 16.0 | 20.0 | 20.0 |
| Fall (Oct-Dec) | | 15.0 | 15.0 | 20.0 | 25.0 | 25.0 |
| Winter (Jan-Mar) | | 15.0 | 15.0 | 20.0 | 25.0 | 25.0 |
| Spring (Apr-Jun) | | 15.0 | 15.0 | 20.0 | 25.0 | 25.0 |
| BOD ₅ /CBOD ₅ (mg/L) | Weekly | BOD ₅ | BOD ₅ | CBOD ₅ | BOD ₅ | BOD ₅ |
| Summer (Jul-Sep) | | 21.0 | 21.0 | 27.0 | 27.0 | 27.0 |
| Fall (Oct-Dec) | | 21.0 | 21.0 | 28.0 | 35.0 | 35.0 |
| Winter (Jan-Mar) | | 21.0 | 21.0 | 28.0 | 35.0 | 35.0 |
| Spring (Apr-Jun) | | 21.0 | 21.0 | 28.0 | 35.0 | 35.0 |

a: Limit due to impairment of receiving segment.
b: Ultraviolet disinfection utilized, hence no limit for TRC

QUAL2Kw rates, input and output are summarized in Appendix A. The WQBELs for conservative constituents are summarized in Appendix B. Per R317-2.14.2, cyanide numeric criteria for aquatic life is based on free cyanide, which is a portion of total cyanide. Models and supporting documentation are available for review upon request.

Files:

- Wasteload Report: *211008-JordanRiverPOTWWLA_2021.docx*
- QUAL2Kw Calibration Model: *jordan_aug2009_q2kw_calib_2010-8-26.xls*
- QUAL2Kw Validation Model: *jordan_q2kw_synoptic_2014-07-22.xlsm*
- QUAL2Kw Wasteload Model: *jordan_potw_q2kw_wla_2021.xlsm*
- JBWRF Metals Wasteload Model: *JBWRF_WLA_2021.xlsm*
- SVWRF Metals Wasteload Model: *SVWRF_WLA_2021.xlsm*
- CVWRF Metals Wasteload Model: *CVWRF_WLA_JR_2021.xlsm*
- SDSWRF Metals Wasteload Model: *SDSDSWWTP_WLA_2021.xlsm*
- SDNWRF Metals Wasteload Model: *SDSDNWWTP_WLA_2021.xlsm*

**Utah Division of Water Quality
Wasteload Analysis
Jordan River POTWs**

References:

Cirrus Ecological Solutions and Stantec Consulting. 2013. *Jordan River Total Maximum Daily Load Water Quality Study – Phase 1*. Prepared for State of Utah, Department of Environmental Quality, Division of Water Quality.

Hansen, Allen and Luce Inc. 2021. Jordan River Low Flow Analysis. Wasatch Front Water Quality Council and South Davis Sewer District.

Neilson, B.T., A.J. Hobson, N. von Stackelberg, M. Shupryt, and J.D. Ostermiller. 2012. *Using QUAL2K Modeling to Support Nutrient Criteria Development and Wasteload Analyses in Utah*. Prepared for State of Utah, Department of Environmental Quality, Division of Water Quality.

Stantec Consulting. 2010. *Jordan River TMDL: 2010 QUAL2Kw Model Calibration Technical Memo Public Draft*. Prepared for State of Utah, Department of Environmental Quality, Division of Water Quality. February 22, 2010. 18 pp.

Utah DWQ. 2010. *Jordan River TMDL QUAL2Kw model refinement*. Prepared by N. Von Stackelberg P.E., State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah DWQ. 2021. *Utah Wasteload Analysis Procedures Version 2.0*. State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah DWQ 2012. *Field Data Collection for QUAL2Kw Model Build and Calibration Standard Operating Procedures Version 1.0*. State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah DWQ. 2015. *Jordan River Summer 2014 Synoptic Survey and QUAL2Kw Model Validation Report*. Prepared by N. Von Stackelberg P.E., State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah DWQ. 2016. *Utah's 2016 303(d) [Water Quality Assessment Report](#)*. December October 2016. State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah DWQ. 2021. *Utah's Combined 2018/2020 303(d) [Water Quality Assessment Report](#)*. August 2021. State of Utah, Department of Environmental Quality, Division of Water Quality.

Utah Division of Water Quality

WASTELOAD ANALYSIS [WLA]

Date: 8/13/2021

Appendix A: QUAL2Kw Analysis for Ammonia

Discharging Facility: Jordan River POTWs
 Receiving Water: Jordan River and State Canal

Fully Mixed: Yes
 Acute River Width: 100%
 Chronic River Width: 100%

Modeling Information

A QUAL2Kw model was used to determine these effluent limits.

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort reflect the environmental conditions expected at low stream flows.

Model Inputs

The following were utilized as inputs for the analysis.

| Headwater - Utah Lake | Summer | Fall | Winter | Spring |
|-------------------------------------|--------|-------|--------|--------|
| Flow (cfs) | 222.0 | 6.4 | 3.2 | 7.7 |
| Temperature, Mean (deg C) | 22.3 | 13.9 | 2.7 | 11.4 |
| Temperature, Diel Range (deg C) | 3.0 | 2.5 | 2.0 | 2.5 |
| Specific Conductance (µmhos) | 1593 | 1689 | 1817 | 1513 |
| Inorganic Suspended Solids (mg/L) | 66.2 | 53.8 | 7.6 | 48.1 |
| Dissolved Oxygen, Mean (mg/L) | 6.9 | 8.5 | 23.2 | 14.2 |
| Dissolved Oxygen, Diel Range (mg/L) | 2.5 | 2.0 | 1.5 | 2.0 |
| CBOD ₅ (mg/L) | 1.8 | 2.7 | 2.3 | 2.0 |
| Organic Nitrogen (mg/L) | 0.426 | 0.396 | 0.533 | 0.441 |
| NH ₄ -Nitrogen (mg/L) | 0.056 | 0.176 | 0.232 | 0.073 |
| NO ₃ -Nitrogen (mg/L) | 0.061 | 0.275 | 0.586 | 0.178 |
| Organic Phosphorus (mg/L) | 0.047 | 0.051 | 0.019 | 0.031 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.038 | 0.040 | 0.039 | 0.035 |
| Phytoplankton (µg/L) | 20.3 | 22.0 | 15.6 | 10.2 |
| Detritus [POM] (mg/L) | 14.0 | 10.4 | 4.7 | 8.5 |
| Alkalinity (mg/L) | 200 | 191 | 220 | 200 |
| pH | 8.4 | 8.2 | 8.1 | 8.3 |

Discharge Information - Jordan Basin WRF

| Chronic | Summer | Fall | Winter | Spring |
|-----------------------------------|--------|-------|--------|--------|
| Flow (MGD) | 6.6 | 6.6 | 7.6 | 7.3 |
| Temperature (deg C) | 22.1 | 18.7 | 15.6 | 18.3 |
| Specific Conductance (µmhos) | 1791 | 1791 | 1791 | 1791 |
| Inorganic Suspended Solids (mg/L) | 1.7 | 1.7 | 1.7 | 1.7 |
| Dissolved Oxygen (mg/L) | 5.0 | 5.0 | 5.0 | 5.0 |
| CBOD ₅ (mg/L) | 15.0 | 15.0 | 15.0 | 15.0 |
| Organic Nitrogen (mg/L) | 0.383 | 0.791 | 0.719 | 0.913 |
| NH ₄ -Nitrogen (mg/L) | 0.620 | 0.058 | 0.084 | 0.074 |
| NO ₃ -Nitrogen (mg/L) | 9.886 | 9.796 | 9.204 | 9.143 |
| Organic Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Phytoplankton (µg/L) | 0.000 | 0.000 | 0.000 | 0.000 |
| Detritus [POM] (mg/L) | 0.5 | 0.5 | 0.5 | 0.5 |
| Alkalinity (mg/L) | 200 | 200 | 200 | 200 |
| pH | 7.6 | 7.5 | 7.4 | 7.4 |

| Acute | Summer | Fall | Winter | Spring |
|------------|--------|------|--------|--------|
| Flow (MGD) | 6.6 | 6.6 | 7.6 | 7.3 |
| pH | 7.6 | 7.5 | 7.4 | 7.4 |

Utah Division of Water Quality

Discharge Information - South Valley WRF

| Chronic | Summer | Fall | Winter | Spring |
|-----------------------------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 21.2 | 20.5 | 19.8 | 19.8 |
| Temperature (deg C) | 21.6 | 20.0 | 14.7 | 16.7 |
| Specific Conductance (µmhos) | 1517 | 1444 | 1543 | 1459 |
| Inorganic Suspended Solids (mg/L) | 0.0 | 0.4 | 2.0 | 1.1 |
| Dissolved Oxygen (mg/L) | 5.0 | 5.0 | 5.0 | 5.0 |
| CBOD ₅ (mg/L) | 15.0 | 15.0 | 15.0 | 15.0 |
| Organic Nitrogen (mg/L) | 1.862 | 1.447 | 1.624 | 1.559 |
| NH4-Nitrogen (mg/L) | 0.108 | 0.103 | 0.340 | 0.188 |
| NO3-Nitrogen (mg/L) | 6.654 | 7.117 | 7.093 | 6.960 |
| Organic Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Phytoplankton (µg/L) | 0.000 | 0.000 | 0.000 | 0.000 |
| Detritus [POM] (mg/L) | 4.1 | 4.2 | 4.8 | 4.4 |
| Alkalinity (mg/L) | 189 | 184 | 170 | 173 |
| pH | 7.7 | 7.7 | 7.6 | 7.6 |

| Acute | Summer | Fall | Winter | Spring |
|--------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 21.2 | 20.5 | 19.8 | 19.8 |
| pH | 7.7 | 7.7 | 7.6 | 7.6 |

Discharge Information - Central Valley WRF

| Chronic | Summer | Fall | Winter | Spring |
|-----------------------------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 47.4 | 43.5 | 44.1 | 46.5 |
| Temperature (deg C) | 21.2 | 18.4 | 12.7 | 14.8 |
| Specific Conductance (µmhos) | 1330 | 1271 | 1422 | 1422 |
| Inorganic Suspended Solids (mg/L) | 1.1 | 0.0 | 0.4 | 0.3 |
| Dissolved Oxygen (mg/L) | 5.0 | 5.0 | 5.0 | 5.0 |
| CBOD ₅ (mg/L) | 27.0 | 28.0 | 28.0 | 28.0 |
| Organic Nitrogen (mg/L) | 3.207 | 0.119 | 0.033 | 1.678 |
| NH4-Nitrogen (mg/L) | 0.681 | 1.297 | 1.842 | 1.794 |
| NO3-Nitrogen (mg/L) | 16.579 | 17.817 | 17.525 | 13.829 |
| Organic Phosphorus (mg/L) | 0.955 | 1.082 | 1.532 | 1.611 |
| Inorganic Ortho-Phosphorus (mg/L) | 3.045 | 2.918 | 2.468 | 2.389 |
| Phytoplankton (µg/L) | 0.000 | 0.000 | 0.000 | 0.000 |
| Detritus [POM] (mg/L) | 4.5 | 6.7 | 5.6 | 4.1 |
| Alkalinity (mg/L) | 172 | 164 | 173 | 179 |
| pH | 7.4 | 7.4 | 7.3 | 7.2 |

| Acute | Summer | Fall | Winter | Spring |
|--------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 75.0 | 75.0 | 75.0 | 75.0 |
| pH | 7.4 | 7.4 | 7.3 | 7.2 |

Discharge Information - South Davis Sewer District South WWTP

| Chronic | Summer | Fall | Winter | Spring |
|-----------------------------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 2.0 | 2.0 | 2.5 | 2.5 |
| Temperature (deg C) | 22.0 | 19.6 | 12.1 | 16.6 |
| Specific Conductance (µmhos) | 2658 | 2659 | 2913 | 2852 |
| Inorganic Suspended Solids (mg/L) | 6.8 | 6.6 | 5.9 | 6.7 |
| Dissolved Oxygen (mg/L) | 5.0 | 5.0 | 5.0 | 5.0 |
| CBOD ₅ (mg/L) | 20.0 | 25.0 | 25.0 | 25.0 |
| Organic Nitrogen (mg/L) | 5.174 | 3.692 | 1.908 | 1.114 |
| NH4-Nitrogen (mg/L) | 7.685 | 13.067 | 27.675 | 16.446 |
| NO3-Nitrogen (mg/L) | 7.685 | 13.067 | 27.675 | 16.446 |
| Organic Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Phytoplankton (µg/L) | 0.000 | 0.000 | 0.000 | 0.000 |
| Detritus [POM] (mg/L) | 4.9 | 4.5 | 7.0 | 6.4 |
| Alkalinity (mg/L) | 282 | 292 | 328 | 323 |
| pH | 7.7 | 7.6 | 7.7 | 7.7 |

| Acute | Summer | Fall | Winter | Spring |
|--------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 2.0 | 2.0 | 2.5 | 2.5 |
| pH | 7.7 | 7.6 | 7.7 | 7.7 |

Utah Division of Water Quality

Discharge Information - South Davis Sewer District North WWTP

| Chronic | Summer | Fall | Winter | Spring |
|-----------------------------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 4.8 | 4.8 | 4.8 | 4.9 |
| Temperature (deg C) | 22.5 | 20.5 | 12.9 | 16.4 |
| Specific Conductance (µmhos) | 1986 | 2017 | 2258 | 1981 |
| Inorganic Suspended Solids (mg/L) | 6.0 | 6.0 | 6.9 | 6.6 |
| Dissolved Oxygen (mg/L) | 5.0 | 5.0 | 5.0 | 5.0 |
| CBOD ₅ (mg/L) | 20.0 | 25.0 | 25.0 | 25.0 |
| Organic Nitrogen (mg/L) | 2.108 | 1.267 | 0.908 | 3.754 |
| NH4-Nitrogen (mg/L) | 7.938 | 8.583 | 14.175 | 9.446 |
| NO3-Nitrogen (mg/L) | 10.351 | 10.170 | 9.671 | 10.839 |
| Organic Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| Phytoplankton (µg/L) | 0.000 | 0.000 | 0.000 | 0.000 |
| Detritus [POM] (mg/L) | 4.9 | 7.8 | 9.2 | 8.9 |
| Alkalinity (mg/L) | 324 | 324 | 324 | 324 |
| pH | 7.2 | 7.2 | 7.4 | 7.4 |

| Acute | Summer | Fall | Winter | Spring |
|--------------|---------------|-------------|---------------|---------------|
| Flow (MGD) | 4.8 | 4.8 | 4.8 | 4.9 |
| pH | 7.2 | 7.2 | 7.4 | 7.4 |

Tributary - Little Cottonwood Creek

| | Summer | Fall | Winter | Spring |
|-------------------------------------|---------------|-------------|---------------|---------------|
| Flow (cfs) | 8.5 | 1.6 | 1.4 | 1.4 |
| Temperature, Mean (deg C) | 16.1 | 11.5 | 3.3 | 9.0 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1085 | 1214 | 2554 | 815 |
| Inorganic Suspended Solids (mg/L) | 33.9 | 15.1 | 9.6 | 12.9 |
| Dissolved Oxygen, Mean (mg/L) | 8.1 | 9.3 | 11.4 | 10.7 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 1.5 | 1.9 | 3.9 | 1.5 |
| Organic Nitrogen (mg/L) | 0.230 | 0.425 | 0.385 | 0.010 |
| NH4-Nitrogen (mg/L) | 0.022 | 0.032 | 0.098 | 0.058 |
| NO3-Nitrogen (mg/L) | 0.424 | 0.647 | 1.040 | 0.591 |
| Organic Phosphorus (mg/L) | 0.039 | 0.016 | 0.010 | 0.016 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.032 | 0.029 | 0.021 | 0.025 |
| Phytoplankton (µg/L) | 17.2 | 17.6 | 6.0 | 16.1 |
| Detritus [POM] (mg/L) | 6.1 | 3.8 | 8.1 | 5.1 |
| Alkalinity (mg/L) | 118 | 238 | 232 | 165 |
| pH | 8.2 | 8.1 | 7.8 | 8.2 |

Tributary - Big Cottonwood Creek

| | Summer | Fall | Winter | Spring |
|-------------------------------------|---------------|-------------|---------------|---------------|
| Flow (cfs) | 21.7 | 10.8 | 5.9 | 7.9 |
| Temperature, Mean (deg C) | 17.0 | 12.1 | 4.5 | 8.8 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1026 | 1088 | 1406 | 655 |
| Inorganic Suspended Solids (mg/L) | 23.9 | 12.9 | 8.7 | 19.3 |
| Dissolved Oxygen, Mean (mg/L) | 8.3 | 9.4 | 11.3 | 10.9 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 1.5 | 1.8 | 3.3 | 1.5 |
| Organic Nitrogen (mg/L) | 0.417 | 0.300 | 0.285 | 0.160 |
| NH4-Nitrogen (mg/L) | 0.023 | 0.023 | 0.050 | 0.036 |
| NO3-Nitrogen (mg/L) | 0.325 | 0.408 | 0.716 | 0.389 |
| Organic Phosphorus (mg/L) | 0.015 | 0.006 | 0.011 | 0.016 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.036 | 0.027 | 0.022 | 0.024 |
| Phytoplankton (µg/L) | 14.7 | 13.2 | 6.5 | 10.3 |
| Detritus [POM] (mg/L) | 6.2 | 4.5 | 8.4 | 4.9 |
| Alkalinity (mg/L) | 142 | 211 | 221 | 155 |
| pH | 8.3 | 8.2 | 8.1 | 8.2 |

Utah Division of Water Quality

| Tributary - Mill Creek above CVWRF | Summer | Fall | Winter | Spring |
|---|---------------|-------------|---------------|---------------|
| Flow (cfs) | 21.4 | 10.1 | 3.0 | 10.1 |
| Temperature, Mean (deg C) | 17.9 | 11.9 | 6.7 | 11.0 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1103 | 1086 | 1068 | 1017 |
| Inorganic Suspended Solids (mg/L) | 14.4 | 14.6 | 21.6 | 11.8 |
| Dissolved Oxygen, Mean (mg/L) | 8.3 | 8.5 | 10.9 | 9.7 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 1.5 | 1.5 | 1.5 | 2.4 |
| Organic Nitrogen (mg/L) | 0.264 | 0.400 | 0.311 | 0.054 |
| NH ₄ -Nitrogen (mg/L) | 0.025 | 0.027 | 0.030 | 0.030 |
| NO ₃ -Nitrogen (mg/L) | 1.063 | 1.411 | 1.765 | 1.341 |
| Organic Phosphorus (mg/L) | 0.018 | 0.025 | 0.018 | 0.010 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.035 | 0.028 | 0.032 | 0.036 |
| Phytoplankton (µg/L) | 4.1 | 5.4 | 5.2 | 2.7 |
| Detritus [POM] (mg/L) | 4.0 | 4.3 | 10.3 | 4.6 |
| Alkalinity (mg/L) | 207 | 237 | 245 | 213 |
| pH | 7.9 | 7.9 | 7.7 | 7.8 |

| Tributary - Decker Lake Outlet | Summer | Fall | Winter | Spring |
|---------------------------------------|---------------|-------------|---------------|---------------|
| Flow (cfs) | 1.9 | 0.4 | 0.3 | 0.3 |
| Temperature, Mean (deg C) | 21.3 | 10.0 | 2.8 | 12.7 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1711 | 1908 | 2660 | 1798 |
| Inorganic Suspended Solids (mg/L) | 52.5 | 41.8 | 19.6 | 26.0 |
| Dissolved Oxygen, Mean (mg/L) | 5.9 | 9.6 | 12.3 | 10.6 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 3.9 | 1.9 | 2.0 | 3.8 |
| Organic Nitrogen (mg/L) | 0.682 | 0.408 | 0.389 | 0.511 |
| NH ₄ -Nitrogen (mg/L) | 0.180 | 0.107 | 0.131 | 0.139 |
| NO ₃ -Nitrogen (mg/L) | 0.568 | 1.085 | 1.444 | 0.580 |
| Organic Phosphorus (mg/L) | 0.022 | 0.023 | 0.024 | 0.037 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.061 | 0.054 | 0.042 | 0.050 |
| Phytoplankton (µg/L) | 19.2 | 16.8 | 14.1 | 25.4 |
| Detritus [POM] (mg/L) | 7.6 | 7.1 | 9.1 | 6.9 |
| Alkalinity (mg/L) | 230 | 246 | 258 | 218 |
| pH | 8.1 | 8.3 | 8.3 | 8.2 |

| Tributary - 1300 South Drain | Summer | Fall | Winter | Spring |
|-------------------------------------|---------------|-------------|---------------|---------------|
| Flow (cfs) | 17.6 | 0.6 | 2.3 | 2.3 |
| Temperature, Mean (deg C) | 19.9 | 13.5 | 8.7 | 13.3 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1928 | 2223 | 2275 | 1968 |
| Inorganic Suspended Solids (mg/L) | 54.6 | 42.7 | 39.0 | 48.4 |
| Dissolved Oxygen, Mean (mg/L) | 7.9 | 9.1 | 10.2 | 10.2 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 2.3 | 2.5 | 1.6 | 1.6 |
| Organic Nitrogen (mg/L) | 0.346 | 0.322 | 0.000 | -0.081 |
| NH ₄ -Nitrogen (mg/L) | 0.029 | 0.031 | 0.065 | 0.038 |
| NO ₃ -Nitrogen (mg/L) | 1.237 | 2.153 | 3.486 | 2.444 |
| Organic Phosphorus (mg/L) | 0.050 | 0.041 | 0.038 | 0.050 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.076 | 0.056 | 0.046 | 0.043 |
| Phytoplankton (µg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| Detritus [POM] (mg/L) | 7.1 | 6.2 | 5.3 | 6.2 |
| Alkalinity (mg/L) | 251 | 296 | 343 | 286 |
| pH | 8.0 | 8.1 | 8.0 | 8.2 |

Utah Division of Water Quality

| Tributary - North Temple Drain | Summer | Fall | Winter | Spring |
|---------------------------------------|---------------|-------------|---------------|---------------|
| Flow (cfs) | 1.6 | 0.1 | 0.2 | 2.1 |
| Temperature, Mean (deg C) | 18.6 | 12.1 | 7.9 | 10.1 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 946 | 1031 | 1680 | 680 |
| Inorganic Suspended Solids (mg/L) | 5.9 | 0.2 | 3.9 | 10.7 |
| Dissolved Oxygen, Mean (mg/L) | 7.7 | 7.7 | 9.8 | 9.5 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 2.1 | 2.4 | 1.5 | 1.7 |
| Organic Nitrogen (mg/L) | 0.161 | 0.000 | 0.058 | 0.184 |
| NH4-Nitrogen (mg/L) | 0.026 | 0.038 | 0.031 | 0.054 |
| NO3-Nitrogen (mg/L) | 2.280 | 2.645 | 2.148 | 0.920 |
| Organic Phosphorus (mg/L) | 0.005 | 0.000 | 0.000 | 0.020 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.030 | 0.022 | 0.020 | 0.033 |
| Phytoplankton (µg/L) | 2.4 | 2.4 | 0.8 | 0.4 |
| Detritus [POM] (mg/L) | 2.5 | 2.5 | 2.5 | 2.5 |
| Alkalinity (mg/L) | 237 | 237 | 257 | 221 |
| pH | 8.1 | 8.5 | 8.2 | 8.2 |

| Minor Tributaries - Quality | Summer | Fall | Winter | Spring |
|-------------------------------------|---------------|-------------|---------------|---------------|
| Temperature, Mean (deg C) | 19.9 | 13.5 | 8.7 | 13.3 |
| Temperature, Diel Range (deg C) | 0.0 | 0.0 | 0.0 | 0.0 |
| Specific Conductance (µmhos) | 1928 | 2223 | 2275 | 1968 |
| Inorganic Suspended Solids (mg/L) | 54.6 | 42.7 | 39.0 | 48.4 |
| Dissolved Oxygen, Mean (mg/L) | 7.9 | 9.1 | 10.2 | 10.2 |
| Dissolved Oxygen, Diel Range (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 2.3 | 2.5 | 1.6 | 1.6 |
| Organic Nitrogen (mg/L) | 0.346 | 0.322 | 0.000 | -0.081 |
| NH4-Nitrogen (mg/L) | 0.029 | 0.031 | 0.065 | 0.038 |
| NO3-Nitrogen (mg/L) | 1.237 | 2.153 | 3.486 | 2.444 |
| Organic Phosphorus (mg/L) | 0.050 | 0.041 | 0.038 | 0.050 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.076 | 0.056 | 0.046 | 0.043 |
| Phytoplankton (µg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| Detritus [POM] (mg/L) | 7.1 | 6.2 | 5.3 | 6.2 |
| Alkalinity (mg/L) | 251 | 296 | 343 | 286 |
| pH | 8.0 | 8.1 | 8.0 | 8.2 |

| Minor Tributaries - Flow (MGD) | Summer | Fall | Winter | Spring |
|---------------------------------------|---------------|-------------|---------------|---------------|
| Corner Canyon Creek | 0.0 | 0.0 | 0.0 | 0.0 |
| Midas Creek (Butterfield) | 0.0 | 0.3 | 0.3 | 0.2 |
| Willow Creek | 0.6 | 0.4 | 0.5 | 0.8 |
| Dry Creek | 0.2 | 0.1 | 0.2 | 0.3 |
| 9000 South Conduit | 0.0 | 0.0 | 0.0 | 0.0 |
| Bingham Creek | 4.7 | 1.0 | 0.9 | 0.4 |

| Diversions - Flow (cfs) | Summer | Fall | Winter | Spring |
|--------------------------------|---------------|-------------|---------------|---------------|
| Jordan Valley Pump Station | 15.6 | 3.0 | 0.0 | 0.0 |
| Utah Lake Distribution Canal | 27.2 | 0.0 | 0.0 | 0.0 |
| Utah & Salt Lake Canal | 62.3 | 0.0 | 0.0 | 0.0 |
| East Jordan & Draper Canal | 40.8 | 0.0 | 0.0 | 0.0 |
| South Jordan Canal | 15.1 | 0.0 | 0.0 | 0.0 |
| Jordan & Salt Lake Canal | 39.6 | 0.0 | 0.0 | 0.0 |
| Beckstead Ditch | 0.0 | 0.0 | 0.0 | 0.0 |
| North Jordan Canal | 17.1 | 23.9 | 35.8 | 38.6 |
| Gardner Mill Race | 0.0 | 0.0 | 0.0 | 0.0 |
| Brighton Canal | 0.0 | 0.0 | 0.0 | 0.0 |
| Surplus Canal | 241.4 | 120.5 | 175.2 | 183.9 |
| Jordan River at Burnham Dam | 96.0 | 76.0 | 41.0 | 49.0 |

Utah Division of Water Quality

| Groundwater - Quality | Summer | Fall | Winter | Spring |
|-----------------------------------|---------------|-------------|---------------|---------------|
| Temperature, Mean (deg C) | 16.0 | 16.0 | 16.0 | 16.0 |
| Specific Conductance (µmhos) | 2000 | 2000 | 2000 | 2000 |
| Inorganic Suspended Solids (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| Dissolved Oxygen, Mean (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| CBOD ₅ (mg/L) | 2.0 | 2.0 | 2.0 | 2.0 |
| Organic Nitrogen (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| NH ₄ -Nitrogen (mg/L) | 0.500 | 0.500 | 0.500 | 0.500 |
| NO ₃ -Nitrogen (mg/L) | 2.000 | 2.000 | 2.000 | 2.000 |
| Organic Phosphorus (mg/L) | 0.050 | 0.050 | 0.050 | 0.050 |
| Inorganic Ortho-Phosphorus (mg/L) | 0.100 | 0.100 | 0.100 | 0.100 |
| Phytoplankton (µg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| Detritus [POM] (mg/L) | 0.0 | 0.0 | 0.0 | 0.0 |
| Alkalinity (mg/L) | 300 | 300 | 300 | 300 |
| pH | 8.0 | 8.0 | 8.0 | 8.0 |

| Groundwater - Flow (cfs) | Summer | Fall | Winter | Spring |
|---------------------------------|---------------|-------------|---------------|---------------|
| Segment 1-32 | 0.5 | 0.0 | 0.0 | 0.0 |
| Segment 32-51 | 4.9 | 14.1 | 20.3 | 21.6 |
| Segment 51-76 | 6.5 | 18.5 | 26.7 | 28.5 |
| Segment 76-84 | 14.9 | 12.5 | 12.2 | 7.6 |
| Segment 84-111 | 50.3 | 42.0 | 41.3 | 25.7 |
| Segment 111-115 | 7.5 | 6.2 | 6.1 | 3.8 |
| Segment 115-118 | 2.8 | 2.8 | 2.8 | 2.8 |
| Segment 118-133 | 77.8 | 3.0 | 12.5 | 37.0 |
| Segment 133-151 | 11.2 | 11.2 | 11.2 | 11.2 |
| Segment 151-162 | 6.8 | 6.8 | 6.8 | 6.8 |
| State Canal 162-171 | 5.6 | 5.6 | 5.6 | 5.6 |
| State Canal 171-172 | 0.6 | 0.6 | 0.6 | 0.6 |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

Effluent Limitations

Effluent Limitations based upon Water Quality Standards for Ammonia

In-stream criteria of downstream segments for Ammonia will be met with an effluent limitation as follows:

| Chronic | Summer | Fall | Fall | Winter | Spring |
|----------------------------|-----------------|----------------|----------------|----------------|----------------|
| Flow (MGD) | Jun-Aug | Sep-Oct | Nov | Dec-Feb | Mar-May |
| Jordan Basin WRF | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 |
| South Valley WRF | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 |
| Central Valley WRF | 75.0 | 75.0 | 75.0 | 75.0 | 75.0 |
| SDSD South WWTP | 4.0 | 4.0 | 4.0 | 4.0 | 4.0 |
| SDSD North WWTP | 12.0 | 12.0 | 12.0 | 12.0 | 12.0 |
| NH4-Nitrogen (mg/L) | | | | | |
| Jordan Basin WRF | 3.0 | 2.5 | 2.5 | 3.0 | 2.5 |
| South Valley WRF | 1.5 | 3.0 | 3.0 | 4.0 | 3.0 |
| Central Valley WRF | 3.7 | 4.5 | 5.9 | 5.8 | 5.3 |
| SDSD South WWTP | 8.0 | 20.0 | 20.0 | 14.0 | 12.0 |
| SDSD North WWTP | 5.5 | 7.5 | 7.5 | 6.5 | 6.0 |
| Acute | Standard | Summer | Fall | Winter | Spring |
| Flow (MGD) | N/A | Jun-Aug | Sep-Nov | Dec-Feb | Mar-May |
| Jordan Basin WRF | | 15.0 | 15.0 | 15.0 | 15.0 |
| South Valley WRF | | 50.0 | 50.0 | 50.0 | 50.0 |
| Central Valley WRF | | 75.0 | 75.0 | 75.0 | 75.0 |
| SDSD South WWTP | | 4.0 | 4.0 | 4.0 | 4.0 |
| SDSD North WWTP | | 12.0 | 12.0 | 12.0 | 12.0 |
| NH4-Nitrogen (mg/L) | Varies | | | | |
| Jordan Basin WRF | | 6.0 | 6.0 | 9.0 | 8.0 |
| South Valley WRF | | 6.0 | 9.0 | 9.4 | 7.4 |
| Central Valley WRF | | 13.1 | 15.9 | 12.3 | 15.9 |
| SDSD South WWTP | | 30.0 | 40.0 | 17.0 | 26.0 |
| SDSD North WWTP | | 24.0 | 16.2 | 13.0 | 15.0 |

Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

Utah Division of Water Quality

Coefficients and Other Model Information

| <i>Parameter</i> | <i>Value</i> | <i>Units</i> |
|--|--------------|--------------|
| Stoichiometry: | | |
| Carbon | 40 | gC |
| Nitrogen | 7.2 | gN |
| Phosphorus | 1 | gP |
| Dry weight | 100 | gD |
| Chlorophyll | 1 | gA |
| Inorganic suspended solids: | | |
| Settling velocity | 0.001 | m/d |
| Oxygen: | | |
| Reaeration model | Internal | |
| Temp correction | 1.024 | |
| Reaeration wind effect | None | |
| O2 for carbon oxidation | 2.69 | gO2/gC |
| O2 for NH4 nitrification | 4.57 | gO2/gN |
| Oxygen inhib model CBOD oxidation | Exponential | |
| Oxygen inhib parameter CBOD oxidation | 0.60 | L/mgO2 |
| Oxygen inhib model nitrification | Exponential | |
| Oxygen inhib parameter nitrification | 0.60 | L/mgO2 |
| Oxygen enhance model denitrification | Exponential | |
| Oxygen enhance parameter denitrification | 0.60 | L/mgO2 |
| Oxygen inhib model phyto resp | Exponential | |
| Oxygen inhib parameter phyto resp | 0.60 | L/mgO2 |
| Oxygen enhance model bot alg resp | Exponential | |
| Oxygen enhance parameter bot alg resp | 0.60 | L/mgO2 |
| Slow CBOD: | | |
| Hydrolysis rate | 0 | /d |
| Temp correction | 1.047 | |
| Oxidation rate | 0.2 | /d |
| Temp correction | 1.047 | |
| Fast CBOD: | | |
| Oxidation rate | 10 | /d |
| Temp correction | 1.047 | |
| Organic N: | | |
| Hydrolysis | 0.4 | /d |
| Temp correction | 1.07 | |
| Settling velocity | 0.05 | m/d |
| Ammonium: | | |
| Nitrification | 2 | /d |
| Temp correction | 1.07 | |
| Nitrate: | | |
| Denitrification | 0.05 | /d |
| Temp correction | 1.07 | |
| Sed denitrification transfer coeff | 0.05 | m/d |
| Temp correction | 1.07 | |
| Organic P: | | |
| Hydrolysis | 0.05 | /d |
| Temp correction | 1.07 | |
| Settling velocity | 0.05 | m/d |
| Inorganic P: | | |
| Settling velocity | 0.5 | m/d |
| Sed P oxygen attenuation half sat constant | 0.05 | mgO2/L |

Utah Division of Water Quality

| | | |
|---|-----------------|---------------|
| Phytoplankton: | | |
| Max Growth rate | 2 | /d |
| Temp correction | 1.07 | |
| Respiration rate | 0.1 | /d |
| Temp correction | 1.07 | |
| Death rate | 0.1 | /d |
| Temp correction | 1 | |
| Nitrogen half sat constant | 15 | ugN/L |
| Phosphorus half sat constant | 2 | ugP/L |
| Inorganic carbon half sat constant | 1.30E-05 | moles/L |
| Phytoplankton use HCO3- as substrate | Yes | |
| Light model | Smith | |
| Light constant | 57.6 | langleys/d |
| Ammonia preference | 25 | ugN/L |
| Settling velocity | 0.05 | m/d |
| Bottom Plants: | | |
| Growth model | Zero-order | |
| Max Growth rate | 50 | gD/m2/d or /d |
| Temp correction | 1.07 | |
| First-order model carrying capacity | 50 | gD/m2 |
| Basal respiration rate | 0.042 | /d |
| Photo-respiration rate parameter | 0.389 | unitless |
| Temp correction | 1.07 | |
| Excretion rate | 0.1 | /d |
| Temp correction | 1.05 | |
| Death rate | 0.1 | /d |
| Temp correction | 1.07 | |
| External nitrogen half sat constant | 163 | ugN/L |
| External phosphorus half sat constant | 48 | ugP/L |
| Inorganic carbon half sat constant | 1.30E-05 | moles/L |
| Bottom algae use HCO3- as substrate | Yes | |
| Light model | Half saturation | |
| Light constant | 50 | langleys/d |
| Ammonia preference | 1 | ugN/L |
| Subsistence quota for nitrogen | 30 | mgN/gD |
| Subsistence quota for phosphorus | 0.4 | mgP/gD |
| Maximum uptake rate for nitrogen | 447 | mgN/gD/d |
| Maximum uptake rate for phosphorus | 114 | mgP/gD/d |
| Internal nitrogen half sat ratio | 2.9 | |
| Internal phosphorus half sat ratio | 1.8 | |
| Nitrogen uptake water column fraction | 1 | |
| Phosphorus uptake water column fraction | 1 | |
| Detritus (POM): | | |
| Dissolution rate | 0.1 | /d |
| Temp correction | 1.07 | |
| Settling velocity | 0.1 | m/d |
| pH: | | |
| Partial pressure of carbon dioxide | 347 | ppm |
| TRC: | | |
| Decay rate | 0.8 | /d |

| Atmospheric Inputs: | Summer | Fall | Winter | Spring |
|-------------------------|--------|------|--------|--------|
| Min. Air Temperature, F | 63.4 | 40.4 | 20.4 | 38.3 |
| Max. Air Temperature, F | 92.8 | 65.7 | 37.3 | 61.4 |
| Dew Point, Temp., F | 60.2 | 43.6 | 26.8 | 41.6 |
| Wind, ft./sec. @ 21 ft. | 9.5 | 8.2 | 6.9 | 9.8 |
| Cloud Cover, % | 10% | 10% | 10% | 10% |

**Utah Division of Water Quality
Salt Lake City, Utah**

WASTELOAD ANALYSIS [WLA] [REDACTED] = not included in the WLA
Addendum: Statement of Basis

| |
|----------|
| 8-Oct-21 |
| 4:00 PM |

Facilities: Jordan Basin Water Reclamation Facility
Discharging to: Jordan River

UPDES No: UT-0025852

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Jordan River: 2B,3B,4
 Antidegradation Review: Level I review completed. Level II review is not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

| | |
|---------------------------------------|--|
| Total Ammonia (TNH3) | Varies as a function of Temperature and pH Rebound. See Water Quality Standards |
| Chronic Total Residual Chlorine (TRC) | 0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average) |
| Chronic Dissolved Oxygen (DO) | 5.5 mg/l (30 Day Average) 4.0 mg/l (7Day Average) 3.0 mg/l (1 Day Average) |
| Maximum Total Dissolved Solids | 1200.0 mg/l |

Acute and Chronic Heavy Metals (Dissolved)

| Parameter | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------|----------------------------------|----------------|---------------------------------|-----------------|
| | Concentration | Load* | Concentration | Load* |
| Aluminum | 87.00 ug/l** | 13.070 lbs/day | 750.00 ug/l | 112.673 lbs/day |
| Arsenic | 150.00 ug/l | 22.535 lbs/day | 340.00 ug/l | 51.079 lbs/day |
| Cadmium | 2.18 ug/l | 0.327 lbs/day | 6.59 ug/l | 0.989 lbs/day |
| Chromium III | 243.79 ug/l | 36.624 lbs/day | 5100.48 ug/l | 766.250 lbs/day |
| ChromiumVI | 11.00 ug/l | 1.653 lbs/day | 16.00 ug/l | 2.404 lbs/day |
| Copper | 27.61 ug/l | 4.147 lbs/day | 46.31 ug/l | 6.957 lbs/day |
| Iron | | | 1000.00 ug/l | 150.231 lbs/day |
| Lead | 16.02 ug/l | 2.406 lbs/day | 411.03 ug/l | 61.750 lbs/day |
| Mercury | 0.0120 ug/l | 0.002 lbs/day | 2.40 ug/l | 0.361 lbs/day |
| Nickel | 152.71 ug/l | 22.941 lbs/day | 1373.49 ug/l | 206.341 lbs/day |
| Selenium | 4.60 ug/l | 0.691 lbs/day | 20.00 ug/l | 3.005 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 33.61 ug/l | 5.049 lbs/day |
| Zinc | 351.34 ug/l | 52.782 lbs/day | 351.34 ug/l | 52.782 lbs/day |

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals Standards Based upon a Hardness of 355.97 mg/l as CaCO₃

IV. Numeric Stream Standards for Protection of Agriculture

| | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|-------------|----------------------------------|-------|---------------------------------|----------------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | 100.0 ug/l | lbs/day |
| Boron | | | 750.0 ug/l | lbs/day |
| Cadmium | | | 10.0 ug/l | 0.75 lbs/day |
| Chromium | | | 100.0 ug/l | lbs/day |
| Copper | | | 200.0 ug/l | lbs/day |
| Lead | | | 100.0 ug/l | lbs/day |
| Selenium | | | 50.0 ug/l | lbs/day |
| TDS, Summer | | | 1200.0 mg/l | 90.14 tons/day |

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

| Metals | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------------|----------------------------------|-------|---------------------------------|---------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | ug/l | lbs/day |
| Barium | | | ug/l | lbs/day |
| Cadmium | | | ug/l | lbs/day |
| Chromium | | | ug/l | lbs/day |
| Lead | | | ug/l | lbs/day |
| Mercury | | | ug/l | lbs/day |
| Selenium | | | ug/l | lbs/day |
| Silver | | | ug/l | lbs/day |
| Fluoride (3) to | | | ug/l | lbs/day |
| Nitrates as N | | | ug/l | lbs/day |

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

| Metals | Maximum Conc., ug/l - Acute Standards | | | |
|----------------|---------------------------------------|---------|--------------|------------------|
| | Class 1C | | Class 3A, 3B | |
| Antimony | ug/l | lbs/day | | |
| Arsenic | ug/l | lbs/day | 4300.00 ug/l | 1163.60 lbs/day |
| Asbestos | ug/l | lbs/day | | |
| Beryllium | | | | |
| Cadmium | | | | |
| Chromium (III) | | | | |
| Chromium (VI) | | | | |
| Copper | | | | |
| Cyanide | ug/l | lbs/day | 2.2E+05 ug/l | 59533.09 lbs/day |
| Lead | ug/l | lbs/day | | |
| Mercury | | | 0.15 ug/l | 0.04 lbs/day |
| Nickel | | | 4600.00 ug/l | 1244.78 lbs/day |
| Selenium | ug/l | lbs/day | | |
| Silver | ug/l | lbs/day | | |
| Thallium | | | 6.30 ug/l | 1.70 lbs/day |
| Zinc | | | | |

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

**Utah Division of Water Quality
Salt Lake City, Utah**

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

| | |
|-----------------------|-------------------------------------|
| Flow, Q, (cfs or MGD) | D.O. mg/l |
| Temperature, Deg. C. | Total Residual Chlorine (TRC), mg/l |
| pH | Total NH3-N, mg/l |
| BOD5, mg/l | Total Dissolved Solids (TDS), mg/l |
| Metals, ug/l | Toxic Organics of Concern, ug/l |

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

| | Stream | | | | | | | | |
|------------------------|---------------------|---------------|-----------|------------------|-------------|-------------|-------------|-------------|-------------|
| | Critical Low | | | | | | | | |
| | Flow | Temp. | pH | T-NH3 | BOD5 | DO | TRC | TDS | |
| | cfs | Deg. C | | mg/l as N | mg/l | mg/l | mg/l | mg/l | mg/l |
| Summer (Irrig. Season) | 27.0 | 19.3 | 8.1 | 0.03 | 3.56 | 7.05 | 0.001 | 1067.5 | |
| Fall | 17.0 | 8.9 | 8.1 | 0.05 | 2.06 | --- | 0.001 | 1054.6 | |
| Winter | 23.0 | 4.8 | 7.9 | 0.04 | 1.91 | --- | 0.001 | 1054.6 | |
| Spring | 24.0 | 14.8 | 8.7 | 0.04 | 2.06 | --- | 0.001 | 1054.6 | |
| Dissolved Metals | Al | As | Cd | CrIII | CrVI | Copper | Fe | Pb | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | |
| All Seasons | 124.00 | 12.10 | 0.06 | 1.35 | 2.65* | 1.12 | 0.0 | 0.12 | |
| Dissolved Metals | Hg | Ni | Se | Ag | Zn | Boron | | | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | | | |
| All Seasons | 0.0000 | 2.50 | 1.09 | 0.25 | 8.62 | 10.0 | | | * 1/2 MDL |

Projected Discharge Information

**Utah Division of Water Quality
Salt Lake City, Utah**

| Season | Flow, MGD | Temp. | TDS mg/l | TDS tons/day |
|--------|-----------|-------|----------|--------------|
| Summer | 15.00000 | 23.5 | 982.67 | 61.45349 |
| Fall | 15.00000 | 20.2 | | |
| Winter | 15.00000 | 17.1 | | |
| Spring | 15.00000 | 20.2 | | |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

| Season | Daily Average | |
|--------|---------------|------------|
| Summer | 15.000 MGD | 23.205 cfs |
| Fall | 15.000 MGD | 23.205 cfs |
| Winter | 15.000 MGD | 23.205 cfs |
| Spring | 15.000 MGD | 23.205 cfs |

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 15 MGD. If the discharger is allowed to have a flow greater than 15 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

| | | | |
|------------------|--------|----------------|-----------|
| WET Requirements | LC50 > | EOP Effluent | [Acute] |
| | IC25 > | 46.2% Effluent | [Chronic] |

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 355.97 mg/l):

| | 4 Day Average | | 1 Hour Average | | Load |
|--------------|---------------|--------------|----------------|------|----------------|
| | Concentration | Load | Concentration | Load | |
| Aluminum | N/A | N/A | 1,114.2 | ug/l | 167.4 lbs/day |
| Arsenic | 310.45 ug/l | 25.1 lbs/day | 530.8 | ug/l | 79.7 lbs/day |
| Cadmium | 4.64 ug/l | 0.4 lbs/day | 10.4 | ug/l | 1.6 lbs/day |
| Chromium III | 525.87 ug/l | 42.5 lbs/day | 8,067.0 | ug/l | 1211.9 lbs/day |
| Chromium VI | 19.17 ug/l | 1.6 lbs/day | 23.0 | ug/l | 3.5 lbs/day |
| Copper | 58.42 ug/l | 4.7 lbs/day | 72.6 | ug/l | 10.9 lbs/day |
| Iron | N/A | N/A | 1,581.8 | ug/l | 237.6 lbs/day |
| Lead | 34.51 ug/l | 2.8 lbs/day | 650.1 | ug/l | 97.7 lbs/day |

**Utah Division of Water Quality
Salt Lake City, Utah**

| | | | | | |
|----------|-------------|--------------|---------|------|---------------|
| Mercury | 0.03 ug/l | 0.0 lbs/day | 3.8 | ug/l | 0.6 lbs/day |
| Nickel | 327.48 ug/l | 26.5 lbs/day | 2,171.1 | ug/l | 326.2 lbs/day |
| Selenium | 8.68 ug/l | 0.7 lbs/day | 31.0 | ug/l | 4.7 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 53.0 | ug/l | 8.0 lbs/day |
| Zinc | 750.11 ug/l | 60.6 lbs/day | 550.7 | ug/l | 82.7 lbs/day |
| Cyanide | 11.25 ug/l | 0.9 lbs/day | 34.8 | ug/l | 5.2 lbs/day |

Effluent Limitations for Heat/Temperature based upon Water Quality Standards

| | | |
|--------|--------------|-------------|
| Summer | 25.6 Deg. C. | 78.1 Deg. F |
| Fall | 14.3 Deg. C. | 57.8 Deg. F |
| Winter | 10.8 Deg. C. | 51.4 Deg. F |
| Spring | 20.9 Deg. C. | 69.6 Deg. F |

Effluent Targets for Pollution Indicators Based upon Water Quality Standards

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

| | Concentration | 1 Hour Average Loading |
|------------------------|---------------|---------------------------|
| Gross Beta (pCi/l) | 50.0 pCi/L | |
| BOD (mg/l) | 5.0 mg/l | 751.2 lbs/day |
| Nitrates as N | 4.0 mg/l | 600.9 lbs/day |
| Total Phosphorus as P | 0.05 mg/l | 7.5 lbs/day |
| Total Suspended Solids | 90.0 mg/l | 13520.8 lbs/day |

Note: Pollution indicator targets are for information purposes only.

Effluent Limitations for Protection of Human Health [Toxics Rule] Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

| | Concentration | Maximum Concentration Load |
|----------------|---------------|-------------------------------|
| Metals | | |
| Antimony | ug/l | lbs/day |
| Arsenic | ug/l | lbs/day |
| Asbestos | ug/l | lbs/day |
| Beryllium | | |
| Cadmium | | |
| Chromium (III) | | |
| Chromium (VI) | | |
| Copper | ug/l | lbs/day |
| Cyanide | ug/l | lbs/day |
| Lead | | |
| Mercury | ug/l | lbs/day |
| Nickel | ug/l | lbs/day |
| Selenium | | |
| Silver | | |
| Thallium | ug/l | lbs/day |
| Zinc | | |

Metals Effluent Limitations for Protection of All Beneficial Uses Based upon Water Quality Standards and Toxics Rule

**Utah Division of Water Quality
Salt Lake City, Utah**

| | Class 4 Acute Agricultural ug/l | Class 3 Acute Aquatic Wildlife ug/l | Acute Toxics Drinking Water Source ug/l | Acute Toxics Wildlife ug/l | 1C Acute Health Criteria ug/l | Acute Most Stringent ug/l | Class 3 Chronic Aquatic Wildlife ug/l |
|----------------|--|--|--|---|--|--|--|
| Aluminum | | 1114.2 | | | | 1114.2 | N/A |
| Antimony | | | | 9303.2 | | 9303.2 | |
| Arsenic | 216.4 | 530.8 | | | 0.0 | 216.4 | 310.5 |
| Asbestos | | | | | | 0.00E+00 | |
| Barium | | | | | | 0.0 | |
| Beryllium | | | | | | 0.0 | |
| Cadmium | 21.6 | 10.4 | | | 0.0 | 10.4 | 4.6 |
| Chromium (III) | | 8067.0 | | | 0.0 | 8067.0 | 525.9 |
| Chromium (VI) | 214.8 | 23.0 | | | 0.0 | 23.00 | 19.17 |
| Copper | 431.4 | 72.6 | | | | 72.6 | 58.4 |
| Cyanide | | 34.8 | 475979.3 | | | 34.8 | 11.3 |
| Iron | | 1581.8 | | | | 1581.8 | |
| Lead | 216.2 | 650.1 | | | 0.0 | 216.2 | 34.5 |
| Mercury | | 3.80 | | 0.32 | 0.0 | 0.32 | 0.026 |
| Nickel | | 2171.1 | | 9952.3 | | 2171.1 | 327.5 |
| Selenium | 106.9 | 31.0 | | | 0.0 | 31.0 | 8.7 |
| Silver | | 53.0 | | | 0.0 | 53.0 | |
| Thallium | | | | 13.6 | | 13.6 | |
| Zinc | | 550.7 | | | | 550.7 | 750.1 |
| Boron | 1622.3 | | | | | 1622.3 | |

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

| | WLA Acute ug/l | WLA Chronic ug/l | |
|----------------|---------------------------|-----------------------------|----------------|
| Aluminum | 1114.2 | N/A | |
| Antimony | 9303.23 | | |
| Arsenic | 216.4 | 310.5 | Acute Controls |
| Asbestos | 0.00E+00 | | |
| Barium | | | |
| Beryllium | | | |
| Cadmium | 10.4 | 4.6 | |
| Chromium (III) | 8067.0 | 526 | |
| Chromium (VI) | 23.0 | 19.2 | |
| Copper | 72.6 | 58.4 | |
| Cyanide | 34.8 | 11.3 | |
| Iron | 1581.8 | | |
| Lead | 216.2 | 34.5 | |
| Mercury | 0.325 | 0.026 | |
| Nickel | 2171.1 | 327 | |
| Selenium | 31.0 | 8.7 | |
| Silver | 53.0 | N/A | |
| Thallium | 13.6 | | |
| Zinc | 550.7 | 750.1 | Acute Controls |
| Boron | 1622.31 | | |

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based

**Utah Division of Water Quality
Salt Lake City, Utah**

strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value. This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

Utah Division of Water Quality
801-538-6052
File Name: JBWRF_WLA_2021.xlsm

APPENDIX - Coefficients and Other Model Information

| | | | | | | | |
|--|---|---|--|--|--|--|---|
| CBOD Coeff. (Kd)20 1/day 2.000 | CBOD Coeff. FORCED (Kd)/day 0.000 | CBOD Coeff. (Ka)T 1/day 1.937 | REAER. Coeff. (Ka)20 (Ka)/day 20.892 | REAER. Coeff. FORCED 1/day 0.000 | REAER. Coeff. (Ka)T 1/day 20.552 | NBOD Coeff. (Kn)20 1/day 0.250 | NBOD Coeff. (Kn)T 1/day 0.237 |
| Open Coeff. (K4)20 1/day 0.000 | Open Coeff. (K4)T 1/day 0.000 | NH3 LOSS (K5)20 1/day 4.000 | NH3 (K5)T 1/day 3.875 | NO2+NO3 LOSS (K6)20 1/day 0.000 | NO2+NO3 (K6)T 1/day 0.000 | TRC Decay K(CI)20 1/day 32.000 | TRC K(CI)(T) 1/day 30.735 |
| BENTHIC DEMAND (SOD)20 gm/m2/day 1.000 | BENTHIC DEMAND (SOD)T gm/m2/day 0.957 | | | | | | |
| K1 CBOD {theta} 1.0 | K2 Reaer. {theta} 1.0 | K3 NH3 {theta} 1.1 | K4 Open {theta} 1.0 | K5 NH3 Loss {theta} 1.0 | K6 NO2+3 {theta} 1.0 | K(CI) TRC {theta} 1.1 | S Benthic {theta} 1.1 |

Antidegradation Review

An antidegradation review (ADR) was conducted to determine whether the proposed activity complies with the applicable antidegradation requirements for receiving waters that may be affected. The Level I ADR evaluated the criteria of R317-2-3.5(b) and determined that a Level II antidegradation Review is not required.

**Utah Division of Water Quality
Salt Lake City, Utah**

WASTELOAD ANALYSIS [WLA] [REDACTED] = not included in the WLA
Addendum: Statement of Basis

| |
|----------|
| 8-Oct-21 |
| 4:00 PM |

Facilities: South Valley Water Reclamation Facility
Discharging to: Jordan River

UPDES No: UT-0024384

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Jordan River: 2B,3B,4
 Antidegradation Review: Level I review completed. Level II review is not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

| | |
|---------------------------------------|--|
| Total Ammonia (TNH3) | Varies as a function of Temperature and pH Rebound. See Water Quality Standards |
| Chronic Total Residual Chlorine (TRC) | 0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average) |
| Chronic Dissolved Oxygen (DO) | 5.5 mg/l (30 Day Average) 4.0 mg/l (7Day Average) 3.0 mg/l (1 Day Average) |
| Maximum Total Dissolved Solids | 1200.0 mg/l |

Acute and Chronic Heavy Metals (Dissolved)

| Parameter | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | | |
|--------------|----------------------------------|-----------------|---------------------------------|------|-------------------|
| | Concentration | Load* | Concentration | | Load* |
| Aluminum | 87.00 ug/l** | 43.567 lbs/day | 750.00 | ug/l | 375.577 lbs/day |
| Arsenic | 150.00 ug/l | 75.115 lbs/day | 340.00 | ug/l | 170.262 lbs/day |
| Cadmium | 2.30 ug/l | 1.151 lbs/day | 7.04 | ug/l | 3.527 lbs/day |
| Chromium III | 257.90 ug/l | 129.150 lbs/day | 5395.84 | ug/l | 2,702.072 lbs/day |
| ChromiumVI | 11.00 ug/l | 5.508 lbs/day | 16.00 | ug/l | 8.012 lbs/day |
| Copper | 29.28 ug/l | 14.661 lbs/day | 49.40 | ug/l | 24.740 lbs/day |
| Iron | | | 1000.00 | ug/l | 500.770 lbs/day |
| Lead | 17.48 ug/l | 8.754 lbs/day | 448.62 | ug/l | 224.653 lbs/day |
| Mercury | 0.0120 ug/l | 0.006 lbs/day | 2.40 | ug/l | 1.202 lbs/day |
| Nickel | 161.85 ug/l | 81.049 lbs/day | 1455.73 | ug/l | 728.984 lbs/day |
| Selenium | 4.60 ug/l | 2.304 lbs/day | 20.00 | ug/l | 10.015 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 37.82 | ug/l | 18.941 lbs/day |
| Zinc | 372.41 ug/l | 186.490 lbs/day | 372.41 | ug/l | 186.490 lbs/day |

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals Standards Based upon a Hardness of 381.3 mg/l as CaCO3

IV. Numeric Stream Standards for Protection of Agriculture

| | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|-------------|----------------------------------|-------|---------------------------------|-----------------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | 100.0 ug/l | lbs/day |
| Boron | | | 750.0 ug/l | lbs/day |
| Cadmium | | | 10.0 ug/l | 2.50 lbs/day |
| Chromium | | | 100.0 ug/l | lbs/day |
| Copper | | | 200.0 ug/l | lbs/day |
| Lead | | | 100.0 ug/l | lbs/day |
| Selenium | | | 50.0 ug/l | lbs/day |
| TDS, Summer | | | 1200.0 mg/l | 300.46 tons/day |

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

| Metals | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------------|----------------------------------|-------|---------------------------------|---------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | ug/l | lbs/day |
| Barium | | | ug/l | lbs/day |
| Cadmium | | | ug/l | lbs/day |
| Chromium | | | ug/l | lbs/day |
| Lead | | | ug/l | lbs/day |
| Mercury | | | ug/l | lbs/day |
| Selenium | | | ug/l | lbs/day |
| Silver | | | ug/l | lbs/day |
| Fluoride (3) to | | | ug/l | lbs/day |
| Nitrates as N | | | ug/l | lbs/day |

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

| Metals | Maximum Conc., ug/l - Acute Standards | | | |
|----------------|---------------------------------------|---------|--------------|-------------------|
| | Class 1C | | Class 3A, 3B | |
| Antimony | ug/l | lbs/day | | |
| Arsenic | ug/l | lbs/day | 4300.00 ug/l | 2882.06 lbs/day |
| Asbestos | ug/l | lbs/day | | |
| Beryllium | | | | |
| Cadmium | | | | |
| Chromium (III) | | | | |
| Chromium (VI) | | | | |
| Copper | | | | |
| Cyanide | ug/l | lbs/day | 2.2E+05 ug/l | 147454.23 lbs/day |
| Lead | ug/l | lbs/day | | |
| Mercury | | | 0.15 ug/l | 0.10 lbs/day |
| Nickel | | | 4600.00 ug/l | 3083.13 lbs/day |
| Selenium | ug/l | lbs/day | | |
| Silver | ug/l | lbs/day | | |
| Thallium | | | 6.30 ug/l | 4.22 lbs/day |
| Zinc | | | | |

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

**Utah Division of Water Quality
Salt Lake City, Utah**

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

| | |
|-----------------------|-------------------------------------|
| Flow, Q, (cfs or MGD) | D.O. mg/l |
| Temperature, Deg. C. | Total Residual Chlorine (TRC), mg/l |
| pH | Total NH3-N, mg/l |
| BOD5, mg/l | Total Dissolved Solids (TDS), mg/l |
| Metals, ug/l | Toxic Organics of Concern, ug/l |

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

| | Stream | | | | | | | | |
|------------------------|---------------------|---------------|-----------|------------------|-------------|-------------|-------------|-------------|--|
| | Critical Low | | | | | | | | |
| | Flow | Temp. | pH | T-NH3 | BOD5 | DO | TRC | TDS | |
| | cfs | Deg. C | | mg/l as N | mg/l | mg/l | mg/l | mg/l | |
| Summer (Irrig. Season) | 47.0 | 19.1 | 8.0 | 0.14 | 3.41 | 7.10 | 0.000 | 1194.4 | |
| Fall | 37.0 | 10.3 | 7.9 | 0.15 | 3.18 | --- | 0.010 | 1277.4 | |
| Winter | 40.0 | 6.8 | 9.5 | 0.15 | 2.58 | --- | 0.000 | 1277.4 | |
| Spring | 40.0 | 14.9 | 8.6 | 0.15 | 3.02 | --- | 0.025 | 1277.4 | |
| Dissolved Metals | Al | As | Cd | CrIII | CrVI | Copper | Fe | Pb | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | |
| All Seasons | 23.80 | 10.24 | 0.33 | 2.58 | 3.33 | 4.46 | 0.0 | 1.42 | |
| Dissolved Metals | Hg | Ni | Se | Ag | Zn | Boron | | | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | | | |
| All Seasons | 0.0000 | 3.14 | 2.37 | 0.80 | 14.71 | 10.0 | | * 1/2 MDL | |

Projected Discharge Information

**Utah Division of Water Quality
Salt Lake City, Utah**

| Season | Flow, MGD | Temp. | TDS mg/l | TDS tons/day |
|--------|-----------|-------|----------|--------------|
| Summer | 50.00000 | 23.9 | 738.67 | 153.98116 |
| Fall | 50.00000 | 19.7 | | |
| Winter | 50.00000 | 16.3 | | |
| Spring | 50.00000 | 19.8 | | |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

| Season | Daily Average | |
|--------|---------------|------------|
| Summer | 50.000 MGD | 77.350 cfs |
| Fall | 50.000 MGD | 77.350 cfs |
| Winter | 50.000 MGD | 77.350 cfs |
| Spring | 50.000 MGD | 77.350 cfs |

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 50 MGD. If the discharger is allowed to have a flow greater than 50 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

| | | | |
|------------------|--------|----------------|-----------|
| WET Requirements | LC50 > | EOP Effluent | [Acute] |
| | IC25 > | 62.2% Effluent | [Chronic] |

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 381.3 mg/l):

| | 4 Day Average | | 1 Hour Average | | Load |
|--------------|---------------|---------------|----------------|------|----------------|
| | Concentration | Load | Concentration | Load | |
| Aluminum | N/A | N/A | 970.6 | ug/l | 486.1 lbs/day |
| Arsenic | 234.92 ug/l | 63.3 lbs/day | 440.2 | ug/l | 220.4 lbs/day |
| Cadmium | 3.50 ug/l | 0.9 lbs/day | 9.1 | ug/l | 4.5 lbs/day |
| Chromium III | 413.04 ug/l | 111.3 lbs/day | 7,034.4 | ug/l | 3522.6 lbs/day |
| Chromium VI | 15.66 ug/l | 4.2 lbs/day | 19.8 | ug/l | 9.9 lbs/day |
| Copper | 44.35 ug/l | 12.0 lbs/day | 63.1 | ug/l | 31.6 lbs/day |
| Iron | N/A | N/A | 1,303.8 | ug/l | 652.9 lbs/day |
| Lead | 27.24 ug/l | 7.3 lbs/day | 584.5 | ug/l | 292.7 lbs/day |

**Utah Division of Water Quality
Salt Lake City, Utah**

| | | | | | |
|----------|-------------|---------------|---------|------|---------------|
| Mercury | 0.02 ug/l | 0.0 lbs/day | 3.1 | ug/l | 1.6 lbs/day |
| Nickel | 258.28 ug/l | 69.6 lbs/day | 1,897.0 | ug/l | 950.0 lbs/day |
| Selenium | 5.96 ug/l | 1.6 lbs/day | 25.4 | ug/l | 12.7 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 49.1 | ug/l | 24.6 lbs/day |
| Zinc | 589.75 ug/l | 158.9 lbs/day | 481.1 | ug/l | 240.9 lbs/day |
| Cyanide | 8.36 ug/l | 2.3 lbs/day | 28.7 | ug/l | 14.4 lbs/day |

**Effluent Limitations for Heat/Temperature based upon
Water Quality Standards**

| | | |
|--------|--------------|-------------|
| Summer | 24.3 Deg. C. | 75.8 Deg. F |
| Fall | 15.2 Deg. C. | 59.4 Deg. F |
| Winter | 11.9 Deg. C. | 53.4 Deg. F |
| Spring | 20.0 Deg. C. | 67.9 Deg. F |

**Effluent Targets for Pollution Indicators
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

| | Concentration | 1 Hour Average Loading |
|------------------------|---------------|---------------------------|
| Gross Beta (pCi/l) | 50.0 pCi/L | |
| BOD (mg/l) | 5.0 mg/l | 2503.8 lbs/day |
| Nitrates as N | 4.0 mg/l | 2003.1 lbs/day |
| Total Phosphorus as P | 0.05 mg/l | 25.0 lbs/day |
| Total Suspended Solids | 90.0 mg/l | 45069.3 lbs/day |

Note: Pollution indicator targets are for information purposes only.

**Effluent Limitations for Protection of Human Health [Toxics Rule]
Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)**

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

| | Concentration | Maximum Concentration Load |
|----------------|---------------|-------------------------------|
| Metals | | |
| Antimony | ug/l | lbs/day |
| Arsenic | ug/l | lbs/day |
| Asbestos | ug/l | lbs/day |
| Beryllium | | |
| Cadmium | | |
| Chromium (III) | | |
| Chromium (VI) | | |
| Copper | ug/l | lbs/day |
| Cyanide | ug/l | lbs/day |
| Lead | | |
| Mercury | ug/l | lbs/day |
| Nickel | ug/l | lbs/day |
| Selenium | | |
| Silver | | |
| Thallium | ug/l | lbs/day |
| Zinc | | |

**Metals Effluent Limitations for Protection of All Beneficial Uses
Based upon Water Quality Standards and Toxics Rule**

**Utah Division of Water Quality
Salt Lake City, Utah**

| | Class 4 Acute Agricultural ug/l | Class 3 Acute Aquatic Wildlife ug/l | Acute Toxics Drinking Water Source ug/l | Acute Toxics Wildlife ug/l | 1C Acute Health Criteria ug/l | Acute Most Stringent ug/l | Class 3 Chronic Aquatic Wildlife ug/l |
|----------------|--|--|--|---|--|--|--|
| Aluminum | | 970.6 | | | | 970.6 | N/A |
| Antimony | | | | 6912.8 | | 6912.8 | |
| Arsenic | 160.8 | 440.2 | | | 0.0 | 160.8 | 234.9 |
| Asbestos | | | | | | 0.00E+00 | |
| Barium | | | | | | 0.0 | |
| Beryllium | | | | | | 0.0 | |
| Cadmium | 15.9 | 9.1 | | | 0.0 | 9.1 | 3.5 |
| Chromium (III) | | 7034.4 | | | 0.0 | 7034.4 | 413.0 |
| Chromium (VI) | 159.2 | 19.8 | | | 0.0 | 19.85 | 15.66 |
| Copper | 318.8 | 63.1 | | | | 63.1 | 44.4 |
| Cyanide | | 28.7 | 353678.1 | | | 28.7 | 8.4 |
| Iron | | 1303.8 | | | | 1303.8 | |
| Lead | 159.9 | 584.5 | | | 0.0 | 159.9 | 27.2 |
| Mercury | | 3.13 | | 0.24 | 0.0 | 0.24 | 0.019 |
| Nickel | | 1897.0 | | 7395.1 | | 1897.0 | 258.3 |
| Selenium | 78.9 | 25.4 | | | 0.0 | 25.4 | 6.0 |
| Silver | | 49.1 | | | 0.0 | 49.1 | |
| Thallium | | | | 10.1 | | 10.1 | |
| Zinc | | 481.1 | | | | 481.1 | 589.8 |
| Boron | 1205.2 | | | | | 1205.2 | |

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

| | WLA Acute ug/l | WLA Chronic ug/l | |
|----------------|---------------------------|-----------------------------|----------------|
| Aluminum | 970.6 | N/A | |
| Antimony | 6912.80 | | |
| Arsenic | 160.8 | 234.9 | Acute Controls |
| Asbestos | 0.00E+00 | | |
| Barium | | | |
| Beryllium | | | |
| Cadmium | 9.1 | 3.5 | |
| Chromium (III) | 7034.4 | 413 | |
| Chromium (VI) | 19.8 | 15.7 | |
| Copper | 63.1 | 44.4 | |
| Cyanide | 28.7 | 8.4 | |
| Iron | 1303.8 | | |
| Lead | 159.9 | 27.2 | |
| Mercury | 0.241 | 0.019 | |
| Nickel | 1897.0 | 258 | |
| Selenium | 25.4 | 6.0 | |
| Silver | 49.1 | N/A | |
| Thallium | 10.1 | | |
| Zinc | 481.1 | 589.8 | Acute Controls |
| Boron | 1205.23 | | |

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based

**Utah Division of Water Quality
Salt Lake City, Utah**

strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value. This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

Utah Division of Water Quality
801-538-6052
File Name: SVWRF_WLA_2021.xlsm

APPENDIX - Coefficients and Other Model Information

| | | | | | | | |
|--|---|---|--|--|--|--|---|
| CBOD Coeff. (Kd)20 1/day 2.000 | CBOD Coeff. FORCED (Kd)/day 0.000 | CBOD Coeff. (Ka)T 1/day 1.920 | REAER. Coeff. (Ka)20 (Ka)/day 15.113 | REAER. Coeff. FORCED 1/day 0.000 | REAER. Coeff. (Ka)T 1/day 14.797 | NBOD Coeff. (Kn)20 1/day 0.250 | NBOD Coeff. (Kn)T 1/day 0.233 |
| Open Coeff. (K4)20 1/day 0.000 | Open Coeff. (K4)T 1/day 0.000 | NH3 LOSS (K5)20 1/day 4.000 | NH3 (K5)T 1/day 3.840 | NO2+NO3 LOSS (K6)20 1/day 0.000 | NO2+NO3 (K6)T 1/day 0.000 | TRC Decay K(CI)20 1/day 32.000 | TRC K(CI)(T) 1/day 30.384 |
| BENTHIC DEMAND (SOD)20 gm/m2/day 1.000 | BENTHIC DEMAND (SOD)T gm/m2/day 0.946 | | | | | | |
| K1 CBOD {theta} 1.0 | K2 Reaer. {theta} 1.0 | K3 NH3 {theta} 1.1 | K4 Open {theta} 1.0 | K5 NH3 Loss {theta} 1.0 | K6 NO2+3 {theta} 1.0 | K(CI) TRC {theta} 1.1 | S Benthic {theta} 1.1 |

Antidegradation Review

An antidegradation review (ADR) was conducted to determine whether the proposed activity complies with the applicable antidegradation requirements for receiving waters that may be affected. The Level I ADR evaluated the criteria of R317-2-3.5(b) and determined that a Level II antidegradation Review is not required.

**Utah Division of Water Quality
Salt Lake City, Utah**

WASTELOAD ANALYSIS [WLA] [REDACTED] = not included in the WLA
Addendum: Statement of Basis

| |
|----------|
| 8-Oct-21 |
| 4:00 PM |

Facilities: Central Valley Water Reclamation Facility
Discharging to: Jordan River

UPDES No: UT-0024392

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Jordan River: 2B,3B,4
 Antidegradation Review: Level I review completed. Level II review is not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

| | |
|---------------------------------------|--|
| Total Ammonia (TNH3) | Varies as a function of Temperature and pH Rebound. See Water Quality Standards |
| Chronic Total Residual Chlorine (TRC) | 0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average) |
| Chronic Dissolved Oxygen (DO) | 5.5 mg/l (30 Day Average) 4.0 mg/l (7Day Average) 3.0 mg/l (1 Day Average) |
| Maximum Total Dissolved Solids | 1200.0 mg/l |

Acute and Chronic Heavy Metals (Dissolved)

| Parameter | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------|----------------------------------|-----------------|---------------------------------|-------------------|
| | Concentration | Load* | Concentration | Load* |
| Aluminum | 87.00 ug/l** | 65.350 lbs/day | 750.00 ug/l | 563.366 lbs/day |
| Arsenic | 150.00 ug/l | 112.673 lbs/day | 340.00 ug/l | 255.393 lbs/day |
| Cadmium | 2.41 ug/l | 1.808 lbs/day | 7.45 ug/l | 5.599 lbs/day |
| Chromium III | 270.40 ug/l | 203.113 lbs/day | 5657.30 ug/l | 4,249.508 lbs/day |
| ChromiumVI | 11.00 ug/l | 8.263 lbs/day | 16.00 ug/l | 12.018 lbs/day |
| Copper | 30.76 ug/l | 23.104 lbs/day | 52.17 ug/l | 39.186 lbs/day |
| Iron | | | 1000.00 ug/l | 751.155 lbs/day |
| Lead | 18.82 ug/l | 14.134 lbs/day | 482.86 ug/l | 362.699 lbs/day |
| Mercury | 0.0120 ug/l | 0.009 lbs/day | 2.40 ug/l | 1.803 lbs/day |
| Nickel | 169.96 ug/l | 127.663 lbs/day | 1528.65 ug/l | 1,148.252 lbs/day |
| Selenium | 4.60 ug/l | 3.455 lbs/day | 20.00 ug/l | 15.023 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 41.78 ug/l | 31.380 lbs/day |
| Zinc | 391.09 ug/l | 293.770 lbs/day | 391.09 ug/l | 293.770 lbs/day |

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals Standards Based upon a Hardness of 403.97 mg/l as CaCO₃

IV. Numeric Stream Standards for Protection of Agriculture

| | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|-------------|----------------------------------|-------|---------------------------------|-----------------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | 100.0 ug/l | lbs/day |
| Boron | | | 750.0 ug/l | lbs/day |
| Cadmium | | | 10.0 ug/l | 3.76 lbs/day |
| Chromium | | | 100.0 ug/l | lbs/day |
| Copper | | | 200.0 ug/l | lbs/day |
| Lead | | | 100.0 ug/l | lbs/day |
| Selenium | | | 50.0 ug/l | lbs/day |
| TDS, Summer | | | 1200.0 mg/l | 450.69 tons/day |

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

| Metals | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|---------------|----------------------------------|-------|---------------------------------|---------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | ug/l | lbs/day |
| Barium | | | ug/l | lbs/day |
| Cadmium | | | ug/l | lbs/day |
| Chromium | | | ug/l | lbs/day |
| Lead | | | ug/l | lbs/day |
| Mercury | | | ug/l | lbs/day |
| Selenium | | | ug/l | lbs/day |
| Silver | | | ug/l | lbs/day |
| Fluoride (3) | | | ug/l | lbs/day |
| to | | | ug/l | lbs/day |
| Nitrates as N | | | ug/l | lbs/day |

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

| Metals | Maximum Conc., ug/l - Acute Standards | | | |
|----------------|---------------------------------------|---------|--------------|-------------------|
| | Class 1C | | Class 3A, 3B | |
| Antimony | ug/l | lbs/day | | |
| Arsenic | ug/l | lbs/day | 4300.00 ug/l | 6907.33 lbs/day |
| Asbestos | ug/l | lbs/day | | |
| Beryllium | | | | |
| Cadmium | | | | |
| Chromium (III) | | | | |
| Chromium (VI) | | | | |
| Copper | | | | |
| Cyanide | ug/l | lbs/day | 2.2E+05 ug/l | 353398.05 lbs/day |
| Lead | ug/l | lbs/day | | |
| Mercury | | | 0.15 ug/l | 0.24 lbs/day |
| Nickel | | | 4600.00 ug/l | 7389.23 lbs/day |
| Selenium | ug/l | lbs/day | | |
| Silver | ug/l | lbs/day | | |
| Thallium | | | 6.30 ug/l | 10.12 lbs/day |
| Zinc | | | | |

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

**Utah Division of Water Quality
Salt Lake City, Utah**

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

| | |
|-----------------------|-------------------------------------|
| Flow, Q, (cfs or MGD) | D.O. mg/l |
| Temperature, Deg. C. | Total Residual Chlorine (TRC), mg/l |
| pH | Total NH3-N, mg/l |
| BOD5, mg/l | Total Dissolved Solids (TDS), mg/l |
| Metals, ug/l | Toxic Organics of Concern, ug/l |

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

| | Stream | | | | | | | | |
|------------------------|---------------------|---------------|-----------|------------------|-------------|-------------|-------------|-------------|-------------|
| | Critical Low | | | | | | | | |
| | Flow | Temp. | pH | T-NH3 | BOD5 | DO | TRC | TDS | |
| | cfs | Deg. C | | mg/l as N | mg/l | mg/l | mg/l | mg/l | mg/l |
| Summer (Irrig. Season) | 182.0 | 18.7 | 8.0 | 0.22 | 4.92 | 7.18 | 0.00 | 1248.8 | |
| Fall | 133.0 | 10.9 | 8.0 | 0.34 | 3.44 | --- | 0.00 | 1158.0 | |
| Winter | 122.0 | 6.3 | 8.0 | 0.44 | 3.94 | --- | 0.00 | 1158.0 | |
| Spring | 116.0 | 12.5 | 8.0 | 0.24 | 3.25 | --- | 0.00 | 1158.0 | |
| Dissolved Metals | Al | As | Cd | CrIII | CrVI | Copper | Fe | Pb | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | |
| All Seasons | 221.00 | 42.77 | 4.23 | 4.45 | 2.65* | 5.36 | 0.0 | 2.74 | |
| Dissolved Metals | Hg | Ni | Se | Ag | Zn | Boron | | | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | | | |
| All Seasons | 0.0000 | 3.38 | 2.47 | 1.17 | 19.93 | 10.0 | | | * 1/2 MDL |

Projected Discharge Information

**Utah Division of Water Quality
Salt Lake City, Utah**

| Season | Flow, MGD | Temp. | TDS mg/l | TDS tons/day |
|--------|-----------|-------|----------|--------------|
| Summer | 75.00000 | NA | 982.67 | 307.26746 |
| Fall | 75.00000 | NA | | |
| Winter | 75.00000 | NA | | |
| Spring | 75.00000 | NA | | |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

| Season | Daily Average | |
|--------|---------------|-------------|
| Summer | 75.000 MGD | 116.025 cfs |
| Fall | 75.000 MGD | 116.025 cfs |
| Winter | 75.000 MGD | 116.025 cfs |
| Spring | 75.000 MGD | 116.025 cfs |

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 75 MGD. If the discharger is allowed to have a flow greater than 75 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

| | | | |
|------------------|--------|----------------|-----------|
| WET Requirements | LC50 > | EOP Effluent | [Acute] |
| | IC25 > | 38.9% Effluent | [Chronic] |

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 403.97 mg/l):

| | 4 Day Average | | 1 Hour Average | | Load |
|--------------|---------------|---------------|----------------|------|----------------|
| | Concentration | Load | Concentration | Load | |
| Aluminum | N/A | N/A | 1,164.9 | ug/l | 875.0 lbs/day |
| Arsenic | 318.21 ug/l | 128.6 lbs/day | 573.1 | ug/l | 430.5 lbs/day |
| Cadmium | - ug/l | 0.0 lbs/day | 10.0 | ug/l | 7.5 lbs/day |
| Chromium III | 687.58 ug/l | 278.0 lbs/day | 10,090.9 | ug/l | 7579.8 lbs/day |
| Chromium VI | 22.02 ug/l | 8.9 lbs/day | 25.4 | ug/l | 19.1 lbs/day |
| Copper | 70.60 ug/l | 28.5 lbs/day | 88.9 | ug/l | 66.8 lbs/day |
| Iron | N/A | N/A | 1,784.3 | ug/l | 1340.3 lbs/day |
| Lead | 44.04 ug/l | 17.8 lbs/day | 859.4 | ug/l | 645.6 lbs/day |

**Utah Division of Water Quality
Salt Lake City, Utah**

| | | | | | |
|----------|-------------|---------------|---------|------|----------------|
| Mercury | 0.03 ug/l | 0.0 lbs/day | 4.3 | ug/l | 3.2 lbs/day |
| Nickel | 431.26 ug/l | 174.3 lbs/day | 2,724.9 | ug/l | 2046.9 lbs/day |
| Selenium | 7.95 ug/l | 3.2 lbs/day | 33.8 | ug/l | 25.4 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 73.6 | ug/l | 55.3 lbs/day |
| Zinc | 973.31 ug/l | 393.5 lbs/day | 682.2 | ug/l | 512.4 lbs/day |
| Cyanide | 13.36 ug/l | 5.4 lbs/day | 39.3 | ug/l | 29.5 lbs/day |

Effluent Limitations for Heat/Temperature based upon Water Quality Standards

| | | |
|--------|--------------|-------------|
| Summer | 24.9 Deg. C. | 76.9 Deg. F |
| Fall | 16.6 Deg. C. | 61.8 Deg. F |
| Winter | 11.8 Deg. C. | 53.3 Deg. F |
| Spring | 18.0 Deg. C. | 64.4 Deg. F |

Effluent Targets for Pollution Indicators Based upon Water Quality Standards

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

| | Concentration | 1 Hour Average Loading |
|------------------------|---------------|---------------------------|
| Gross Beta (pCi/l) | 50.0 pCi/L | |
| BOD (mg/l) | 5.0 mg/l | 3755.8 lbs/day |
| Nitrates as N | 4.0 mg/l | 3004.6 lbs/day |
| Total Phosphorus as P | 0.05 mg/l | 37.6 lbs/day |
| Total Suspended Solids | 90.0 mg/l | 67603.9 lbs/day |

Note: Pollution indicator targets are for information purposes only.

Effluent Limitations for Protection of Human Health [Toxics Rule] Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

| | Concentration | Maximum Concentration Load |
|----------------|---------------|-------------------------------|
| Metals | | |
| Antimony | ug/l | lbs/day |
| Arsenic | ug/l | lbs/day |
| Asbestos | ug/l | lbs/day |
| Beryllium | | |
| Cadmium | | |
| Chromium (III) | | |
| Chromium (VI) | | |
| Copper | ug/l | lbs/day |
| Cyanide | ug/l | lbs/day |
| Lead | | |
| Mercury | ug/l | lbs/day |
| Nickel | ug/l | lbs/day |
| Selenium | | |
| Silver | | |
| Thallium | ug/l | lbs/day |
| Zinc | | |

Metals Effluent Limitations for Protection of All Beneficial Uses Based upon Water Quality Standards and Toxics Rule

**Utah Division of Water Quality
Salt Lake City, Utah**

| | Class 4 Acute Agricultural ug/l | Class 3 Acute Aquatic Wildlife ug/l | Acute Toxics Drinking Water Source ug/l | Acute Toxics Wildlife ug/l | 1C Acute Health Criteria ug/l | Acute Most Stringent ug/l | Class 3 Chronic Aquatic Wildlife ug/l |
|----------------|--|--|--|---|--|--|--|
| Aluminum | | 1164.9 | | | | 1164.9 | N/A |
| Antimony | | | | 11045.1 | | 11045.1 | |
| Arsenic | 256.9 | 573.1 | | | 0.0 | 256.9 | 318.2 |
| Asbestos | | | | | | 0.00E+00 | |
| Barium | | | | | | 0.0 | |
| Beryllium | | | | | | 0.0 | |
| Cadmium | 19.1 | 10.0 | | | 0.0 | 10.0 | 0.0 |
| Chromium (III) | | 10090.9 | | | 0.0 | 10090.9 | 687.6 |
| Chromium (VI) | 249.9 | 25.4 | | | 0.0 | 25.43 | 22.02 |
| Copper | 505.3 | 88.9 | | | | 88.9 | 70.6 |
| Cyanide | | 39.3 | 565098.0 | | | 39.3 | 13.4 |
| Iron | | 1784.3 | | | | 1784.3 | |
| Lead | 252.6 | 859.4 | | | 0.0 | 252.6 | 44.0 |
| Mercury | | 4.28 | | 0.39 | 0.0 | 0.39 | 0.031 |
| Nickel | | 2724.9 | | 11815.7 | | 2724.9 | 431.3 |
| Selenium | 124.6 | 33.8 | | | 0.0 | 33.8 | 7.9 |
| Silver | | 73.6 | | | 0.0 | 73.6 | |
| Thallium | | | | 16.2 | | 16.2 | |
| Zinc | | 682.2 | | | | 682.2 | 973.3 |
| Boron | 1925.9 | | | | | 1925.9 | |

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

| | WLA Acute ug/l | WLA Chronic ug/l | |
|----------------|---------------------------|-----------------------------|----------------|
| Aluminum | 1164.9 | N/A | |
| Antimony | 11045.10 | | |
| Arsenic | 256.9 | 318.2 | Acute Controls |
| Asbestos | 0.00E+00 | | |
| Barium | | | |
| Beryllium | | | |
| Cadmium | 10.0 | 0.0 | |
| Chromium (III) | 10090.9 | 688 | |
| Chromium (VI) | 25.4 | 22.0 | |
| Copper | 88.9 | 70.6 | |
| Cyanide | 39.3 | 13.4 | |
| Iron | 1784.3 | | |
| Lead | 252.6 | 44.0 | |
| Mercury | 0.385 | 0.031 | |
| Nickel | 2724.9 | 431 | |
| Selenium | 33.8 | 7.9 | |
| Silver | 73.6 | N/A | |
| Thallium | 16.2 | | |
| Zinc | 682.2 | 973.3 | Acute Controls |
| Boron | 1925.92 | | |

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based

**Utah Division of Water Quality
Salt Lake City, Utah**

strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value. This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

Utah Division of Water Quality
801-538-6052
File Name: CVWRF_WLA_JR_2021.xlsm

APPENDIX - Coefficients and Other Model Information

| | | | | | | | |
|--|---|---|---|--|---|--|---|
| CBOD Coeff. (Kd)20 1/day 0.520 | CBOD Coeff. FORCED (Kd)/day 0.000 | CBOD Coeff. (Ka)T 1/day 0.490 | REAER. Coeff. (Ka)20 (Ka)/day 2.040 | REAER. Coeff. FORCED 1/day 0.000 | REAER. Coeff. (Ka)T 1/day 1.978 | NBOD Coeff. (Kn)20 1/day 0.250 | NBOD Coeff. (Kn)T 1/day 0.226 |
| Open Coeff. (K4)20 1/day 0.000 | Open Coeff. (K4)T 1/day 0.000 | NH3 LOSS (K5)20 1/day 4.000 | NH3 (K5)T 1/day 3.766 | NO2+NO3 LOSS (K6)20 1/day 0.000 | NO2+NO3 (K6)T 1/day 0.000 | TRC Decay K(CI)20 1/day 32.000 | TRC K(CI)(T) 1/day 29.647 |
| BENTHIC DEMAND (SOD)20 gm/m2/day 1.000 | BENTHIC DEMAND (SOD)T gm/m2/day 0.921 | | | | | | |
| K1 CBOD {theta} 1.0 | K2 Reaer. {theta} 1.0 | K3 NH3 {theta} 1.1 | K4 Open {theta} 1.0 | K5 NH3 Loss {theta} 1.0 | K6 NO2+3 {theta} 1.0 | K(CI) TRC {theta} 1.1 | S Benthic {theta} 1.1 |

Antidegradation Review

An antidegradation review (ADR) was conducted to determine whether the proposed activity complies with the applicable antidegradation requirements for receiving waters that may be affected. The Level I ADR evaluated the criteria of R317-2-3.5(b) and determined that a Level II antidegradation Review is not required.

**Utah Division of Water Quality
Salt Lake City, Utah**

WASTELOAD ANALYSIS [WLA] [REDACTED] = not included in the WLA
Addendum: Statement of Basis

| |
|-----------------|
| 8-Oct-21 |
| 4:00 PM |

Facilities: South Davis Sewer District South Wastewater Treatment Plant **UPDES No:** UT-0021628
Discharging to: Jordan River

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Jordan River: 2B,3B,4
 Antidegradation Review: Level I review completed. Level II review is not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

| | |
|---------------------------------------|--|
| Total Ammonia (TNH3) | Varies as a function of Temperature and pH Rebound. See Water Quality Standards |
| Chronic Total Residual Chlorine (TRC) | 0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average) |
| Chronic Dissolved Oxygen (DO) | 5.5 mg/l (30 Day Average) 4.0 mg/l (7Day Average) 3.0 mg/l (1 Day Average) |
| Maximum Total Dissolved Solids | 1200.0 mg/l |

Acute and Chronic Heavy Metals (Dissolved)

| Parameter | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | | |
|--------------|----------------------------------|----------------|---------------------------------|-------|-----------------|
| | Concentration | Load* | Concentration | Load* | Load* |
| Aluminum | 87.00 ug/l** | 3.485 lbs/day | 750.00 | ug/l | 30.046 lbs/day |
| Arsenic | 150.00 ug/l | 6.009 lbs/day | 340.00 | ug/l | 13.621 lbs/day |
| Cadmium | 2.37 ug/l | 0.095 lbs/day | 7.32 | ug/l | 0.293 lbs/day |
| Chromium III | 266.44 ug/l | 10.674 lbs/day | 5574.36 | ug/l | 223.318 lbs/day |
| ChromiumVI | 11.00 ug/l | 0.441 lbs/day | 16.00 | ug/l | 0.641 lbs/day |
| Copper | 30.29 ug/l | 1.213 lbs/day | 51.29 | ug/l | 2.055 lbs/day |
| Iron | | | 1000.00 | ug/l | 40.062 lbs/day |
| Lead | 18.39 ug/l | 0.737 lbs/day | 471.90 | ug/l | 18.905 lbs/day |
| Mercury | 0.0120 ug/l | 0.000 lbs/day | 2.40 | ug/l | 0.096 lbs/day |
| Nickel | 167.38 ug/l | 6.706 lbs/day | 1505.50 | ug/l | 60.313 lbs/day |
| Selenium | 4.60 ug/l | 0.184 lbs/day | 20.00 | ug/l | 0.801 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 40.50 | ug/l | 1.623 lbs/day |
| Zinc | 385.16 ug/l | 15.430 lbs/day | 385.16 | ug/l | 15.430 lbs/day |

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals Standards Based upon a Hardness of 396.76 mg/l as CaCO₃

IV. Numeric Stream Standards for Protection of Agriculture

| | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|-------------|----------------------------------|-------|---------------------------------|----------------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | 100.0 ug/l | lbs/day |
| Boron | | | 750.0 ug/l | lbs/day |
| Cadmium | | | 10.0 ug/l | 0.20 lbs/day |
| Chromium | | | 100.0 ug/l | lbs/day |
| Copper | | | 200.0 ug/l | lbs/day |
| Lead | | | 100.0 ug/l | lbs/day |
| Selenium | | | 50.0 ug/l | lbs/day |
| TDS, Summer | | | 1200.0 mg/l | 24.04 tons/day |

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

| Metals | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|---------------|----------------------------------|-------|---------------------------------|---------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | ug/l | lbs/day |
| Barium | | | ug/l | lbs/day |
| Cadmium | | | ug/l | lbs/day |
| Chromium | | | ug/l | lbs/day |
| Lead | | | ug/l | lbs/day |
| Mercury | | | ug/l | lbs/day |
| Selenium | | | ug/l | lbs/day |
| Silver | | | ug/l | lbs/day |
| Fluoride (3) | | | ug/l | lbs/day |
| to | | | ug/l | lbs/day |
| Nitrates as N | | | ug/l | lbs/day |

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

| Metals | Maximum Conc., ug/l - Acute Standards | | | |
|----------------|---------------------------------------|---------|--------------|-------------------|
| | Class 1C | | Class 3A, 3B | |
| Antimony | ug/l | lbs/day | | |
| Arsenic | ug/l | lbs/day | 4300.00 ug/l | 3249.14 lbs/day |
| Asbestos | ug/l | lbs/day | | |
| Beryllium | | | | |
| Cadmium | | | | |
| Chromium (III) | | | | |
| Chromium (VI) | | | | |
| Copper | | | | |
| Cyanide | ug/l | lbs/day | 2.2E+05 ug/l | 166234.93 lbs/day |
| Lead | ug/l | lbs/day | | |
| Mercury | | | 0.15 ug/l | 0.11 lbs/day |
| Nickel | | | 4600.00 ug/l | 3475.82 lbs/day |
| Selenium | ug/l | lbs/day | | |
| Silver | ug/l | lbs/day | | |
| Thallium | | | 6.30 ug/l | 4.76 lbs/day |
| Zinc | | | | |

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

**Utah Division of Water Quality
Salt Lake City, Utah**

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

| | |
|-----------------------|-------------------------------------|
| Flow, Q, (cfs or MGD) | D.O. mg/l |
| Temperature, Deg. C. | Total Residual Chlorine (TRC), mg/l |
| pH | Total NH3-N, mg/l |
| BOD5, mg/l | Total Dissolved Solids (TDS), mg/l |
| Metals, ug/l | Toxic Organics of Concern, ug/l |

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

| | Stream | | | | | | | | |
|------------------------|---------------------|---------------|-----------|------------------|-------------|-------------|-------------|-------------|-------------|
| | Critical Low | | | | | | | | |
| | Flow | Temp. | pH | T-NH3 | BOD5 | DO | TRC | TDS | |
| | cfs | Deg. C | | mg/l as N | mg/l | mg/l | mg/l | mg/l | mg/l |
| Summer (Irrig. Season) | 134.0 | 20.6 | 7.9 | 0.71 | 6.03 | 6.91 | 0.00 | 796.7 | |
| Fall | 104.0 | 9.9 | 7.9 | 0.74 | 5.24 | --- | 0.00 | 782.4 | |
| Winter | 51.0 | 6.8 | 7.9 | 0.87 | 6.15 | --- | 0.00 | 782.4 | |
| Spring | 64.0 | 13.9 | 7.9 | 0.46 | 4.26 | --- | 0.00 | 782.4 | |
| Dissolved Metals | Al | As | Cd | CrIII | CrVI | Copper | Fe | Pb | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | |
| All Seasons | 232.00 | 8.03 | 0.39 | 2.58 | 3.31 | 5.01 | 0.0 | 1.53 | |
| Dissolved Metals | Hg | Ni | Se | Ag | Zn | Boron | | | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | | | |
| All Seasons | 0.0000 | 2.70 | 1.61 | 0.63 | 19.46 | 10.0 | | | * 1/2 MDL |

Projected Discharge Information

**Utah Division of Water Quality
Salt Lake City, Utah**

| Season | Flow, MGD | Temp. | TDS mg/l | TDS tons/day |
|--------|-----------|-------|----------|--------------|
| Summer | 4.00000 | 5.0 | 845.39 | 14.09829 |
| Fall | 4.00000 | 5.0 | | |
| Winter | 4.00000 | 5.0 | | |
| Spring | 4.00000 | 5.0 | | |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

| Season | Daily Average | |
|--------|---------------|-----------|
| Summer | 4.000 MGD | 6.188 cfs |
| Fall | 4.000 MGD | 6.188 cfs |
| Winter | 4.000 MGD | 6.188 cfs |
| Spring | 4.000 MGD | 6.188 cfs |

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 4 MGD. If the discharger is allowed to have a flow greater than 4 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

| | | | |
|------------------|--------|----------------|-----------|
| WET Requirements | LC50 > | 98.5% Effluent | [Acute] |
| | IC25 > | 20.9% Effluent | [Chronic] |

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 396.76 mg/l):

| | 4 Day Average | | 1 Hour Average | | Load |
|--------------|---------------|---------------|----------------|------|----------------|
| | Concentration | Load | Concentration | Load | |
| Aluminum | N/A | N/A | 6,358.6 | ug/l | 254.7 lbs/day |
| Arsenic | 3,224.33 ug/l | 69.5 lbs/day | 3,934.4 | ug/l | 157.6 lbs/day |
| Cadmium | 45.39 ug/l | 1.0 lbs/day | 82.4 | ug/l | 3.3 lbs/day |
| Chromium III | 5,980.15 ug/l | 128.9 lbs/day | 65,902.3 | ug/l | 2640.1 lbs/day |
| Chromium VI | 177.46 ug/l | 3.8 lbs/day | 153.4 | ug/l | 6.1 lbs/day |
| Copper | 577.78 ug/l | 12.5 lbs/day | 552.4 | ug/l | 22.1 lbs/day |
| Iron | N/A | N/A | 11,827.2 | ug/l | 473.8 lbs/day |
| Lead | 383.39 ug/l | 8.3 lbs/day | 5,564.7 | ug/l | 222.9 lbs/day |

**Utah Division of Water Quality
Salt Lake City, Utah**

| | | | | | |
|----------|---------------|---------------|----------|------|---------------|
| Mercury | 0.27 ug/l | 0.0 lbs/day | 28.4 | ug/l | 1.1 lbs/day |
| Nickel | 3,733.48 ug/l | 80.5 lbs/day | 17,776.9 | ug/l | 712.2 lbs/day |
| Selenium | 69.26 ug/l | 1.5 lbs/day | 219.1 | ug/l | 8.8 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 472.2 | ug/l | 18.9 lbs/day |
| Zinc | 8,304.47 ug/l | 179.0 lbs/day | 4,344.8 | ug/l | 174.1 lbs/day |
| Cyanide | 117.81 ug/l | 2.5 lbs/day | 260.2 | ug/l | 10.4 lbs/day |

Effluent Limitations for Heat/Temperature based upon Water Quality Standards

| | | |
|--------|--------------|--------------|
| Summer | 60.6 Deg. C. | 141.2 Deg. F |
| Fall | 41.9 Deg. C. | 107.4 Deg. F |
| Winter | 24.6 Deg. C. | 76.2 Deg. F |
| Spring | 35.2 Deg. C. | 95.3 Deg. F |

Effluent Targets for Pollution Indicators Based upon Water Quality Standards

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

| | 1 Hour Average | |
|------------------------|-----------------------|----------------|
| | Concentration | Loading |
| Gross Beta (pCi/l) | 50.0 pCi/L | |
| BOD (mg/l) | 5.0 mg/l | 200.3 lbs/day |
| Nitrates as N | 4.0 mg/l | 160.2 lbs/day |
| Total Phosphorus as P | 0.05 mg/l | 2.0 lbs/day |
| Total Suspended Solids | 90.0 mg/l | 3605.5 lbs/day |

Note: Pollution indicator targets are for information purposes only.

Effluent Limitations for Protection of Human Health [Toxics Rule] Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

| | Maximum Concentration | |
|----------------|------------------------------|---------|
| | Concentration | Load |
| Metals | | |
| Antimony | ug/l | lbs/day |
| Arsenic | ug/l | lbs/day |
| Asbestos | ug/l | lbs/day |
| Beryllium | | |
| Cadmium | | |
| Chromium (III) | | |
| Chromium (VI) | | |
| Copper | ug/l | lbs/day |
| Cyanide | ug/l | lbs/day |
| Lead | | |
| Mercury | ug/l | lbs/day |
| Nickel | ug/l | lbs/day |
| Selenium | | |
| Silver | | |
| Thallium | ug/l | lbs/day |
| Zinc | | |

Metals Effluent Limitations for Protection of All Beneficial Uses Based upon Water Quality Standards and Toxics Rule

**Utah Division of Water Quality
Salt Lake City, Utah**

| | Class 4 Acute Agricultural ug/l | Class 3 Acute Aquatic Wildlife ug/l | Acute Toxics Drinking Water Source ug/l | Acute Toxics Wildlife ug/l | 1C Acute Health Criteria ug/l | Acute Most Stringent ug/l | Class 3 Chronic Aquatic Wildlife ug/l |
|----------------|--|--|--|---|--|--|--|
| Aluminum | | 6358.6 | | | | 6358.6 | N/A |
| Antimony | | | | 97415.7 | | 97415.7 | |
| Arsenic | 2265.5 | 3934.4 | | | 0.0 | 2265.5 | 3224.3 |
| Asbestos | | | | | | 0.00E+00 | |
| Barium | | | | | | 0.0 | |
| Beryllium | | | | | | 0.0 | |
| Cadmium | 218.2 | 82.4 | | | 0.0 | 82.4 | 45.4 |
| Chromium (III) | | 65902.3 | | | 0.0 | 65902.3 | 5980.2 |
| Chromium (VI) | 2209.6 | 153.4 | | | 0.0 | 153.37 | 177.46 |
| Copper | 4422.6 | 552.4 | | | | 552.4 | 577.8 |
| Cyanide | | 260.2 | 4984059.5 | | | 260.2 | 117.8 |
| Iron | | 11827.2 | | | | 11827.2 | |
| Lead | 2232.3 | 5564.7 | | | 0.0 | 2232.3 | 383.4 |
| Mercury | | 28.39 | | 3.40 | 0.0 | 3.40 | 0.272 |
| Nickel | | 17776.9 | | 104212.2 | | 17776.9 | 3733.5 |
| Selenium | 1097.8 | 219.1 | | | 0.0 | 219.1 | 69.3 |
| Silver | | 472.2 | | | 0.0 | 472.2 | |
| Thallium | | | | 142.7 | | 142.7 | |
| Zinc | | 4344.8 | | | | 4344.8 | 8304.5 |
| Boron | 16985.8 | | | | | 16985.8 | |

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

| | WLA Acute ug/l | WLA Chronic ug/l | |
|----------------|---------------------------|-----------------------------|----------------|
| Aluminum | 6358.6 | N/A | |
| Antimony | 97415.71 | | |
| Arsenic | 2265.5 | 3224.3 | Acute Controls |
| Asbestos | 0.00E+00 | | |
| Barium | | | |
| Beryllium | | | |
| Cadmium | 82.4 | 45.4 | |
| Chromium (III) | 65902.3 | 5980 | |
| Chromium (VI) | 153.4 | 177.5 | Acute Controls |
| Copper | 552.4 | 577.8 | Acute Controls |
| Cyanide | 260.2 | 117.8 | |
| Iron | 11827.2 | | |
| Lead | 2232.3 | 383.4 | |
| Mercury | 3.398 | 0.272 | |
| Nickel | 17776.9 | 3733 | |
| Selenium | 219.1 | 69.3 | |
| Silver | 472.2 | N/A | |
| Thallium | 142.7 | | |
| Zinc | 4344.8 | 8304.5 | Acute Controls |
| Boron | 16985.78 | | |

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based

**Utah Division of Water Quality
Salt Lake City, Utah**

strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value. This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

Utah Division of Water Quality
801-538-6052
File Name: SDSWRF_WLA_2021.xlsm

APPENDIX - Coefficients and Other Model Information

| | | | | | | | |
|--|---|---|---|--|---|--|---|
| CBOD Coeff. (Kd)20 1/day 0.830 | CBOD Coeff. FORCED (Kd)/day 0.000 | CBOD Coeff. (Ka)T 1/day 0.852 | REAER. Coeff. (Ka)20 (Ka)/day 3.450 | REAER. Coeff. FORCED 1/day 0.000 | REAER. Coeff. (Ka)T 1/day 3.498 | NBOD Coeff. (Kn)20 1/day 0.250 | NBOD Coeff. (Kn)T 1/day 0.261 |
| Open Coeff. (K4)20 1/day 0.000 | Open Coeff. (K4)T 1/day 0.000 | NH3 LOSS (K5)20 1/day 4.000 | NH3 (K5)T 1/day 4.108 | NO2+NO3 LOSS (K6)20 1/day 0.000 | NO2+NO3 (K6)T 1/day 0.000 | TRC Decay K(CI)20 1/day 32.000 | TRC K(CI)(T) 1/day 33.103 |
| BENTHIC DEMAND (SOD)20 gm/m2/day 1.000 | BENTHIC DEMAND (SOD)T gm/m2/day 1.037 | | | | | | |
| K1 CBOD {theta} 1.0 | K2 Reaer. {theta} 1.0 | K3 NH3 {theta} 1.1 | K4 Open {theta} 1.0 | K5 NH3 Loss {theta} 1.0 | K6 NO2+3 {theta} 1.0 | K(CI) TRC {theta} 1.1 | S Benthic {theta} 1.1 |

Antidegradation Review

An antidegradation review (ADR) was conducted to determine whether the proposed activity complies with the applicable antidegradation requirements for receiving waters that may be affected. The Level I ADR evaluated the criteria of R317-2-3.5(b) and determined that a Level II antidegradation Review is not required.

**Utah Division of Water Quality
Salt Lake City, Utah**

WASTELOAD ANALYSIS [WLA] [REDACTED] = not included in the WLA
Addendum: Statement of Basis

| |
|----------|
| 8-Oct-21 |
| 4:00 PM |

Facilities: South Davis Sewer District North Wastewater Treatment Plant **UPDES No:** UT-0021636
Discharging to: Jordan River

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Jordan River: 2B,3B,4
Antidegradation Review: Level I review completed. Level II review is not required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

| | |
|---------------------------------------|--|
| Total Ammonia (TNH3) | Varies as a function of Temperature and pH Rebound. See Water Quality Standards |
| Chronic Total Residual Chlorine (TRC) | 0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average) |
| Chronic Dissolved Oxygen (DO) | 5.5 mg/l (30 Day Average) 4.0 mg/l (7Day Average) 3.0 mg/l (1 Day Average) |
| Maximum Total Dissolved Solids | 1200.0 mg/l |

Acute and Chronic Heavy Metals (Dissolved)

| Parameter | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------|----------------------------------|----------------|---------------------------------|-----------------|
| | Concentration | Load* | Concentration | Load* |
| Aluminum | 87.00 ug/l** | 10.456 lbs/day | 750.00 ug/l | 90.139 lbs/day |
| Arsenic | 150.00 ug/l | 18.028 lbs/day | 340.00 ug/l | 40.863 lbs/day |
| Cadmium | 2.29 ug/l | 0.275 lbs/day | 7.00 ug/l | 0.841 lbs/day |
| Chromium III | 256.58 ug/l | 30.837 lbs/day | 5368.13 ug/l | 645.167 lbs/day |
| ChromiumVI | 11.00 ug/l | 1.322 lbs/day | 16.00 ug/l | 1.923 lbs/day |
| Copper | 29.12 ug/l | 3.500 lbs/day | 49.11 ug/l | 5.903 lbs/day |
| Iron | | | 1000.00 ug/l | 120.185 lbs/day |
| Lead | 17.34 ug/l | 2.084 lbs/day | 445.04 ug/l | 53.487 lbs/day |
| Mercury | 0.0120 ug/l | 0.001 lbs/day | 2.40 ug/l | 0.288 lbs/day |
| Nickel | 160.99 ug/l | 19.349 lbs/day | 1448.00 ug/l | 174.028 lbs/day |
| Selenium | 4.60 ug/l | 0.553 lbs/day | 20.00 ug/l | 2.404 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 37.42 ug/l | 4.497 lbs/day |
| Zinc | 370.43 ug/l | 44.520 lbs/day | 370.43 ug/l | 44.520 lbs/day |

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO₃

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals Standards Based upon a Hardness of 378.91 mg/l as CaCO₃

IV. Numeric Stream Standards for Protection of Agriculture

| | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|-------------|----------------------------------|-------|---------------------------------|----------------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | 100.0 ug/l | lbs/day |
| Boron | | | 750.0 ug/l | lbs/day |
| Cadmium | | | 10.0 ug/l | 0.60 lbs/day |
| Chromium | | | 100.0 ug/l | lbs/day |
| Copper | | | 200.0 ug/l | lbs/day |
| Lead | | | 100.0 ug/l | lbs/day |
| Selenium | | | 50.0 ug/l | lbs/day |
| TDS, Summer | | | 1200.0 mg/l | 72.11 tons/day |

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

| Metals | 4 Day Average (Chronic) Standard | | 1 Hour Average (Acute) Standard | |
|--------------------|----------------------------------|-------|---------------------------------|---------|
| | Concentration | Load* | Concentration | Load* |
| Arsenic | | | ug/l | lbs/day |
| Barium | | | ug/l | lbs/day |
| Cadmium | | | ug/l | lbs/day |
| Chromium | | | ug/l | lbs/day |
| Lead | | | ug/l | lbs/day |
| Mercury | | | ug/l | lbs/day |
| Selenium | | | ug/l | lbs/day |
| Silver | | | ug/l | lbs/day |
| Fluoride (3) to | | | ug/l | lbs/day |
| Nitrates as N | | | ug/l | lbs/day |

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

| Metals | Maximum Conc., ug/l - Acute Standards | | | |
|----------------|---------------------------------------|---------|--------------|------------------|
| | Class 1C | | Class 3A, 3B | |
| Antimony | ug/l | lbs/day | | |
| Arsenic | ug/l | lbs/day | 4300.00 ug/l | 1681.82 lbs/day |
| Asbestos | ug/l | lbs/day | | |
| Beryllium | | | | |
| Cadmium | | | | |
| Chromium (III) | | | | |
| Chromium (VI) | | | | |
| Copper | | | | |
| Cyanide | ug/l | lbs/day | 2.2E+05 ug/l | 86046.39 lbs/day |
| Lead | ug/l | lbs/day | | |
| Mercury | | | 0.15 ug/l | 0.06 lbs/day |
| Nickel | | | 4600.00 ug/l | 1799.15 lbs/day |
| Selenium | ug/l | lbs/day | | |
| Silver | ug/l | lbs/day | | |
| Thallium | | | 6.30 ug/l | 2.46 lbs/day |
| Zinc | | | | |

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

**Utah Division of Water Quality
Salt Lake City, Utah**

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

| | |
|-----------------------|-------------------------------------|
| Flow, Q, (cfs or MGD) | D.O. mg/l |
| Temperature, Deg. C. | Total Residual Chlorine (TRC), mg/l |
| pH | Total NH3-N, mg/l |
| BOD5, mg/l | Total Dissolved Solids (TDS), mg/l |
| Metals, ug/l | Toxic Organics of Concern, ug/l |

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

| | Stream | | | | | | | | |
|------------------------|---------------------|---------------|-----------|------------------|-------------|-------------|-------------|-------------|--|
| | Critical Low | | | | | | | | |
| | Flow | Temp. | pH | T-NH3 | BOD5 | DO | TRC | TDS | |
| | cfs | Deg. C | | mg/l as N | mg/l | mg/l | mg/l | mg/l | |
| Summer (Irrig. Season) | 54.0 | 21.2 | 7.9 | 0.36 | 6.03 | 6.82 | 0.00 | 880.9 | |
| Fall | 44.0 | 10.1 | 7.9 | 0.57 | 4.80 | --- | 0.00 | 954.4 | |
| Winter | 26.0 | 5.8 | 8.0 | 0.64 | 5.73 | --- | 0.00 | 954.4 | |
| Spring | 31.0 | 13.5 | 8.0 | 0.26 | 63.16 | --- | 0.00 | 954.4 | |
| Dissolved Metals | Al | As | Cd | CrIII | CrVI | Copper | Fe | Pb | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | |
| All Seasons | 24.30 | 8.89 | 0.47 | 2.78 | 4.75 | 5.91 | 0.0 | 2.15 | |
| Dissolved Metals | Hg | Ni | Se | Ag | Zn | Boron | | | |
| | ug/l | ug/l | ug/l | ug/l | ug/l | ug/l | | | |
| All Seasons | 0.0000 | 4.90 | 1.62 | 0.75 | 18.84 | 10.0 | | * 1/2 MDL | |

Projected Discharge Information

**Utah Division of Water Quality
Salt Lake City, Utah**

| Season | Flow, MGD | Temp. | TDS mg/l | TDS tons/day |
|--------|-----------|-------|----------|--------------|
| Summer | 12.00000 | NA | 982.67 | 49.16279 |
| Fall | 12.00000 | NA | | |
| Winter | 12.00000 | NA | | |
| Spring | 12.00000 | NA | | |

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

| Season | Daily Average | |
|--------|---------------|------------|
| Summer | 12.000 MGD | 18.564 cfs |
| Fall | 12.000 MGD | 18.564 cfs |
| Winter | 12.000 MGD | 18.564 cfs |
| Spring | 12.000 MGD | 18.564 cfs |

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 12 MGD. If the discharger is allowed to have a flow greater than 12 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

| | | | |
|------------------|--------|----------------|-----------|
| WET Requirements | LC50 > | EOP Effluent | [Acute] |
| | IC25 > | 66.3% Effluent | [Chronic] |

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 378.91 mg/l):

| | 4 Day Average | | 1 Hour Average | | Load |
|--------------|---------------|--------------|----------------|------|----------------|
| | Concentration | Load | Concentration | Load | |
| Aluminum | N/A | N/A | 1,805.5 | ug/l | 217.0 lbs/day |
| Arsenic | 560.47 ug/l | 36.3 lbs/day | 821.6 | ug/l | 98.7 lbs/day |
| Cadmium | 7.57 ug/l | 0.5 lbs/day | 16.5 | ug/l | 2.0 lbs/day |
| Chromium III | 994.84 ug/l | 64.3 lbs/day | 13,171.6 | ug/l | 1583.0 lbs/day |
| Chromium VI | 29.18 ug/l | 1.9 lbs/day | 32.4 | ug/l | 3.9 lbs/day |
| Copper | 96.63 ug/l | 6.3 lbs/day | 111.9 | ug/l | 13.5 lbs/day |
| Iron | N/A | N/A | 2,454.4 | ug/l | 295.0 lbs/day |
| Lead | 61.54 ug/l | 4.0 lbs/day | 1,089.2 | ug/l | 130.9 lbs/day |

**Utah Division of Water Quality
Salt Lake City, Utah**

| | | | | | |
|----------|---------------|--------------|---------|------|---------------|
| Mercury | 0.05 ug/l | 0.0 lbs/day | 5.9 | ug/l | 0.7 lbs/day |
| Nickel | 615.03 ug/l | 39.8 lbs/day | 3,546.9 | ug/l | 426.3 lbs/day |
| Selenium | 13.27 ug/l | 0.9 lbs/day | 46.7 | ug/l | 5.6 lbs/day |
| Silver | N/A ug/l | N/A lbs/day | 90.7 | ug/l | 10.9 lbs/day |
| Zinc | 1,393.15 ug/l | 90.1 lbs/day | 881.8 | ug/l | 106.0 lbs/day |
| Cyanide | 20.33 ug/l | 1.3 lbs/day | 54.0 | ug/l | 6.5 lbs/day |

Effluent Limitations for Heat/Temperature based upon Water Quality Standards

| | | |
|--------|--------------|-------------|
| Summer | 31.1 Deg. C. | 87.9 Deg. F |
| Fall | 18.9 Deg. C. | 66.0 Deg. F |
| Winter | 12.6 Deg. C. | 54.6 Deg. F |
| Spring | 20.9 Deg. C. | 69.6 Deg. F |

Effluent Targets for Pollution Indicators Based upon Water Quality Standards

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

| | Concentration | 1 Hour Average Loading |
|------------------------|---------------|---------------------------|
| Gross Beta (pCi/l) | 50.0 pCi/L | |
| BOD (mg/l) | 5.0 mg/l | 600.9 lbs/day |
| Nitrates as N | 4.0 mg/l | 480.7 lbs/day |
| Total Phosphorus as P | 0.05 mg/l | 6.0 lbs/day |
| Total Suspended Solids | 90.0 mg/l | 10816.6 lbs/day |

Note: Pollution indicator targets are for information purposes only.

Effluent Limitations for Protection of Human Health [Toxics Rule] Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

| | Concentration | Maximum Concentration Load |
|----------------|---------------|-------------------------------|
| Metals | | |
| Antimony | ug/l | lbs/day |
| Arsenic | ug/l | lbs/day |
| Asbestos | ug/l | lbs/day |
| Beryllium | | |
| Cadmium | | |
| Chromium (III) | | |
| Chromium (VI) | | |
| Copper | ug/l | lbs/day |
| Cyanide | ug/l | lbs/day |
| Lead | | |
| Mercury | ug/l | lbs/day |
| Nickel | ug/l | lbs/day |
| Selenium | | |
| Silver | | |
| Thallium | ug/l | lbs/day |
| Zinc | | |

Metals Effluent Limitations for Protection of All Beneficial Uses Based upon Water Quality Standards and Toxics Rule

**Utah Division of Water Quality
Salt Lake City, Utah**

| | Class 4 Acute Agricultural ug/l | Class 3 Acute Aquatic Wildlife ug/l | Acute Toxics Drinking Water Source ug/l | Acute Toxics Wildlife ug/l | 1C Acute Health Criteria ug/l | Acute Most Stringent ug/l | Class 3 Chronic Aquatic Wildlife ug/l |
|----------------|--|--|--|---|--|--|--|
| Aluminum | | 1805.5 | | | | 1805.5 | N/A |
| Antimony | | | | 16808.1 | | 16808.1 | |
| Arsenic | 390.9 | 821.6 | | | 0.0 | 390.9 | 560.5 |
| Asbestos | | | | | | 0.00E+00 | |
| Barium | | | | | | 0.0 | |
| Beryllium | | | | | | 0.0 | |
| Cadmium | 37.7 | 16.5 | | | 0.0 | 16.5 | 7.6 |
| Chromium (III) | | 13171.6 | | | 0.0 | 13171.6 | 994.8 |
| Chromium (VI) | 382.8 | 32.4 | | | 0.0 | 32.36 | 29.18 |
| Copper | 764.6 | 111.9 | | | | 111.9 | 96.6 |
| Cyanide | | 54.0 | 859948.3 | | | 54.0 | 20.3 |
| Iron | | 2454.4 | | | | 2454.4 | |
| Lead | 384.6 | 1089.2 | | | 0.0 | 384.6 | 61.5 |
| Mercury | | 5.89 | | 0.59 | 0.0 | 0.59 | 0.047 |
| Nickel | | 3546.9 | | 17980.7 | | 3546.9 | 615.0 |
| Selenium | 190.7 | 46.7 | | | 0.0 | 46.7 | 13.3 |
| Silver | | 90.7 | | | 0.0 | 90.7 | |
| Thallium | | | | 24.6 | | 24.6 | |
| Zinc | | 881.8 | | | | 881.8 | 1393.2 |
| Boron | 2930.9 | | | | | 2930.9 | |

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

| | WLA Acute ug/l | WLA Chronic ug/l | |
|----------------|---------------------------|-----------------------------|----------------|
| Aluminum | 1805.5 | N/A | |
| Antimony | 16808.08 | | |
| Arsenic | 390.9 | 560.5 | Acute Controls |
| Asbestos | 0.00E+00 | | |
| Barium | | | |
| Beryllium | | | |
| Cadmium | 16.5 | 7.6 | |
| Chromium (III) | 13171.6 | 995 | |
| Chromium (VI) | 32.4 | 29.2 | |
| Copper | 111.9 | 96.6 | |
| Cyanide | 54.0 | 20.3 | |
| Iron | 2454.4 | | |
| Lead | 384.6 | 61.5 | |
| Mercury | 0.586 | 0.047 | |
| Nickel | 3546.9 | 615 | |
| Selenium | 46.7 | 13.3 | |
| Silver | 90.7 | N/A | |
| Thallium | 24.6 | | |
| Zinc | 881.8 | 1393.2 | Acute Controls |
| Boron | 2930.85 | | |

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based

**Utah Division of Water Quality
Salt Lake City, Utah**

strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is not required.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value. This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

Utah Division of Water Quality
801-538-6052
File Name: SDNWRF_WLA_2021.xlsm

APPENDIX - Coefficients and Other Model Information

| | | | | | | | |
|--|---|---|---|--|---|--|---|
| CBOD Coeff. (Kd)20 1/day 1.000 | CBOD Coeff. FORCED (Kd)/day 0.000 | CBOD Coeff. (Ka)T 1/day 1.059 | REAER. Coeff. (Ka)20 (Ka)/day 6.012 | REAER. Coeff. FORCED 1/day 0.000 | REAER. Coeff. (Ka)T 1/day 6.191 | NBOD Coeff. (Kn)20 1/day 0.250 | NBOD Coeff. (Kn)T 1/day 0.275 |
| Open Coeff. (K4)20 1/day 0.000 | Open Coeff. (K4)T 1/day 0.000 | NH3 LOSS (K5)20 1/day 4.000 | NH3 (K5)T 1/day 4.235 | NO2+NO3 LOSS (K6)20 1/day 0.000 | NO2+NO3 (K6)T 1/day 0.000 | TRC Decay K(CI)20 1/day 32.000 | TRC K(CI)(T) 1/day 34.401 |
| BENTHIC DEMAND (SOD)20 gm/m2/day 1.000 | BENTHIC DEMAND (SOD)T gm/m2/day 1.081 | | | | | | |
| K1 CBOD {theta} 1.0 | K2 Reaer. {theta} 1.0 | K3 NH3 {theta} 1.1 | K4 Open {theta} 1.0 | K5 NH3 Loss {theta} 1.0 | K6 NO2+3 {theta} 1.0 | K(CI) TRC {theta} 1.1 | S Benthic {theta} 1.1 |

Antidegradation Review

An antidegradation review (ADR) was conducted to determine whether the proposed activity complies with the applicable antidegradation requirements for receiving waters that may be affected. The Level I ADR evaluated the criteria of R317-2-3.5(b) and determined that a Level II antidegradation Review is not required.