

**WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis
SUMMARY**

Discharging Facility: **Jordanelle Special Service District-Keetley Water Treatment Plant**
 UPDES No: UT0022403
 Current Flow: 12.00 MGD Design Flow
 Design Flow 12.00 MGD

Receiving Water: **Jordanelle Reservoir**
 Lake Classification: 1C,2A,3A,4

TDS (mg/l) 120.74 Average
 Hardness (mg/l) 306.28 Average
 pH 7.87 Average
 Temp (C) 10.371 Average

Selected Effluent Limit Summary:		WQ Standard:
Flow, MGD:	12.00 MGD Design Flow	
BOD, mg/l:	25.0 All Season	5 Indicator
Dissolved Oxygen, mg/l:	5.00 All Season	6.50 30 Day Average
TNH3, Chronic, mg/l:	57.33 All Season	Varies Function of pH and Temperature
TDS, mg/l:	3672.71 All Season	1200
Zinc, ug/l	543.96 All Season Varies	Function of Hardness
Copper, ug/l	55.66 All Season Varies	Function of Hardness

Modeling Parameters:

Acute Dilution Ratio 3.29 to 1
 Chronic Dilution Ratio: 18.81 to 1

Level 1 Antidegradation Level Completed: Level II Review required - Class 1C drinking water source.

Date: 2/9/2023

Wasteload Analysis - Total Maximum Daily Load (Lake TMDL)

2/16/2023 8:16

Facility: Jordanelle Special Service District-Keetley Water Treatment Plant UPDES No: UT- UT0022403
Discharging to: Jordanelle Reservoir

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on lake water quality. The wasteload analysis does not take into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and p 100 100 may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), unionized ammonia (as a function of pH and temperature, measured and evaluated interms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine water quality response to point source discharges. Models aid in the effort of anticipating water quality at future effluent flows at critical environmental conditions (e.g., high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may be modified by narrative criteria and other conditions as determined by staff of the Division of Water Quality.

II. Receiving Water and Lake / Reservoir Classification

Jordanelle Reservoir 1C,2A,3A,4

III. Numeric Water Quality Standards for Protection of Aquatic Wildlife

Total Ammonia (TNH3)	Function of Temperature and pH	pH	Temp
	1.54 mg/l as N (4 Day Average)	8.70	10.3
	3.18 mg/l as N (1 Hour Average)	8.30	10.3
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average)		
	0.019 mg/l (1 Hour Average)		
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average)		
	5.00 mg/l (7Day Average)		
	4.00 mg/l (1 Day Average)		
Maximum Total Dissolved Solids [Class 4 Ag]	1200 mg/l		
Maximum Boron [Class 4 Ag]	750 mg/l		

Acute and Chronic Heavy Metals (Dissolved)

Parameter	4 Day Average (Chronic) Standard Concentration	1 Hour Average (Acute) Standard Concentration
Aluminum	87.000 ug/l	750 ug/l
Antimony	ug/l	ug/l
Arsenic	190.000 ug/l	360.00 ug/l

Utah Division of Water Quality

Asbestos	ug/l		ug/l
Barium	ug/l	1000.00	ug/l
Beryllium	ug/l		ug/l
Cadmium	0.289 ug/l	3.47	ug/l
Chromium III	92.567 ug/l	1936.68	ug/l
Chromium VI	11.000 ug/l	16.00	ug/l
Copper	10.051 ug/l	15.20	ug/l
Cyanide	ug/l		ug/l
Iron	ug/l	1000.00	ug/l
Lead	3.556 ug/l	91.24	ug/l
Mercury	0.012 ug/l	2.40	ug/l
Nickel	95.00 ug/l	505.13	ug/l
Selenium	5.000 ug/l	20.00	ug/l
Silver	ug/l	4.40	ug/l
Thallium			
Zinc	129.015 ug/l	129.01	ug/l

Based upon a Hardness of 109.12 mg/l as CaCO₃

Based upon 161.32 mg/l as CaCO₃

Organics [Pesticides]

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard
Parameter	Concentration		Concentration
Aldrin		1.500	ug/l
Chlordane	0.0043 ug/l	1.200	ug/l
DDT, DDE	0.001 ug/l	0.550	ug/l
Dieldrin	0.0056 ug/l	0.240	ug/l
Endosulfan, a & b	0.056 ug/l	0.110	ug/l
Endrin	0.036 ug/l	0.086	ug/l
Guthion			
Heptachlor & H. epoxide	0.0038 ug/l	0.260	ug/l
Lindane	0.08 ug/l	1.000	ug/l
Methoxychlor		0.030	ug/l
Mirex		0.001	ug/l
Parathion	0.0130 ug/l	0.066	ug/l
PCB's	0.014 ug/l		
Pentachlorophenol	15.00 ug/l	19.000	ug/l
Toxephene	0.0002 ug/l	0.730	ug/l

IV. Numeric Water Quality Standards for Protection of Agriculture

	1 Hour Average (Acute) Standard
	Concentration
TDS	1200 mg/l
Arsenic	100 ug/l
Boron	750 ug/l
Cadmium	10 ug/l
Chromium	100 ug/l
Copper	200 ug/l
Lead	100 ug/l
Selenium	50 ug/l
TDS	1200 mg/l

V. Numeric Water Quality Standards for Protection of Human Health (Class 1C Waters)

Metals	1 Hour Average (Acute) Standard
	Concentration
Arsenic	10 ug/l
Barium	1000 ug/l

Utah Division of Water Quality

Cadmium	10	ug/l
Chromium	50	ug/l
Lead	50	ug/l
Mercury	2	ug/l
Selenium	50	ug/l
Silver	50	ug/l
Fluoride (3)	1.4	ug/l
to	2.4	ug/l
Nitrates as N	10	ug/l
Chlorophenoxy Herbicides		
2,4-D	100	ug/l
2,4,5-TP	10	ug/l
Methoxychlor	100	ug/l

VI. Numeric Water Quality Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

	Maximum Conc., ug/l - Acute Standards	
	Class 1C	Class 3A, 3B, 3C, 3D
	[2 Liters/Day for 70 Kg Person over 70 Yr.	[6.5 g for 70 Kg Person
Antimony	5.6 ug/l	640 ug/l
Arsenic	A	A
Beryllium	C	C
Cadmium	C	C
Chromium III	C	C
Chromium VI	C	C
Copper	1,300 ug/l	
Lead	C	C
Mercury	A	A
Nickel	100 ug/l	4,600 ug/l
Selenium	A	4,200 ug/l
Silver		
Thallium	0.24 ug/l	6.3 ug/l
Zinc	7400 ug/l	26,000 ug/l
Cyanide	140 ug/l	220,000 ug/l
Asbestos	7.00E+06 Fibers/L	
2,3,7,8-TCDD Dioxin	5.0 E-9 ug/l	5.1 E-9 ug/l
Acrolein	190 ug/l	290 ug/l
Acrylonitrile	0.051 ug/l	0.25 ug/l
Alachlor	2 ug/l	
Benzene	2.2 ug/l	51 B ug/l
Bromoform	4.3 ug/l	140.00 ug/l
Carbofuran	40	
Carbon Tetrachloride	0.23 ug/l	1.60 ug/l
Chlorobenzene	100 ug/l	21,000 ug/l
Chlorodibromomethane	0.4 ug/l	13.00 ug/l
Chloroethane		
2-Chloroethylvinyl Ether		
Chloroform	5.7 ug/l	470.00 ug/l
Dalapon	200 ug/l	
Di(2ethylhexl)adipate	400 ug/l	
Dichlorobromopropane	0.2	

Utah Division of Water Quality

Dichlorobromomethane	0.55 ug/l	17.00 ug/l
1,1-Dichloroethane		
1,2-Dichloroethane	0.38 ug/l	37.00 ug/l
1,1-Dichloroethylene	7 ug/l	3.20 ug/l
Dichloroethylene (cis-1,2)	70	
Dinoseb	7	
Diquat	20	
1,2-Dichloropropane	0.5 ug/l	15.00 ug/l
1,3-Dichloropropene	0.34 ug/l	1,700 ug/l
Endothall	100	
Ethylbenzene	530 ug/l	29,000 ug/l
Ethylidibromide	0.05 ug/l	
Glyphosate	700 ug/l	
Haloacetic acids	60 ug/l E	
Methyl Bromide	47 ug/l	1,500 ug/l
Methyl Chloride	F	F
Methylene Chloride	4.6 ug/l	590.00 ug/l
Ocamyl (vidate)	200 ug/l	
Picloram	500 ug/l	
Simazine	4 ug/l	
Styrene	100 ug/l	
1,1,2,2-Tetrachloroethane	0.17 ug/l	4.00 ug/l
Tetrachloroethylene	0.69 ug/l	3.30 ug/l
Toluene	1000 ug/l	200,000 ug/l
1,2 -Trans-Dichloroethylene	100 ug/l	140,000 ug/l
1,1,1-Trichloroethane	200 ug/l	F
1,1,2-Trichloroethane	0.59 ug/l	16.00 ug/l
Trichloroethylene	2.5 ug/l	30.00 ug/l
Vinyl Chloride	0.025 ug/l	530.00 ug/l
Xylenes	10000 ug/l	
2-Chlorophenol	81 ug/l	150 ug/l
2,4-Dichlorophenol	77 ug/l	290 ug/l
2,4-Dimethylphenol	380 ug/l	850 ug/l
2-Methyl-4,6-Dinitrophenol	13 ug/l	280 ug/l
2,4-Dinitrophenol	69 ug/l	5,300 ug/l
2-Nitrophenol		
4-Nitrophenol		
3-Methyl-4-Chlorophenol		
Penetachlorophenol	0.27 ug/l	3.00 ug/l
Phenol	21000 ug/l	1,700,000 ug/l
2,4,6-Trichlorophenol	1.4 ug/l	2.40 ug/l
Acenaphthene	670 ug/l	990 ug/l
Acenaphthylene	ug/l	ug/l
Anthracene	8300 ug/l	40,000 ug/l
Benzidine	0.000086 ug/l	0.00 ug/l
BenzoaAnthracene	0.0038 ug/l	0.02 ug/l
BenzoaPyrene	0.0038 ug/l	0.02 ug/l
BenzobFluoranthene	0.0038 ug/l	0.02 ug/l
BenzoghiPerylene	ug/l	
BenzokFluoranthene	0.0038 ug/l	0.02 ug/l
Bis2-ChloroethoxyMethane	ug/l	
Bis2-ChloroethylEther	0.03 ug/l	0.53 ug/l
Bis2-ChloroisopropylEther	1400 ug/l	65,000 ug/l
Bis2-EthylhexylPhthalate	1.2 ug/l	2.20 ug/l

Utah Division of Water Quality

4-Bromophenyl Phenyl Ether	ug/l		
Butylbenzyl Phthalate	1500 ug/l		1,900 ug/l
2-Chloronaphthalene	1000 ug/l		1,600 ug/l
4-Chlorophenyl Phenyl Ether	ug/l		
Chrysene	0.0038 ug/l		0.02 ug/l
Dibenzoa, hAnthracene	0.0038 ug/l		0.02 ug/l
1,2-Dichlorobenzene	420 ug/l		17,000 ug/l
1,3-Dichlorobenzene	320 ug/l		960 ug/l
1,4-Dichlorobenzene	63 ug/l		2,600 ug/l
3,3-Dichlorobenzidine	0.021 ug/l		0.03 ug/l
Diethyl Phthalate	17000 ug/l		44,000 ug/l
Dimethyl Phthalate	270000 ug/l		1,100,000 ug/l
Di-n-Butyl Phthalate	2000 ug/l		4,500 ug/l
2,4-Dinitrotoluene	0.11 ug/l		3.40 ug/l
2,6-Dinitrotoluene	ug/l		
Di-n-Octyl Phthalate	ug/l		
1,2-Diphenylhydrazine	0.036 ug/l		0.20 ug/l
Fluoranthene	130 ug/l		140.00 ug/l
Fluorene	1100 ug/l		5,300 ug/l
Hexachlorobenzene	0.00028 ug/l		0.00029 B ug/l
Hexachlorobutenedine	0.44 ug/l		18.00 ug/l
Hexachloroethane	1.4 ug/l		3.30 ug/l
Hexachlorocyclopentadiene	40 ug/l		17,000 ug/l
Ideno 1,2,3-cdPyrene	0.0038 ug/l		0.02 ug/l
Isophorone	35 ug/l	B	960.00 ug/l
Naphthalene			
Nitrobenzene	17 ug/l		690 ug/l
N-Nitrosodimethylamine	0.00069 ug/l		3.00 ug/l
N-Nitrosodi-n-Propylamine	0.005 ug/l		0.51 ug/l
N-Nitrosodiphenylamine	3.3 ug/l		6.00 ug/l
Phenanthrene			
Pyrene	830 ug/l		4,000 ug/l
1,2,4-Trichlorobenzene	260 ug/l		940 ug/l
Aldrin	0.000049 ug/l		0.000050 ug/l
alpha-BHC	0.0026 ug/l		0.00 ug/l
beta-BHC	0.0091 ug/l		0.02 ug/l
gamma-BHC (Lindane)	0.2 ug/l		0.06 ug/l
delta-BHC			
Chlordane	0.0008 ug/l		0.00 ug/l
4,4-DDT	0.00022 ug/l		0.00 ug/l
4,4-DDE	0.00022 ug/l		0.00 ug/l
4,4-DDD	0.00031 ug/l		0.00 ug/l
Dieldrin	0.000052 ug/l	B	0.000054 ug/l
alpha-Endosulfan	62 ug/l		89 ug/l
beta-Endosulfan	62 ug/l		89 ug/l
Endosulfan Sulfate	62 ug/l		89 ug/l
Endrin	0.059 ug/l		0.81 ug/l
Endrin Aldehyde	0.29 ug/l		0.30 ug/l
Heptachlor	0.000079 ug/l	B	0.000079 ug/l
Heptachlor Epoxide	0.000039 ug/l	B	0.000039 ug/l
Polychlorinated Biphenyls	0.000064 ug/l	B,D	0.000064 ug/l
Toxaphene	0.00028 ug/l		0.00028 ug/l

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Water Quality Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and

QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

The Utah Reservoir and Lake Model is a simple round jet model which was received from EPA Region 8. It assumes a discharge expands into the receiving water as a 1/2 cone from the point of discharge with the appropriate dilution.

The dilution ratios for this wasteload analysis are as follows:

Acute Dilution Ratio:	3.3 to 1
Chronic Dilution Ration:	18.8 to 1

VIII. Modeling Information

The required information for the model may include the following information for both the lake and effluent conditions:

Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH3-N, mg/l
BOD5, mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

D.O. mg/l

Other Conditions

In addition to the lake and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

Lake Information	Temp.	pH	T-NH3	BOD	DO	TRC	TDS
	Deg. C		mg/l as N	mg/l	mg/l	mg/l	mg/l
	10.3	8.9	0.00	N/A	N/A	0.00	120.7
Discharge Information	Season		Flow, MGD	Temp.			
	All Seasons		12.0	10.4			

IX. Effluent Limitations based upon Water Quality Standards

Effluent Limitation for Flow

All Seasons		
Not to Exceed:	12.00 MGD	Daily Average
	18.56 cfs	Daily Average
WET Requirements	As determined by Permits & Compliance Branch	

Effluent Limitation for Biological Oxygen Demand (BOD)

	Concentration
30 Day Average	25.0 mg/l as BOD5
30 Day Average	20.0 mg/l as CBOD5

Effluent Limitation for Dissolved Oxygen (DO)

	Concentration
	1 Day Average (Acute)
30 Day Average	5.00 mg/l

Effluent Limitation for Total Ammonia

4 Day Average [Chronic]	
Concentration	Load

Utah Division of Water Quality

All Seasons	57.33 mg/l as N	5736.3 lbs/day
	1 Hour Average [Acute] Concentration	Load
	25.0 mg/l as N	2504.6 lbs/day

Effluent Limitation for Total Residual Chlorine

	4 Day Average [Chronic] Concentration	Load
All Seasons	0.207 mg/l	20.7 lbs/day
	1 Hour Average [Acute] Concentration	Load
	0.063 mg/l	6.3 lbs/day

Effluent Limitations for Metals

	4 Day Average (Chronic)		1 Hour Average (Acute)	
	Concentration	Load	Concentration	Load
Aluminum	1190.99 ug/l*	119.2 lbs/day	2411.05 ug/l	241.2
Arsenic	2776.43 ug/l	277.8 lbs/day	1113.25 ug/l*	111.4
Barium			3291.11 ug/l	329.3
Cadmium	0.00 ug/l*	0.0 lbs/day	9.40 ug/l	0.9
Chromium III	1452.61 ug/l*	145.3 lbs/day	2768.45 ug/l	277.0
Chromium VI	206.87 ug/l	20.7 lbs/day	52.66 ug/l*	5.3
Copper	74.63 ug/l	7.5 lbs/day	55.66 ug/l*	5.6
Iron			3205.92 ug/l	320.8
Lead	21.52 ug/l*	2.2 lbs/day	352.84 ug/l	35.3
Mercury	0.17 ug/l*	0.017 lbs/day	7.89 ug/l	0.8
Nickel	1008.50 ug/l*	100.9 lbs/day	2303.74 ug/l	230.5
Selenium	77.61 ug/l	7.8 lbs/day	59.41 ug/l*	5.9
Silver			21.81 ug/l	2.2
Zinc	30824.06 ug/l	3,084.3 lbs/day	543.96 ug/l*	54.4

* Most stringent between Chronic & Acute Effluent Limitations

Effluent Limitations for Organics [Pesticides]

Pesticide	4 Day Average		1 Hour Average	
	Concentration	Load	Concentration	Load
Aldrin			4.9367 ug/l	0.319
Chlordane	0.0809 ug/l*	0.005 lbs/day	3.9493 ug/l	0.255
DDT, DDE	0.0188 ug/l*	0.001 lbs/day	1.8101 ug/l	0.117
Dieldrin	0.1053 ug/l*	0.007 lbs/day	0.7899 ug/l	0.051
Endosulfan	1.0532 ug/l	0.068 lbs/day	0.3620 ug/l*	0.023
Endrin	0.6770 ug/l	0.044 lbs/day	0.2830 ug/l*	0.018

Utah Division of Water Quality

Guthion			0.0000 ug/l	0.000
Heptachlor	0.0715 ug/l*	0.005 lbs/day	0.8557 ug/l	0.055
Lindane	1.5045 ug/l*	0.097 lbs/day	3.2911 ug/l	0.213
Methoxychlor			0.0987 ug/l	0.006
Mirex			0.0033 ug/l	0.000
Parathion			0.2172 ug/l	0.014
PCB's	0.2633 ug/l	0.017 lbs/day	0.0000 ug/l*	0.000
Pentachlorophenol	282.0948 ug/l	18.246 lbs/day	62.5310 ug/l*	4.045
Toxephene	0.0038 ug/l*	0.000 lbs/day	2.4025 ug/l	0.155

Effluent Limitations for Protection of Human Health (Class 1C Waters)

Metals	1 Hour Average (Acute) Standard	
	Concentration	Load
Arsenic	32.91 ug/l	2.13
Barium	3291.11 ug/l	212.87
Cadmium	32.91 ug/l	2.13
Chromium	164.56 ug/l	10.64
Lead	164.56 ug/l	10.64
Mercury	6.58 ug/l	0.43
Selenium	164.56 ug/l	10.64
Silver	164.56 ug/l	10.64
Fluoride	4.61 ug/l	0.30
to	7.90 ug/l	0.51
Nitrates as N	32.91 ug/l	2.13
Pesticides		
2,4-D	329.11 ug/l	21.29
2,4,5-TP	32.91 ug/l	2.13
Methoxychlor	329.11 ug/l	21.29

Effluent Limitations for Protection of Human Health [Toxics Rule]

Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)

Toxics Rule Parameters	Maximum Conc., ug/l - Acute Standards			
	Class 1C		Class 3A, 3B	
	[2 Liters/Day for 70 Kg Person over 70 Yr.		[6.5 g for 70 Kg Person over 70 Yr. Pe	
Antimony	18.43 ug/l	1.19 lbs/day	18.43 ug/l	1.2
Arsenic				
Beryllium				
Cadmium				
Chromium III				
Chromium VI				
Copper	4278.44 ug/l	276.73 lbs/day	4278.44 ug/l	276.7
Lead				
Mercury		lbs/day	329.11 ug/l	21.3
Nickel	329.11 ug/l	21.29 lbs/day		
Selenium			24354.18 ug/l	1575.2
Silver			460.75 ug/l	29.8
Thallium	0.79 ug/l	0.05 lbs/day		
Zinc	24354.18 ug/l	1575.23 lbs/day	625.31 ug/l	40.4

Utah Division of Water Quality

Cyanide	460.75 ug/l	29.80 lbs/day	0.17 ug/l	0.0
Asbestos	23037741.33 ug/l	1.49E+06 lbs/day	14.15 ug/l	0.9
0	0.00 ug/l	0.00 lbs/day		
2,3,7,8-TCDD Dioxin	0.00 ug/l	0.00 lbs/day	329.11 ug/l	21.3
Acrolein	625.31 ug/l	40.45 lbs/day	1.32 ug/l	0.1
Acrylonitrile	0.17 ug/l	0.01 lbs/day		
Benzene	7.24 ug/l	0.47 lbs/day		
Bromoform	14.15 ug/l	0.92 lbs/day	18.76 ug/l	1.2
Carbon Tetrachloride	0.00 ug/l	0.00 lbs/day		
Chlorobenzene	329.11 ug/l	21.29 lbs/day		
Chlorodibromomethane	1.32 ug/l	0.09 lbs/day	1.25 ug/l	0.1
Chloroethane	0.00 ug/l	0.00 lbs/day	23.04 ug/l	1.5
2-Chloroethylvinyl Ether	0.00 ug/l	0.00 lbs/day	1.65 ug/l	0.1
Chloroform	18.76 ug/l	1.21 lbs/day	1.12 ug/l	0.1
Dichlorobromomethane	1.81 ug/l	0.12 lbs/day	154.68 ug/l	10.0
1,1-Dichloroethane	0.00 ug/l	0.00 lbs/day		
1,2-Dichloroethane	1.25 ug/l	0.08 lbs/day	15.14 ug/l	1.0
1,1-Dichloroethylene	23.04 ug/l	1.49 lbs/day	0.56 ug/l	0.0
1,2-Dichloropropane	1.65 ug/l	0.11 lbs/day	3291.11 ug/l	212.9
1,3-Dichloropropene	1.12 ug/l	0.07 lbs/day	1.94 ug/l	0.1
Ethylbenzene	1744.29 ug/l	112.82 lbs/day	8.23 ug/l	0.5
Methyl Bromide	154.68 ug/l	10.00 lbs/day	0.08 ug/l	0.0
Methyl Chloride	0.00 ug/l	0.00 lbs/day	266.58 ug/l	17.2
Methylene Chloride	15.14 ug/l	0.98 lbs/day	253.42 ug/l	16.4
1,1,2,2-Tetrachloroethane	0.56 ug/l	0.04 lbs/day	1250.62 ug/l	80.9
Tetrachloroethylene	2.27 ug/l	0.15 lbs/day	42.78 ug/l	2.8
Toluene	3291.11 ug/l	212.87 lbs/day		
1,2 -Trans-Dichloroethylene	329.11 ug/l	21.29 lbs/day		
1,1,1-Trichloroethane	0.00 ug/l	0.00 lbs/day	0.89 ug/l	0.1
1,1,2-Trichloroethane	1.94 ug/l	0.13 lbs/day	69113.22 ug/l	4470.2
Trichloroethylene	8.23 ug/l	0.53 lbs/day	4.61 ug/l	0.3
Vinyl Chloride	0.08 ug/l	0.01 lbs/day	2205.04 ug/l	142.6
2-Chlorophenol	266.58 ug/l	17.24 lbs/day		
2,4-Dichlorophenol	253.42 ug/l	16.39 lbs/day	27316.18 ug/l	1766.8
2,4-Dimethylphenol	1250.62 ug/l	80.89 lbs/day		
2-Methyl-4,6-Dinitrophenol	42.78 ug/l	2.77 lbs/day	0.01 ug/l	0.0
2,4-Dinitrophenol	227.09 ug/l	14.69 lbs/day	0.01 ug/l	0.0
2-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.01 ug/l	0.0
4-Nitrophenol	0.0000 ug/l	0.0000 lbs/day		
3-Methyl-4-Chlorophenol	0.0000 ug/l	0.0000 lbs/day	0.01 ug/l	0.001
Penetachlorophenol	0.8886 ug/l	0.0575 lbs/day		
Phenol	69113.2240 ug/l	4.47E+03 lbs/day	0.10 ug/l	0.006
2,4,6-Trichlorophenol	4.6075 ug/l	0.2980 lbs/day	4607.55 ug/l	298.016
Acenaphthene	2205.04 ug/l	142.62 lbs/day		
Acenaphthylene	0.00 ug/l	0.00 lbs/day	4936.66 ug/l	319.3
Anthracene	27316.18 ug/l	1766.81 lbs/day	3291.11 ug/l	212.9
Benzidine	0.00 ug/l	0.00 lbs/day		
BenzoaAnthracene	0.01 ug/l	0.00 lbs/day	0.01 ug/l	0.0
BenzoaPyrene	0.01 ug/l	0.00 lbs/day	0.0 ug/l	0.0
BenzobFluoranthene	0.01 ug/l	0.00 lbs/day	1382.26 ug/l	89.4
BenzoghiPerylene	0.00 ug/l	0.00 lbs/day	1053.15 ug/l	68.1
BenzokFluoranthene				
Bis2-ChloroethoxyMethane				
Bis2-ChloroethylEther	0.0987 ug/l	0.00639 lbs/day	5.59E+04 ug/l	3.62E+03

Utah Division of Water Quality

Bis2-Chloroisopropyl Ether	4607.5483 ug/l	2.98E+02 lbs/day	8.89E+05 ug/l	5.75E+04
Bis2-Ethylhexyl Phthalate	3.9493 ug/l	0.25544 lbs/day	6582.21181 ug/l	425.73746
4-Bromophenyl Phenyl Ether	0.0000 ug/l	0.00000 lbs/day	0.36202 ug/l	0.02342
Butylbenzyl Phthalate	4936.6589 ug/l	3.19E+02 lbs/day		
2-Chloronaphthalene	3291.1059 ug/l	212.86873 lbs/day		
4-Chlorophenyl Phenyl Ether	0.0000 ug/l	0.00000 lbs/day	0.11848 ug/l	0.00766
Chrysene	0.0125 ug/l	0.00081 lbs/day	427.84377 ug/l	27.67293
Dibenzo(a,h)Anthracene	0.0125 ug/l	0.00081 lbs/day	3620.21649 ug/l	234.15560
1,2-Dichlorobenzene	1382.2645 ug/l	89.40487 lbs/day	0.00092 ug/l	0.00006
1,3-Dichlorobenzene	1053.1539 ug/l	68.11799 lbs/day	1.44809 ug/l	0.09366
1,4-Dichlorobenzene	207.3397 ug/l	13.41073 lbs/day	4.60755 ug/l	0.29802
3,3-Dichlorobenzidine				
Diethyl Phthalate				
Dimethyl Phthalate				
Di-n-Butyl Phthalate	6582.21181 ug/l	425.73746 lbs/day		
2,4-Dinitrotoluene	0.36202 ug/l	0.02342 lbs/day	55.948800 ug/l	3.618768
2,6-Dinitrotoluene	0.00000 ug/l	0.00000 lbs/day	0.002271 ug/l	0.000147
Di-n-Octyl Phthalate	0.00000 ug/l	0.00000 lbs/day	0.016456 ug/l	0.001064
1,2-Diphenylhydrazine	0.11848 ug/l	0.00766 lbs/day	10.860649 ug/l	0.702467
Fluoranthene	427.84377 ug/l	27.67293 lbs/day		
Fluorene	3620.21649 ug/l	234.15560 lbs/day	2.73E+03 ug/l	1.77E+02
Hexachlorobenzene				
Hexachlorobutenedine				
Hexachloroethane	4.61 ug/l	0.30 lbs/day		
Hexachlorocyclopentadiene				
Ideno 1,2,3-cdPyrene				
Isophorone	115.19 ug/l	7.45 lbs/day		
Naphthalene				
Nitrobenzene				
N-Nitrosodimethylamine	0.00 ug/l	0.00 lbs/day		
N-Nitrosodi-n-Propylamine	0.02 ug/l	0.00 lbs/day	0.00 ug/l	0.0
N-Nitrosodiphenylamine	1.09E+01 ug/l	7.02E-01 lbs/day		
Phenanthrene	0.00 ug/l	0.00 lbs/day	204.05 ug/l	13.2
Pyrene	2731.62 ug/l	176.68 lbs/day		
1,2,4-Trichlorobenzene			204.05 ug/l	13.2
Aldrin			0.19 ug/l	0.0
alpha-BHC	0.00855688 ug/l	0.000553 lbs/day		
beta-BHC	0.02994906 ug/l	0.001937 lbs/day		
gamma-BHC (Lindane)	0.65822118 ug/l	0.042574 lbs/day		
delta-BHC		0.000000 lbs/day		
Chlordane	0.00263288 ug/l	0.000170 lbs/day		
4,4-DDT	0.00072404 ug/l	0.000047 lbs/day		
4,4-DDE	0.00072404 ug/l	0.000047 lbs/day		
4,4-DDD	0.00102024 ug/l	0.000066 lbs/day		
Dieldrin		0.000000 lbs/day		
alpha-Endosulfan	204.05 ug/l	13.198 lbs/day		
beta-Endosulfan	204.05 ug/l	13.198 lbs/day		
Endosulfan Sulfate	204.05 ug/l	13.198 lbs/day		
Endrin	0.19417525 ug/l	0.013 lbs/day		

Utah Division of Water Quality

Endrin Aldehyde	0.95442071 ug/l	0.062 lbs/day		
Heptachlor		lbs/day		
Heptachlor Epoxide		lbs/day		
Polychlorinated Biphenyls		lbs/day		
0	0.00000000 ug/l	0.000000 lbs/day		
Toxaphene	0.00092151 ug/l	0.000060 lbs/day		
Specific Parameter: TDS	0 ug/l	0.000000 lbs/day	3672.71 mg/l	237.6

Effluent Limitations for the Protection of Agriculture

	1 Hour Average (Acute) Standard	
	Concentration	Load
Arsenic	329.11 ug/l	21.29
Boron	2468.33 ug/l	159.65
Cadmium	32.91 ug/l	2.13
Chromium	329.11 ug/l	21.29
Copper	658.22 ug/l	42.57
Lead	329.11 ug/l	21.29
Selenium	164.56 ug/l	10.64

**Metals Effluent Limitations for Protection of All Beneficial Uses
Based upon Water Quality Standards and Toxics Rules**

	Class 4 Acute Agricultural ug/l	Class 3 Acute Aquatic Wildlife ug/l	Acute Toxics Drinking Water Source ug/l	Acute Toxics Wildlife ug/l	1C Acute Health Criteria ug/l	Acute Most Stringent ug/l	Class 3 Chronic Aquatic Wildlife ug/l
Aluminum		2411.05				2411.05	1190.99
Antimony			18.43			18.43	
Arsenic	329.11	1113.25			32.91	32.91	2776.43
Asbestos							
Barium		3291.11			3291.11	3291.11	
Cadmium	32.91	9.40			32.91	9.40	0.00
Chromium (III)		2768.5			164.56	164.56	1452.61
Chromium (VI)	329.11	52.66				52.66	206.87
Copper	658.22	55.66				55.66	74.63
Cyanide				460.75		460.75	
Iron		3205.92				3205.92	
Lead	329.11	352.84			164.56	164.56	21.52
Mercury		7.8918			6.58	6.58	0.1723
Nickel		2303.74		329.11		329.11	1008.50
Selenium	164.56	59.41			164.56	59.41	77.61
Silver		21.81			164.56	21.81	
Thallium				0.79		0.79	
Zinc		543.96				543.96	30824.06

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

	Acute		Chronic	
	ug/l	lbs/day	ug/l	lbs/day
Aluminum	2411.05	241.2	1190.99	119.2
Antimony	18.43	1.8		
Arsenic	32.91	3.3	2776.43	277.8
Asbestos				
Cadmium	9.40	0.9	0.00	0.0
Chromium (III)	164.56	16.5	1452.61	145.3
Chromium (VI)	52.66	5.3	206.87	20.7
Copper	55.66	5.6	74.63	7.5
Cyanide	460.75	46.1		
Iron	3205.92	320.8		
Lead	164.56	16.5	21.52	2.2
Mercury	6.58	0.7	0.17	0.0
Nickel	329.11	32.9	1008.50	100.9
Selenium	59.41	5.9	77.61	7.8
Silver	21.81	2.2		
Zinc	543.96	54.4	30824.06	3084.3

Effluent Indicators / Targets for Pollution Indicators

Water quality targets for pollution Indicators will be met with an effluent limit as follows:

	Indicator / Target	Target	
	mg/l	mg/l	lbs/day
Gross Beta (pCi/l)	50.0 pCi/L		
BOD	5.0	16.46	1668.03
Nitrates as N	4.0	13.16	1334.43
Total Phosphorus as P	0.05	0.16	16.68
Total Suspended Solids	90.0	296.20	30024.58

Other Effluent Limitations are based upon R317-1.

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing water users.

Category III waters fall under special rules for the determination of effluent limits. These rules allow more stringent effluent limitations based upon additional factors, including: "blue-ribbon" fisheries, special recreation areas, and drinking water sources.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless shown that this is not attainable. Refer to the Forum's Guidelines for additional information.

The permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

The permit writers may utilize other information to adjust these limits or to determine other limits based upon best available technology and other considerations. Under no circumstances however, may those alterations allow for the violation of water quality standards by the permittee.

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information.

XIV. Notice of Availability of Information

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

Prepared by:
Christopher L Shope, PhD
Utah Division of Water Quality
801-536-4309

Jordanelle_DW_WLA_2023_Jet_Model.xlsm