



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
Erica Brown Gaddis, PhD  
Director

January 6, 2022

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO RENEW A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME: Kamas City Corporation  
MAILING ADDRESS: 170 North Main, Kamas, UT 84036  
TELEPHONE NUMBER: (435) 783-4630  
FACILITY LOCATION: Simpson Road, Kamas, UT 84036  
UPDES PERMIT NO.: UT0020966  
PERMITTED OUTFALLS: 001  
RECEIVING WATER: Beaver Creek

**BACKGROUND**

The Kamas City Wastewater Treatment Facility (Kamas) was last upgraded in 1991. At present, the facility consists of an 18" inlet pipe, grinder and a screen, influent flow meter, followed by 5 waste stabilization ponds (first 3 are aerated), ultraviolet light disinfection, effluent flow meter and a 10 KW Koler generator. The facility has seven 20 HP Aero-O2 aerators manufactured by Aeratrion Industries International, Inc. The five cells cover 3.4, 6.7, 3.4, 3.2 and 2.1 acres respectively. Total surface area of the lagoon is approximately 18.8 acres. The total area of the facility is contained within a chain link fence and occupies an area of 900 feet by 1,300 feet. The wastewater lagoon is located approximately one-quarter (0.25) mile northwest of Kamas, Utah, in Summit County.

**PUBLIC COMMENTS**

Public comments are invited any time prior to the deadline of the close of business on **February 7, 2022**. A public hearing can be requested, although must be filed during the comment period. Written public comments can be submitted to: Danielle Lenz, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at:

Page 2  
Kamas City Corporation  
Public Notice

[wqcomments@utah.gov](mailto:wqcomments@utah.gov). After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under “Public Participation” at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Danielle Lenz at (385) 363-8250.

DWQ-2021-034662