



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

June 19, 2020

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Logan City Corporation, Wastewater Treatment Plant
MAILING ADDRESS: 290 North 100 West
TELEPHONE NUMBER: 435-716-9752
FACILITY LOCATION: West-Northwest of Logan City Outfall 002, located on the easterly right-of-way off Benson Road and Swift Slough
UPDES PERMIT NO.: UT0021920
PERMITTED OUTFALLS 001A, 001B, 002
RECEIVING WATER: Ditches, Cutler Reservoir, and Swift Slough

BACKGROUND

Logan City WWTP consists of a 7-cell facultative lagoon system and additional treatment wetlands. Total treatment area is 460 Acres of Lagoons, 240 acres of treatment wetlands. While the design capacity is 30 MGD, discharge from Outfall 002 is limited by the permit to 22 MGD during irrigation season and 16 MGD during non-irrigation season. Due to new permit effluent limits set forth by the Cutler Reservoir TMDL and new EPA ammonia rules, the facility has started building a new facility to bring it into compliance with the new discharge requirements. A compliance schedule in the new permit will allow the facility to operate under its current conditions until a time when it can comply with the new limits set forth by the Cutler Reservoir TMDL and new EPA ammonia rules.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **July 20, 2020**. Written public comments can be submitted to: Lonnie Shull, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lushull@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Notices" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Lonnie Shull at 801-536-4394.

DWQ-2020-012970

195 North 1950 West • Salt Lake City, UT
Mailing Address: PO Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 536-4300 • Fax (801) 536-4301 • TDD (801) 536-4284

www.deq.utah.gov

Printed on 100% recycled paper