



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

June 19, 2020

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF A MODIFICATION OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to modify a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Manti City Corporation Wastewater Lagoons
MAILING ADDRESS:	50 South Main Street, Manti, UT 84642
TELEPHONE NUMBER:	(435) 835-2401
FACILITY LOCATION:	1 mile North of Manti City, Sanpete County, Utah
UPDES PERMIT NO.:	UT0026026
OUTFALLS:	001, 001R, 002R
RECEIVING WATERS:	San Pitch River

BACKGROUND

The Manti City Wastewater Treatment Facility is located approximately 1 mile north of Manti City, Utah in Sanpete County. According to the most recent census data, the population of Manti is approximately 3,297 with approximately 850 sewer connections. The facility has been upgraded and will continue upgrades during the life of this permit. The design capacity is 0.33 million gallons per day (MGD) with a maximum effluent flow of 0.97 MGD. The facility plans to reuse the water in the summer and discharge to the San Pitch River in the winter. Currently the facility does not have the ability to discharge to the San Pitch River as there is no discharge pipe from the lagoons to the river.

This permit has been modified to identify the location of the current land application site (001R) and the proposed land application site (002R). The permit was additionally updated to be consistent with current reuse management practice, limits, and sampling requirements listed in R317-3-11.5. Section I (a) (2) was added to include reporting requirements for reuse sampling. These are the only changes being proposed with this permit modification and subject to public comment. All other permit provisions remain unopened and unchanged.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **July 20, 2020**. Public comments can be submitted to: Leanna Littler, UPDES Surface Water Section, Utah Division of

Public Notice of UPDES Permit Modification

UPDES Permit No. UT0026026

Page 2

Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lnittler@utah.gov. After considering public comment the Utah Division of Water Quality may issue, revise, or abandon the permit. The permit is available for public review under <https://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Leanna Littler at 801-536-4397.

DWQ-2020-012335