



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of Environmental Quality

Kimberly D. Shelley
Interim Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

December 6, 2021

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF A MODIFICATION OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to modify a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Manti City Corporation
MAILING ADDRESS:	50 South Main Street, Manti, UT 84642
TELEPHONE NUMBER:	(435) 835-2401
FACILITY LOCATION:	1 mile North of Manti City, Sanpete County, Utah
UPDES PERMIT NO.:	UT0026026
OUTFALLS:	001, 001R, 002R
RECEIVING WATERS:	San Pitch River

BACKGROUND

The Manti City Wastewater Treatment Facility (Manti) is located at 1500 N 100 E, Manti, Sanpete County, Utah. The design capacity is 0.33 MGD with maximum design capacity is 0.97 MGD, an average five-year flow of 0.29 MGD, and a population equivalent of 3,862 with 25 miles of sewer collection pipes. The facility consists of an influent pump station, influent 8-inch Parshall Flume, influent flow meter, grinder, bar screen, and three facultative lagoon cells totaling 41.5 acres. Cell #1 is 14.1 acres, cell #2 is 13.6 acres, cell #3 is 13.7 acres with chlorination for disinfection on the effluent. Manti's UPDES permit allows for discharge to the San Pitch River between October 1 and February 28 each calendar year. Currently, Manti does not have a pipeline to the San Pitch River. The facility holds the water in the lagoons during the winter months. During the summer, the water is piped to City owned property where it is reused to irrigate pasture. In the future, Manti will install a pipe to discharge into the San Pitch River.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **January 6, 2022**. Public comments can be submitted to: Sarah Ward, Individual Permits Section, Utah Division of Water

Page 2

Public Notice of UPDES Permit Modification
UPDES Permit No. UT0026026

Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: sarahward@utah.gov. After considering public comment the Utah Division of Water Quality may issue, revise, or abandon the permit. The permit is available for public review under <https://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Ward at 385.332.9574.

DWQ-2021-030824