



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

November 27, 2019

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF MODIFICATION OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to modify a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Mona Wastewater Treatment Facility
MAILING ADDRESS:	50 West Center Street, Mona, UT 84645
TELEPHONE NUMBER:	(435) 623-4913
FACILITY LOCATION:	Approximately 300 West 560 North, Mona, UT
UPDES PERMIT NO.:	UT0025950
OUTFALLS:	001
RECEIVING WATERS:	Mona Reservoir

BACKGROUND

Mona City (**Mona**) completed a new wastewater treatment plant in 2012. The facility is a Membrane Bioreactor (MBR) with a hydraulic design capacity of 0.5 MGD and serves a population of approximately 1600. The facility does not currently include any categorical industries in the service area, and there are no plans for any to start up in the foreseeable future. The design has dual process trains able to run in parallel. This permit has Biosolids and Storm Water Industrial components. The modification is to include the Total phosphorus limit of 1.0 mg/l in compliance with the Technology-Based Phosphorus Effluent Limit standards, UAC R317-1-3.3.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **December 27, 2019**. Written public comments can be submitted to: Daniel Griffin, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dgriffin@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Daniel Griffin at 801-536-4387.

DWQ-2017-008267