



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

August 27, 2020

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to reissue a Utah Pollutant Discharge Elimination System (UPDES) permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES permit and statement of basis (including the Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Morgan City
MAILING ADDRESS: 90 West Young Street
PO Box 1085
Morgan, Utah 84050
TELEPHONE NUMBER: 801.821.6324
FACILITY LOCATION: 90 West Young Street
Morgan, Utah 84050
UPDES PERMIT NO.: UT0020893
PERMITTED OUTFALLS 001
RECEIVING WATER: Weber River

BACKGROUND

The Morgan City Wastewater Treatment Facility (Morgan) is located approximately 1.5 northwest of Morgan, Utah in Morgan County. Morgan has a population of approximately 4,200 with 1,400 sewer connections. The design capacity of the facility is 0.45 million gallons per day (MGD). The outfall discharges to the Weber River located at latitude 41°03'07" N and longitude 111°41'57" W.

The facility comprises of two influent lift stations with influent 8-inch Parshall Flume, influent flow meters, grinders, headworks screening and grit removal system, four aerated lagoon cells, switchover chlorination, dechlorination equipment, reaeration equipment, effluent 90 degree "v" notch weir and effluent flow meter. Chlorination takes place in two maze type configuration contact basins following the last stabilization cell. The first lagoon cell has six aerators, pond two has three aerators, pond three has two aerators and pond one has one aerator.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **September 28, 2020**. Written public comments can be submitted to: Sarah Leavitt Ward, UPDES Surface Water Section,

Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: sarahward@utah.gov. After considering public comment, the Division of Water Quality may reissue, revise, or abandon it. The permit is available for public review under “Public Participation” at <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Leavitt Ward at 385.332.9574.

DWQ-2020-016658